



- NOTES:
1. THE GE MPL NUMBER FOR THIS SYSTEM IS P-33.
 2. LOCATE ROOM RADIATION MONITOR RE-8711 NEAR SAMPLE STATION 1C-353.
 3. SYMBOLS REPRESENT VENDOR SUPPLIED MULTIPORT VALVES.
 4. SECONDARY CONTAINMENT ATMOSPHERE SAMPLE IS TAKEN FROM REACTOR BLDG NORTH-ELEV. 757'-6".
 5. PCV-8720 AND PCV-8710 PRESSURE REGULATORS INCLUDE DUAL (UPSTREAM AND DOWNSTREAM) PRESSURE INDICATORS.
 6. IODINE CARTRIDGE IS MOUNTED WITH QUICK DISCONNECTS WHICH INCORPORATE A CRITICAL ORIFICE.

REVISIONS	BY	CHK	DATE

REGULATORY DOCKET FILE COPY

BECHTEL
ANN ARBOR, MICHIGAN

DUANE ARNOLD ENERGY CENTER-UNIT NO. 1
IOWA ELECTRIC LIGHT AND POWER COMPANY
CEDAR RAPIDS, IOWA

P & ID
POST ACCIDENT SAMPLING

JOB No.	DRAWING No.	REV.
7884	M-187	1

FOR INFORMATION ONLY

H
G
F
E
D
C
B
A