

Hoxie, Chris

OK to release

From: Hoxie, Chris
Sent: Saturday, March 26, 2011 9:42 PM
To: Uhle, Jennifer
Cc: Lee, Richard; Gibson, Kathy
Subject: Brian's Q

In regards to Brian's question about how salt water may influence the dynamics of a fuel coolant interaction:

Here are two references:

http://www.iaea.org/inis/collection/NCLCollectionStore/_Public/42/006/42006251.pdf

On page 396, states that pure water vs. salt water made no difference in an experiment designed to measure peak pressures for fuel coolant interactions in a lab setting.

Reference 2:

Although it might not be one-for-one, here is a reference to research that indicates the salt might actually dampen the steam explosion (or at least it does maybe when lava hits sea water....)

Caveats: This reference 2 is not nuclear oriented. Not specific to the Japan case. This is really complex and should be answered by an expert. Depends so much on the actual conditions in the Japan plants...

At least I did not find anything that says salt makes things worse!

Impure coolants and interaction dynamics of phreatomagmatic eruptions

James D. L. White E-mail The Corresponding Author, *

Geology Department, University of Otago P.O. Box 56, Dunedin 9015, New Zealand

Received 12 January 1996;

revised 18 June 1996;

accepted 18 June 1996. ;

Available online 26 February 1999.

Abstract

Phreatomagmatic eruptions resulting from interaction of magma with groundwater are common in many terrestrial settings, and their explosivity is widely accepted to result from fuel-coolant interaction (FCI) processes. Relatively little attention has been given to the precise nature of the volcanic settings in which phreatomagmatic FCI's take place, but several lines of evidence indicate that they almost inevitably involve mixing of magma with impure, sediment-laden water. Consideration of the effects of these impure coolants on the fuel-coolant interaction process suggests that: (1) impure coolants enhance the ability of magma to mix with large volumes of coolant; and **(2) maximum unit-volume explosivity of FCI's is damped relative to interactions with pure water.** It is probably unrealistic to back-calculate water-magma mass ratios for most, if not all, phreatomagmatic eruptions because: (1) effects of impure coolants on fragmentation efficiency and eruption explosivity are not yet known; and (2) aspects of the vent environments in which phreatomagmatism occurs may influence fragmentation processes, explosive efficiency, and resultant particle populations as or more strongly than water-magma mass ratios. To estimate mass ratios for individual bursts, or for eruptions as a whole, one must distinguish particle populations resulting from many different processes in phreatomagmatic vents, including primary fragmentation, induced fragmentation, vent-wall collapse and pyroclast recycling. Incorporation of accidental blocks beyond the zone of phreatomagmatic interaction and ejection of unvaporized water further complicate efforts at reconstruction.

4/28/11

Schaperow, Jason

Subject: Support for Fukushima accident
Location: Charlie's office

Start: Mon 3/28/2011 10:00 AM
End: Mon 3/28/2011 11:00 AM
Show Time As: Tentative

Recurrence: Daily
Recurrence Pattern: every day from 10:00 AM to 11:00 AM

Meeting Status: Not yet responded

Organizer: Schaperow, Jason
Required Attendees: Esmaili, Hossein; Salay, Michael; Marksberry, Don; Helton, Donald; Tinkler, Charles

Request you come to Charlie's office at 10:00 a.m. to meet.

Schaperow, Jason

From: Schaperow, Jason
Sent: Monday, March 28, 2011 2:05 PM
To: Greenwood, Carol
Subject: RE: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

Thanks.

From: Greenwood, Carol
Sent: Monday, March 28, 2011 1:54 PM
To: Schaperow, Jason
Subject: RE: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

Yes, Thank you!

Carol

From: Schaperow, Jason
Sent: Monday, March 28, 2011 1:53 PM
To: Greenwood, Carol
Cc: Santiago, Patricia
Subject: RE: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

Hi Carol,

I got a call from the Ops Center yesterday morning at 0600 for support. So, I worked from 0600 to 0800 yesterday. I used the link below to add this to your timesheet. Did I do it correctly?

Thanks,
Jason

From: Greenwood, Carol
Sent: Friday, March 18, 2011 10:31 AM
To: Armstrong, Kenneth; Bajorek, Stephen; Boyd, Christopher; Elkins, Scott; Hoxie, Chris; Lee, Richard; Rubin, Stuart; Santiago, Patricia; Sherbini, Sami; Tinkler, Charles; Voglewede, John; Zigh, Ghani; Tomon, John
Subject: FW: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

Please update the Excel spreadsheet [by clicking here](#) with names and dates of any staff that have or will be performing emergency-related premium work in response to the events in Japan.
This applies to the IRC, OIP, OPA or wherever they are doing emergency work.

Please confirm to me when your branch is updated.

The spreadsheet is at g:\DSA\Directors Office\JapanResponseWork.xlsx if the above link doesn't work.

Regards

Carol Greenwood

Lead Administrative Assistant

RES/DSA

U.S. Nuclear Regulatory Commission

Phone: 301-251-3319



From: Gibson, Kathy

Sent: Friday, March 18, 2011 8:07 AM

To: Greenwood, Carol

Subject: Fw: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

Would you check with the BCs and compile this list for Andrea for DsA? Thx

From: Valentin, Andrea

To: Gibson, Kathy; Scott, Michael; Coyne, Kevin

Sent: Fri Mar 18 08:00:34 2011

Subject: Reminder: FW: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

This is a reminder to provide me with a list of names of staff that are performing emergency-related premium work (and the dates that the people worked) in response to the events in Japan. This applies to the IRC, OIP, OPA or wherever they are doing emergency work.

Thanks,
Andrea

From: Khan, Charline

Sent: Thursday, March 17, 2011 7:29 AM

To: RidsAcrsAcnw_MailCTR Resource; RidsAslbpManagement Resource; RidsOgcMailCenter Resource; RidsOcaaMailCenter Resource; RidsOcfoMailCenter Resource; RidsOigMailCenter Resource; RidsOipMailCenter Resource; RidsOcaMailCenter Resource; RidsOpaMail Resource; RidsSecyMailCenter Resource; RidsSecyCorrespondenceMCTR Resource; RidsEdoMailCenter Resource; RidsAdmMailCenter Resource; RidsCsoMailCenter Resource; RidsOeMailCenter Resource; RidsFsmeOd Resource; RidsOiMailCenter Resource; RidsOIS Resource; RidsHrMailCenter Resource; RidsNroOd Resource; RidsNroMailCenter Resource; RidsNmssOd Resource; RidsNrrOd Resource; RidsNrrMailCenter Resource; RidsResOd Resource; RidsResPmdaMail Resource; RidsSbcrMailCenter Resource; RidsNsirOd Resource; RidsNsirMailCenter Resource; RidsRgn1MailCenter Resource; RidsRgn2MailCenter Resource; RidsRgn3MailCenter Resource; RidsRgn4MailCenter Resource

Cc: Davidson, Lawrence; Buchholz, Jeri; Johns, Nancy

Subject: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE EVENTS IN JAPAN

MEMORANDUM TO: Those on the Attached List

FROM: Miriam L. Cohen, Director/RA by J. Buchholz for/
Office of Human Resources

DATED: March 16, 2011

**SUBJECT: WAIVER OF WORK SCHEDULE AND PAY CAP RULES FOR WORK IN RESPONSE TO THE
EVENTS IN JAPAN**

ADAMS Accession No. ML11075A003 refers

NOTE: Electronic distribution only

Charline Khan

Administrative Assistant (Rotation)

U.S. NUCLEAR REGULATORY COMMISSION

Office of Human Resources

P:301-492-2318

Charline.Khan@nrc.gov

Releasable

Bensi, Michelle

From: Bensi, Michelle
Sent: Monday, March 28, 2011 2:35 PM
To: Guzman, Richard
Subject: RE: Confirmation on Pilgrim info (site fact sheet for governor)

Richard,
This is great. Thank you very much.
Shelby

From: Guzman, Richard
Sent: Monday, March 28, 2011 1:18 PM
To: Bensi, Michelle
Subject: RE: Confirmation on Pilgrim info (site fact sheet for governor)

Shelby,

Both items are addressed in the FSAR as follows:

- The seismic design standard for Pilgrim safety-related equipment was determined by applying the effects of the largest earthquake in the region, an event measuring 6.0 on the Richter scale, at Cape Anne, 60 miles north. This event is then applied at the closest epicentral location consistent with geologic structure of the site.

2.5.3.3.2 Safe Shutdown Earthquake

The Safe Shutdown Earthquake is generally considered to be a recurrence of the largest earthquake in the region at the closest epicentral distance which is consistent with the geologic structure. The Cape Ann series of earthquakes appear to be the most severe earthquakes which need be considered for plant design. The occurrence of an earthquake as large as the maximum Cape Ann sequence (intensity VIII, estimated magnitude 6), with its epicenter at the closest approach of faulting associated with the Boston and Narragansett Basins (17 mi west of the site) is the most critical situation for the site. Horizontal ground acceleration at estimated foundation depths (within the compact glacial deposits) due to the above earthquake would be about 0.15 g.

- A tsunami at Pilgrim such as occurred in Japan is not considered to be a probable event based on the known geological features in the area. The emergency diesel generators that provide power if the site loses off-site power and are built in reinforced concrete watertight buildings and the fuel tanks are built underground in reinforced concrete.

FSAR pg 8.5-4 – “Both generators are housed in reinforced concrete Class I structures. Each unit is completely enclosed to provide independence from the other unit.”

FSAR pg 8.5-8 – “Each diesel generator is capable of starting and continuously operating at full rated capacity for a period of 7 days using fuel stored onsite in underground storage tanks.”

I've also attached the applicable FSAR sections for additional information. Hope this helps!

Have a good one,
Rich

Rich Guzman

4/28/11

Sr. Project Manager
NRR/DORL
US NRC
301-415-1030
Richard.Guzman@nrc.gov

From: Bensi, Michelle
Sent: Monday, March 28, 2011 12:15 PM
To: Guzman, Richard
Subject: RE: Confirmation on Pilgrim info (site fact sheet for governor)

Richard,
I just found out that the SLO wants to give this information to the MA governor by the end of the day. The appointment between the NRC and SLO for the governor is at 2pm today (at which time we'd like to have "fact-checked" everything), so there's a bit of a time crunch on things.
Thanks again,
Shelby

From: Bensi, Michelle
Sent: Monday, March 28, 2011 11:59 AM
To: Guzman, Richard
Subject: Confirmation on Pilgrim info (site fact sheet for governor)

Hi Richard,

Thanks for taking the time to talk with me a few minutes ago.

The Massachusetts SLO has pulled together a factsheet for the governor. We've been asked to review it for errors. Here are the two "facts" I need to confirm relative to Pilgrim (extracted directly out of document):

- The seismic design standard for Pilgrim safety-related equipment was determined by applying the effects of the largest earthquake in the region, an event measuring 6.0 on the Richter scale, at Cape Anne, 60 miles north. This event is then applied at the closest epicentral location consistent with geologic structure of the site.
- A tsunami at Pilgrim such as occurred in Japan is not considered to be a probable event based on the known geological features in the area. The emergency diesel generators that provide power if the site loses off-site power and built in reinforced concrete watertight buildings and the fuel tanks are built underground in reinforced concrete.

I know you are busy, but I'd really appreciate it if you could get back to me quickly on these two points.

Thanks again,
Shelby

Michelle Bensi, Ph.D.
Reliability and Risk Engineer
Nuclear Regulatory Commission
Office of Nuclear Regulatory Research
Division of Risk Analysis
Operating Experience and Generic Issues Branch

Bensi, Michelle

From: Bensi, Michelle
Sent: Monday, March 28, 2011 3:02 PM
To: OST02 HOC; OST01 HOC
Subject: RE: RST Support Seismology Q&A position

Hello,

I was brought in primarily to assist with compilation of a seismic Q&A document and I continue to work on that this week. Thus, I wasn't planning to work any shifts in the Ops Center this week. Please let me know if this is a problem.

Thanks,

Michelle Bensi

From: OST02 HOC
Sent: Friday, March 25, 2011 4:34 PM
To: Weaver, Thomas; Munson, Clifford; Seber, Dogan; Devlin, Stephanie; Bensi, Michelle
Subject: RST Support Seismology Q&A position

Please designate which shifts this weekend and next week, starting 7:00am, tomorrow morning, March 26th, for Seismology Q&A questions . Send responses back to OST01. HOC@nrc.gov, OST02.HOC@nrc.gov.

EST Admin Support
NRC Operations Center
eMail: OST02.HOC@nrc.gov

4/28/11

Schaperow, Jason

From: Schaperow, Jason
Sent: Monday, March 28, 2011 4:10 PM
To: Chang, Richard
Subject: RE: SOARCA 2011 RIC Slides

Thank you.

From: Chang, Richard
Sent: Monday, March 28, 2011 3:21 PM
To: Dacus, Eugene
Cc: Sheron, Brian; Schaperow, Jason; Armstrong, Kenneth; Gibson, Kathy; Wagner, Katie
Subject: SOARCA 2011 RIC Slides

Eugene,

Here is the link for the SOARCA session at the 23rd Regulatory Information Conference.

https://ric.nrc-gateway.gov/docs/abstracts/SessionAbstract_58.htm

Please let me know if there is anything else that I can help you with.

Richard Chang
Program Manager
RES/DSA/SPB
301-251-7980

4/29/11

Schaperow, Jason

From: Schaperow, Jason
Sent: Tuesday, March 29, 2011 9:40 AM
To: Chang, Richard
Subject: RE: FYI- News Article on SOARCA

Thanks.

From: Chang, Richard
Sent: Tuesday, March 29, 2011 7:35 AM
To: Schaperow, Jason; Tinkler, Charles; Santiago, Patricia; Ghosh, Tina; Armstrong, Kenneth
Subject: FYI- News Article on SOARCA

http://news.yahoo.com/s/ap/20110329/ap_on_re_us/us_us_japan_nuclear_blackouts_2

Richard Chang
Program Manager
RES/DSA/SPB
301-251-7980

4/29/11

Schaperow, Jason

From: Schaperow, Jason
Sent: Tuesday, March 29, 2011 9:51 AM
To: Chang, Richard
Subject: RE: SOARCA Peer Review Committee

Sounds good to me.

From: Chang, Richard
Sent: Tuesday, March 29, 2011 8:31 AM
To: Tinkler, Charles; Schaperow, Jason
Cc: Ghosh, Tina
Subject: SOARCA Peer Review Committee

Guys,

I am planning on writing the Peer Review Committee an e-mail stating that the events in Japan have delayed the release of Appendix A to them by an as-of-yet undetermined amount of time (and that an estimate will not be available until the reactors in Japan stabilize).

Do you have any thoughts on that?

Thanks,

Richard Chang
Program Manager
RES/DSA/SPB
301-251-7980

4/29/2011

Schaperow, Jason

From: Schaperow, Jason
Sent: Tuesday, March 29, 2011 11:42 AM
To: Lee, Richard
Subject: RE: DOE trip to Milestone

Thanks. Very interesting.

From: Lee, Richard
Sent: Tuesday, March 29, 2011 11:20 AM
To: Esmaili, Hossein; Gauntt, Randy (home); Randy Gauntt (SNL); Salay, Michael
Cc: Tinkler, Charles; Schaperow, Jason; Katie Wagner
Subject: DOE trip to Milestone

Enclosed is a brief trip report from Per Peterson on DOE trip to Milestone yesterday.

Katie: Please log in on share point. It is provided to DSA staff for information.

4/29/11

Lee, Richard

From: Lee, Richard
Sent: Tuesday, March 29, 2011 9:39 PM
To: Powers, Dana A
Subject: RE: gauntt to japan

He will pay for this. Have you able to get one of his staff to answer the questions. Larry and some can help.

From: Powers, Dana A [dapower@sandia.gov]
Sent: Tuesday, March 29, 2011 7:30 PM
To: Lee, Richard
Subject: gauntt to japan

I take it you have heard that Randy is being sent to Japan by SNL! He is just trying to get out of preparing response to the peer reviewers. Dana

4/29/11

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Tuesday, March 29, 2011 9:24 AM
To: McNamara, Nancy
Subject: RE: Briefing Package for MA Visit & 11:00 call
Attachments: Fukushima Presentation (3-25) with GI199.pptx


Nancy,

I took the liberty of adding the GI-199 slides to the Fukushima presentation so that they have the same look and can be together if you are printing handouts. I also decided to swap the position of GI-199 slides 3 and 4. The revised presentation is attached for your use.

Ben

From: McNamara, Nancy
Sent: Tuesday, March 29, 2011 8:59 AM
To: Beasley, Benjamin; Schmidt, Wayne
Subject: Briefing Package for MA Visit & 11:00 call
Importance: High

4/29/5



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Events at Fukushima Units 1-4

March 30, 2011


Bill Dean, Regional Administrator

Fukushima Units 1 - 4



3/11 Earthquake & 3/12 Unit 1 Hydrogen Explosion

After earthquake 11 March




Explosion 0630 GMT 12 March



After explosion 0730 GMT




Fukushima plants



BWR with Mark 1 Containment


Secondary containment:
Area of explosion at
Fukushima Daiichi 1

Primary containment:
Remains intact and safe




Boiling Water Reactor Design


Mark I Containment Release Pathways Simplified



Most Recent View of Units 3 & 4



Japanese Depiction of Cooling Water Sources at Units 3 & 4 (Prior to the Return of Offsite Power)





Current Conditions - NRC's Assessment

- Units 1, 2, 3 Stable w/some degree of core damage. Being cooled with fresh water.
- Units 2 and 3 some primary containment damage. Releases of radioactivity including significant contamination in the lower levels of the Unit 2 and Unit 3 turbine buildings.
- The spent fuel pools on Units 1-4 have experienced varying water levels, but also have been receiving seawater from helicopters and spray systems.



Current Conditions - NRC's Assessment Cont.

- The U-2 spent fuel pool receiving fresh water and they are trying to change all the units from fire trucks to normal pumping in the next few days.
- Tokyo Electric Power Company has restored electric power to the site and the six reactor control rooms, and the situation, in general, continues to further stabilize, although many hurdles remain.



NRC Response Efforts

- NRC continues to monitor the unfolding events in Japan.
- NRC is coordinating their response with other federal agencies.
- NRC has deployed a team to Tokyo.
- NRC providing technical assistance to the U.S. Ambassador in Japan and the Japanese Government.
- NRC continues assessment of radiological conditions, dose projections, and protective action recommendations.
- NRC Chairman Jaczko in Japan this week and keeps White House apprised.



Ensuring Reactor Safety

- General Design Criteria (10CFR50, Appendix A) lay out the deterministic basis for the design of nuclear power plant safety systems.
- In 1975 NRC completed its first PRA study and continues to evaluate the risks to the public from the operation of nuclear power plants to within our safety goals by limiting the chance of core damage and fission product release to the environment.



Ensuring Reactor Safety

- Significant activity to evaluate the chance and consequences of a Station Blackout (SBO Rule 10CFR50.63 1988) plant procedures and changes implemented in the 1990s.
- Generic Letters 88-20 “Individual Plant Examination for Severe Accident Vulnerabilities”
- NRC Maintenance Rule (10CFR50.65, 1991)
Implemented in 1996




Ensuring Reactor Safety

- In 2000 the NRC implemented the Reactor Oversight Program (ROP).
- Following September 11, 2001, the NRC and industry conducted detailed assessments . NRC issued orders for licensees to take actions to develop and implement guidance and strategies intended to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies in the following areas: (i) Fire fighting; (ii) Operations to mitigate fuel damage; and (iii) Actions to minimize radiological release.



NRC Initiatives

- NRC Issued Information Notice 2011-005
- NRC Commission supported the establishment of an agency task force.
- Temporary Instruction 2515/183
- Ongoing Communications with the public, Congressional, State (SLO), Local Agencies



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Overview of Generic Issue 199

Updated Seismic Hazard Estimates



Background: GI-199 Safety/Risk Assessment Context and Results

- **Generic Issues Program Stages**
 - Identification – Early Site Permit reviews
 - Acceptance
 - Screening
 - Safety/Risk Assessment
 - Regulatory Assessment
- **Safety / Risk Assessment Results**
 - Operating power plants are safe.
 - Overall seismic risk estimates remain small
 - The new seismic data for some plants meet the criteria for further evaluations



GI-199 Safety / Risk Assessment Assumptions

- Performed a conservative, screening-level assessment to evaluate whether further investigations are warranted.
 - The nature of the information used (seismic hazard data, plant-level fragility information) make these estimates useful only as a screening tool.
 - The results should not be interpreted as definitive estimates of plant-specific seismic risk because some analyses were conservative making the calculated risk higher than in reality.



GI-199 Current Status

- Evaluating plant-specific information to determine if improvements to seismic safety are warranted
- Additional information is needed to consider plant-specific backfits



Next Steps for GI-199

- Issued an Information Notice to inform plants of the GI-199 Safety/Risk Assessment results. (September 2010)
- NRC is developing a generic communication to request needed data. (2011)

Lee, Richard

From: Lee, Richard
Sent: Wednesday, March 30, 2011 2:05 PM
To: Salay, Michael; 'Michael Salay'
Subject: Your names on the list to go to Japan

Importance: High

Mike:

Your name is among the 4 that was sent to the Chairman for approval to go to Japan. We should hear back by this afternoon or late tonight. Chairman up on the Hill this morning.

If you go, you can leave on Sunday. You are to replace one who will be returning to U.S. on 4/06 or 4/07.

Richard

4/29/6

Lee, Richard

From: Lee, Richard
Sent: Wednesday, March 30, 2011 3:08 PM
To: Case, Michael
Cc: Sheron, Brian; Uhle, Jennifer; Gibson, Kathy
Subject: RE: 3rd Team to Japan

Thanks, Mike:
I spoke to Michele Evans earlier.
Richard

-----Original Message-----

From: Case, Michael
Sent: Wednesday, March 30, 2011 3:05 PM
To: Gibson, Kathy
Cc: Sheron, Brian; Uhle, Jennifer; Lee, Richard
Subject: 3rd Team to Japan

Hi Kathy

Just a quick update from Michele. She is still waiting for feedback from the Chairman on the size of the team but it looks like Mike Salay is still on the short list.

Michele has been in contact with Richard and as soon as she gets the OK she'll let Richard know so he can get Mike back from Europe.

Sent from Blackberry
Michael Case.

4/29/11

A11

Lee, Richard

From: Richard L Garwin [rlg2@us.ibm.com]
Sent: Wednesday, March 30, 2011 5:59 PM
To: Binkley, Steve
Cc: Brinkman, Bill; Hurlbut, Brandon; Sheron, Brian; Poneman, Daniel; Harold McFarlane; Harold Denton; Adams, Ian; John Holdren; JOE H. PAYER; Kelly, John E (NE); John Grossenbacher; Owens, Missy; Per Peterson; Lyons, Peter; Phil Finck; Dick Garwin; Lee, Richard; Bob Budnitz; Rolando Szilard; SCHU; Aoki, Steven; Koonin, Steven; Steve Fetter; Binkley, Steve; DAgostino, Thomas
Subject: Measuring water level in dry well by coupling to the organ-pipe resonance of the contained air?

I'll estimate this.

Dick Garwin

4/29/11

Lee, Richard

From: Lee, Richard
Sent: Thursday, March 31, 2011 7:49 AM
To: 'Gauntt, Randall O'
Subject: RE: Mike Salay is on his way to Japan soon

Great. Where are you working out of?

-----Original Message-----

From: Gauntt, Randall O [<mailto:rogaunt@sandia.gov>]
Sent: Thursday, March 31, 2011 2:55 AM
To: Lee, Richard
Subject: Re: Mike Salay is on his way to Japan soon

OK. We have arrived on Thursday PM.
I am here with Jeff LaChance. We are expecting to be here 2 weeks minimum. Who knows.
Randy

----- Original Message -----

From: Lee, Richard [<mailto:Richard.Lee@nrc.gov>]
Sent: Wednesday, March 30, 2011 08:43 PM
To: Gauntt, Randall O
Subject: Mike Salay is on his way to Japan soon

Randy:

Mike is leaving for Japan on Sunday, April 3. I asked him to return from the Phebus meeting in the Netherlands.

Richard

4/29/11

Beasley, Benjamin

From: Boska, John
Sent: Thursday, March 31, 2011 8:56 AM
To: Kauffman, John
Cc: Beasley, Benjamin; Khanna, Meena; Jessup, William; Salgado, Nancy
Subject: RE: RE: Outcomes from Meeting With New York State Officials
Attachments: image001.gif

Just to inform everyone on the use of 10CFR50, Appendix A, General Design Criteria, I refer to this wording we use in Indian Point license amendments:

"The following explains the applicability of General Design Criteria (GDC) for IP2 and IP3. The construction permits for IP2 and IP3 were issued by the Atomic Energy Commission (AEC) on October 14, 1966 and August 13, 1969, and the operating licenses were issued on September 28, 1973, and December 12, 1975. The plant GDC are discussed in the Updated Final Safety Analysis Report (UFSAR) Chapter 1.3, "General Design Criteria," with more details given in the applicable UFSAR sections. The AEC published the final rule that added Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants," in the *Federal Register* (36 FR 3255) on February 20, 1971, with the rule effective on May 21, 1971. In accordance with an NRC staff requirements memorandum from S. J. Chilk to J. M. Taylor, "SECY-92-223 - Resolution of Deviations Identified During the Systematic Evaluation Program," dated September 18, 1992 (ADAMS Accession No. ML003763736), the Commission decided not to apply the Appendix A GDC to plants with construction permits issued prior to May 21, 1971. Therefore, the GDC which constitute the licensing bases for IP2 and IP3 are those in the UFSARs."

This same information applies to many older reactors. In all cases, we should just refer to the UFSAR. I will edit this reply to delete references to GDC 2, and just reference the UFSAR (the effect in this case is the same). As a general principle, appendices to 10CFR50 do not apply to plants unless there are specific words invoking the appendix. For example, here are quotes from Appendix A:

"Under the provisions of § 50.34, an application for a construction permit must include the principal design criteria for a proposed facility."

"Also, there may be water-cooled nuclear power units for which fulfillment of some of the General Design Criteria may not be necessary or appropriate. For plants such as these, departures from the General Design Criteria must be identified and justified."

So the only way to tell which 10CFR50 Appendix A GDC apply to a plant is to read the UFSAR. They don't apply in a blanket manner.

John Boska
Indian Point Project Manager, NRR/DORL
U.S. Nuclear Regulatory Commission
301-415-2901
email: john.boska@nrc.gov

From: Kauffman, John
Sent: Thursday, March 31, 2011 7:17 AM
To: Boska, John
Cc: Beasley, Benjamin
Subject: RE: Outcomes from Meeting With New York State Officials

John,
Please see my input below on follow-up items assigned to me. Please contact me if you have any questions or need further assistance.



John V. Kraffman

Senior Reactor Systems Engineer
US NRC/RES/DRA/OEGIB
Washington, DC 20555 Mail Stop: C-2A07M
Phone: 301-251-7465
Fax: 301-251-7410

Please visit the [internal GIP web page](#) or [external GIP web page](#).

1) GI-199 Safety/Risk Assessment Report

Ben Beasley previously provided you the link to the GI-199 Safety/Risk Assessment report, including the memorandum and all enclosures/attachments. Ben also provided electronic versions of the following publically available documents:

ML100270598 (Transmittal Memo)
ML100270639 (Safety/Risk Assessment (S/RA) report)
ML100270064 (Appendix A of the S/RA report)
ML100270691 (Appendix B of the S/RA report)
ML100270731 (Appendix C of the S/RA report)
ML100270756 (Appendix D of the S/RA report)

2a) Discussion of Spent Fuel Pools and GI-199 (this is from a write-up provided by Meena Khanna that Billy Jessup put together)(please note that I have 1 question/suggested edit in the next to last paragraph)

Spent fuel pools (SFPs) were not specifically evaluated as part of GI-199. However, based on their design attributes (as follows), SFPs remain safe. SFPs are constructed of reinforced concrete, several feet thick, with a stainless steel liner to prevent leakage and maintain water quality. Due to their configuration, SFPs are inherently structurally-rugged and are designed to the same seismic requirements as the nuclear plant. Information Notices related to GI-199 were sent to nuclear power plant licensees and licensees of independent spent fuel storage installations (ISFSIs).

Note: Typically, SFPs are about 40 feet deep and vary in width and length. The fuel is stored in stainless steel racks and submerged with approximately 23 feet of water above the top of the stored fuel. Each plant has a preferred SFP make-up water source (the refueling water storage tank for pressurized water reactors and the condensate storage tank for boiling water reactors). SFPs have alternate means of make-up such as service water systems and the fire water system. SFPs are also typically designed (e.g. with anti-siphon check valves) and instrumented such that leakage is minimized and promptly detected.

There has been a previous Generic Issue (GI-173) concerning spent fuel pool safety (ML013520142). This issue was closed in 2001 with no new requirements. In resolving this issue, the staff implemented an action plan for operating reactors that involved: gathering technical information for all operating reactors through plant visits, reviews of design and licensing documents, and performance of a survey using regional personnel; analyzing capabilities to maintain safe storage conditions for irradiated fuel at each site; and developing proposed actions to address identified concerns. For representative plants having one or more of the design features of concern, the staff estimated the frequency of a significant loss of coolant inventory or a sustained loss of cooling, which were selected as conservative surrogate conditions for fuel damage. These estimated frequencies were compared against screening criteria developed for reactor accidents to assess the need for

new or revised requirements. The screening criteria used for comparison with the endstate frequencies were: below 1E-06 per year, no action; between 1E-06 and 1E-05 per year, engineering judgement was used to determine need for detailed evaluation; and above 1E-05, a detailed evaluation would be performed. Several licensees took voluntary actions to address the concerns identified at their facilities. For the remaining facilities, the staff concluded that no new or revised requirements were justified.

The Japanese earthquake did not change our understanding of the seismic hazard at U.S. nuclear power plants or the conclusions of GI-199. This is because the effect of a single earthquake is small on the estimated seismic hazard, unless it occurs in an area not previously recognized as being capable of producing earthquakes, or is larger than previously believed possible in a region. In a seismic hazard study, the seismic source zones are specifically delineated to include a sufficient number of earthquakes to provide a stable estimate of the seismicity rate and are thus relatively insensitive to the addition of a single earthquake. If an earthquake does occur in an area not previously recognized as being capable of producing earthquakes or if an earthquake occurs that is larger than previously believed possible in a region, changes to the seismic hazard model used to develop seismic hazard estimates would be required. This Japanese earthquake occurred on a "subduction zone", which is the type of tectonic region that produces earthquakes of the largest magnitude. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Subduction zone earthquakes are also required to produce the kind of massive tsunami seen in Japan. In the continental US, the only subduction zone is the Cascadia subduction zone which lies off the coast of northern California, Oregon and Washington. So, a continental earthquake and tsunami as large as in Japan could only happen there. Nevertheless, the NRC intends to conduct an extensive lessons learned evaluation of the Japanese earthquake and tsunami. NRC will enhance our regulatory program as appropriate based on the results of the lessons learned evaluation.

2b) Discussion of Indian Point Spent Fuel Pools

General Information:

GDC 2 requires that structures important to safety be designed to withstand the effects of natural phenomena combined with those of normal and accident conditions without loss of capability to perform their safety function. As such, all structures at Indian Point Units 2 and 3 (IP2 and IP3, respectively), including the spent fuel pools (SFPs), which fall under this classification are designed to withstand loads due to earthquakes, in combination with other loads.

Load combinations and specifications cited in SRP Section 3.8.4, "Other Seismic Category I Structures," provide acceptable engineering criteria to accomplish that function for structures such as SFPs. Meeting these requirements provides added assurance that safety-related structures will be designed to withstand the effects of natural phenomena and will perform their intended safety function.

Indian Point Units 2 and 3:

Chapter 9 of the IP2 and IP3 Final Safety Analysis Reports (FSARs) indicates that the SFP structures are classified as Seismic Category I. The IP2 FSAR is specific regarding the design criteria, and indicates that the IP2 SFP was designed in accordance with the provisions of American Concrete Institute (ACI)-318, "Building Code Requirements for Reinforced Concrete" (see Section 9.5.2.1.4 of the IP2 FSAR). The 1989 license amendment issued for IP3 SFP re-rack indicates that the design criteria used to evaluate the SFP structure are based on the provisions in ACI 349-80, "Code Requirements for Nuclear Safety-Related Concrete Structures."

As indicated above, based the classification of these structures, they are required to be designed against bounding loading combinations which include loads due to a safe shutdown earthquake. As such, the structural analyses are performed to ensure that the SFPs will remain functional during and after a safe shutdown earthquake.

The following licensing actions relate to the structural analysis of the IP2 and IP3 SFPs for conditions which include loads due to seismic events:

The NRC issued a license amendment in 1989 for a re-rack of the IP3 SFP (ML003778816). An extensive review of the structural aspects of the re-rack was performed by Brookhaven National Laboratory (BNL) and is included as Appendix A of the NRC staff's safety evaluation associated with this amendment. This review explicitly notes that the licensee demonstrated that the design basis requirements associated with the IP3 SFP would continue to be satisfied following the re-rack. As such, the licensee demonstrated that under design basis loading combinations, which include loads due to a safe shutdown earthquake, the applicable ACI provisions would continue to be satisfied following the re-rack.

The NRC issued a license amendment in 1990 for a re-rack of the IP2 SFP (ML003778320). In the NRC staff's associated safety evaluation, it was noted that the licensee evaluated the effects of the high density racks on the SFP structure and concluded that the structure would continue to satisfy the design basis requirements prescribed by the ACI code. These design basis requirements include withstanding the loads generated under a safe shutdown earthquake.

Subsequent to the re-rack of the IP2 SFP, the NRC staff's review of the licensee's request to review [should this be renew?] the IP2 operating license included a number of audit items. Audit Item 360 associated with the renewal of the IP 2 operating license focused on the leakage previously discovered at the IP2 site. The licensee provided information to the NRC staff by letter dated November 6, 2008, which presented the results of structural evaluations (finite element analyses) performed for the IP2 SPF walls. The model used in this structural analysis accounted for bounding conditions which may exist due to the potential for degradation resulting from the SFP leakage (i.e., no credit for reinforcing steel). This is a very conservative assumption given that all testing performed by the licensee up to the date of the November 6, 2008, submittal demonstrated that there was no concern for degradation of the rebar due to boron concentrations resulting from SFP leakage. The results of the analysis showed that the structure contained significant margin against failure when the structure was subjected to design basis loading conditions, including those due to a design basis earthquake, even if no rebar was considered in the model.

The overall conclusion which is demonstrated by the re-rack evaluations and the additional IP2 SFP evaluation is that the licensee has shown multiple times that the design basis requirements associated with the design of the SFP structure are satisfied. As such, the licensee has demonstrated that there is reasonable assurance that the structure will maintain its ability to serve its safety function during and after a safe shutdown earthquake or other natural phenomena.

Lee, Richard

From: Powers, Dana A [dapower@sandia.gov]
Sent: Thursday, March 31, 2011 11:38 AM
To: Lee, Richard; Kelly, John E (NE)
Subject: Test CST with Seawater

John, I spoke to Nenoff. She has a commercial sample of the crystalline silicon titanates and thinks she can test with seawater if you don't have someone already positioned to do the testing. Dana

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Thursday, March 31, 2011 1:12 PM
To: Ibarra, Jose
Subject: RE: DRA Support to Japanese Event

In conjunction with NRR and Region 1, Doug Coe, Marty Stutzke and Ben Beasley have supported meetings with the Governor's offices from New York and Massachusetts.

From: Ibarra, Jose
Sent: Thursday, March 31, 2011 12:51 PM
To: Barnes, Valerie; Nicholson, Thomas; Siu, Nathan; Stutzke, Martin; Ott, William; Salley, MarkHenry; Peters, Sean; Beasley, Benjamin; Coyne, Kevin; Demoss, Gary
Subject: DRA Support to Japanese Event

All,
DRA would like to take credit for special support given related to the Japanese Event. Can you in one sentence or two tell me what special support you have provided. I will construct the text for an DRA accomplishment to be included in the OP Plan update. I need that information today to meet the due date of the Op Plan update. Thanks. Jose

4/302

Lee, Richard

From: Richard L Garwin [rlg2@us.ibm.com]
Sent: Thursday, March 31, 2011 4:35 PM
To: Adams, Ian
Cc: Brinkman, Bill; Narendra, Blake; Hurlbut, Brandon; Sheron, Brian; Butnitz, Bob (pacbell.net); Smith, Haley; McFarlane, Harold; Adams, Ian; Kelly, John E (NE); Grossenbacher, John (INL); Pitzer, Karrie S.; Chambers, Megan (S4); Owens, Missy; Miller, Neile; Fitzgerald, Paige; Peterson, Per; Lyons, Peter; Finck, Phillip; Garwin, Dick (EOP); Lee, Richard; Budnitz, Bob; Szilard, Ronaldo; Steve Fetter; Aoki, Steven; Binkley, Steve; Mustin, Tracy
Subject: Useful website for technical details vs time.

<http://www.nisa.meti.go.jp/english/files/en20110331-2-2.pdf>

More generally, <http://www.nisa.meti.go.jp/english>
Don't be put off by the titles of the press releases.

Dick Garwin

Bensi, Michelle

From: Bensi, Michelle
Sent: Thursday, March 31, 2011 4:53 PM
To: Kauffman, John
Subject: RE: Reminder--OEGIB Weekly Activities Input due by noon tomorrow, Friday 4/1/2011. [eom]

Thanks,
Shelby

Last week activities

- Seismic Q&A document in response to events in Japan
- Presentation (and prep) for joint branch meeting

Next week activities

- Seismic Q&A document
- Out-of-office Friday (CHU)

From: Kauffman, John
Sent: Thursday, March 31, 2011 3:59 PM
To: Bensi, Michelle; Criscione, Lawrence; Ibarra, Jose; Killian, Lauren; Lane, John; Reisifard, Mehdi; Perkins, Richard; Salomon, Arthur; Smith, April; Wegner, Mary
Subject: Reminder--OEGIB Weekly Activities Input due by noon tomorrow, Friday 4/1/2011. [eom]

4/30/11

Bonaccorso, Amy

From: CL Spriggs [boardwaxmax@excite.com]
Sent: Friday, April 01, 2011 12:09 PM
To: NRC Allegation
Subject: Website issue

Hello:

Please check this website.

http://en.wikipedia.org/wiki/List_of_nuclear_reactors

If you scroll to the bottom, the U.S. nuclear plants in the NE are listed with GPS coordinates.
Realize this is not your site, but damn, how smart is that?

Cheers
Craig

4/305

Beasley, Benjamin

From: Lane, John
Sent: Friday, April 01, 2011 10:06 AM
To: Hogan, Rosemary; Stutzke, Martin; Perkins, Richard; Bensi, Michelle
Cc: Beasley, Benjamin; Kauffman, John
Subject: Seismic Review Table
Attachments: Seismic Review Table_ML1108807472.pdf

Attached is an old NUREG/CR that I worked on back in 1980 entitled, the Seismic Review Table. With the exception of myself, everyone else involved with it is either retired, deceased or both (a causal relationship has not been established between the report and those ends).

It's a tabulation of the FSAR approved seismic/structural designs for the plants that were in house as of that timeframe (which is most of the current fleet). It includes a relatively comprehensive view of each plant's design in terms of OBE/SSE earthquake level and spectra, the soil-structure assumptions, and the containment design loads. It even includes proximity to local dams.

It is in ADAMS and I'm considering making it publicly available at some point. (If you have any opinion on that, pls. let me know.)

I hope it's of some value to you in either the Japan-related, GI-199, or pre-GI dam-related on-going efforts.

jcl

u/306

Seismic Review Table

Prepared by M. Subudhi, M. Reich, B. Koplik, J. Lane

**Department of Nuclear Energy
Brookhaven National Laboratory**

**Prepared for
U. S. Nuclear Regulatory
Commission**

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

GPO Sales Program
Division of Technical Information and Document Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

and

National Technical Information Service
Springfield, Virginia 22161

Seismic Review Table

Manuscript Completed: April 1980
Date Published: May 1980

Prepared by
M. Subudhi, M. Reich, B. Koplik, J. Lane*

Structural Analysis Group
Department of Nuclear Energy
Brookhaven National Laboratory
Upton, NY 11973

*Staff, U.S. Nuclear Regulatory Commission

Prepared for
Division of Operating Reactors
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
NRC FIN No. A3326

ABSTRACT

The Seismic Review Table is a summary of Engineering Design parameters that were employed in the seismic analysis and design of nuclear power plants. The table covers 71 reactors licensed to operate by the U.S.N.R.C. The information contained is listed plant by plant and consists of OBE and SSE "g" Level and Modified Mercalli Intensity; Earthquake Time History used to develop the ground response spectra or as input in the dynamic analysis; Number of Earthquake Components used and Method of Combining Them; Method of Modal Combination; Type of Ground Design Spectra; Method of Generation of Floor Response Spectra; Type of Foundation and Depth; Type, Thickness, Shear Wave Velocity and Shear Modulus Profile of the Surrounding Subgrade Soil and Bedrock; Ground Water Table Depth; nearby Dams; Modelling Method used for soil-structure interaction; Material Damping of Soil; Limitation on Modal Damping . Damping Values; and Loading Combinations, and Acceptance Criteria for Category I Structures, Mechanical Equipment, Piping, and Electrical systems. The goal of the Seismic Review Table is to provide a reference of the available information relevant to the seismic design of currently licensed nuclear power plants.

TABLE OF CONTENTS

	<u>Page</u>
Abstract.....	iii
Acknowledgements.....	vii
Introduction.....	1
Program Tasks and Accomplishments.....	2
Table I - Contents of Seismic Review Table (Currently Licensed in the United States).....	I-1

ACKNOWLEDGEMENTS

The authors wish to acknowledge their indebtedness and gratitude to various people consulted during the preparation of the Seismic Review Tables. Particular thanks are due to our Department Librarians, Mrs. Helen Todosow and Mrs. Catherine Green for their help in gathering and obtaining the various FSAR's, amendments, etc. and to Dr. C. P. Tan of the Structural Engineering Branch, NRC, for the Containment Vessel data shown in Table I of this report. Grateful acknowledgement is also due to Larry Shao, Acting Assistant Director of Engineering Programs, Division of Operating Reactors and Assistant Director for General Reactor Safety Research, NRC, and Dr. P. T. Kuo, Section Leader, Seismic Review Group, NRC, for their constructive criticism and advice regarding the contents of the review tables. Finally to Miss Joan Murray who with patience typed and retyped the corrected drafts, our sincerest gratitude is due.

INTRODUCTION

The intent of this report is to enable a quick reference of the major seismic design parameters inherent in the 71 currently licensed nuclear power plants. All of the presented data was obtained from the existing Final Safety Analysis Reports (FSAR) and their associated amendments. The results are tabulated for each plant in a five page "Seismic Review Table." The major headings in the table are:

- A) Earthquake data
- B) Method of combination (e.g., modes and earthquakes directional components)
- C) Design spectra
- D) Foundation and liquefaction assessment
- E) Soil-structure interaction
- F) Damping, load combination and acceptance criteria and allowable stresses for:
 - 1) Category I structures
 - 2) Mechanical Equipment and piping
 - 3) Electrical equipment

Table I lists all of the plants together with the names of the owners, the location, the principal reactor contractor, the plant architectural engineers, the type of plant (PWR, BWR, HTGR), the type of containment vessel, and the electrical and thermal power output. FSAR's for all the plants listed in the table have been reviewed and the tabulated results are given in this report. For completeness Figure 1 depicting the geographical locations of the operational plants is also included.

PROGRAM TASKS AND ACCOMPLISHMENTS

Efforts under this program can be subdivided into three distinct stages: Stage 1 involved the determination and collection of all available plant FSAR's and related questions, answers, and amendments. Next, under Stage 2, the collected information was reviewed in detail for relevance to the information needed for the Seismic Review Table. Finally, under Stage 3, the pertinent parameters were assembled and summarized in tabular form.

With reference to the work carried out under Stage 1, it should be realized that the documented information contains numerous sections, subsections, and amendments per plant which were compiled over a span of many years. This information had to be reviewed to ascertain which documents were available and which had to be ordered. This was accomplished by carrying out a careful review of the documents and comparing the information contained within the documents against the information compiled in the following reference reports:

Title Listing of Civilian Power Reactor Docket Literature in Nuclear Science Abstracts, volumes 21-26 (1967-1972), TID-3354 R1. U.S. Atomic Energy Commission, Technical Information Center, April 1973.

Title Listing of Civilian Power Reactor Docket Literature in Nuclear Science Abstracts, volumes 27 (Jan.-June 1973), TID-3324-R1-S1. U.S. Atomic Energy Commission, Technical Information Center, September 1973.

Title Listing of Power Reactor Docket Information, PRDI-74-12. U.S. Atomic Energy Commission, Technical Information Center, December 1974.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-75/12. U.S. Energy Research and Development Administration, Technical Information Center, December 1975.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-76/12/P1. U.S. Energy Research and Development Administration, Technical Information Center, December 1976.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-77/12/P1. U.S. Dept. of Energy, Technical Information Center, December 1977.

Power Reactor Docket Information, Annual Cumulation, NUREG/PRDI-78/12/P1. U.S. Dept. of Energy, Technical Information Center, December 1978.

Since there was no specific standardized FSAR format until 1975-76, each FSAR had to be examined on an individual basis. In a number of cases the FSAR was actually defined as an amendment to the PSAR. Once it was determined what information was missing and what part of the missing information involved seismic design criteria, the necessary steps were taken to obtain the required documents.

Once the material needed for the review was compiled, Stage 2 efforts were initiated. For each plant assembled FSAR's were first reviewed for the pertinent seismic information. These were available either in "hard cover" or in "microfiche" form. Next, the amendments which include various questions and answers about the plant raised over a period of many years were reviewed and the gathered information was then compiled and referenced for section and page number.

Under Stage 3, the compiled reference material of Stage 2 was prepared and extracted for insertion into the Seismic Review Tables. The information given in the table thus reflects the data up to and including the latest amendments available at time of publication. The tables are numbered according to the numbering scheme shown in the first column of Table I. For each number, a set of five pages comprising the Seismic Review Table is presented with the page number appearing in the lower right hand corner in sequence. As an example, page 8-2 would indicate the eighth entry on Table I, with the number 2 representing the second page of the five-page review table.

Referring to the Seismic Review Tables, the first item assembled is on page 1 of the five-page table. The name of the plant with reactor unit numbers (if more than one), the type of reactors, and containment, Nuclear Steam System Supplier (NSSS), the architect engineer, and the CP/OL issue dates. Next, under the heading of earthquake data, information pertaining to OBE, SSE, and earthquake time-history was assembled. The OBE and SSE information was further broken down into horizontal and vertical "g" values and Modified Mercalli Intensity values. Reference pages, sections, and amendment numbers are listed in the tables for all assembled information. Under the time history column, names of the earthquake records used are given. These records in turn are

used either for the development of the ground design spectra or are modified so that their response spectra envelopes the specified ground design spectra. Generally speaking, this information was available for most of the plants. However, some of the early plants, such as Yankee Rowe, did not have this information in the reviewed dockets, and thus the term "not available" is written in the table. For those cases where the available information was unclear, the term "unclear information" appears in the table, together with the pertinent page numbers where the unclear information is given so that the reader can look up the information for further insight.

Returning to headings OBE and SSE, in many plants the vertical components were equal to two-thirds of the horizontal, with OBE values typically one-half of the SSE. For the earthquake time-history, the older plants usually used El Centro or Taft, while the newer plants used synthetic time-histories.

Methods of combinations were assembled under the subheadings "Number of Earthquake Components Used and Its Combination" and "Modal Combination." The information under these headings includes such items as the the number of horizontal and vertical components used for the analysis, the number of modes considered, and how they were combined, e.g., absolute sum, SRSS, or algebraic sum. It is to be noted that the term "modal combination used" in the table refers to the response spectrum analysis.

The final item on page 1 involves the design spectra with the two subheadings entitled "Type of Ground Design Spectra" and "Method of Generation of Floor Response Spectra." Ground design spectra includes the Housner, Newmark, and Regulatory Guide 1.60 response spectra or any other method specified in the FSAR's. The most commonly used method for generating the floor response spectra was the time-history method. When information regarding the input

time-history was available, it was also included under this heading. For some of the older plants, the ground design spectra was directly used with some amplification factor.

Turning to page 2 of 5 of the table, the major headings are "Foundation and Liquefaction Assessment" and "Soil-Structure Interaction." The first item contains four subtopics: "Type of Foundation," "Bearing Information" (including information related to the type, thickness, and shear velocity profile), "Groundwater Table," and "Dams." Foundation description and bedrock characteristics are listed for the containment building. Information regarding structures on pile foundations is also given under this heading. Bearing Information lists such items as type of rock (dolomite, glacial fill, sandstone, etc.), the thickness of the various soil deposits, and shear wave velocities. Groundwater Table information and the existence of nearby dam locations were obtained from the site geological survey.

"Soil Structure Interaction" consists of four subtopics. "Method of Modelling" lists the mathematical model chosen for generating the floor response spectra of the reactor building and the soil beneath it. Usually the structure is modeled as a conventional stick model while the soil is represented as either a lumped spring or finite element model. It is to be noted that a number of plants have their foundation on bedrock. When reviewing the soil structure interaction modelling method, it was found that for some plants a fixed base method was employed. For these cases, the notation fixed base method appears. For cases where no statement was found as to the type of modelling used, the term "not available" was entered in the table. The term "not available" should only be interpreted as a statement of fact with reference to the material presented in the FSAR; it only means that no information about the particular item was found. Other subtopics include the "Soil Shear Strength Modulus Profile," "Material Damping of Soil," and the "Limitation on Modal Damping."

Pages 3, 4, and 5 of the Seismic Review Table are devoted respectively to Category I--structure, mechanical, piping and electrical equipment. Each of these pages have common headings that include "Damping Values" (OBE/SSE) and "Design Criteria," with the latter heading containing subheadings for load

combination and acceptance criteria/allowable stresses. "Method of Qualification" (testing or analytical) was included for the mechanical equipment, piping and electrical equipment given on pages 4 and 5. Generally, very little information was available for electrical equipment.

The information listed for the 11 SEP plants (Big Rock Point, Dresden 1 and 2, Ginna, Haddam Neck, LaCrosse, Millstone 1, Oyster Creek, Palisades, San Onofre 1, and Yankee Rowe) was partly obtained through the use of unpublished docket search reports supplied to us by the Systematic Evaluation Program Branch, DOR. This information supplements what was obtained by Brookhaven staff members in their docket search.

In conclusion, this report contains much information covering a wide range of seismic topics. It is possible that some relevant information has been inadvertently overlooked. The Structural Engineering Branch of the Division of Engineering has the responsibility for maintaining these tables and would appreciate any contribution from interested parties as to additions or modifications which might be made to improve it.

The information contained here comprises a data base which will be used to evaluate conformance of the operating reactors with current seismic design guidelines.

NUCLEAR POWER REACTORS IN THE UNITED STATES




FIGURE 1

CONTENTS

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
1-1	Arkansas Nuclear One, Unit 1 (Arkansas Power & Light Co.)	Russellville, Ark.	B&W	Bechtel	PWR	(11)	850	2,568
2-1	Arkansas Nuclear One, Unit 2 (Arkansas Power & Light Co.)	Russellville, Ark.	Comb.	Bechtel	PWR	(11)	912	2,815
3-1	Beaver Valley Power Station, Unit 1 (Duquessne Light Co., Ohio Edison Co., and Pennsylvania Power Co.)	Shippingport, Pa.	West.	S&W	PWR	(7)	852	2,652
4-1	Big Rock Point Plant Nuclear (Consumer Power Co.)	Big Rock Point, Mich.	GE	Bechtel	BWR	(1)	72	240
5-1	Browns Ferry Nuclear Power Station, Unit 1 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
5-1	Browns Ferry Nuclear Power Station, Unit 2 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
5-1	Browns Ferry Nuclear Power Station, Unit 3 (Tennessee Valley Authority)	Decatur, Ala.	GE	TVA	BWR	(2)	1,065	3,293
6-1	Brunswick Steam Electric Plant, Unit 1 (Carolina Power & Light Co.)	Southport, N.C.	GE	UE&C	BWR	(5)	821	2,436
6-1	Brunswick Steam Electric Plant, Unit 2 (Carolina Power & Light Co.)	Southport N.C.	GE	UE&C	BWR	(5)	821	2,436
7-1	Calvert Cliffs Nuclear Power Plant, Unit 1 (Baltimore Gas & Electric Co.)	Lusby, Md.	Comb.	Bechtel	PWR	(10)	845	2,700
7-1	Calvert Cliffs Nuclear Power Plant, Unit 2 (Baltimore Gas & Electric Co.)	Lusby, Md.	Comb.	Bechtel	PWR	(10)	845	2,700
8-1	Cooper Nuclear Station (Nebraska Public Power District and Iowa Power and Light Co.)	Brownville, Nebr.	GE	B&R	BWR	(2)	778	2,381
9-1	Crystal River Nuclear Plant, Unit 3 (Florida Power Corp.)	Red Level, Fla.	B&W	Gilbert	PWR	(10)	825	2,452

TABLE I: CURRENTLY LICENSED REACTORS IN UNITED STATES

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
10-1	Davis-Besse Nuclear Power Station, Unit 1 Cleveland Electric Illuminating Co.)	Oak Harbor, Ohio	B&W	Bechtel	PWR	(4)	906	2,772
11-1	Donald C. Cook Nuclear Power Plant, Unit 1 (Indiana and Michigan Electric Co.)	Bridgman, Mich.	West.	AEP	PWR	(6)	1,054	3,250
11-1	Donald C. Cook Nuclear Power Plant, Unit 2 (Indiana and Michigan Electric Co.)	Bridgman, Mich.	West.	AEP	PWR	(6)	1,100	3,391
12-1	Dresden Nuclear Power Station, Unit 1 (Commonwealth Edison Co.)	Morris, Ill.	GE	Bechtel	BWR	(1)	200	700
13-1	Dresden Nuclear Power Station, Unit 2 (Commonwealth Edison Co.)	Morris, Ill.	GE	S&L	BWR	(2)	794	2,527
13-1	Dresden Nuclear Power Station, Unit 3 (Commonwealth Edison Co.)	Morris, Ill.	GE	S&L	BWR	(2)	794	2,527
14-1	Duane Arnold Energy Center, Unit 1 (Iowa Electric Light & Power Co., Central Iowa Power Cooperative, and Corn Belt Power Cooperative)	Palo, Iowa	GE	Bechtel	BWR	(2)	538	1,593
15-1	Edwin I. Hatch Nuclear Plant, Unit 1 (Georgia Power Co.)	Baxley, Ga.	GE	Bechtel	BWR	(2)	786	2,436
16-1	Edwin I. Hatch Nuclear Plant, Unit 2 (Georgia Power Co.)	Baxley, Ga.	GE	Bechtel	BWR	(2)	795	2,436
17-1	Fort Calhoun Station, Unit 1 (Omaha Public Power District)	Fort Calhoun, Nebr.	Comb.	G&H	PWR	(9)	457	1,420
18-1	Fort St. Vrain Nuclear Generating Station (Public Service Co. of Colorado)	Platteville, Colo.	GA	S&L	HTGR	(9)	330	842
19-1	Haddam Neck Plant (Connecticut Yankee Atomic Power Co.)	Haddam Neck, Conn.	West.	S&W	PWR	(8)	575	1,825
20-1	H. B. Robinson Plant, Unit 2 (Carolina Power & Light Co.)	Hartsville, S. C.	West.	Ebasco	PWR	(9)	700	2,200

CURRENTLY LICENSED REACTORS IN UNITED STATES (continued)

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
21 -1	Humboldt Bay Power Plant, Unit 3 (Pacific Gas & Electric Co.)	Eureka, Calif.	GE	Bechtel	BWR	(1)	63	242
22 -1	Indian Point Station, Unit 1 (Consolidated Edison Co. of New York, Inc.)	Buchanan, N.Y.	B&W	UE&C	PWR	(3)	265	615
23 -1	Indian Point Station, Unit 2 (Consolidated Edison Co. of New York, Inc.)	Buchanan, N.Y.	West.	UE&C	PWR	(8)	873	2,758
24 -1	Indian Point Station, Unit 3 (Power Authority of New York)	Buchanan, N.Y.	West.	UE&C	PWR	(8)	965	2,760
25 -1	James A. FitzPatrick Nuclear Power Plant (Power Authority of the State of New York)	Scriba, N.Y.	GE	S&W	BWR	(2)	821	2,436
26 -1	Joseph M. Farley Nuclear Plant, Unit 1,2 (Alabama Power Co.)	Dothan, Ala.	West.	Bechtel	PWR	(11)	821	2,652
27 -1	Kewaunee Nuclear Power (Wisconsin Power & Light Co., Wisconsin Public Service Co. and Madison Gas & Electric Co.)	Carlton, Wis.	West.	Pioneer	PWR	(4)	535	1,650
28 -1	La Crosse (Genoa) Nuclear Generating Station (Dairyland Power Cooperative)	La Crosse, Wis.	AC	S&L	BWR	(1)	50	165
29 -1	Maine Yankee Atomic Power Plant (Maine Yankee Atomic Power Co.)	Wiscasset, Maine	Comb.	S&W	PWR	(7)	790	2,500
30 -1	Millstone Nuclear Power Station, Unit 1 (Northeast Nuclear Energy Co.)	Waterford, Conn.	GE	Ebasco	BWR	(2)	660	2,011
31 -1	Millstone Nuclear Power Station, Unit 2 (Northeast Nuclear Energy Co.)	Waterford, Conn.	Comb.	Bechtel	PWR	(11)	830	2,560
32 -1	Monticello Nuclear Generating Plant (Northern States Power Co.)	Monticello, Minn.	GE	Bechtel	BWR	(2)	545	1,670
33 -1	Nine Mile Point Nuclear Station, Unit 1 (Niagara Mohawk Power Corp.)	Scriba, N.Y.	GE	S&W	BWR	(2)	610	1,850

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
34-1	North Anna Power Station, Unit 1 (Virginia Electric & Power Co.)	Mineral, Va.	West.	S&W	PWR	(7)	907	2,775
35-1	Oconee Nuclear Station, Unit 1 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
35-1	Oconee Nuclear Station, Unit 2 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
35-1	Oconee Nuclear Station, Unit 3 (Duke Power Co.)	Seneca, S. C.	B&W	Utility & Bechtel	PWR	(10)	887	2,568
36-1	Oyster Creek Nuclear Power Plant, Unit 1 (Jersey Central Power & Light Co.)	Toms River, N.J.	GE	B&R	BWR	(2)	650	1,930
37-1	Palisades Nuclear Plant, Unit 1 (Con- sumers Power Co. of Michigan)	South Haven, Mich.	Comb.	Bechtel	PWR	(10)	805	2,530
38-1	Peach Bottom Atomic Power Station, Unit 2 (Philadelphia Electric Co., Public Ser- vice Electric & Gas Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Peach Bottom, Pa.	GE	Bechtel	BWR	(2)	1,065	3,293
38-1	Peach Bottom Atomic Power Station, Unit 3 (Philadelphia Electric Co., Public Ser- vice Electric & Gas Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Peach Bottom, Pa.	GE	Bechtel	BWR	(2)	1,065	3,293
39-1	Pilgrim Nuclear Power Station, Unit 1 (Boston Edison Co.)	Plymouth, Mass.	GE	Bechtel	BWR	(7)	655	1,998
40-1	Point Beach Nuclear Plant, Unit 1 (Wis- consin Electric Power Co. and Wisconsin Michigan Power Co.)	Two Creeks, Wis.	West.	Bechtel	PWR	(10)	497	1,518
40-1	Point Beach Nuclear Plant, Unit 2 (Wis- consin Electric Power Co. and Wisconsin Michigan Power Co.)	Two Creeks, Wis	West.	Bechtel	PWR	(10)	497	1,518

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
41-1	Prairie Island Nuclear Generating Plant, Unit 1 (Northern States Power Co.)	Red Wing, Minn.	West.	Pioneer	PWR	(4)	530	1,650
41-1	Prairie Island Nuclear Generating Plant, Unit 2 (Northern States Power Co.)	Red Wing, Minn.	West.	Pioneer	PWR	(4)	530	1,650
42-1	Quad-Cities Station, Unit 1 (Commonwealth Edison Co. and Iowa-Illinois Gas & Electric Co.)	Cordova, Ill.	GE	S&L	BWR	(2)	789	2,511
42-1	Quad-Cities Station, Unit 2 (Commonwealth Edison Co. and Iowa -Illinois Gas & Electric Co.)	Cordova, Ill.	GE	S&L	BWR	(2)	789	2,511
43-1	Rancho Seco Nuclear Generating Station, Unit 1 (Sacramento Municipal Utility District)	Clay Station, Calif.	B&W	Bechtel	PWR	(11)	918	2,772
44-1	Robert Emmett Ginna Nuclear Power Plant, Unit 1 (Rochester Gas & Electric Co.)	Ontario, N.Y.	West.	Gilbert	PWR	(9)	490	1,520
45-1	Salem Nuclear Generating Station, Unit 1,2 (Public Service Electric & Gas Co., Philadelphia Electric Co., Atlantic City Electric Co., and Delmarva Power & Light Co.)	Salem, N.J.	West.	UE&C	PWR	(8)	1,090	3,338
46-1	San Onofre Nuclear Generating Station, Unit 1 (Southern California Edison and San Diego Gas & Electric Co.)	San Clemente, Calif.	West.	Bechtel	PWR	(3)	436	1,347
47-1	Shippingport Atomic Power Station (DOE and Duquesne Light Co.)	Shippingport, Pa.	West.	B&R, S&W	PWR	(3)	60	236
48-1	St. Lucie Plant, Unit 1 (Florida Power & Light Co.)	Fort Pierce, Fla.	Comb.	Ebasco	PWR	(4)	802	2,560
49-1	Surry Power Station, Unit 1 (Virginia Electric & Power Co.)	Gravel Neck, Va.	West.	S&W	PWR	(7)	822	2,441

CURRENTLY LICENSED REACTORS IN UNITED STATES (continued)

Seismic Review Table No.	Name and/or owner	Location	NSSS Manufac- turer **	Architect Engineer **	Reac- tor Type	Containment Type *	Power	
							Unit Size Net MW(e)	Reactor MW (t)
49 -1	Surry Power Station, Unit 2 (Virginia Electric & Power Co.)	Gravel Neck, Va.	West.	S&W	PWR	(7)	822	2,441
50 -1	Three Mile Island Nuclear Station, Unit 1 (Metropolitan Edison Co.)	Middletown, Pa.	B&W	Gilbert	PWR	(10)	819	2,535
51 -1	Three Mile Island Nuclear Station, Unit 2 (Metropolitan Edison Co.)	Middletown, Pa.	B&W	B&R	PWR	(10)	906	2,772
52 -1	Trojan Nuclear Plant, Unit 1 (Portland General Electric Co., Eugene Water & Electric Board, and Pacific Power & Light Co.)	Prescott, Oreg.	West.	Bechtel	PWR	(12)	1,130	3,411
53-1	Turkey Point Plant, Unit 3 (Florida Power & Power Co.)	Florida City, Fla.	West.	Bechtel	PWR	(10)	693	2,200
53 -1	Turkey Point Plant, Unit 4 (Florida Power & Power Co.)	Florida City, Fla.	West.	Bechtel	PWR	(10)	693	2,200
54 -1	Vermont Yankee Nuclear Power Station (Vermont Yankee Nuclear Power Corp.)	Vernon, Vt.	GE	Ebasco	BWR	(2)	514	1,593
55 -1	Yankee-Rowe Nuclear Power Station (Yankee Atomic Electric Co.)	Rowe, Mass.	West.	S&W	PWR	(3)	175	600
56 -1	Zion Nuclear Plant, Unit 1 (Commonwealth Edison Co.)	Zion, Ill.	West.	S&L	PWR	(10)	1,040	3,250
56 -1	Zion Nuclear Plant, Unit 2 (Commonwealth Edison Co.)	Zion, Ill.	West.	S&L	PWR	(10)	1,040	3,250

* Containment types:

- (1) Pre-Mark (Steel)
- (2) Mark I (Steel)
- (3) Dry Containment-Spherical (Steel)
- (4) Dry Containment-Cylindrical (Steel)
- (5) Mark I (Reinforced Concrete)
- (6) Ice Condenser (Reinforced Concrete)
- (7) Sub-Atmospheric (Reinforced Concrete)
- (8) Atmospheric (Reinforced Concrete)
- (9) Without Buttresses (Pre-Stressed Concrete)

- (10) 6 Buttresses With Shallow Dome (Pre-Stressed Concrete)
- (11) 3 Buttresses With Shallow Dome (Pre-Stressed Concrete)
- (12) 3 Buttresses With Hemispherical Dome (Pre-Stressed Concrete)

** Manufacturers and Engineers

AC = Allis-Chalmers Mfg. Co.
AEP = American Electric Power Service Corp.

B&R = Burns & Roe, Inc.
B&W = Babcock & Wilcox Co.
Comb. = Combustion Eng., Inc.
GA = General Atomic
GE = General Electric Co.
G&H = Gibbs & Hills, Inc.
S&W = Stone & Webster Eng. Corp.
S&L = Sargent & Lundy Engineers
TVA = Tennessee Valley Authority

UE&C = United Engineers & Constructors
West. = Westinghouse Electric Corp.

I-6

CURRENTLY LICENSED REACTORS IN UNITED STATES (continued)

SEISMIC REVIEW TABLE

Docket Number

50-313

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
ARKANSAS NUCLEAR UNIT No. 1	0.10	0.067	VII	0.20	0.133	A synthetic time history is generated so that its response spectra envelops the ground design spectrum.	Three components: 2 horizontal & 1 vertical Each horizontal was combined with the ver- tical, assuming simultaneous occurrences.	SRSS (No closely spaced modes).	Housner	Time-history method Vertical ground response spec- trum was used for equipment design (no ver- tical floor response spec- tra generated).
Reactor type: PWR Containment type: 3 buttresses with shallow dome (prestressed con- crete)										
NSSS Manufacturer: Babcock & Wilcox Arcitect Engineer: Bechtel										
12-68/5-74	Sec. 5.1.1.2.5 p. 5-28a		p. 2-19	Sec. 5.1.1.2.5 p. 5-28a		p. 5.A-6 Amend. 28	Sec. 5.A.4.1 p.5.A-5 Amend. 28	Sec. 5.A.4.2 p. 5.A-7	Sec. 5.A 4.1 p. 5.A-5 Figs. 5.A-1 and 5.A-2	Sec. 5.A.4.2 p. 5.A-6 p. 5-28c Amend. 23

8/18/72

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Flat Slab 9 feet "All Class I structures utilize the shale bedrock as a foundation"	Bedrock which consists of Pennsylvanian McAlester formation shale.	13 ft to 24 ft.	Properties of shale, 10,000 to 14,500 fps.	Most wells drilled into bedrock are less than 150 ft.	Not avail-able.	Stick model with soil springs, as indicated in Fig. 5A-3 Fig. 5A-4 Fig. 5A-5	Not available	Unclear in-formation	Not availabl
Sec. 5.1.1.1 p. 5.1 Sec. 2.7.2	p. 2-24	p. 2-16	Table 2-5 p. 2-28	Sec. 2.5.3 p. 2-7a				Sec. 5.1.1.5.6 p. 2-28a	

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	(% critical damping)	$Y = 1/\phi (1.25 D + 1.0 R + 1.25 E)$ $Y = 1/\phi (1.25 D + 1.25 H + 1.25 E)$ $Y = 1/\phi (1.25 D + 1.25 H + 1.25 W)$ $Y = 1/\phi (1.0 D + 1.8 E)$ (For structural element carrying mainly earthquake forces.) $Y = 1/\phi (1.0 D + 1.0 R + 1.0 E')$ $Y = 1/\phi (1.0 D + 1.0 H + 1.0 E')$ (0.9 D is used where dead load subtracts for critical stress in the first three equations.) Y = yield strength. D = dead load. R = force or pressure on structure due to rupture of any pipe. H = force on structure due to thermal expansion. E = design earthquake load. E' = maximum earthquake load. W = tornado load $\phi = 0.9$ for reinforced concrete, 0.85 for shear, bond. Anchorage in reinforced concrete. 0.75 for spirally reinforced concrete component members. 0.70 for tied component members. 0.90 for fabricated structural steel, and 0.90 for reinforced steel (not prestressed) in direction of tension.	ACI-318-63 Code AWS D12.1-61 Ultimate strength design "Design of Protective Structures", Dept. of Navy, NP-3726, August 1950.
Welded steel plate assemblies	1.0/1.0		
Welded steel framed structures	2.0/2.0		
Bolted or riveted steel framed structure	2.5/2.5		
Reinforced concrete equipment supports	2.0/3.0		
Reinforced concrete frames and buildings	3.0/5.0		
Prestressed concrete structure	2.0/5.0		
Sec. 5.A.4 p. 5.A-6		Sec. 5.A.3 p. 5.A-3 p. 5.A-4	Sec. 5.A.3 p. 5.A-3 p. 5-38a Amend. 28

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Steel piping (% critical damping) 0.5/0.5	Analytical and/or testing	L. C. for Internals, vessels, integral support attachments and piping: <u>L.C.</u> Design loads + design earthquake loads Design loads + SSE Design loads + pipe rupture Design loads + SSE Sec. 4.1.2 p. 4-4	ASME BPVC, Section III ANSI B31.7 Nuclear Power piping code - Sec. A.3 p. A-2
Sec. 5A.4 p. 5A-6	Sec. 5.A.4.2 p. 5A-6 p. 5A-8		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	<p>Class I electrical equipment is seismic qualified in accordance with the IEEE Guide for seismic qualification of Class I electrical equipment for nuclear power generating stations, JcNPS/Sec. 5 (to be designated IEEE 344).</p> <p>Sec. 8.1 p. 8-1, Amendment No. 22, December 14, 1971</p>

SEISMIC REVIEW TABLE

Docket Number
50-368

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Arkansas Nuclear One Unit No. 2 Reactor type: PWR Containment type: 3 buttresses with shallow dome (prestressed con- crete) NSSS Manufacturer: Combustion Engin- eering Architect Engineer: Bechtel <										

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete flat circular slab. Depth not available. p. 3.8-46	Moderate to stiff, plastic, red and tan clay with occasional zone of silty clay, which overlies black, dense, horizontally bedded shale and interbedded shale and sandstone of the McAlester formation. p. 2.5-9	70 ft to 90 ft. p. 2.5-8	Not available.	About 10 ft below ground surface. p. 2.5-11	Ozark Dam Dardanelle Dam Robert S. Kerr Dam p. 2.4-6 to 2.4-8	Stick model with fixed base p. 3.7-3	Not available.	No soil damping p. 3.7-2	Not available.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel frame structures (2.0/5.0)	<p>A. Design loading case: 1) $D+L+F+T_o$ 2) $D+L+F+P+T_A$</p> <p>B. Factored loading case:</p> <p>1. $C = 1/\phi ((1.0+0.05) D + 1.5 P + 1.0 T_A + 1.0 F)$</p> <p>2. $C = 1/\phi ((1.0+0.05) D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F)$</p> <p>3. $C = 1/\phi ((1.0+0.05) D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_o)$</p> <p>4. $C = 1/\phi ((1.0+0.05) D + 1.0 F + 1.25 H + 1.0 W' + 1.0 T_o)$</p> <p>5. $C = 1/\phi ((1.0+0.05) D + 1.0 P + 1.0 T_A + 1.0 H + 1.0 E' + 1.0 F)$</p> <p>6. $C = 1/\phi ((1.0+0.05) D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_o)$</p> <p>C = Required capacity of the containment D = Dead loads. E = Operating basis earthquake loads. E' = Design basis earthquake loads. F = Prestress loads. H = Pipe expansion loads. L = Live loads. P = LOCA pressure loads. R = Pipe rupture loads. T = LOCA thermal loads. T_o = Operating thermal loads. W' = Tornado wind and tornado missile loads. φ = Capacity reduction factors.</p>	<p>ACI 318-63 AISC 1969 Supplement 1, 2, November 1970 and December 1971.</p>
Bolted and riveted steel (3.0/5.0)		
Reinforced concrete structure and equipment supports (3.0/5.0)		
Prestressed concrete structures (2.0/5.0)		
Bolted or riveted steel frame structures (2.5/2.5)		
P. 3.7-15	p. 3.8-7 to 3.8-8	p. 3.8-3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
(% critical damping) Steel piping 0.5/0.5	Analytical	Loading combination 1: normal operating loads + OBE loads. Loading combination 2: normal operating loads + DBE loads.	ASME BPVC Section III
Vital piping 0.5/1.0		Loading combination 3: normal operating loads + DBE loads + pipe rupture loads.	
Welded steel plate assemblies 1.0/1.0			
p. 3.7-15	p. 3.6-6	p. 3.6-4	p. 3.6-4

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	<p>Equipment supplied by NSSS vendor:</p> <p>Combustion Engineering Topical Report CENPD-61</p> <p>Equipment supplied by other than NSSS vendor:</p> <p>IEEE Standard 344-1971</p> <p>p. 3-10.2</p>

SEISMIC REVIEW TABLE

Docket Number
50-334

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Beaver Valley Power Station Unit No. 1 Reactor type: PWR Containment type: Sub-atmospheric (Reinforced con- crete) NSSS Manufacturer: Westinghouse Architect Engineer: Stone & Webster	0.06	0.04	IV	0.125	0.085	Compared with El Centro 1940 and Taft 1952, Golden Gate 1957.	Three com- ponents. Combination is simul- taneous.	SRSS	Housner response spectra was gener- ated which enveloped El Centro, Taft and Golden Gate time histories. Performed by Dr. R. V. Whitman	Time-history method.
6-70/7-76	Sec.2.5.3 p. 2.5-4	Sec.2.5.3 p. 2.5-4	Sec.2.5.3 p. 2.5-3	Sec.2.5.3 p. 2.5-4	Sec.2.5.3 p. 2.5-4	Sec. 2.6.4.2 p. 2.6-11	Q. 3.15-5 Amend. 5 10/10/73	Q. 3.15-1 Amend. 1 4/23/73	Figs. 2.5-1 and 2.5-2 Pg. 2.5-3	
App. B.1-3							App. 2D			

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _g PROFILE						
Reinforced concrete mat 10 ft thick	Gravel terrace	100 ft	Varying from 800 to 1250 psf	10 ft to 50 ft average 30 ft below surface.	3.1 miles downstream from Montgomery Lock and Dam 19.6 miles upstream from New Cumberland Rock and Dam.	Stick model with soil springs.	(1) Containment structure G = 22,000 psi (2) Fuel building, auxiliary building and other near surface building G = 17,000 psi (3) Intake structure G = 17,000 psi	Not available.	5% OBE 7% DBE
Sec. 2.6.3.1 p. 2.6-3	Sec. 2.4 p. 2.4-2	Sec. 2.4 p. 2.4-2	Sec. 2.6.2.3 p. 2.6-3	Sec. 2.3.2.1.1 p. 2.3-3	Sec. 2.3.1 p. 2.3-1	Sec. 2.6.4.4 p. 2.6-15	Sec. 2.5.3 p. 2.5-5		App. B pg. B.1-3

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure	5.0/7.0	Concrete structure D.L. + L.L. D.L. + L.L. + OBE D.L. + L.L. DBE D.L. + L.L. + TOR D.L. + L.L. + F	Using working stress design ACI 318-63
Steel reinforced concrete (no cracking)	0.5 to 1.0		
Welded steel, well reinforced concrete (with slight cracking)	2.0		
Reinforced concrete (with consider- able cracking)	2.0	Steel structure D.L. + L.L. D.L. + L.L. + OBE D.L. + L.L. + DBE D.L. + L.L. + TOR D.L. + L.L. + F	Steel structure, AISC-63, Part I Specified minimum yield strength for structural steel.
Bolt steel	5.0		
Welded steel	5.0		
Reinforced concrete	5.0		
Bolted steel	7.0		
Amendment I, Sec. B.1.2, Table B.1-3, p. B.1-3 4/23/73		Amendment VII, p. B.1-6 (3/29/74)	Amendment VII, P. B.1-7 3/29/74

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping	0.5/1.0	Analytical and testing.	<p>Pressure piping</p> <p>1. Normal conditions</p> <p>(a) $P_m \leq S$</p> <p>(b) $P_m \text{ (or } P_L) \leq S$</p> <p>2. Upset conditions</p> <p>(a) $P_m \leq 1.2 S$</p> <p>(b) $P_m + P_B \leq 1.5 S$</p> <p>3. Emergency conditions</p> <p>(a) $P_m \leq 1.2 S$</p> <p>(b) $P_m + P_B \leq 1.5 (1.2 S)$</p> <p>Pressure vessel</p> <p>1. Normal conditions</p> <p>(a) $P_m \leq S_m$</p> <p>(b) $P_m + P_B \leq 1.5 S_m$</p> <p>(c) $P_m + P_B + Q \leq 3 S_m$</p> <p>2. Upset conditions</p> <p>(a) $P_m \leq S_m$</p> <p>(b) $P_m + P_B \leq 1.5 S_m$</p> <p>(c) $P_m + P_B + Q \leq 3 S_m$</p> <p>3. Emergency conditions</p> <p>(a) $P_m \leq 1.2 S_m$</p> <p>(b) $P_m + P_B \leq 1.5 (1.2 S_m)$</p>	<p>Piping</p> <p>ANSI, B31.1 pressure piping code with diameters of 6 in. NPS and below.</p> <p>ASME BPVC, Section III (1968 edition)</p>
Amendment I, Table B.1-3 4/23/73		For further details refer to Table B.3-4		Question 3.22-1

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Testing for mounted components	<p>"Class I instrumentation and electrical equipment are designed to maintain their capability to:</p> <ol style="list-style-type: none"> 1. Initiate a protective action during DBE and OBE 2. Withstand seismic disturbances during post accident operation 	<p>IEEE STD 344-1971 "Seismic Qualification of Class I Electric Equipment for NPP Generating Station".</p> <p>p. B. 2-14</p>

SEISMIC REVIEW TABLE*

Docket Number
50-155

NAME AND NSSS TYPE OF THE PLANT CP/OL ISSUE DATE	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Big Rock Point Nuclear Plant Reactor type: BWR Containment type: Pre-Mark (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel 5-60/8-62	Not used	Not used	Not avail- able	.05 and 0.025 (see last column of this page) 0.12 for RDS only. Sec. 2-11	not used	not used	one horizon- tal component 3 direc- tions with SRSS for reactor depressuriza- tion system only Sec. 2-11	SRSS for RDS only	Not used	The lateral concrete loads for design of internal concrete structures were determined from U.B.C. requirements. A seismic factor of 0.025 was used for the equivalent lateral coefficient for these structures as well as other major structures, e.g. turbine building, 240 ft. high stack, control room and waste storage building. RDS re-analyzed in 1974 using R.G. 1.60, floor response spectra by Kapur method.

*Information obtained from BNL Docket search and SEPB Report prepared by LLL; EDAC Report #175-130.04, January 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
The lower segment of the spherical steel vessel is embedded in concrete and the structure extends 27 ft. below grade. The foundation consists of a combination of a 3-foot thick concrete mat and reinforced concrete footings from 38 ft. to 8 ft. below grade.	Rock	Not available	Not available	Not available	Not available	Not used	Not available	Not used	Not available

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% Critical damping)	DESIGN CRITERIA
		LOAD COMBINATION ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment: used in 1974 reanalysis of reactor depressurization system to acceleration equal to 0.12g. RDS components assumed to have damping values of R.G. 1.61.	4.0	<p> <u>Containment</u>; Seismic (0.05g) + DL + snow <u>Internal Concrete Structure</u>: Seismic (0.05g) + DL + equipment <u>NSSS</u>: Seismic (0.05g) + DL + pressure <u>NSSS Piping</u>: Seismic (0.025g) + pressure + equipments <u>Turbine Building</u>: Seismic (0.025g) + DL + equipment </p> <p>Sec. 3-3</p>
		<p> Containment: ASME B and PV Sec. VI, VIII, IX UBC - 1958 ACI - 318-56 </p> <p>Sec. 2-11</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	<u>Containment/Reactor Vessel:</u> ASME BPVC Sec. II, VI, VIII, IX, 1958 <u>Piping and Supports:</u> ASA B 31.1 1955

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	Test		MIL-STD-167, Mechanical vibration of shipbord equipment MIL-STD-901C, Requirements for shock test. "Seismic qualification of RDS for BRP plant". Amend. 8, Docket 50155-50

SEISMIC REVIEW TABLE

Docket Number
50-259, 260, 348

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Browns Ferry Nuclear Plant Unit Nos. 1, 2, & 3 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Tennessee Valley Authority	0.10	0.067	VII	0.20	0.13	Design spectra com- pared with the El Centro, May 1940, N-S component, normalized to maximum accelera- tion. El Centro time history enveloped ground spectrum and was used in time- history analyses	Three com- ponents: Each hori- zontal com- bined with vertical component simultan- eously. "A vertical acceleration is considered to act simultaneously (with horizontal) and to increase or decrease the ver- tical load, which- ever is most conservative.	SRSS	Housner design spectra	Time-history method.
Unit 1: 5-67/6-73 Unit 2: 5-67/6-74 Unit 3: 7-68/8-76	Sec. 2.5.4 p. 2.5-6	p.12.2-2	p. 2.5-6	Sec. 2.5.4 p. 2.5-6	p.12.2-2	Sec. 2.5-4 pp. 2.5-7, 2.5-8, 2.5-12	p. 12.2-32 Sec. C.3-2 p. C.0-3	Sec. C.3-2 p. C.0-3	Figs. 2.5-15 and 2.5-16 , 2.5-17 p. 2.5-7	Sec. 12.2.2.8 p. 12.2-12

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
base slab with a circular mass of concrete at the center supporting the drywell.	Bedrock	Average depth 54 ft (41 to 69 ft)	Not available.	Ground water is derived from precipitation.	Wheeler Dam Wilson Dam	Lumped mass model with soil springs	2,300,000 psi bedrock	Not available	5% for all modes
	Tuscomb formation	50 ft below bedrock							
	Fort Payne formation	145 ft below Tuscomb-ia							
Sec. 12.2.2.1 p. 12.2-1	Sec. 2.5 pp. 2.5-	2.3.2 1&2.5-2		Sec. 2.4.2.1 p. 2.4.1	p. 2.4-3	Sec. 12.2.2.8 p. 12.2-11	Sec. 2.5.2.4.2 p. 2.5-5	p. 12.2-69	Sec.12.2.2.8 p. 12.2-31

p. 12.2-69
Fig. 12.2-78

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Steel structure	1.0	<p>These loads are considered in the following combinations: Reactor building Case 1. Prestartup - DL+LL+P Case 2. Operating - DL+LL+P+THERM+RESTR Case 3. Operating + Earthquake -A. DL+LL+P+THERM+RESTR+OBE -B. DL+LL+P+THERM+RESTR+DBE</p> <p>where</p> <p>DL = dead load LL = live load P = pressure transmitted through polyurethane foam at operating temperature OBE = Operating Basis Earthquake (0.1 g) DBE = Design Basis Earthquake (0.2 g) THERM = thermal load at operating temperatures RESTR = restraint to thermal growth of shield by pools</p> <p>For more details: refer to Tables 12.2-1 through 12.2-43</p>	<p>ACI-318-63</p> <p>N.O. + OBE $\leq 0.5 f_y$</p> <p>N.O. + DBE $\leq 0.85 f'_c$ or $0.9 f_y$</p> <p>Ultimate strength method</p>
Concrete	5.0		
Sec. 12.2.2 p. 12.2-4		Sec. 12.2.2.2.3 p. 12.2-4	AEC Q. 12.2-10 p. 12.2-4

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSR	(% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping	0.5	Analytical	Deformation limit Table C.0-1	Piping
			Primary stress limit Table C.0-2	ANSI B31.1.0
			Buckling stability limit Table C.0-3	ANSI B31.7
Equipment	1.0		Fatigue limit Table C.0-4	Vessel
			For details refer to Tables C.0-1 to C.0-7.	ASME BPVC, Section III
Sec. C.3-2 p. C.0-3		Appendix C Section C.3	Section C.2-6 p. C.0-2	Appendix C Section C.4-1

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-324, 325

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Brunswick Steam Elec- tric Plant Units 1 & 2	0.08	0.053	VII (SSE)	0.16	0.107	1940 N-S El Centro spectrum normalized by a factor was used for developing the design spectra.	Three components, each horizontal was combined with the vertical, resulting in two distinct load cases.	For piping equipment by SRSS C.4.3.2	The envelope of the Housner spectra and the El Centro spec- tra was termed as the smoothed 1940 N-S El Centro nor- malized spectrum. Fig. 2.6-7 Fig. 2.6-9	Time-history method
Reactor type: BWR						For struc- ture abso- lute sum.				
Containment type: Mark I (Reinforced con- crete)										
NSSS Manufacturer: General Electric										
Architect Engineer: United Engineers & Constructors										
Unit 1: 2-70/10-76	Sec. 2.6	Sec. 2.6	Sec. 2.6	Sec. 2.6	Sec. 2.6	Sec. 2.6.6.1	C4.3.2	Comment		
Unit 2: 2-70/12-74	p. 2.6-6	p. 2.6-10	p. 2.6-11	p. 2.6-7	p. 2.6-11	p. 2.6-10	p. C-56	C-10 MC.10-1 Amend. 14 1972	Sec. 2.6 p. 2.6-9 Fig. 2.6-7	Comment C.3,P.MC.3-1 Amend. 13 (Sept. 72)

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat foundation, founded on a strata of very dense-fine to medium-coarse sand. Depth not available.	Sand and clay.	115 ft	Thick. (ft) V _s (ft/sec)	Table M.2.17-1 gives ground water details.	Not available.	Lumped mass with soil springs. See design reports 4, 9, and 10.	Not available	Soil structure interaction damping .04/.07 critical damping for OBE/DBE.	Not available.
	Limestone	115 ft	35 750						
			30 1400						
	Hard calcareous clay and cretaceous rock.	down to 1500 ft	43 5500						
			127 4500						
			1290 3000						
	Crystal-line								
Sec. 12.2.1 p. 12.2-1	Sec. 1.5 p. 1.5-2	Sec. 1.5 p. 1.5-2	Fig. 2.6-7	Comment 2.17 EM2.17-1 Amend. 14, 11/72		C.57, p. MC.57-1		Table C-1	

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete: Primary containment Other Class I structures Steel structures: (Reactor building and other Class I structures) Bolted or riveted Welded	4.0/7.0 4.0/7.0	Primary containment (Drywell & Suppression Chambers) $U_1 = (1.0+0.1) D + 1.50 P + 1.0 T_{1.5} + 1.0 R$ $U_2 = (1.0+0.1) D + 1.25 P + 1.0 T_{1.25} + 1.25 E + 1.0 R$ $U_3 = (1.0+0.1) D + 1.00 P + 1.0 T_{1.00} + 1.00 E' + 1.0 R$ $T_P = (1.0+0.1) D + 1.15 P$ (Pressure test condition)	Codes ACI 318-63, Part IV B Ultimate strength design AISC (1963) specification for the erection of structural steel Plant stack design, ACI 307-69
	5.0/10.0 2.0/5.0	Class I Structures $U = 1.5 D + 1.8 L + 1.0 T + R + Pr$ $U = 1.5 D + 1.5 L + 1.5 E + 1.0 T + R + Pr$ $U = 0.9 D + 1.5 W + 1.0 T + R + Pr$ $U = (1.0+0.1) D + 1.0 E' + 1.0 T + R + Pr$ $U = (1.0+0.1) D + 1.0 W' + 1.0 T + R + Pr$ $U = 1.5 \bar{D} + 1.5 L + 1.5 W + 1.0 T + R + Pr$	Comment 22 p. MC.22-1 Amendment 13 (Sept. 1972) C-5

Table C-1

Sec. C.2.6.1
p. C-9

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE	(% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
			LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Equipment	1.0/2.0	Analytical and testing	<u>Piping</u> <u>Design condition</u>	<u>Load combination</u>	<u>Stress limits</u>	ANSI B31.1 - 1967
Piping	0.5/2.0		Design, normal and upset	Pressure	S_h	Power piping ASME BPVC, Sec. III
				Pressure; dead weight	S_h	<u>Valves</u>
				Pressure, dead weight, OBE	$1.25 S_h$	ANSI-B31.1-67 ANSI-B16.5
				Pressure, dead weight, thermal	$S_n + S_h$	<u>Pumps</u>
			Emergency	Pressure, dead weight, DBE	$1.8 S_h$	ANSI-B31.1-67 ASME Sec. III. Class C
Table C-1		Sec. 2.2 C-4	Table C-7 through C-29 Amendment 13, Comment 4.3, p. M4.3-1			Amendment 13 (Sept. 1972) p. M4.1-1 Sec. A.1.1, p. 2

p. MC.18-3

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Analytical and Testing	OBE Combined stresses $\leq 0.6 S_y$. DBE Combined stresses $\leq 0.9 S_y$.	IEEE 344-1971 Equip <u>Max. Hor. "g"</u> Voltage 8.5 pre-amp Temp. control 12 switch Intermediate 1.5 range monitor see Table C-30
	Sec. 2.2 p. C-4	Comment 7.8, p. M7.8-5 Amendment 13 (Sept. 1972)	Table C-30 Comment 7.8 p. M7.8-2 Amendment 13 (Sept. 1972)

SEISMIC REVIEW TABLE

Docket Number
50-317, 318

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Calvert Cliffs Nuclear Power Plant Units No. 1 & 2 Reactor type: PWR Containment type: 6 Buttresses with shallow dome (prestressed con- crete) NSSS Manufacturer: Combustion Engineer- ing Architect Engineer: Bechtel	0.08	0.053	VII	0.15	0.10	Compared with digit- alized El Centro earthquake 1940 (E-W) normalized to: 0.08 g horizontal 0.053 g vertical	Horizontal and vertical components combined simultaneously.	SRSS in- cluding closely spaced modes.	1. Housner spectra for frequency >0.33 cps. 2. Newmark spectra for frequency <0.33 cps (Figs. 2.6-4, and 2.6-5)	"Digitized" El Centro was used in the analysis of Class I equipment. Class 2 struc- tures use UBC Zone 3. AEC TID 7024 "Nuclear Reactors and Earthquakes".
Unit 1:7-69/7-74 Unit 2:7-69/11-76	Sec. 2.6.5.2 p. 2.6-9	Sec. 2.6.5.2 p. 2.6-9	← Sec. 2.6.5.3 p. 2.6-9 →		Sec. 2.6.5.4 p. 2.6-10	Sec. 5A.3.1.4 p. 5A-5				

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Foundation for containment: 10 ft thick reinforced concrete slab. 									

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Welded steel framed structure 2. Bolted or riveted steel framed structure 3. Reinforced concrete frames and buildings 4. Prestressed concrete structures	(translational)	$Y \geq 1/\phi (1.05 D + 1.5 P + 1.0 T_A + 1.0 F)$ $Y \geq 1/\phi (1.05 D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F)$ $Y \geq 1/\phi (1.05 D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_O)$ $Y \geq 1/\phi (1.05 D + 1.25 H + 1.0 F + 1.25 W + 1.0 T_O)$ $Y \geq 1/\phi (1.0 D + 1.0 P + 1.0 T_A + 1.0 H + 1.0 E' + 1.0 F)$ $Y \geq 1/\phi (1.0 D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_O)$	ACI-318-63, when ϕ is taken as 1.
	1.0/1.0	Y = Yield strength.	
	2.5/2.5	D = Dead load.	
	3.0/5.0	E = OBE	
1. Rocking motion for prestressed concrete structures 2. Rocking motion for reinforced concrete structures	(rotational)	$E' = SSE$ W = Tornado wind load. P = LOCI pressure load. F = Final prestress load. T_A = Thermal load incident temperature gradient through walls and expansion liner R = Force or pressure on structure due to rupture of one pipe. H = Thermal expansion force. T_O = Thermal load due to normal operating temperature gradient through walls. ϕ = Reduction factor.	Sec. 5A.3.1.2 p. 5A-3
	5.0/7.0		
Sec. 5A.3.1.4 pp. 5A-5 and 5A-6		Sec. 5A.3.1.2 pp. 5A-3 and 5A-4	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
(% critical damping) (Translational) Steel piping 0.5/0.5 Welded steel plate assemblies 1.0/1.0	Analytical	<p>Vessels Piping</p> <p>1. Design loading + OBE: $P_m \leq S_m$ $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$ $P_B + P_L \leq 1.5 S_m$</p> <p>2. Normal operating $P_m \leq S_D$ $P_m \leq S_D$ + SSE: $P_B \leq 1.5 \left[1 - \left(\frac{P_m}{S_D} \right)^2 \right] S_D$ $P_B \leq \frac{4}{\pi} S_D \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$</p> <p>3. Normal operating $P_m \leq S_L$ $P_m \leq S_L$ + SSE + pipe $P_B \leq 1.5 \left[1 - \left(\frac{P_m}{S_L} \right)^2 \right] S_L$ $P_B \leq \frac{4}{\pi} S_L \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$ rupture:</p> <p> P = Calculated primary membrane stress. P_B = Calculated primary bending stress. P_L = Calculated primary local membrane stress. S_m = Allowable stress limit ASME BPVC III. S_Y = Yield at temperature ASME BPVC III. S_D = Design stress. S_L = $S_Y + 1/3 (S_U - S_Y)$. S_U = Tensile strength at temperature. </p>	Reactor vessel: ASME BPVC III Piping: ASME BPVC III (1967) USAS B 31.7, Class I (Code cases 83, 1477 are included).
Sec. 5A.3.1.4 p. 5A-5	p. 5A-5	Sec. 4.2.1, Table 4-2 pp. 4-5 to 4-7	Sec. 4.2.1, Table 4-2 p. 4-7

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	<p>"All electrical-systems and components vital to plant safety, including the emergency diesel generators, are designed as Class I so their integrity is not impaired by the design basis earthquake, high winds, or disturbances on the external electrical system".</p> <p>pg. 8.1</p>	Not available

SEISMIC REVIEW TABLE

Docket Number
50-298

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OSE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Cooper Nuclear Station Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Burns & Roe, Inc.	0.10	0.05	VII	0.20	0.10	The accelerogram of the N69W component of the July 21, 1952 Kern County earth- quake recorded at Taft, California was used to develop re- sponse spectra	Three components: two horizontal and one vertical. Each horizontal was combined with the vertical simultaneously.	Reactor vessel in- ternals: SRSS for re- sponse spec- trum method; algebraic sum for time- history method	Design spectrum re- sponse curves gen- erated from 1952 Taft earthquake	Time-history method.
6-68/1-74	Vol. 1 Sec. 5.2.3 p. II-5-4	Vol. 1 Sec. 5.2.3 p. II-5-4	Vol. 1 Sec. 5.2.1 p. II 5-3	Vol. 1 Sec. 5.2.3 p. II-5-4	Vol. 1 Sec. 5.2.3 p. II-5-4	Vol. 1 Sec. 5.2.4 p. II-5-4	App. C Sec. 3.3.3 p. C-3-12	Vol. 1 Sec. 3.5.3 p. III-3-12	Vol. 1, Sec. 5.2.4 p. II-5-4, Figs. II-5-7 to II-5-10	Vol. VII Amend 9 Q.12.35

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Mat foundation. Depth not available.	Dense structure fill extending from the bed-rock surface to the mat foundation. Silty sand, sand silt, silt clay, clay.	Dense structure: not available. Silty sand: 10 to 25 ft.	Not available.	Not available.	Not available.	Stick model with rocking springs. No vertical or horizontal soil springs were included	Not available	5%	Not available.
Vol. I Sec. 5.2.3 p. II-5-4	Vol. I Sec. 5.1.4, p. II-3	Vol. I Sec. 5.1.4, p. II-3				Vol. VII Amend 13 Q.12.55		Vol. V Appendix C p. C-2-7	

5.3

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures.	5.0/7.0	D+E D+R D+R+E D+E+Flood D+T D+R+E'	ACI-318-63 for reinforced concrete.
Steel frame structures.	2.0		AISC Manual of Steel Construction (Sixth Edition)
Welded assemblies.	1.0		
Bolted and riveted assemblies	2.0		
Vol. IV, p. XII-2-16 Table XII-2-5		D = Dead load of structure and equipment. R = Loads resulting from jet forces and pressure and temperature due to rupture of a single pipe. E = OBE E' = SSE Flood = Loads due to flooding. W = Wind loads. T = Tornado loads.	Vol. V Sec. 2.4 p. C-2-3
		Appendix C Sec. 2.2 p. C-2-1	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE	(Z criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping system	0.5	Analytical and Testing	Deformation limit Table C-3-2 Primary stress limit Table C-3-3 Buckling stability limit Table C-3-4 Fatigue limit Table C-3-5 Loading criteria Table C-3-7	Reactor vessel ASME BPVC, Sec. III Vol. V, Table C-3-7, p. C-3-14 Piping USAS, B31.1.0
Vol. IV, p. XII-2-16 Table XII-2-5		Vol. V, Sec. 3.3.26 & 3.3. 2, p. C-3-11 & C-3-12. Appendix C Vol. VII p. 12.61.1	p. C-3-3, p. C-3-14, Table C-3-7 App. C, Table C-3-7	Vol. V, Table C-3-7, p. C-3-28

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-302

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA	
	HOR. g	VERT. g	INTENSITY MM	HOR. g						VERT. g
CP/OL ISSUE DATE										
Crystal River Nuclear Generating Plant, Unit 3 Reactor type: PWR Containment type: Mark I (steel) NSSS Manufacturer: Babcock & Wilcox Architect Engineer: Gilbert Associates 9-68/12-76	0.05	0.033	V	0.10	0.067	Response spectrum method was used in design. Floor response spec- tra generated with either 1940 N-S El Centro, 1952 N21E Taft or other time-history. Ref. Sec. 5.4.5 p.5-65A Amend. 26 (5-25-73) and Sec. 2.5.4.1 p. 2-31	Three components: Each horizontal combined with the vertical by absolute sum, although "struc- tural response due to vertical input was assumed to be insignificant". Sec. 5.4.5 p.5-65 Amend. 26 (5-25-73)	SRSS Sec. 5.4.5.2 p.5-66 D Amend. 32 (10-1-73)	Spectra developed were estimated by two methods: Housner and Estere and Rosenblueth p. 2-32	Approximate method not based on time-history GAI Topical 1729 Sec. 5.4.5 p. 5-65A Amend. 26 (5-25-73)

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For reactor building Mat foundation thickness 12.5 ft. Sec. 2.5.7 p. 2-36 and Sec. 5.2, p.5-7 Amend.26, (5-25-73)	Natural soil: Laminated underlying organic sandy silts and clays interspersed with a pleistocene marine deposits. Bedrock: biogenic carbonates of tertiary age.	Average of thickness of approximately 4 ft. Approximately 20 ft. beneath the present ground surface.	Not available	Depth of approximately 10 ft. below ground surface. Based on a ground datum of 100 ft. groundwater levels were recorded to rise approximately 1.5 ft. at peaks of high tides. Sec. 2.5 p. 2-20 and Sec. 2.5.3.5 p. 2-29 and p.2-30	Not available.	Stick model with fixed base. Soil spring model was used to check accuracy of fixed base model. Sec. 5.4.5.2 p. 5-66 and Sec. 5.4.5 p. 5-65 and p. 5-65a Amend. 32 (10-1-73)	Not available.	"Sum of material and radiation damping was assumed as small as 5%." p. 5-65a	Not available.

Sec. 2.5.3
p. 2-22

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING ODE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor building shell	2.0	a) $c = (1.0 \pm .05) D + 1.5P + 1.0T$ b) $c = (1.0 \pm .05) D + 1.25P + 1.0T' + 1.25 (E \text{ or } W)$ c) $c = (1.0 \pm .05) D + 1.0P + 1.0 \frac{T}{T} + 1.0E'$ d) $c = (1.0 \pm .05) D + 1.0 W_T + 1.0 \bar{P}_t$ D= Dead load P= Design accident pressure load E= Seismic load based on 0.05g. E'= Seismic load based on 0.10g. W= Wind load based on Tornado P _T = Pressure load based on external pressure drop of 3 psig between inside and outside of reactor building. Sec. 5.2.3.2.1 p. 5-32	Reactor building:
Concrete support: Structure (Inside reactor building)	2.0		R. C. ACI 318-63
Steel assemblies and structure	2.5		Structure concrete ACI 301-66
a) bolted	1.0		Structure steel AISC. 1963.
b) welded	1.0		
Other concrete structure (Above ground)	5.0		
p. 5-42			Sec. 5.2.3.1 p. 5-31

SEISMIC REVIEW TABLE

MECHANICAL & PIPING																	
DAMPING OBE/SEE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA															
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES														
Vital piping systems. 0.5	Analyses and test.	For piping: primary stress + OBE $\leq 1.2 \times S_h$ thermal stress $\leq S_c$ where $S_c = t (1.25 S_c^A + 0.25 S_h)$ S_c^A = allowable stress S_c^A = basic material allowable stress at max. (hot) temp. S_h = basic material allowable stress at min. (cold) temp. S_c = p. 5-641 Amend. 45(7-11-75) and p. 5-63	Reactor coolant system: ASME, boiler and pressurizer Vessel code, Sec. III, Art. 9 Summer, 1967 For piping (belongs to reactor coolant) USAS Sec. B31.7														
	Details. Ref. Table 5-5 p.5-86 AMEND. 17 (4-10-72) Sec. 5.4.5 p. 5-65 AMEND. 40 (7-3-74) p.5-64b AMEND. 45,(7-14-75)	<table><thead><tr><th>Case</th><th>Load Combination</th><th>Stress Limits</th></tr></thead><tbody><tr><td>I)</td><td>Design loads + design earthquake loads</td><td>$P_m \leq 1.00 S_m$ $P_L + P_b \leq 1.5 S_m$</td></tr><tr><td>II)</td><td>Design loads + maximum hypothetical earthquake loads</td><td>$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$</td></tr><tr><td>III)</td><td>Design loads + pipe rupture loads</td><td>$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$</td></tr><tr><td>IV)</td><td>Design loads + maximum hypothetical earthquake loads</td><td>$P_m \leq 2/3 S_y$ $P_L + P_b \leq 2/3 S_y$</td></tr></tbody></table> <p>P_L = Primary local membrane stress intensity P_m = Primary general membrane stress intensity P_b = Primary bending stress intensity S_m = Allowable membrane stress intensity S_u = Ultimate stress for unirradiated material at operating temperature</p>	Case	Load Combination	Stress Limits	I)	Design loads + design earthquake loads	$P_m \leq 1.00 S_m$ $P_L + P_b \leq 1.5 S_m$	II)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$	III)	Design loads + pipe rupture loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$	IV)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 2/3 S_y$ $P_L + P_b \leq 2/3 S_y$
Case	Load Combination	Stress Limits															
I)	Design loads + design earthquake loads	$P_m \leq 1.00 S_m$ $P_L + P_b \leq 1.5 S_m$															
II)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$															
III)	Design loads + pipe rupture loads	$P_m \leq 1.2 S_m$ $P_L + P_b \leq 1.2 (1.5 S_m)$															
IV)	Design loads + maximum hypothetical earthquake loads	$P_m \leq 2/3 S_y$ $P_L + P_b \leq 2/3 S_y$															

p. 5-42

Sec. 5.4.5
p. 5-65
AMEND. 40
(7-3-74)
p.5-64b AMEND.
45,(7-14-75)

Amendment 48, (3-16-76)
p. 5-64a

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number

50-346

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Davis-Besse Nuclear Power Station, Unit 1 Reactor type: PWR Containment type: Dry containment -cylindrical (steel) NSSS Manufacturer: Babcock & Wilcox Architect Engineer: Bechtel	0.08	.053	VII	0.15	0.10	E-W component of Helena Earthquake of October 31, 1935 was used as the basis for developing accelerograms of the OBE & DBE.	3 com- ponents: each hor- izontal combined with the vertical resulting two seis- mic load cases.	SRSS	Design spectrum re- sponse curves were developed by Newmark's method modifying the spec- tral amplification factors.	Time-history method.
	Vol. 1, Append. 2C Sec.D p. 2C-36	Vol. 1 Append.2C Sec. D p. 2C-36	Vol. 1, Append. 2C, p. 2C-31	Vol. 1, Append. 2C, p. 2C-31	Vol. 1, Append. 2C, p. 2C-39	Vol. 1, Append. 2C, p. 2C-39	Vol. 2C, Sec. 3.7.1.6 p. 3-51	Vol. 2 Sec. 3.7.3.3 p. 3-63 Fig. 3-24	Vol. 1, Append. 2C, p. 2C-41 to 45	Vol. 2 Sec. 3.7.2 p. 3-54

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Main structure: Mat footings & Auxiliary building: Pier footings bearing on bedrock Depth not available. Vol. 1 Sec. 2.5.1.10.2 p. 2-126 to 128	Soil: Glaciola-guatrine and a till deposit. Bedrock: Tymochtee formation which consists of argillaceous dolomite with interbedded gypsum, anhydrite and shale strata.	 8 ft. to 10 ft.	For bedrock 5,700 fps to 7,500 fps Vol. 1 Sec. 2.5.1.7 p. 2-123	Prior to construction 571 ft. to 572 ft. (I.G. L.D.) During construction 525 ft. (I.G. L.D.) Vol. 1 Sec. 2.5.1.5 p. 2-122	Not available.	Stick model with fixed base for the containment and the auxiliary building Vol. 2 Sec. 3.7.2 p. 3-52 to 55	Soil: For OBE: 10 KIPS/ft ² For SSE: 12 KIPS/ft ² Bedrock: For OBE: 150 KIPS/ft ² For SSE: 180 KIPS/ft ² Vol. 1, Sec. 2.5.1.8, p. 2-124	Soil: For OBE: 0.04 For SSE: 0.05 Bedrock: For OBE: 0.01 For SSE: 0.02 Vol. 1 Sec. 2.5.1.8 p. 2-124	Not available.

Vol. 1,
 Sec. 2.5.1.8,
 p. 2-123 and p. 2-124

SEISMIC REVIEW TABLE

STRUCTURES							
DAMPING ONE/SSE (% critical damping)					DESIGN CRITERIA		
					LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Welded steel	< 1/4 σ _y	1/2σ _y	σ _y	>σ _y	Class I Structures: Operation during normal and OBE conditions	Concrete	
							Concrete
1.0	2.0	5.0	7.0	U=1.5D + 1.8L U=1.25(D + L + H _o + E) + 1.0 T _o U=1.25(D + L + H _o + W) + 1.0 T _o U=0.9D + 1.25(H _o + E) + 1.0 T _o U=0.9D + 1.25(H _o + W) + 1.0 T _o	A.C.I. Code. 318-63 Ultimate strength method		
Bolted and Riveted steel	1.0	5.0	10.0	20.0	Structural steel	f _s 1.25f _s 1.33f _s	
Reinforced concrete	1.0	2.0	7.0	10.0			
Vol. 2, Table 3-7, pg. 3-50							
D= Dead load of structure and equipment plus other permanent loads, e.g., soil or hydrostatic loads L=Live load and piping loads R=Force or pressure on structure due to pipe rupture T _o =Thermal loads due to temp. gradient, operating H _o =Force due to thermal expansion of pipes, operating T _a =Thermal loads due to temp. gradient, accident H _a =Force on structure due to thermal exp., accident E=force due to OBE E'=force due to SSE W=Wind load=wind velocity 90 mph at 30 ft. above gr. W'=Tornado loads including differential pressure							
During accident and SSE conditions:							
Concrete:							
U=1.0D + 1.0L + 1.25E + 1.0T _a + 1.0H _a + 1.0R U=1.0D + 1.25E + 1.0T _a + 1.0H _a + 1.0R U=1.0D + 1.0L + 1.0E' + 1.0T _o + 1.25H _o + 1.0R U=1.0D + 1.0L + 1.0E' + 1.0T _a + 1.0H _a + 1.0R U=1.0D + 1.0L + 1.0W' + 1.0T _o + 1.25 H _o							
Structural Steel							
D + L + R + T _o + H _o + E' D + L + R + T _a + H _a + E'						1.5f _s 1.5f _s	

Vol. 2, Sec. 3.1.1.3, pg. 3-76

Vol. 2, Sec. 3.8.1.1.6, pg. 3-72

SEISMIC REVIEW TABLE

MECHANICAL & PIPING									
DAMPING OBE/SSE					METHOD OF QUALIFICATION	DESIGN CRITERIA			
						LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
						Code Class I Pressure Vessels			ASME BPVC, Section III, Class "A" 1968 edition for reactor vessel, steam generator, pressurizer, reactor coolant pump, casing. ANSI B 31.7 - 1968 for piping
						<u>Condition</u>	<u>Stress Intensity</u>		
						Normal	$P_M \leq S_M$ $P_M \text{ (or } P_L) + P_B \leq 1.5 S_M$ $P_M \text{ (or } P_L) + P_B + Q \leq 3.0 S_M$ $P_M \text{ (or } P_L) + P_B + Q + F \leq S_E$		
						Emergency	$P_M \leq 1.2 S_M \text{ or } S_Y \text{ whichever}$ <div>is larger</div> $P_M \text{ (or } P_L) + P_B \leq 1.5 (1.2 S_M)$ $\text{or } 1.5 S_Y \text{ whichever is larger}$ $\text{or } 0.8 C_L$		
	$< 1/4\sigma_y$	$1/2\sigma_y$	σ_y	$> \sigma_y$	analytical				
Vital piping	0.5	0.5	2.0	—					
Piping	0.5	1.0	2.0	5.0					
Vol. 2, Table 3-7, p. 3-50					Vol. 2 Sec. 3.7.2.1 p. 3-52	See Table 5-13 for upset and faulted condition Tables 5-12,13,14,15,16,17, 18 p. 5-79 through 5-85			Tables 5-10, p. 5-77

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OSE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	<p>IEEE 344-1971 and IEEE 336-1971</p> <p>Vol. 2, Sec. 3.10, p. 3-176, Vol. 2 Append. 3D, p. 3D-85</p>

SEISMIC REVIEW TABLE

Docket Number
50-315, 316

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S				
<p>CP/OL ISSUE DATE</p> <p>Donald C. Cook Nu- clear Plant Units No. 1 & 2</p> <p>Reactor type: PWR</p> <p>Containment type: Dry Condenser (Reinforced con- crete)</p> <p>NSSS Manufacturer: Westinghouse</p> <p>Architect Engineer: American Electric Power Service Corporation</p> <p>3-69/10-74</p>	0.10	0.067	VII	0.20	0.133	<p>El Centro (as present- ed in TID 7024) Normalized to the rec- ommended ground accel- eration was used to develop response spec- tra.</p> <p>Two-thirds of horizontal taken as vertical and combined with the full horizontal response. No further details available.</p>	SRSS	<p>Response spectra as shown in Figs. 2.5-2 and 2.5-3 were generated from El Centro earth- quake.</p>	<p>Time-history method.</p>
	Vol. I Sec. 2.8.6 p. 2.8-2	Vol. I Sec. 2.8.6 p. 2.8-2		Vol. I Sec. 2.8.6 p. 2.8-2	Vol. I Sec. 2.8.6 p. 2.8-2	<p>Vol. I Sec. 2.5.2 p. 2.5-5</p>	<p>AEC Ques- tion 5.74 p. 5.74-1</p>	<p>Vol. IX Amend. 9 Q.5.72-1</p>	<p>Amend. 16 Question 5.71 p. 5.71-6</p>

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Mat foundation Depth not available.	Compact sand, re-compacted sand or stiff clay deposits on shale bedrock.	120 to 200 ft	900 fps	ground water elevation 593 ft	Not available,	Stick model with soil springs.	Not available,	Not available,	Not available,
Sec. 2.5.2 p. 2.5.2	Sec.2.3.2 p. 2.3-4	Sec. 2.3 Fig.2.3-2	Vol. IX, Amend. 19, p. 5.85-2	Vol. I, Sec. 2.4.2 p. 2.4-4		Amend. 16. Question 5.71 Fig. 5.71-1			

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping 0.5/0.5	Analytical and Testing	<p>For pressure vessels:</p> <p>1. (a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ (c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$ } Normal condition</p> <p>2. (a) $P_m \leq S_m$ (b) $P_m + P_B \leq 1.5 S_m$ (c) $P_m + P_B + Q \leq 3.0 S_m$ } Upset condition</p> <p>For pressure piping:</p> <p>1. (a) $P_m \leq S$ (b) $P_m + P_B \leq S$ } Normal condition</p> <p>2. (a) $P_m \leq 1.2 S$ (b) $P_m + P_B \leq 1.2 S$ } Upset condition</p>	<p>1. ASME BPVC, Section III</p> <p>2. USAS.1, B31.1 code (power piping)</p>

Amendment 19, Q. 5.85
p. 5.85-2

Amendment 25
Q. 4.31-1

Tables 1 and 2, p. B-18 and p. B-19.

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE *

Docket Number

50-010

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Dresden Nuclear Power Station Unit 1 Reactor type: BWR Containment type: Pre-Mark (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel	None used (0.10)**	None used (0.067)**	None used	None used (0.20)**	None used (0.13) **	None used	None used Two comps., ** vertical + worst case horizontal	None used SRSS **	None used	No floor response spectra generated UBC, 1955 used for containment (Zone 2) and internal con- crete structure (Zone 1) Housner spectra Times 2 used for ECCS and Core Spray System.
5-56/9-59										

* Data are obtained from FHSR Docket 50-010 and SEPB Report "Seismic Design Bases and Criteria for Dresden Unit 1 Nuclear Generating Station," EDAC 175-130.03, January 1979.

** Used for ECCS and Core Spray System only.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Circular concrete foundation 37 ft. below grade.	Limestone Shale Dolomited Limestone	20-45 ft. 70 ft. 100-400ft.	Not used, bed-rock site	"Groundwater found @ various levels beneath the site".	Dresden Dam	No SSI model used	Not used	Not used	Not used

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	<u>Internal Concrete Structures:</u> E + pressure + equipment (E = 0.025g)	UBC, 1955 ACI, 318-55 AISC, 1955

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping 0.5	None	<u>Containment:</u> 1.) 0.033g 2.) pressure + snow + wind	<u>Steel Containment Sphere and NSSS:</u> ASME Section VIII (1955 ed.) and UBC, 1955
Welded assembly 1.0		<u>NSSS:</u> 1.) 0.025g 2.) operational transients	<u>Piping and ECCS, Core Spray:</u> ANSI B31.7, and ASME Sec. III, (1974 ed.)
Bolted assembly 1.0		<u>ECCS:</u> 1.) earthquake + operational + blowdown	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE*

Docket Number
50-237,249

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OI. ISSUE DATE										
Dresden Nuclear Power Station Unit 2 and 3 Reactor type: BWR Containment type: Mark-I (steel) NSSS Manufacturer: General Electric Architect Engineer: Sargent and Lundy Engineers. Unit 2: 1-66/12-69 Unit 3: 10-66/1-71	0.10	0.067	VII	0.20	0.133	N-S component of the El Centro Earthquake (May, 1940) nor- malized to a maximum ground acceleration of 0.1g was used for time history analysis. 				

*Information was obtained from BNL Docket Search and SEP-B Report
 "Seismic Review of Dresden Unit 2 for the Systematic Evaluation Program", NUREG/CR-0891, July 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE (calculated)	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE (calculated)						
Reinforced concrete mat founded on competent rock p. 12.1-10	The site consists of an upper layer of Pennsylvanian Pottsville sandstone of variable thickness which is 40-50 ft. Next below is a layer of about 15 to 35 ft. of Ordovician Maquoketa limestone based on a 65 ft. layer of Maquoketa dolomitic shale. The Ordovician system has a total thickness approaching 1000 ft. with the Cambrian system next below. Brecciated rock is found on same cross sections and is indicative of ancient faulting. p. III-1-3		Sandstone = 2,600 fps Limestone = 8,600 fps Argillaceous Dolomite = 4,700 fps Shale = 3,900 fps Dolomite Shale = 4,700 fps p. III-2-21	Not available	Dresden Dam p. 2.5-1	Fig. 12.1.8 and Fig. 12.1.9 indicate stick model with fixed base. p. 12.1-12 Lumped mass and stick model (torsional effects not considered.)	Sandstone = 18.7 x 10 ⁴ psi Limestone = 250 x 10 ⁴ psi Argillaceous = 68x10 ⁴ psi Dolomite = 68x10 ⁴ psi Shale = 44x10 ⁴ psi Dolomite = 74x10 ⁴ psi Shale	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures 5.0	<u>Reactor building + all other Class I structures</u> a) D + R + E	a) Normal allowable code stresses, AISC for structural steel, ACI-318-63 without increase for seismic
Steel frame structures 2.0	b) D + R + E [*] Stresses are limited to the minimum yield pt. case an analysis, using the limit-design approach the energy absorption capacity which should be energy input. AEC publication TID-7024 "Nuclear 5.7.	as a general case. In this approach, is made to determine such that it exceeds the
Welded assemblies 1.0		Reactor and Earthquake" Sec.
Bolted and Riveted assemblies 2.0	<u>Primary containment</u> (including penetrations) a) D + P + H + T + E	a) ASME, Sec. III, Class B, without the usual increase for seismic loadings.
Reactor and turbine building 5.0	b) D + P + R + H + T + E	Same as (a), above except local yielding is permitted in the area of jet force where the shell is backed up by concrete. In areas not backed up by concrete, primary local membrane stresses at the jet force <0.9 x yield pt. of material at 300°F.
Ventilation stack 5.0		
Drywell 5.0		
Control room 5.0	c) D + P + R + H + T + E [*] Primary membrane stresses, in general, do not exceed the yield pt. of the material. If the total stresses exceeded yield pt. an analysis was made to determine that the energy absorption capacity exceeded the energy input from the earthquake. The same criteria as in (b), above, is applied to the effect of jet force for this loading condition.	
Amend 13 - Unit 2-SAR		
Amend 14 - Unit 3-SAR		

D = Dead load of structure and equipment plus any other permanent loads contributing stress.
P = Pressure due to loss-of-coolant accident, R = Jet force on pressure on structure due to rupture of any one pipe,
H = Force on structure due to thermal expansion of pipes under operation conditions, T = Thermal loads on containment due to loss-of-coolant accident, E = Design earthquake load.

SEISMIC REVIEW TABLE

MECHANICAL & PIPING

DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Suppression chamber	Analytical model	<u>Reactor Primary Vessel Internals</u> a) D + E	a) ASME, Sec. III Class A vessel
Feedwater lines		b) D + E'	b) The secondary and primary plus secondary stresses are examined on a rational basis taking into account elastic and plastic strains. These strains are limit to preclude failure by deformation which would compromise any of the engineered safeguards or prevent safe shut-down of the reactor.
Vital piping systems			
Reactor pressure vessel			
Recirculation loop piping		c) P + D	c) ASME, Sec. III, Class A
Main steam lines		<u>Reactor Primary Vessel Supports</u> a) D + H + E	a) AISC for structural steel ACI for reinforced concrete
Suppression chamber ring header	Question 2.16 Amend. 7,8	b) D + H + R + E	b) Stresses do not exceed: - 150% of AISC allowable for structural steel - 90% of yield stress for reinforcing bars - 85% of ultimate stress for concrete
		c) D + H + E'	c) The design is such that energy absorption capacity exceeds energy input.

p. 12. 1-6

ECSS: a.) D + T + H + E

b.) D + T + H + E'

a.) Piping - ASA B 31.1 (1955 ed.) and code cases

Pumps - ASME Sec. III, Class C

Shellside - ASME Sec. III, Class C and TEMA C

Tubeside - ASME Sec. VIII, TEMA C

b.) Same as P + D above

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Analysis and Generic Testing	Battery racks - No structural design calculations Instrumentation and control room panels - GE generic tests* Motor Control Center - Cutler Hammer Co. Generic Tests ** - Vibration test and analysis of 7700 Line Motor Control Center, # 70ICS100, 8-70 Transformers - No tests or calculations Cable trays - S. and L. Engrs., Specs, for Cable Pans and Hangers, Spec. K-2197	Not available

* GE - "Seismic Testing of Instrumentation" Dresden 2, 1-71

** Wyle Labs - "Seismic Simulation Test Report for Modified Unitrol
Motor Control Center, Report 43746-1, 10-77

SEISMIC REVIEW TABLE

Docket Number
50-331

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Duane Arnold Energy Center Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel 6-70/2-74	For struc- tures on bedrock or loft fill: 0.06 For struc- ture on 30-50 ft. of soil: 0.09. Sec. 2.6.2.1.1 p. 2.6-24 Table 2.6-2	For struc- ture on bedrock: 0.05 For struc- ture on soil: 0.06 Sec. 2.6.2.1.1 p. 2.6-24 Table 2.6-2	Not avail- able. <							

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reactor building: mat foundation on bedrock. Depth: not available. 									

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OSE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure and all internal concrete structures:	2.0/5.0	(1) Normal loads + operating basis earthquake (2) Normal loads + maximum probable flood (3) Normal loads + design basis earthquake (4) Normal loads + tornado loads (5) Normal loads + design basis loss-of-coolant accident reference	ACI-318-63 Ultimate strength design.
Other conventionally reinforced concrete structures, such as shear walls or rigid frames:	5.0/5.0	For further information refer to Sec. 12.4.2, p. 12.4-1.	
Table C.5-1		p. 12.4-3	p. 12.4-7

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% of critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Welded structural steel assemblies: 1.0/1.0</p> <p>Bolted or riveted steel assemblies: 2.0/2.0</p> <p>Piping systems: 0.5/1.0</p> <p>Table C.5-1</p>	<p>Analytical and testing.</p> <p>Sec. C.5.2.3-1 p. C.5-6,7</p>	<p>Table C.2-1 (partial)</p> <p><u>Summary of Loading Conditions and Criteria</u></p> <p>Reactor Pressure Vessel - Normal - ASME Code, Special Criteria Upset - ASME Code, Special Criteria (Table C.2-2) Emergency - ASME Code, Special Criteria (Table C.2-2) Faulted - ASME Code, Special Criteria (Table C.2-2)</p> <p>Piping - Normal - Industry Codes, Table C.2-2 Upset - Industry Codes, Table C.2-2 Emergency - Industry Codes, Table C.2-2 Faulted - Industry Codes, Table C.2-2</p> <p>Tables C.2-1 through C.2-25, p. C.2-11 through C.2-73</p>	<p>ANSI B31.1.0-1967 B31.7</p> <p>ASME, BPVC</p> <p>Sec. A.1.2 p. A.1-3</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Analysis or testing.	<p><u>GE equipment:</u> "All instrumentation required for nuclear safety is capable of performing all functions important to safety during normal operation, during DBA and post-accident operation. Qualification is achieved by test and/or analysis at acceleration values of 1.5g horizontal and 0.5g vertical over a frequency of 0.25 to 33 Hz".</p> <p><u>Bechtel supplied equipment:</u> "Purchase specifications will require that each type of Class 1 device be individually qualified by vibration test or suitable analysis. The methods ... will meet the general requirements of IEEE Standard 344-1971.</p>	IEEE 344-1971
	Sec. C.5.2 .3.1 p. C.5-6, 7	For further information refer to: Appendix M: Section M.3.3, p. M.3-27 through p. M.3-34	

SEISMIC REVIEW TABLE

Docket Number
50-321

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. s	VERT. s	INTENSITY MM	HOR. s	VERT. s					
CP/OL ISSUE DATE										
Edwin I. Hatch Nuclear Power Plant Unit No. 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel 9-69/8-74	0.08	0.053	VII	0.15	0.10	N-S component of 1940 El-Centro earthquake.	2 com- ponents: Worst horizontal component plus vertical combined simultan- eously P. C-13	SRSS including closely spaced modes.	Conform to the aver- age spectra by G.W. Housner for T ≤4 s. Normalized to the peaks (horizontal) of OBE and SSE.	Time-history method Class II UBC Sec. 12.6.2.1 p. 12-21
	Sec. 12.3.3.2 p. 12-8		Sec. 2.5.9 p. 2-33	Sec. 12.3.3.2 p. 12-8	Sec. 12.3.3.2 p. 12-8	Sec. 12.6.2.1 p. 12-21		Sec. 12.6.2.1 p. 12-20	Sec. 2.5.9 p. 2-33 Fig. 2.5-5 and 6	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat foundations for the following buildings: reactor, turbine, control, diesel generator, and radwaste. The foundation for the main stack is a reinforced concrete mat on steel H-piles.	Duplin: (cemented clay-sand grading to sandy clay). Beneath: (sand, sandy-clay) Clay, sand, gravel, etc. Crystal-line basement rock.	135 ft 10 to 70 ft 65 ft 4000 ft	2450 fps	Summary of domestic well study is given in Table 2.4-3, pp. 2-18 and 2-19 of Section 2.4.6.2. Summary of Piezometer Installation Data is given in Table 2.4-4, pp. 2-20 and 2-21 of Section 2.4.6.2 No liquefaction potential has been found.	Not available.	Stick model with soil springs.	23,300 ksf Amendment 14, 4/72 Vol. VIII of FSAR Table Q 12.3.3.2.4-1 of Question 12.3.3.2.4	Translation and rotation of foundation soil - 4.5%DBE - 5.5%DBE Table 12.3-2 p. 12-10	Unclear in - formation Ref: PSAR Sec. XII-3.1
Sec. 12.5 p. 12-18	Sec. 2.7.4 p. 2-41		Amend. 14 (4/72) p. 12.3.3.2.4-2	Sec. 2.7.7 p. 2-45		Amendment 12 12/72 Sec. 12.6.2.1 p. 12-20 Fig. 12.6-1			

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(Z critical damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structures:	3.0/5.0	Class I structures	They are classified according to the load combination case. For details, see Sec. 12.4, pp. 12-15 and 12-16.
Steel frame structures:	3.0/5.0	1. Primary containment.	
Bolted and riveted assemblies:	3.0/5.0	(a) D+L+H+T+E (b) D+L+H+P+R+T+E	Generally used: ASME, Sec. III, Class B. For steel structures, AISC. For concrete structure: ACI 318-63 and 307-69
Welded assemblies:	2.0/3.0	(c) D+L+H+P+R+T+E' (d) D+E+F	
Vital piping:	0.5/1.0	2. Reactor pressure vessel support.	
Translation and rotation of foundation soil:	4.5/5.5	(a) D+L+H+E (b) D+L+H+R+P+T	
		(c) D+L+H+T+P+T+E (c) D+L+H+R+P+T+E'	
		3. Reactor building and all other Class I structures.	
		(a) D+L+H+E (b) D+L+H+W	
		(c) D+L+H+E' (d) D+L+H+W'	
		4. Reactor building crane structure.	
		(a) D+L+C+I (b) D+L+C+E	
		(c) D+L+C+E' (d) D+L+C+W	
		(d) D+L+C+W'	
		Class II structures: designed according to applicable codes and standards.	
		NOTE: D = dead load, L = live load, C = crane load, I = impact load, P = pressure due to LOCA, R = jet force, T = thermal load, E = OBE, E' = SSE, W = wind, W' = tornado wind, and F = hydrostatic.	
Amendment 12, 2/72, Vol. III		Sec. 12.4, p. 12-15	
Sec. 12, Table 12.3-2			
p. 12-10			

SEISMIC REVIEW TABLE

MECHANICAL & PIPING													
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA											
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES										
Piping: 0.5/2.0	Analytical and testing.	<p>Reactor vessel:</p> <p>1. Normal + OBE</p> <p>2. Normal + piping rupture or normal + SSE</p> <p>3. Normal + SSE + piping rupture</p> <p>Piping: Dead loads + external loads + thermal loads.</p> <table><tr><td>1. Dead + pressure</td><td rowspan="3">}</td><td rowspan="3">USAS B31.1.10</td></tr><tr><td>2. Dead + pressure + OBE</td></tr><tr><td>3. Dead + pressure + thermal</td></tr><tr><td>4. Dead + pressure + SSE</td><td rowspan="3">}</td><td rowspan="3">Low probability of occurrence</td></tr><tr><td>5. Dead + maximum pressure + OBE</td></tr><tr><td>6. Dead + maximum pressure + SSE</td></tr></table> <p>More details on Table C-3.1 of Section: NSSS Equipment Loading Design on FSAR, Vol. IV, pp. C-14 to C-46.</p>	1. Dead + pressure	}	USAS B31.1.10	2. Dead + pressure + OBE	3. Dead + pressure + thermal	4. Dead + pressure + SSE	}	Low probability of occurrence	5. Dead + maximum pressure + OBE	6. Dead + maximum pressure + SSE	ASME, BPVC, Section III, Nuclear Vessels, 1965 Edition and Winter 1966 Addenda with additions listed on page I-1 of Appendix I of Reactor Pressure Vessel Report.
1. Dead + pressure	}	USAS B31.1.10											
2. Dead + pressure + OBE													
3. Dead + pressure + thermal													
4. Dead + pressure + SSE	}	Low probability of occurrence											
5. Dead + maximum pressure + OBE													
6. Dead + maximum pressure + SSE													
Sec. A.3.1.4 p. A-4	Amendment 13 3/72 Sections C.1.1 and C.12, p. C-1		pp. C-10, C-12										

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-366

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OSE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
CP/OL ISSUE DATE										
Edwin I. Hatch Nuclear Power Plant Unit No. 2	0.08	0.053	VII	0.15	0.10	Modified Taft 1952 horizontal component was used for develop- ing synthetic accel- eration time history.	3 compo- nents: Each hori- zontal combined with the vertical simulta- neously, re- sulting in two separ- ate seis- mic cases.	SRSS with close modes summed absolute- ly.	Modified Newmark design spectra.	Time-history method.
Reactor type: BWR										
Containment type: Mark I (steel)										
NSSS Manufacturer: General Electric										
Architect Engineer: Bechtel										
	</									

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat 27'2" thick at middle dry well and 12'4" thick at other sections. <									

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING DBE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structure:	3.0/5.0	Steel containment	ASME, BPVC, Sec. III
Steel frame structures:	3.0/5.0	(a) Initial and final testings	AISC 1969 Ed.
Bolted and riveted assemblies:	3.0/5.0	(1) $D+L+P_t+T_t+E$	ACI 318-63
Welded assemblies:	2.0/3.0	(2) $D+L+P_t+T_t+E'$	
Translation and rotation of soil: (NSSS)-	4.0/5.0	(b) Normal operating	
Drywell-building (coupled):	3.0/5.0	(1) $D+L+T_o+R_o+E$	
Suppression chamber:	2.0/3.0	(2) $D+L+T_o+R_o+E'$	
Reactor pressure vessel, support skirt, shroud head, separator and guide tubes:	2.0/3.0	(3) $D+L+T_e+R_e+P_e+E$	
Fuel:	7.0/7.0	(4) $D+L+T_e+R_e+P_e+E'$	
Table 3.7A-1 and 3.7B-1		(c) Refueling	
		(1) $D+L+E$	
		(2) $D+L+E'$	
		(d) Accident	
		(1) $D+L+T_a+R_a+P_a+E$	
		(2) $D+L+T_a+R_a+P_a+E'$	
		(3) $D+L+T_a+R_a+P_a+Y_r+Y_j+Y_m+E'$	Sec. 3.8.2.2 p. 4
		(e) Flood	Sec. 3.8.3.2 p. 45
		(1) $D+L+E+F$	Sec. 3.8.4.2 p. 57
			Sec. 3.8.5.2 p. 78

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OSE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping systems Fuel	0.5/1.0 7.0/7.0	Analytical and supplementary testing	Load combination definitions are according to ASME Sec III NB-3200 through NB-3600. For details see tables below, e.g., Table 3.9-4, "Reactor Pressure Vessel Internals and Associated Piping."	ASME, BPVC, Section III
	(NSSS) Secs. 3.7B.2.1 3.7B.2.1.6.1 3.7B.2.1.6.2 3.7B.2.1.7.1 3.7B.2.1.7.2 3.7B.2.1.8		Table 3.9-4, through 3.9-64	Table 3.9.-1, 3.9-2 Sec. 3.9.1.6 p. 3.9-8

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number

50-285

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE Fort Calhoun Station Unit #1 Reactor type: PWR Containment type: Without Buttresses (Prestressed Con- crete) NSSS Manufacturer: Combustion Engi- neering Architect Engineer: Gibbs & Hill, Inc. 6-68/5-73	0.08	.053	Unclear information	0.17	.0113	Time history—1940 El Centro and 1952 Taft normalized to the ground acceler- ation of the maximum hypothetical earth- quake are used for developing floor response spectra.	3 compo- nents. Combina- tion not available.	SRSS	Response spectra conform to the average spectra developed by Housner for fre- quency > 0.33 HZ and Newmark for frequency < 0.33 HZ.	Time history method.
	Sec. 2.4 p. 2.4-3	Sec. 2.4 p. 2.4-3	Sec. 2.4 p. 2.4.1	Sec. 2.4 p. 2.4.3	Sec. 2.4 p. 2.4.3	Sec. F.2.2.4 p. F-10	App. F Sec. F.2.5 p. F-12	App. F Sec. F.2.2.3 p. F-9	App. F Sec. F.2.1.4 p. F-6	App. F Sec. F.2 p. F.10 & F.14

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
High strength concrete mat supported by pile foundation resting on bedrock (containment, auxiliary bldg.)	Compact granular.	60 ft	Not available.	Missouri River Valley.	Gavin Point	Stick model with soil springs.	Not available.	Not available.	0.05 SSE
	Fluvial deposits on limestone.	4-8 ft		Domestic wells depth 20 ft to 35 ft.	Fort Randall				0.02 OBE
	Bedrock underlain by rock strata.	19-21 ft		Commercial wells depth 50 ft to 75 ft.	Big Bend Oahe Garrison Fort Peck				
Sec. 5.1 p. 5.1.1 Covering letter "Dames & Moore" App. C p. 10	Sec. 5.1 p. 5.1.1 App. C p. 6	Sec. 5.1 p. 5.1.1 App. C p. 6		Sec. 2.7.2 p. 2.7-6	Sec. 2.7 p. 2.7-1	Sec. F.2.2.3 p. F-8			Sec. F.2.2.3 p. F.9

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure: 2.0/2.0	1. D+L+S+T'''	Ultimate strength method ACI 318-63
Concrete support structures for reactor vessel and steam generators: 2.0/2.0	2. D+L+S+T'''+W or E	Modified ultimate strength design
Steel Assemblies: Bolted or riveted 2.0/2.0 Welded 1.0/1.0	3. D+L+P+S+T+W or E	No loss of function design for extreme environmental loading
Vital piping systems: 0.5/0.5	where:	
Rigid vault type concrete structures: 2.0/5.0	D = Dead load including equipment weights and hydrostatic loading	
Framed concrete structures: 5.0/7.0	L = Live load	
	S = Post-tensioning load (which varies with time)	
	P = Accident design pressure	
	T = Thermal loads based on a temperature corresponding to pressure P	
	W = Wind load	
	E = Design earthquake	
	T''' = Thermal loads based on normal operating temperature	
	For further details refer to section 5.5.	
Sec. F-2.1.3 p. F-6	Sec. 5.5 p. 5.5-1 to 5.5-5a	Sec. F.2.1.1 p. 5.5-1 Sec. 5.5 p. F.3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Mechanical equipment: 2.0/2.0</p> <p>Piping: 0.5/0.5</p>	<p>Analytical and testing.</p>	<p>Reactor vessel:</p> <p>1. Design loading + OBE</p> $P_m \leq S_m$ $P_b + P_L \leq 1.5 S_m$ <p>2. Normal operation + SSE</p> $P_m \leq S_d$ $P_b \leq 1.5 \left[1 - \left(\frac{P_m}{S_d} \right)^2 \right] S_d$ <p>3. Normal operation + SSE + pipe rupture</p> $P_m \leq S_L$ $P_b \leq 1.5 \left[1 - \left(\frac{P_m}{S_L} \right)^2 \right] S_L$ <p>where $S_L = S_y + (1/3) (S_u - S_y)$ $S_d = 1.2 S_m$</p> <p>Piping:</p> <p>1. Design load + OBE</p> <p>2. N.O. + SSE</p> <p>3. N.O. + SSE + pipe rupture</p> <p>For reactor vessel and piping Sec. F.2.1.2 Table F.1, p. F.4 and F.5, Appendix F</p>		<p>ASME, BPVC, Section III</p> <p>USAS, B31.1 and B31.7</p>
<p>Appendix F Sec. F.2.1.3 p. F.6 Table F.2</p>	<p>Appendix F Sec. F.2.2.2 p. F-7C</p>	<p>Applicable code allowable</p> $P_m \leq S_d$ $P_b \leq 4/\pi S_d \cos \left(\frac{\pi}{2} \cdot \frac{P_m}{S_d} \right)$ $P_m \leq S_L$ $P_b \leq 4/\pi S_L \cos \left(\frac{\pi}{2} \cdot \frac{P_m}{S_L} \right)$		<p>Appendix F Sec. F.2.1.1 p. F.3</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	<p>Shop test, prototype test, field test or seismic analysis to meet Class I seismic criteria.</p> <p>Appendix F Sec. 6.14 Sec. F.2.2.2 p. 6.1-4 p. F.7.C, 7d</p>	<p>"Special seismic restraints will be installed at the electrical cable trays. The cable will be supported vertically and horizontally so as to meet the stress criteria under all conditions including postulated earthquakes."</p> <p>Sec. F.2.2.2 p. F.7.C</p>	<p>According to IEEE 344 "Guide for Seismic Qualification of Class I Equipment for Nuclear Power Generating Station"</p> <p>Sec. F.2.2.2 and Sec. 7.2.2 p. F.7.C and p. 7.2.1</p>

SEISMIC REVIEW TABLE

Docket Number

50-267

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Fort St. Vrain Nuclear Generating Station (Unit 1) Reactor type: HTGR Containment type: Prestressed Concrete NSSS Manufacturer: Gulf General Atomic Architect Engineer: Sargent and Lundy Engineers	0.05	0.033	VII	0.10	0.067	TID-7024, "Nuclear Reactors and Earthquakes", AEC, 8/63	The hori- zontal re- sults from spec- tral anal- ysis were combined simulta- neously with the vertical	PCRV: "Linear super- position of all modal contribu- tions". All other Cat. I struct: SRSS	Response spectra were developed as recommended in AEC TID-7024. Housner	TID-7024
	Amend. 14 Sec. 5.2.1.1 p. 5.2-4	Amend. 14 Sec. 5.2.1. p. 5.2-4		Amend. 14 Sec. 5.2.1.1 p. 5.2-4	Amend. 14 Sec. 5.2.1.1 p. 5.2-4	p. 14.1-1, App. E.13	p. 5.3-33	p. 14.1-4	Fig. 14.1-1 Sec. 14.1 p. 14.1-1, 14.1-3	p. 14.1-1 App. E.13
9-68/12-73										

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
1. Reactor, turbine buildings and heavy equipment, as well as the main and service water cooling towers. Straight shaft piers. Drilled into the claystone bedrocks.	The major plant facilities will be founded on Pierre Shale bedrock (dark gray, silty shale). 44 to 54 ft. p 1.2-2		Not available	Ground water level was well below proposed foundation level, except reactor building which extends below the water level.	V _S = 1200 fpe @ 20 ft. V _S = 2400 fpe @ 65 ft. Boring UH1	Lumped mass model with soil springs	G _S = 850 psi @ 20 ft. G _S = 104,000 psi @ 65 ft. Boring UH1	Not available	Not available
2. Miscellaneous light equipment. Spread footings.	Above it lies St. Vrain Platte River alluvia sands and gravel								
Sec. 2.6 p. 2.6-20				Sec. 2.6 p. 2.6-21	Table 3-1	p. E. 37-12 Fig. E.13-1	Table 3-1 p. 3-8		

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (Z Criti- cal damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete: 2.0/5.0	PCRV: $DL + 1.23 NWP + E' + TL$ $DL + 1.23 NWP + 1.5 TL$ NWP = Normal working pressure DL = Dead load E' = SSE earthquake loads TL = Temperature loads	For reactor core support structure:
PCRV. (prestressed concrete reactor vessel) 2.0/5.0		Concrete. ACI 318-63
Welded steel 2.0/5.0		Metal. ASME B and PV Code
Bolted steel 2.0/10.0		Sec. III. Class A
Amend. 16, p. 14.1-3	Table E.1-1	<u>Stress Criteria: Operating</u> Principal Comp. $0.45 Cf'_c$ Principal tension $3\sqrt{f'_c}$ Bearing tendon area $0.6f'_c 3\sqrt{ab'/ab'} < f'_c$ Bearing: Shear Anchors $0.6f'_c$ average
		Table E.1-1 Sec. 3.2, p. 3.2-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital steel piping 0.5/0.5	Dynamic seismic method for Class I System and piping based on Fig. "SSE" ground acceleration Sec. 1.4 p. 1.4-3 and Tests for Class I systems, Q. 5.1, Amend. 16 Attachment A, p. 5.1-1 and Q. 5.11, Amend. 16 Attachment A p. 5.11-1 and Amend. 1 Attachment A p. 5.11-9	For PCRV Internal Steel Structure: a) D. L. + Operating mechanical load $\leq 0.667 F_y$ b) D. L. + Operating mechanical load + Design seismic loads $\leq F_y$ c) D. L. + Operating mechanical + twice design seismic load \leq No loss of safety function	For all piping systems: ANSI B.31.1.0-1967. For containment tank: ASME Code Sec. III-C For coolers: ASME Code Sec VIII Sec. 4.2, p. 4.2-10 Sec. 4.2, p.4.2-28 Sec. 4.2, p.4.2-35
Amend. 16, p. 14.1-3		Amend. 16, p. 5.21-1, Table 3.2-1	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Tests and inspections. For auxiliary electrical system.	Not available	Not available

Amend. 25
p. 8.4-1

SEISMIC REVIEW TABLE*

Docket Number

50-213

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Haddam Neck Nuclear Power Plant, Unit 1. Reactor type: PWR Containment type: Reinforced Concrete Cylindrical NSSS Manufacturer: Westinghouse Architect Engineer: Stone and Webster Engineering Corp.	Not used	Not used	Not used	0.17 						

*Information obtained from BNL Docket search and SEPB Report prepared by LLL, EDAL Report # 175-130.01, January 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Containment- 9 ft. mat. Spent fuel pit founded on bedrock with lowerside walls embedded in rock and earth. Major structures are founded directly on the granitic gneiss bedrock. Minor structures are founded either on rock on piles driven to rock or on spread footings in compacted granular fill. 2.4-2	<u>SAMPLE:</u> Boring L-11 Loose loam Firm fine sand and gravel boulder schist Fig. 2.4-4	Not available + 5.0 -2.0 -8.0 -30.0	21 ft. MSL is yard grade. Calculated site flood stage is 15.1 MSL GWL: - 8 ft. MSL 2.3-3	Not available	Fixed base with single degree of freedom (containment).	Not available	Not used	Not used ..	

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
R/C containment: Include mat	7.0	<p>Reinforcing steel - primary plus secondary</p> <p>operating + incident - 33.3 ksi</p> <p>operating + .03g hor. - 26.7 ksi</p> <p>operating + .03g hor. + incident - 33.3 ksi</p> <p>operating + incident + 0.17g hor. - 40.0 ksi</p> <hr/> <p>- wind loads up to 150 mph</p> <p>- 30 psf snow and ice (not included in combination)</p> <p>p. 3.2-2</p> <hr/> <p><u>Non-safety related systems:</u></p> <p>E (=0.03g): No loss of function</p>
R/C framed structure	5.0	
Steel framed structures, include support. structure and foundation		
bolted	2.5	
welded	1.0	
Table 2.5-2		p. 3.2-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
<p>Piping:</p> <p>Carbon steel 0.5</p> <p>Stainless steel 1.0</p> <p>Reactor internals and CRD</p> <p>welded 1.0</p> <p>bolted 2.0</p> <p>Mechanical equipment includes pumps and fans 2.0</p>	Analytical	<p>Reactor coolant Safety Injection System:</p> <p>Operating loads + E < working Stress (E = 0.17g)</p> <hr/> <p>Main Steam Piping:</p> <p>Operating loads + E < Working Stress (E= 0.03g)</p>	<p>Component</p> <p>Steam generator- Reactor Coolant Pumps- Reactor Coolant Piping - Pressurizer</p> <p>Safety and Relief Valves</p> <p>Loop Stop Valves Loop Check Valves Pressure Control and Relief System Piping</p> <p>Low Pressure Surge Tank</p>	<p>Design Code</p> <p>ASME Section VIII (1956 ed.) ASME Section VIII (1956 ed.) ASA B31.1 (1955 ed.) ASME Section VIII (1956 ed.) and Code Case Nos. 1224 and 1234 ASME Section I (1956 ed.) and Code Case Nos. 1224 and 1234 ASA B16.5 (1957 ed.) ASA B16.5 (1957 ed.) ASA B31.1 (1955 ed.)</p> <p>ASME Section VIII (1956 ed.)</p>

Table 2.5.2

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	No testing	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number
50-261

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OSE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
CP/OL ISSUE DATE	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
H. B. Robinson Nuclear Steam Electric Plant Unit No. 2 Reactor type: PWR Containment type: without buttresses (prestressed con- crete) NSSS Manufacturer: Westinghouse Architect Engineer: Ebasco 4-67/8-70	0.10	0.067	VII	0.20	0.133	Not used.	K and Y (vertical) or Z and Y (vertical) applied together. Combina- tion not available.	Absolute sum.	Housner spectra.	No floor re- sponse spectra generated. Housner spectra used for components.
	p. 5.1.2 -6	p. 5.1.2 -6		p. 5.1.2 -6	p. 5.1. 2-6	p. 5A-4	Question III A 11	Question IIA	Figures 2.9-2 9.9-3 p. 2.9-9	p. 5A-4

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
A 144 ft. diameter circular reinforced concrete slab 10 ft. in thickness supported by 923 steel pile. p. 5.1.2-20	The piedmont crystal-line basement rock at the site is overlaid with 460 ft. of unconsolidated coastal plain sediment. These sediments are comprised: 30 ft. of surface alluvium *	The middendorf is made up of sands, silty and sandy clay, sandstone and mudstone. Fig. 2.8-2 Basement Rock Middendorf 430ft. Alluvium 30ft.	Not available.	Not available.	Earth dam at the site has a central vertical clay core and supporting shells of compacted sand. The crest of the dam is at El. 230, the normal pool is at El. 220 and the dam has a maximum height of 50 ft. The crown width of dam is 15 ft. and side slopes are 1(vertical): **	Not available. **DAM (cont.) 3(horizontal) on upstream side and 1 (vertical): 2.5(Horizontal) on downstream with 15 ft. berm at El. 200. Sec. 2.9.8 p. 2.9-10 Dock. 50261-104	Not available.	Not available.	The modal analysis was performed utilizing the same damping factor for each mode.
TYPE (cont.) over 430 ft. middendorf formations. Sec. 2.8.3 p. 2.8-6 Dock. 50261-104	(cont.)								Question III A4

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure:	2.0	For containment structure:	For containment structure using ACI 318-63 Ultimate strength design.
Concrete support structure of reactor vessel:	2.0	(a) $C=1.0D+0.05D+1.5P+1.0(T+TL)+1.0B$	
Concrete structures above ground:		(b) $C=1.0D+0.05D+1.25P+1.0(T'+TL')+1.25E+1.0B$	
(a) Shear wall	5.0	(c) $C=1.0D+0.05D+1.0P+1.0(T'+TL')+1.0E'+1.0B$	
(b) Rigid frame	5.0	(d) $C=1.0D+0.05D+1.0P_T+1.0(T_T+TL_O)+1.25WT+1.0B$	
		(e) $C=1.0D+0.05D+1.15P_D$	
		Symbols used in these formulas are defined on p. 5.1.2-9.	
Table 5A.1-1 p. 5A-5		p. 5.1.2-8	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital pipe systems: 0.5 Steel assemblies: (a) Bolted or riveted 2.5 (b) Welded 1.0	Analytical	<div> <div>Vessels</div> <div>Piping</div> </div> <div> 1. Normal loads $P_m \leq S_m$ $P_L + P_B \leq 1.5S_m$ </div> <div> 2. Normal + design earthquake loads $P_m \leq S_m$ $P_L + P_B \leq 1.5S_m$ </div> <div> 3. Normal + assumed hypothetical earthquake loads $P_m \leq 1.2S_m$ $P_L + P_B \leq 1.2(1.5S_m)$ </div> <div> 4. Normal + pipe rupture loads $P_m \leq 1.2S_m$ $P_L + P_B \leq 1.2(1.5S_m)$ </div> <div> P_m = primary general membrane stress; or stress intensity. P_L = primary local membrane stress; or stress intensity. P_B = primary bending stress; or stress intensity. S_m = stress intensity value from ASME, BPVC Code, Section III S = allowable stress from USAS B31.1 Code for pressure piping. </div>	Pressure piping: USAS B31.1 Pressure vessel: ASME, BPVC
		Table 5A.3-1	p. 5A-3

Table 5A.1-1
p. 5A-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Circuits and equipment were subjected to vibration tests which simulated the seismic conditions for the "low seismic" class of plants.	Not available.	Electrical equipment: WCAP 7397-L
	p. 7.5-13		p. 7.5-14 Amendment 10

SEISMIC REVIEW TABLE

Docket Number
50-133

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Humboldt Bay Power Plant, Unit 3 Reactor type: BWR Containment type: Pre-mark (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel 11-60/8-62	0.25 <									

Information gathered from FHSR Amend. 11 (50133-1), Amend. 13 (50133-3)
FSAR Supp. (50133-59), FSAR proposed Amend (50133-124), FSAR Supp. Emergency Plant (50133-183)
and Summary Report of Seismic Design Review, Rev. 3, 1977.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Not available	Sand and alluvium overlaying strata of Hookton and Carlotta formation which are more or less consolidated sands. Gravels and clays and conglomerates with good structural properties.	Not available	Not available	Not available	Not available	2 dimensional finite element model which includes embedded reactor caissons p. 5-1		BC -	TOP 4A

FHSR, Amend 11,
Sec. I, p. 155

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & 'ALLOWABLE' STRESSES
R. G. 1.61 (BC-TOP-4A)	<p><u>Accident Condition</u> Concrete structures:</p> $U = D + L + T_A + H_A + R + 1.5 P$ $U = D + L + T_A + H_A + R + 1.25 P + 1.25 E$ $U = D + L + T_A + H_A + R + P + E'$ $U = D + L + T_O + H_O + E'$ <p>Steel Structures <u>Elastic</u> working stress</p> $1.6S = D + L + T_A + H_A + R + P$ $1.6S = D + L + T_A + H_A + R + P + E$ $1.6S = D + L + T_A + H_A + R + P + E'$ <p><u>Plastic</u></p> $0.9 Y = D + L + T_A + H_A + R + 1.5 P$ $0.9 Y = D + L + T_A + H_A + R + 1.25 P + 1.25 E$ $0.9 Y = D + L + T_A + H_A + R + P + E'$ <p>App. B-3</p>	<p>AWS D1.1-74 welded steel tanks for oil storage, API 650, 1973 BC-TOP-9A, Design of structures for missile impact, Rev. 2, 1974</p> <p>UBC - 1973 ACI -214 - 65 ACI -318 - 71 AISC - 1969</p> <p>p. C-1 p. C-2</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reg. Guide 1.61 (BC-TOP-4A)	Test or Analysis	<u>Piping System</u>		
		Plant Operating Condition	Loading Condition	ASME SEC.III Ref.
		Normal	P + W	Eq.(8) of NC-3652.1
		Upset	P + W + OBE	Eq.(9) of NC-3652.2
			P + W + FV*	
		Faulted	P + W + SSE	Eq.(9) of Code Case 1606 NC-3652.2
		Normal & Upset	TH	Eq.(10) of NC-3652.3(a)
			P + W + TH	Eq.(11) of NC-3652.3(b)
		<u>Vessel Loading Conditions</u>		
		Upset	P + W + OBE	NC-3300 Sec. VIII Code Case 1607
Table 6.1				Allowable Stress
				S_H
				$1.2 S_H$
				$2.4 S_H$
				S_A
				$S_A + S_H$
				$P_M \leq 1.10 S$
				$(P_M \text{ or } P_L) + P_B \leq$
				$1.65 S$
				$P_M \leq 2.0 S$
				$(P_M \text{ or } P_L) + P_B \leq$
				$2.4 S$
		p. B-5,6		
		BN-TOP-2, Design for pipe break effects		

*Applies to main steam line

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number
50-3

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Indian Point Nuclear Generating Station, Unit No. 1 Reactor type: BWR Containment type: Dry containment- spherical (steel) NSSS Manufacturer: Babcock and Wilcox Architect Engineer: United Engineers and Constructors 5-56/3-62	None	None	Not avail- able	0.10g for containment structure (including steel sphere and interior structure), nu- clear service bldg., chemical systems bldg., fuel handling bldg., stack J. Blume p. vi,	.090g for screenwell house 0.03g for superheater bldg. 0.05g for vertical analysis	Synthetic Time History "Earthquake Analysis of Piping Systems." 9-12-69 J. Blume Report, p. 1-2	Each hori- zontal combined with vertical simul- taneously Sheet* 161.1 p. D.2-2	SRSS Sheet 10.1 p. 1-6	Synthetic design spectra TID-7024 Housner "Earthquake and Tornado Analysis of Structures" 9-5-69 J. Blume Report p.1-2	Time-history method J. Blume Report on Piping Systems, p. 1-2 Class I structure Sheet 10.1, p. 1-4, 5 Piping Sheet 11.1, p. 1-2, 5 Reanalyzed, Sheet 4.30, p. 1,2,3

* "Sheet" refers to microfiche Sheet #

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat.	Hard, well-bedded dolomitic limestone, bedrock is extremely jointed and fractured joint systems extended at near right angles to bedding, other systems are irregular. The intensity is almost brecciation.	Foundation sits on bed-rock	Not available	Not available	Not available	Stick model with foundation rigidly fixed to bed-rock.	Not available	No damping assumed	Not available
Sheet 10.1 p. 2-1		Sheet 10.1 p. 2-1				Sheet 10.1 p. 2-1		Sheet 10.1 p. 2-1	

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING ONE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete 5.0/5.0 Structural steel - bolted 2.0/2.5 - welded 1.0/1.0	<p>First analysis-</p> $C = (1.0 \pm 0.05) D + (E \text{ or } W)$ <p>C = Required load capacity; E = earthquake loads D = Normal loads (dead load of structure, plus any normal Sheet 10.1, p. 1-3 operating live loads)</p> <hr/> <p>Reanalysis-</p> $U = D + L + F_{eqs} + T_a = P_A - \text{steel containment}$ $U = D + L + T_a + F_{eqs} - \text{Biological shield}$ $U = D + L + F_{eqs} - \text{other Class I structures}$ <p>D = Dead loads; L = live loads T_a = Thermal loads; P_A = pressure loads F_{eqs} = SSE loads</p> <p style="text-align: right;">Sheet 4.30, p. 1 and 2 Sheet 114.2, Question 7</p>	<p>ACI Standard- ACI 318-63 "Ultimate Strength Design" ASME BPVC, Sec. VIII</p> <p style="text-align: right;">Sheet 4.1, p. 1-4 Sheet 10.1, p. 1-3 and Sheet 10.2</p>
Sheet 10.1, p. 1-2 Sheet 430, p. 1		

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Piping <				

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number
50-247

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OSE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
CP/OL ISSUE DATE	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
Indian Point Nuclear Generating Station, Unit No. 2	0.10	0.05	VI	0.15	0.10	None used	Horizontal and verti- cal. acting simultan- eously	SRSS	Housner	No floor re- sponse spectra generated; ground response spectra used for piping and com- ponents.
Reactor type: PWR										
Containment type: Atmospheric (Reinforced Concrete)										
NSSS Manufacturer: Westinghouse										
Architect Engineer: United Engineers & Constructors										

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Mat foundation 9ft. thick. Sec. 1.3.0 p. 1.0-4 Supp. 6 (2/70)	Hard, wellbedded dolomitic limestone. This bedrock is extremely jointed and fractured. Joint systems extended at near right angles to bedding; other systems are irregular. The intensity may be described almost as brecciation.	Not available.	Not available.	Stony Point: about 35ft. depth Rockland County 100ft. to 300ft. depth At the fringe of Westchester County depth less than 50ft. Vol. 1, Sec. 2.5, p. 5-10	Not available.	Structure; Stick Model Fixed base Sec. 3.1.5, p. 3.0-9, Suppl. 9	Not available.	Not available.	Not available.

Sec. 2.7
p. W-4

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment structure	2.0	*	ACI 318-63
Concrete support structure of reactor vessel	2.0	a) $C = 1.0D \pm 0.05D + 1.5P + 1.0 (T + TL)$ b) $C = 1.0D \pm 0.05D + 1.25P + 1.0 (T' + TL') + 1.25E$ c) $C = 1.0D \pm 0.05D + 1.0P + 1.0 (T'' + TL'') + 1.0E'$ C = Required load capacity section D = Dead load of structure and equipment loads P = Accident pressure load T = Load due to maximum temperature gradient through the concrete shell and mat based upon temperature associated with 1.5 x (accident pressure) TL = Load exerted by the liner based upon temperature associated with 1.5 x (accident pressure) T' = Load due to maximum temperature gradient through the concrete shell and mat based upon temperature associated with 1.25 x (accident pressure) TL' = Load exerted by the liner based upon temperature associated with 1.25 x (accident pressure) E = Load resulting from operational basis earthquake T'' = Load due to maximum temperature gradient through the concrete shell, and mat based upon temperature associated with the accident pressure TL'' = Load exerted by the liner based upon temperature associated with the accident pressure E' = Load resulting from design basis earthquake	
Steel assemblies:			
(a) bolted or riveted	2.5		
(b) welded	1.0		
Concrete structures above ground			Sec. 2.1.12, p. 2.0-7 and Sec. 2.1.13, p. 2.0-8 Supp. 6
(a) shear wall	5.0		
(b) rigid frame	5.0		
* One damping value is given, but not clear whether for O.B.E. or D.B.E.			
Sec. 5.1.3.8, p. 5.1.3-6		Sec. 2.1.12, p. 2.0-5, Supp. 6	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA				
		LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Vital Piping Systems 0.5 *	Analytical and Testing	<u>L. C.</u> 1. Normal loads 2. Normal + Design E.Q. 3. Normal + SSE 4. Normal + pipe rupture	<u>Vessel</u> $P_M \leq S_M$ $P_L + P_B \leq 1.5 S_M$ Same as above $P_M \leq 1.2 S_M$ $P_L + P_B \leq 1.2 (1.5 S_M)$ Same as above	<u>Piping</u> $P_M \leq S$ $P_L + P_B \leq S$ $P_M \leq 1.2 S$ $P_L + P_B \leq 1.2 S$ $P_M \leq 1.2 S$ $P_L + P_B \leq 1.2 (1.5 S)$ Same as above	<u>Supports</u> Working stress or applicable factored load value 1 1/3 working stress Maintain equip. within stress limits Same as above	For mechanical: ASME , BPVC, Section III For piping: USAS B31.1 (1955) For further details refer to Q. 4.10 Sec. 3.2.3, p. 3.2.3-3 Sec. Q. 4.5, p. Q. 4.5-1 Supp. 6
* One damping value is given. But not clear whether for O.B.E. or D.B.E.		Table A.3-1				
Sec. 5.1.3.8, p. 5.1.3-7		Sec. 5.1.3.8 p.5.1.3-6 and Q.4.5, Q.4.5-1 Supp. 6				

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number
50-286

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Indian Point Nuclear Generating Station, Unit No. 3	.10	.05	VII	.15	.10	Compared with (1) El Centro 12/30/34 and 5/18/40 (2) Olympia 4/13/49 (3) Taft 7/21/52.	3 compo- nents: Each hori- zontal combined with vertical component by abso- lute sum.	SRSS, closely spaced (10%) modes combined by abso- lute sum.	Containment response: Housner spectra	Time history.
Reactor type: PWR										
Containment type: Atmospheric (reinforced con- crete)										
NSSS Manufacturer: Westinghouse										
Architect Engineer: United Engineer and Contractors										
8-69/5-76	Sec. 5.1. 2.2 p. 5.1.2 -4	Sec. 5.1. 2.2 p. 5.1.2 -4		Sec. 5.1. 2.2 p. 5.1.2 -4	Sec. 5. 1.2.2 p. 5.1. 2-4	p. A1-9, Appendix A1 Curves-Fig. A1-1&2	Question 5.22	p. Q5.28 -1 p. Q5.37 -1	Sec. 5.1.3.5 p. 5.1.3-3	p. Q4.32-1 Vol. VI

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Concrete base mat--9 feet thick.	Fine-grained phyllite, a schist, and limestone with bedrock lying close to the surface. Bedrock is jointed and fractured.	Not available.	Not available.	Fluctuates between El. 35 to El. 55 (MSL)	Three reservoirs are within five mile radius. No information on dams is available.	Structure: stick model Soil: cantilever beam assumption indicates fixed base modeling.	Not available.	Not available.	Not available.
Sec. 5.1.2.1 p. 5.1.2-1	Sec. 2.7 p. 2.7-1			See Fig. 2.7-3	Sec. 2.5 p. 2.5-2	Appendix 5A Sec. 3.1.5 p. 5A-26+28			

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(Z criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Containment:	2.0/5.0	Containment factored load equations: (a) $C=1.0D+0.05D+1.5P+1.0(T+TL)$ (b) $C=1.0D+0.05D+1.25P+1.0(T'+TL')+1.25E$ (c) $C=1.0D+0.05D+1.0P+1.0(T''+TL'')+1.0E'$ (d) $C=1.0D+0.05D+1.0W'$	Containment concrete-- ACI-318-63
Concrete support structure of reactor vessel:	2.0/2.0		Ultimate strength design ACI 318-63 Part IV-B
Concrete structures above ground:			
(a) shear wall	5.0/5.0	(a) = LOCI	
(b) rigid frame	5.0/5.0	(b) = Design base accident (DBA)+OBE (c) = DBA+SSE	
Steel assemblies:			
(a) bolted or riveted	2.5/2.5	where	
(b) welded	1.0/1.0	C = required load capacity D = dead loads P = accident pressure load T = maximum temperature gradient load associated with 1.5P. TL = liner load due to temperature associated with 1.5P. W' = tornado wind and external pressure drop T' and TL' are T and TL but due to 1.25P. T'' and TL'' are T and TL but due to 1.0P. E = operational base earthquake load E' = design base earthquake load	
Sec. 2.1.8, p. 5A-10, Appendix 5A Table A.1-1, p. A1-10, Appendix A1		p. 5A-13 Appendix 5-A Table 3.2, 4.1	p. 5.1.1-2 p. 5A-13, Appendix 5-A

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA				
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES		
Piping:	0.5/0.5	Analytical.		<u>Piping</u>	<u>Vessels</u>	Piping: ANSI B31.1-1955 ASME BPVC Sec. III-1965
			(1) Normal=D+T+P	$P \leq \sigma$	$P_m \leq S_m$ & $P_L \leq 1.5S_m$ $P_m \text{ (or } P_L) + P_B \leq 1.5S_m$	
			(2) Upset=D+T+P+E	$P \leq 1.2\sigma$	$P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$	
			(3) Faulted=D+T+P+E'	Design limit curves	$P_m \leq (1.25S_m)$ or S_y or $P_L \leq (1.25S_m)$ or $1.5S_y$ whichever is larger	
			(4) Faulted=D+T+P+PR	Design limit curves	$P_m \text{ (or } P_L) + P_B \leq 1.5(1.2S_m)$ or $1.5S_y$ whichever is larger	
			(5) Faulted=D+T+P+E'+PR	Design limit curves	For stress limit refer to Table A.1-3	
			D = dead load, T = thermal load, P = pressure load, E = OBE, E' = SSE			
			Table A.1-1, p. A.1-10 p. 4.2-8; p. 4.3-29			
			Table 4.10-6 & 10 p. 4.9-2			
			Table 4.10-6 & 10 p. 4.9-2			

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

[illegible]

SEISMIC REVIEW TABLE

Docket Number
50-333

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g				
CP/OL ISSUE DATE James A. Fitzpatrick Nuclear Power Plant Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Stone and Webster Engineering Corp. 5-70/10-74	0.08	.053	VIII	0.15	0.10	Articifical time- history used	SRSS	Housner	Time-history method.
	p. 2.6-1	p. 2.6-1		p. 2.6-1	p.2.6-1	Sec. 2.6 , p. 2.6-1	3 components. Results for earthquake in X and Y(vertical) directions simultaneously, and Z and Y directions simultaneously were computed separately. App. C 3.3 p. C.3-4	Sec. 12.5.1 p. 12.5-1	Sec. 2.6, p. 2.6-2 See Fig. 2.6-1 and Fig. 2.6-2 Sec. 12.5.4, p. 12.5-13

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat. 5'-9" thick embedded 45 ft. below top of bedrock in the surrounding area <									

SEISMIC REVIEW TABLE

STRUCTURES					
DAMPING OBE/SSE	(2% criti- cal damping)	DESIGN CRITERIA			
		LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Concrete structures	2.0/5.0	<u>L. C.</u> 1. Normal dead + live load	<u>Structural steel</u> AISC Code	<u>Concrete</u> ACI 318 working stress	Building code requirements ACI-318 (working stress de- sign)
Steel frame structures, Bolted and riveted assemblies	2.0/3.0	2. "1" + wind	1/3 increase of AISC	1/3 increase per ACI Code	Specific for structural con- crete ACI-301
Welded assemblies	1.0/1.0	3. "1" + OBE	Same as above	Same as above	Concrete chimneys ACI-307
Fluid containers	0.5/0.5	4. "1" + DBE	90% of yield	75% of ultimate	AISC
		5. Normal dead + tornado load	Same as above	Same as above	NY State Building Construction Code
		6. Normal dead + max. possible flood	Same as above	Same as above	
Sec. 12, Table 12.4-2		Table 12.4.3			Sec. 12.4.8 to 12.4-5

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping systems 0.5/1.0	Analytical	<p><u>Piping:</u></p> <ol style="list-style-type: none"> General membrane primary stress: $S_{LP} + S_{DL} \leq S_m$ Operating basis earthquake: M_R $S_{LP} + S_{DL} + S_{OBEQ} = S_{LP} + \frac{M_R}{SM} i \leq 1.8 S_m$ <p>where $M_R = \sqrt{(M_{x1} \pm M_{x2})^2 + (M_{y1} \pm M_{y2})^2 + (M_{z1} \pm M_{z2})^2}$</p> Design basis earthquake $S_{LP} + (S_{DL} + S_{TH} + S_{DBEQ}) = S_{LP} + \frac{M_R}{SM} i \leq 3 S_m$ <p>where</p> $M_R = \sqrt{(M_{x1} + M_{x2} \pm M_{x3})^2 + (M_{y1} + M_{y2} \pm M_{y3})^2 + (M_{z1} + M_{z2} \pm M_{z3})^2}$ <p> S_{LP} = Longitudinal Pressure Stress S_{DL} = Dead Load Stress S_{TH} = Thermal Stress S_{OBEQ} = Operating Earthquake Stress S_{DBEQ} = Design Earthquake Stress S_m = Allowable Stress at operating temperature </p> <p> i = Appropriate stress intensification factor SM = Section modulus </p>	<p><u>For piping:</u> ANSI B31.1.0 App. C.3.3, p. c.3-3</p> <p><u>Mechanical:</u> ASME BPVC Section III Subsection B, 1968 Edition and Addenda published to June 30, 1968.</p> <p>App. I.3.2.2, p. I.3-2</p>

Sec. 12, Table 12.4-2

Sec. 12.5.4,
p. 12.5-11

Section 12.5.4, p. 12.5-10 to p. 12.5-11

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT

DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number
50-348

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. s	VERT. s	INTENSITY MM	HOR. s	VERT. s					
CP/OL ISSUE DATE										
Joseph M. Farley Nuclear Power Plant Units I and II	0.05	0.033	VI	0.10	0.067	Synthesized time history.	3 compo- nents: Each horizontal combined with vertical component.	SRSS Closely spaced modes are combined absolutely	Modified Newmark curves.	Time history method.
Reactor type: PWR										
Containment type: 3 buttresses with shallow dome (prestressed con- crete)										
NSSS Manufacturer: Westinghouse										
Architect Engineer: Bechtel										
Unit I: 8-72/6-77	Sec.	Sec.	Sec.	Sec.	Sec.	Sec.	Sec.	Sec.	Sec.	Sec.
Unit II: 8-72/6-77	2.5.2.11	2.5.2.11	2.5.2.10 p. 2.5-33	2.5.2.10 p.2.5-33	2.5.2.10 p.2.5-33	3.7.1.2 p. 3.7-2	3.7.3.7 p. 3.7-14	3.7.3.3.4 p. 3.7-13	3.7.1.1 p. 3.7-1	3.7.2.1 p. 3.7-6

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G_s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V_p PROFILE						
Rigid mat foundation 9 ft. thick on Lisbon formation.	Upper residium. Lower residium. Moody's limestone Lisbon Formation	40 ft 30 ft 10 ft	Not available.	Approximately 55-65 ft below grade.	There are 13 dams upstream, 14 dams in area: Jim Woodruff, Columbia, Walter F. George, Eagle, City Mills, North Highlands, Oliver, Goat Rock, Bartlett's Ferry, Riverview, Langdale, West Point, Morgan Falls, and Buford Dams.	Stick model with soil springs.	Soils- 3,000-21,000 psi Lisbon- 50,000-970,000 psi	0.04 critical damping for OBE. 0.07 critical damping for SSE.	Not available.
Sec. 2B6.2 p. 2B-15 Sec. 3.8.1.1 p. 3.8-1	Sec. 2B.4.3.2 p. 2B-8	Sec. 2B.4.3.2 p. 2B-8		Sec. 2B.4.3.2 p. 2B-8	Fig. 2.4-14	Sec. 3.7.1.6 p. 3.7-3	Sec. 2B.7.2.2 p. 2B-20	Table 3.7-1	

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(X criti- cal damping)	DESIGN CRITERIA
		LOAD COMBINATION
Welded steel frame structures:	2.0/5.0	Design loading case:
Reinforced concrete structures plus equipment supports:	2.0/5.0	1. D+F+L (construction case)
Prestressed concrete structures:	2.0/5.0	2. D+F+L+T _o +E (or W) (operating case)
		3. D+F+L+P+T _e (design accident case)
		4. D+F+L+T _s +E (or W) (prolonged shutdown case)
		5. D+F+L+1.15P (test case)
		Factored loading case:
		1. $C=1/\phi(1.0D+1.5P+1.0T_a+1.0F)$
		2. $C=1/\phi(1.0D+1.25P+1.0T_a+1.25H+1.25E \text{ (or } 1.25W) +1.0F)$
		3. $C=1/\phi(1.0D+1.25H+1.0R+1.0F+1.25E \text{ (or } 1.25W) +1.0T_o)$
		4. $C=1/\phi(1.0D+1.25H+1.0F+1.25W_c+1.0T_o)$
		5. $C=1/\phi(1.0D+1.0P+1.0T_a+1.0H+1.0E'+1.0F)$
		6. $C=1/\phi(1.0D+1.0H+1.0R+1.0E'+1.0F+1.0T_o)$
Table 3.7-1		Sec. 3.8.1.3 p. 3.8-13
		ACI 318-63 AISC 1969 AEC Reg. Guides For further details refer to Section 3.8.1.2. Sec. 3.8.1.2 p. 3.8-3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping:	0.5/1.0	L. C. -Class 1 Components	<u>Stress Limits</u>	ASME, BPVC, Section III, Table 3.9-3
Welded steel plate assemblies:	1.0/2.0		Normal	"Design Criteria for Components not covered by ASME Code."
Bolted and riveted steel:	3.0/5.0		Upset	Ex. Heat exchangers - ARI 410-64
			Faulted	Fan AMCA Test Code 300-67, 211 A-67
Table 3.7-1	Sec. 3.7.2.1 p. 3.7-5 3.9-1, 3.9-24 3.9-3	p. 3.9-1, Table 3.9-1, Table 5.2-4, -5, -6, -7		Table 3.9-3 Section 3.9.2, 3.9.2

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Testing and analysis.	For electrical cable tunnels: (Dead load + live load + E.Q.) $0.75 \leq$ maximum allowable stress	IEEE 344-1971
	Sec. 3.10.1 p. 3.10-2	Table 3.8-14	Sec. 3.10.1,2 p. 3.10-2,3

SEISMIC REVIEW TABLE

Docket Number
50-305

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. 8	VERT. 8	INTENSITY MM	HOR. 8	VERT. 8					
CP/OL ISSUE DATE										
Kewaunee Nuclear Power Plant	0.06	0.04	V normal fo- cus shock within 7 miles of plant site.	0.12	0.08	Synthetic time history	Horizontal and vertical components	SRSS	Newmark method	Spectral method
Reactor type: PWR										
Containment type: Dry containment- cylindrical (steel)			VII normal fo- cus shock				Combina- tion not known			Blume report #JAB-PS-01 , JAB-PS-03
NSSS Manufacturer: Westinghouse										
Architect Engineer: Pioneer										
						</				

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	C _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Soil-bearing type (Raft-type formation)	Glacial till	60-150 ft	Shear wave velocity soil =2500 fps	Varies from 10-30 ft below ground surface	Not available.	Stick model with soil springs.	Glacial till G=1x10 ⁷ lbs/sq ft	5% critical damping OBE,SSE	Not available.
Concrete base slab	Glacial lacustrine deposits								
35 ft. depth of slab	Bedrock (Niagra dolomite)		350-600 ft				Shear wave velocity rock =11,500 fps		
App. E Sec. E.1-E.3 Fig. E.2-5	App. A p. 16	App. A p. 16	App. A p. 16	App. A p. 11		App. B Sec. B.6.3 p. B.6-5	App. A p. 26 - Table 7	App. B Table B.6-5	

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor Containment vessel	1.0/1.0	Normal operating Dead+live+wind+snow OBE Dead+live+DBA+snow+greater of the OBE or wind DBE Dead+live+snow+DBA+DBE Tornado Dead+live+300 mph design tornado+tornado missile, if any	ACI 318-63
Shield building	2.0/2.0		
Reactor containment vessel internal concrete	5.0/5.0		
Steel frame structures	2.0/2.0		
Reinforced concrete construction	2.0/2.0		
App. B Table B.6-5		Table B.6-1	App. B Table B.6-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping systems Mechanical Equipment	0.5/0.5 2.0/2.0	Analytical or Tests.	<div><div>Pressure Vessels</div><div>Piping</div></div> <div>Normal condition: (a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$ Upset condition: (a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.5S_m$ (c) $P_m \text{ (or } P_L) + P_b + Q \leq 3.0S_m$ Emergency condition: (a) $P \leq 1.2S_m \text{ or } S_y$ (b) $P_m \text{ (or } P_L) + P_b \leq 1.8S_m$ or $1.5S_y$ Faulted condition: (a) Stainless steel: design limit curve (b) Carbon steel: (i) $P_m = 1.5S_m \text{ or } 1.2S_y$ (ii) $P_m \text{ (or } P_L) + P_b \leq 2.25S_m$ or $1.875S_y$</div> <div>$P \leq S$ <</div>	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Analysis	<p>"Electrical equipment and its supports were designed to be sufficiently rigid so that its natural frequency will be out of the range of resonance with the building structure".</p> <p>B.7-10C</p>	Not available

SEISMIC REVIEW TABLE *

Docket Number

50-409

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
La Crosse (Genoa) Nuclear Generating Station Reactor type: BWR Containment type: Pre-Mark (steel) NSSS Manufacturer: Allis Chalmers, Manufacturing Co. Architect Engineer: Sargent and Lundy Engineers 3-63/7-67	.06	.04	VI	.12	.08	Taft 1952 record chosen as initial accelerogram. A ground time-history which envelops the 2% damping curve of R.G. 1.60 was gene- rated for analysis of major structures such as the containment.	Horizontal only for RCB Maximum horizontal spectra (x or z direction) are added simultan- eously with the vertical for major piping and equipment.	SRSS for equipment and piping (R.S.) Algebraic sum for reactor bldg. (time his- tory method.)	R.G. 1.60 used as basis to develop response spectra from Taft earth- quake. (not specifi- cally stated as such but curves are those of R.G. 1.60)	No vertical response spectra generated, instead use 2/3 of horizontal ground response spectra. Horizontal re- sponse spectra derived from time history analysis. Reanalysis of Mechanical and Piping, 1975-77, No amplification of vertical response.
	Sec. 2.4	Sec. 2.4	Sec. 2.4	Sec. 2.4	Sec. 2.4					

*Information was obtained from BNL Docket search and SEP8 Report "Seismic Review of La Crosse BWR Phase I Report."

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Pile foundation 232 piles will support 50 tons each	15 ft. of hydraulic fill overlies about 100-130 ft. of glacial outwash and fluvial deposits at the site. Bedrock of flat-lying sandstone and shale of the	Dresbach group extends below these deposits about 650 ft. where it makes contact with the crystalline basement.	Not available	Not available	Not avail-able	Lumped-mass for structure soil-spring and dashpot deconvolution process used; soil layers modeled as shear beam (2% damping used)	Not available	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES				
	DAMPING OBE/SSE	(% Critical damping)	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor Containment	$\frac{1}{2}$ SSE 3.0 up	SSE 7.0 up	Structural Steel - Elastic: Construction: $1.0 D + 1.0 L + 1.0 T + W < 1.33 \text{ AISC (1969)}$ Test: $1.0 D + 1.0 L + 1.0 T + 1.0 R_o < 1.33 \text{ AISC (1969)}$ Normal: $1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o < \text{AISC}$ Severe Environmental: $1.0 D + 1.0 L + 1.0 T + 1.0 R + E < \text{AISC}$ Extreme Environmental: $1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o + E' < 1.6 \text{ AISC}$	Allowable structural Capacities for RCB, Two stacks, turbine building waste disposal building:
Turbine building		7.0		
Stacks		7.0 up		
New diesel genera- tor building	4.0	7.0	R/C - strength design: Construction: $1.1 D + 1.3 L + 1.3 T_o + 1.3 W$ Test: $1.1 D + 1.3 L + 1.3 T_o + 1.3 R_o$ Normal: $1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o$ Severe Environmental: $1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o + 1.3 W$ $0.9 D + 1.3 T_o + 1.3 R_o + 1.3 W$ $1.4 D + 1.7 L + 1.3 T_o + 1.3 R_o + 1.4 E$ $0.9 D + 1.3 T_o + 1.3 R_o + 1.4 E$ Extreme Environmental: $1.0 D + 1.0 L + 1.0 T_o + 1.0 R_o + 1.0 E'$ Section 3.7.1; Table 4.5-1 and 4.5-2	Concrete: $\frac{1}{2}$ SSE SSE Moment M_u $0.63 M_u$ Shear V_u $0.60 V_u$ Steel Moment $0.66 M_y$ M_y Shear $0.40 V$ $0.53 V$

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Piping $\frac{1/2 \text{ SSE}}{1.0}$ $\frac{\text{SSE}}{2.0}$	Not available	<u>M.S. Piping:</u> Load conditions from NB-3110, 3620 <u>Design:</u> (Primary) $P_o + DL + E < 1.5 S_M$ <u>Normal:</u> (Primary and secondary) $T + P + SA + TA + E < 3 S_M$ <u>Upset:</u> Same as for <u>normal</u> condition <u>Emergency:</u> (Primary stress) $< 2.25 S_M$ <u>Faulted:</u> $P_o + DL + E < 3.0 S_M$ (Main steam piping and feedwater piping designed as Class 2 since fatigue loads not considered). Follows R.G. 1.48, EQ 8,9,10,11 of ASME Code	Piping: AEC Reg. Position 1 and Subsection NB-3600 of Section III of ASME B&PV Code	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number

50-309

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Maine Yankee Atomic Power Company Reactor type: PWR Containment type: Sub-atmospheric (Reinforced concrete) NSSS Manufacturer: Combustion Engineer- ing Architect Engineer: Stone & Webster Engineering Corp.	0.05	0.033	VI	0.10	.067	No earthquake time- history used.	Each hori- zontal combined with the vertical resulting in two load cases. The method of com- bination is un- clear.	No combin- ation used flexural mode used only.	Housner spectra	Empirical procedure used for piping to provide amplified response spectra. For equipment and anchors used equi- valent static load method or Housner response spectra. Amendment 22 (4-71) Q. 4.4 Q. 4.5 Method used de- scribed in Section 5.1.1.2.2 p. 5-6
10-68/9-72	Sec. 1.3.2 p. 1-6	Sec. 1.3.2 p. 1-6		Sec. 1.3.2 p. 1-6	p. 1-6	Amendment 20 (3-71) Q. 4.5	p.5-3	p. 5-6	Sec. 2.5.4 p. 2-27 Figs. 2.5.6 and 2.5.7	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Flat reinforced concrete slab bearing on bedrock with a central reactor vessel pit. 10 ft. thick	Major structure Hard crystal-line bedrock Minor structure on rock or compacted granular fill above the rock.	Joints in bedrock are medium spaced, ranging from 1 to 5 ft intervals or and less.	7,000 fps	Dug wells: less than 25 ft deep. Drilled wells: depth of 100 ft or more.	Not available.	Translational & Rocking modes were not incorporated in the dynamic model.	1.80x10 ⁶ -2.06x10 ⁶ psi	Not available.	Not available.
Sec. 5.1 p. 5-1	Sec. 2.4 p. 2-23	Sec. 2.4 p. 2-23	Sec. 2.4 p. 2-23	Sec. 2.3.3 p. 2-22		Sec. 5.1.1.2.2 p. 5-6	Sec. 2.4 p. 2-23		

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reactor containment.	5.0/7.0	1. $(1.0+0.05) D + 1.5 P + 1.0 (T+TL)$ 2. $(1.0+0.05) D + 1.25 P + 1.0 (T+TL) + 1.25 E$ 3. $(1.0+0.05) D + 1.0 T + 1.0 C$ 4. $(1.0+0.05) D + 1.0 P + 1.0 (T+TL) + 1.0 E'$	Containment: Ultimate strength methods ACI 318-63, Sec. 1504, Part IV B or the Ultimate Strength Design Handbook ACI Special Publication No. 17.
2. Reinforced concrete structure, other than containment (on rock or soil).	5.0/7.0		
3. Reinforced concrete structure (not on soil or rock).	2.0/5.0	D = dead load P = design pressure load TL = load by exposed liner T = temperature gradient load E = OBE E' = SSE	
4. Steel framed structure Bolted or riveted Welded	3.0/5.0 1.0/2.0		
5. Reactor vessel Welded assemblies Bolted assemblies	1.0/1.0 3.0/3.0		
Table 2.5-1		Section 5.1.1.2, p. 5-2	Section 5.1.1.2, p. 5-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION *		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Mechanical equipment.	2.0/2.0	Analytical	Reactor vessel internal structure	ASME BPVC, Section III
2. Piping.	1.0/2.0		1. Design loading + OBE $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$ 2. Normal Operating + SSE $P_m \leq S_D$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_D})^2] S_D$ 3. Normal Operating + SSE + pipe rupture $P_m \leq S_L$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_L})^2] S_L$ Where: $S_L = S_y + (1/3)(S_u - S_y)$ $S_D = 1.2 S_m$	
Amendment 20 (3-71) Q. 4.9, Table 2.5-1	Amendment 22 (4-71) Q. 4.8		Piping Applicable code allowables 1. Design load + OBE $P_m \leq S_D$ $P_B \leq \frac{4}{\pi} S_D \cos(\frac{\pi}{2} \frac{P_m}{S_D})$ 2. N.O. + SSE $P_m \leq S_L$ $P_B \leq \frac{4}{\pi} S_L \cos(\frac{\pi}{2} \frac{P_m}{S_L})$ 3. N.O. + SSE + pipe rupture	p. 3-4, 4.2-4

*For reactor internals: Table 3.2-1, p. 3-4
Vessels and piping: Table 4.2-3, p. 4.2-4

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE *

Docket Number

50-245

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Millstone Point Nuclear Power Station Unit 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Ebasco	0.07	0.05	VII	0.17	0.113	Taft 69° west earth- quake record (Blume response spec- trum is more con- servative than Taft response spectrum)	Horizontal and verti- cal (X+Y,Z+Y) The resulting seismic stress for the two motions were com- bined linearly.	No modal combina- tion needed for time his- tory. Un- clear in- formation for re- sponse spectrum method.	Housner	<u>Equivalent Static Method</u> - for intake structure, turbine bldg., main steam lines, Class I piping in reactor and turbine bldg., batteries and battery racks. <u>Time History Method:</u> Reactor bldg., ventilation stack, radwaste/control room, condensate storage tank <u>Response Spectrum</u> Gas turbine bldg., recirculation loop piping, torus, RPV, isolation condensor, fuel racks
5-66/10-70	Sec. XII p. XII- 1.7	Sec. XII p. XII- 1.7		Sec. XII p. XII- 1.7	p. XII- 1.7	Q VII - A.9 and Q VII - A.10 Amend. 17	Sec. XII p. XII- 1.7		Fig. XII-1.2 Fig. XII-1.3 Sec. XII p. XII-1.7	p. XII-1.12

Information obtained from BNL Docket Search and SEPB Report,
"Seismic Review of Millstone Nuclear Power Station, Unit 1"

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete square mat (42'-6") and six feet of thickness at elevation of 32'-0". The foundation is supported directly on the bedrock. Gas turbine building founded on piles. Turbine build mat foundation on piles.	not applicable	not applicable	14,000 fps Sec. XII-p. XII-1.13	Not available	None	Lumped mass with soil springs (for reactor bldg. only). Rocking mode was considered for reactor bldg. Fixed base without rocking for other major structures. Sec. XII p. XII-1.2.1	Not available	Not available	Not available

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% critical damping)		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reinforced concrete structures	5.0	1. D + R + E - Normal allowable code stresses are used in AISC and ACI increase in design stress for earthquake loads is not permitted.	1. AISC 2. ACI Code
2. Steel frame structures	2.0	2. D + R + E' - Stresses are limited to the minimum yield point. In few cases, stresses may exceed yield pt. then in this case the limit-design method as discussed in AEC publication TID -7024 "Nuclear Reactor and Earthquakes", Section 5.7, to determine that the energy absorption capacity exceeds the energy input.	
3. Welded assemblies	1.0		
4. Bolted and riveted assemblies	2.0		
5. Ventilation stack	5.0		
6. Radwaste Bldg., Control room	5.0		
7. Condensate storage tank	0.5(fluid) 2.0(tank)		
8. Gas Turbine Bldg.	5.0		
		D = Dead load R = Jet force or pressure due to rupture of any one pipe E = Design earthquake load E' = maximum earthquake load Sec. XII - 1.12	Table XII-1
		1. DL + LL + OL + E (.07g)	
		2. DL + LL + OL + W	
		3. DL + LL + OL + E'(.17g)	
Sec. XII and Table VII - A.14-1, p. XII-1.7 Q.A.14, Amend. 17		Table XII -1 p. XIII - 1.3	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Vital Piping System 0.5 Sec. XII p. XII-1.7	Analytical	<u>Reactor Vessel Internals</u> 1. D + E Stress criteria of ASME Section III, Class A vessel 2. D + E' The secondary and primary plus secondary stresses are examined on a rational basis taking into account elastic and plastic strains.	ASME Section III, Class B USAS - B31.1-1967
2. Containment heat exchange 2.0			
3. RPV 2.0			
4. Recirculation loop piping 0.5		<u>Emergency Core Cooling Systems</u> 1. D + T + H + E Stresses remain within code allowable. USAB-B 31.1 plus code cases (piping)	
5. Suppression chamber 2.0		2. D + T + H + E' Primary stresses are within the stress criteria of ASME Section III, Class A. The secondary and primary plus secondary stresses and examined on a rational basis taking into account elastic and plastic strains. These strains are limited to preclude failure by deformation.	
		<u>Primary Containment</u> 1. D + P + H + T + E D =Dead load 2. D + P + R + H + T + E P =Pressure due to LOCA 3. D + P + R + H + T + E R =Jet-force or pressure on structure due to rupture of any one pipe H = Force on structure due to thermal expansions of pipes T = Thermal loads on containment due to LOCA E = Design E.Q. load; E' = maximum E.Q. load	Sec. XII Question A.14, Amend 17 Table XII-1

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE TRESSES
Not available	Not available	Battery racks and batteries were designed to withstand lateral and vertical seismic loads of 0.12g horizontal and 0.046g vertical	Not available

SEISMIC REVIEW TABLE

Docket Number
50-336

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
CP/OL ISSUE DATE Millstone Nuclear Power Plant Unit 2 Reactor type: PWR Containment type: 3 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Combustion Engineer- ing Architect Engineer: Bechtel 12-70/9-75	0.09	0.06	VII	0.17	0.11	Synthetic time- history	3 compo- nents: Each hori- zontal combined with vertical component simultane- ously.	Absolute sum method.	Separate sets of design spectra were developed for rock foundation and backfill. Housner for rock foundation. Modified Newmark for backfill	Time history method.
	Sec. 5.8.1.1 p. 5.8-1	Sec. 5.8.3.2.2 p. 5.8-8	Amend. 39 Sec. 2.6	Sec. 5.8.1.1 p. 5.8-1	Sec. 5.8.3.2 p. 5.8-8	Sec. 5.8.1.1 p. 5.8-1 Fig. 5.8-6	Sec. 5.8.4 p. 5.8-11	Sec. 5.8.3.2.1.1 p. 5.8-7	Sec. 5.8.1 p. 5.8-1 Fig. 5.8-1,2 Fig. 5.8-3,4	Sec. 5.8.4 p. 5.8-11

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	C _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reactor building mat rests on unweathered rock. Depth: 8½ feet Sec. 2.7.5 p. 2.7-3 Sec. 5.2.1 p. 5.2-1	Glacial deposits: Ablation till and a dense basal till which lies above the bedrock. Bedrock consist of Monson gneiss intruded by westerly granite. Sec. 2.4 p. 2.4-4 p. 2.4-5	Glacial deposits: 0 to 30 ft Bedrock: 11 to 54 ft below ground. Sec. 2.4 p. 2.4-4 p. 2.4-5	5500-7500 fps in bedrock. Sec. 2.4.4 p. 2.4-9	Little or no ground water is present in bedrock. So virtually all ground water is restricted to the soil overburden. Water level is subjected to considerable seasonal fluctuations. Sec. 2.5.2 p. 2.5-2 Fig. 2.4-2c, 2d	Not available.	Backfill: Stick model with soil springs. Bedrock: Stick model with fixed base. Sec. 5.8.2 p. 5.8-3,4	Not available.	2%/5% Table 5.8-1 p. 5.8-9	2% Sec. 5.8.3.3 p. 5.8-10

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel plate assemblies:	1.0/1.0	a. D+F+L	Construction case
Welded steel framed structures:	2.0/2.0	b. D+F+L+T _o +E	Operating case
Bolted or riveted steel framed structures:	2.5/2.5	c. D+F+L+P+T ₁	Design incident case
Reinforced concrete equipment supports:	2.0/3.0	d. D+F+L+T _g +E	Prolonged shutdown case
Reinforced concrete frames and buildings:	3.0/5.0	e. D+F+L+1.15P	Test case
Prestressed concrete structures:	2.0/5.0	D = dead loads	ACI-318-63
		L = live loads	ACI-301-66
		F = prestressing loads	ASME, BPVC (1968)
		P = design pressure	AISC, 1963
		T ₁ = thermal loads due to the loss of coolant incident	
		T _o = thermal loads due to operating temperature	
		T _g = thermal loads due to transient wall temperature over a prolonged shutdown (20 F at exterior face, 70 F at center, 50 F at interior face)	
		E = operating basis earthquake loads (0.09 g)	
		For further details refer to Section 5.2.3.2.5.	
		Sec. 5.2.3.2.4	
		p. 5.2.8	
Table 5.8-1, p. 5.8-9			Sec. 5.1.2 p. 5.1-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE	(% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Steel piping:	0.5/0.5	Analytical and testing.	<p>Reactor coolant system (vessels):</p> <p>1. Design loading + OBE</p> $P_m \leq S_m$ $P_b + P_L \leq 1.5 S_m$ <p>2. Normal operation + SSE</p> $P_m \leq S_m$ $P_b \leq 1.5 \left[1 - \left(\frac{P_m}{S_D} \right)^2 \right] S_D$ <p>3. Normal operation + SSE + pipe rupture</p> $S_L = S_y + (1/3) (S_u - S_y)$ <p>R.C.S. (Piping)</p> <p>1. Design loading + OBE</p> $P_m \leq S_m$ $P_b + P_L \leq 1.5 S_m$ <p>2. Normal operation + SSE</p> $P_m \leq S_m$ $P_b \leq 4/\pi S_D \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$ <p>3. Normal operation + SSE + pipe rupture</p> $P_m \leq S_L$ $P_b \leq 4/\pi S_L \cos\left(\frac{\pi}{2} \cdot \frac{P_m}{S_D}\right)$	<p>Piping--</p> <p>ANSI B 31.7</p> <p>ANSI B 31.1.0</p> <p>Sec. 1.2.14, p. 1.2-21 and</p> <p>Sec. 4.5.2.1, p. 4.5-5</p> <p>Pressure vessels--</p> <p>ASME, BPVC, p. 1.2-19 and</p> <p>Sec. 4.5.2.2, p. 4.5-5</p>
Sec. 5.8.3.3 p. 5.8-9		Sec. 5.8.5 p. 5.8-12	See Table 4.2-2, p. 4.2-3. For mechanical see Sec. 3.2.1, p. 3.2-1 to 3.2-5.	

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number
50-263

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. s	VERT. s	INTENSITY MM	HOR. s	VERT. s					
CP/OL ISSUE DATE										
Monticello Nuclear Generating Plant, Unit 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel 										

Analysis
p-6

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE *	THICKNESS	V _s PROFILE						
Reinforced concrete mat/ founded on medium sand with some gravel. Sec. 2.2.1.1 p. 12-2.13	Decomposed granitic and basic rocks of precambrian age comprise the formation. 75 to 122 ft.		Not available.	The water table beneath the low terraces which border the Mississippi River usually lies at about river elevation and slopes very slightly toward the river during periods of normal stream flow. Groundwater at shallow depths moves toward the Mississippi River or its tributaries at variable gradients depending on local conditions. Sec. 5.4, p. 2-5.3 and Fig. 2-5-3	Not available.	Stick model with soil springs. Append. A. at Seismic Analysis Part p. 2	Not available.	Not available.	10.0% of critical damping. Append. A Table 1 p.8
	Wethered precambrian crystalline rocks are directly below the above strata. 10 to 15 ft.							App. A Sec. 2.1.9 p. 12-2.8	
	Above the sandstone is a series of alluvial strata consists predominantly of clean sands with gravel, as well as a few layers of clay and gracial till. 50 ft.								

Sec. 5.3, p. 1-5.2, *Because of space Type and Thickness columns are combined together.
p. 2-5.3

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% criti- cal damping)		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Recommended damping:		1. Primary containment a. D + P + H + T + OBE b. D + P + R + H + T + OBE c. D + P + R + H + T + SSE	AISC - Sixth Edition ACI - 318-63 ASME CODE Sec. III and IX ACI 505-54 for R. C. Chimney
Reactor-building (massive construction with many cross walls and equipment and providing only secondary containment)	5.0	2. Reactor building and all other Class 1 structure a. D + R + OBE b. D + R + SSE c. D + W d. D + W'	
Thin-shell and prestressed concrete	2.0		
Steel structures	2.0		
Ref. Append. A., Table 1. p.8		Sec. 2.1.4, p. 12-2.3 and 12-3.6	Sec. 2.1.4, NSP-1, p. 12-2.6 Table 12-2-1 Sec. 2-1.4, p. 12-2.4 and p. 12-2.5

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping: Vital Damping System 0.5	Analytical	3. Reactor vessel supports a. D + H + R + OBE b. D + H + R + SSE 4. Reactor vessel internals a. D + O.B.E. b. D + S.S.E. c. D + P 5. Emergency core cooling system (ECCS) a. D + O.B.E. b. D + S.S.E. <hr/> For piping: Suction header pipe: Dead loads + seismic loads + OBE = 820 psi } allowable Dead loads + seismic loads + SSE = 1640 psi } stress is 17,500 psi	ASME Sec. III and USAS B 31.1-1967
Append. A, Table 1, p. 8	Sec. 2.1.9, p. 12-28	Sec. 2.1.4, p. 12-2.3-12.2.6 p. 12-2.11	Sec. 2.1.4., p. 12-2.5 and p. 12-2.6

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	<p>Inspection and testing for:</p> <ol style="list-style-type: none"> 1. Auxiliary Power System 2. Plant standby generator systems. 3. D-L Power supply systems. 4. Reactor protection system power supplies. <p>Sec. 8 p. 8.3-5 p. 8.4-4 p. 8.5-6 p. 8.6-2</p>	Not available.	<p>For diesel-generator set:</p> <p>Equipment shall conform to applicable standards of the NEMA, ASA, DEMA, ASME, NBFW, NIPA, ASTM, IEE, USASI and state and local regulations.</p> <p>Sec. 4.1 p. 8-4.1</p>

SEISMIC REVIEW TABLE

Docket Number
50-220

NAME AND NSSS TYPE OF THE PLANT CP/OL ISSUE DATE	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Nine Mile Point Nuclear Station Unit No. 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Stone & Webster Engineering Corp. 4-65/8-69	Not used	Not used	IX PHSR III-1	0.11 PHSR III-1	0.055 Amend- ment 6, Supp. 2, Ques- tion I-11	Not used	Not avail- able.	SRSS Amend. 6, Supp.2, Question I-2.	Housner PHSR VI-22 App. c	Analysis by Reserve Energy- Technique, by John Blume PHSR III-1

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
All major structures founded on Oswego sandstone. Reactor bldg. is founded in rock to a depth of 60 ft. 									

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSR	(1/2 criti- cal damping)	DESIGN CRITERIA
		LOAD COMBINATION
critical damping for integral reinforced- concrete structures.....	5.0	Reactor bldg. Waste disposal bldg. screen and pump house drywell radial steel framing: DL + LL + OL + Design Earthquake
critical damping for ventilation stack...	7.5	Reactor vessel concrete pedestal DL + Equipment Load + Temp. (operating) DL + Equipment Load + Jet Load + Temp. + Design Earthquake
Details: First supplement to PHSR in answer to question III-1(d)		See Table I-4 for 10 load combinations for the drywell
Amendment 6, Supp. 2, Question I-5		Supplement 2, question I-4, question I-9
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		1. ACI-318-63 2. For proportioning of concrete members: Part IV-A "Working stress design" of Code 318-63. 3. Reinforced-concrete ventilation stack: ACI 505-54 4. AISC specifications for the design, fabrication and erection of structural steel for building. 5. New York State Building Code 6. UBC
		Amend. 6, Supp. 2, Question I-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	<p>Core spray piping and sparger ring located in the reactor vessel: Equations given in ASME Section III.</p> <p><u>Drywell</u> - ASME Sect. VIII plus Code Case 1270N-5, 1271N, 1272N-5</p> <p>Amend. 5-Supp 1 (5/20/68) Question II-12.</p>	<p>1. "Method of Differences"</p> <p>2. Reactor internals: ASME Code Class A</p> <p>1. Amend. 6, Supp. 2, Question I-10</p> <p>2. Amend. 5, Supp. 1 FSAR Question I-5</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OSE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-338

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
North Anna Power Station Unit 1	0.06g for struc- tures on rock	0.04g for struc- tures on rock	VII	0.12g for struc- tures on rock	0.08g for struc- tures on rock	E-W and N-S compo- nents of Helena, Montana 1935 earth- quake, and the S-E component of the San Francisco 1957 earthquake.	2 components: Horizontal plus ver- tical added simultan- eously	SRSS	Developed from Helena 1935 and San Francisco 1957 by enveloping the response spectra shown in Fig. 2.5-9 thru Fig. 2.5-12.	Time history method.
Reactor type: PWR	0.09g for struc- tures on soil	0.06g for struc- tures on soil		0.18g for struc- tures on soil	0.12g for struc- tures on soil					
Containment type: Sub-atmospheric (reinforced con- crete)										
NSSS Manufacturer: Westinghouse										
Architect Engineer: Stone and Webster										
2-71/11-77	p. 1.2-2 1.2-3	p. 1.2-2 p. 1.2-3		p. 1.2-2 1.2-3	p.1.2-2 1.2-3	p. 2.5-9	p. 3.7-10	Sec. 3.7	p. 2.5-9	Sec. 3.7

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Flat reinforced concrete mat 10 ft. thick. Founded on concrete backfill.	Saprolite soil weathered rock	Not available.	Not available.	Not available.	North Anna Reservoir	Stick model with soil springs.	Fresh and slightly weathered rock $G = 1.0 \times 10^6$ psi Soils @ 10 ft. depth 14,000 psi @ 20 ft. depth 19,800 psi	Not available.	Not available.
p. 1.2-2 p. 2.5-17	p. 2.5-12				Sec. 2.4. 1.1	Sec. 3.7 p. 2.5-9	p. 2.5-24		

SEISMIC REVIEW TABLE

STRUCTURES				
DAMPING OBE/SSE			DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Stress Level	Type & Condition of Struct, Syst. or Component	Percentage Critical Damping	Containment Structural Loading Criteria:	
1. Low Stress, well below proportional limit. Stresses be- low 0.25 yield point.	a. Steel, reinforced concrete; no crack- ing and no slipping at joints.	0.5 to 1.0	$(1.0 \pm 0.05) D \pm 1.0 P \pm 1.0 (T + TL) + 1.5 E$ $(1.0 \pm 0.05) D \pm 1.0 P \pm 1.0 (T + TL) + 1.0 (DBE)$ $(1.0 \pm 0.05) D + 1.25 P + (T' + TL') + 1.25 E$	AISC Manual ACI 301-66 ACI 318-63
2. Working stress limited to 0.5 yield point stress	a. Welded steel, well reinforced concrete (with only slight cracking) b. Bolted steel	2.0 5.0		
3. At or just below yield point	a. Welded steel b. Reinforced con- crete c. Bolted steel	5.0 5.0 7.0		
Table 3.7.2-1			p. 3.8-87, Table 3.8.2.2-1	p. 3.7-49 3.8-17

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Piping 0.5/1.0	Analysis and Testing	<p>ASME Class 1 Piping: based on Subarticle NB-3650</p> <p><u>Class A Components</u></p> <p>1) Normal a) $P_m \leq S_m$, b) $P \leq 1.5 S_m$, c) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ d) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$</p> <p>2) Upset a) $P_m < S_m$, b) $P_L \leq 1.5 S_m$ (SIC) c) $P_m \text{ (or } P_L) + P_B + P_B \leq 1.5 S_m$ d) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$</p> <p>3) Faulted i) $P_m \leq 1.2 S_m$ or S_y whichever is larger, AND $P_m \text{ (or } P_L) + P_B \leq 1.5 (1.2) S_m$ or $1.5 S_y$ whichever is larger ii) Table 5.2-15</p>	<p>ANSI B31.7-1969 ASME BPVC Sec. III</p>

p. 3.7-23

p. 3.7-46,47
p. 3.7-22

p. 3.7-30, p. 5.2-46, T 5.2-15

p. 3.1-101
p. 3.7-49

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
NOT AVAILABLE	Analysis and testing	NOT AVAILABLE	IEEE Standard 344-1971
	p. 3.10-1		p. 3.10-1

SEISMIC REVIEW TABLE

Docket Number
50-269, 270, 287

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Oconee Nuclear Station Unit Nos. 1,2,3 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Babcock & Wilcox Architect Engineer: Utility & Bechtel Unit #1: 11-67/2-73 Unit #2: 11-67/10-73 Unit #3: 11-67/7-74	0.05 for rock foundation	0.03	VI	0.10 for rock foun- dation. 0.15 for over- burden foun- dation.	0.07	Time history record of the N-S, May 1940 El Centro Earthquake was used (vertical and N-S horizontal components) at 0.01 sec intervals for the first 30 sec of dura- tion.	3 com- ponents: Each hori- zontal combined with the vertical simultane- ously.	Absolute sum	R-S smooth curve with max. accelera- tion of .15g @ 2% damping. Housner.	Time-history method.
									</	

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete foundation slab. Depth = 8½ feet thick. Founded on bedrock.	Banded biotite hornblende gneiss and granite gneiss. The surface has weathered unevenly and the residual soils grade down irregularly.	Sound Rock is found at depths of 5-40 feet	Not available in FSAR	Not available in FSAR.	"Design of Keowee and Jocassee Dam" Refer to PSAR p. 2.4.3 and Question 8.6-PSAR Supp. 1, Question 12.1-PSAR Supp. 4, Question 12.2-PSAR Supp. 4, Item 11-PSAR Supp. 5, Item 1-PSAR Supp. 6.	Stick model with soil springs.	Not available	in FSAR.	2% OBE 5% SSE
Sec. 5.1.2.1 p. 5-2			Refer to Sec. 2.5 and Sec. 2.6 p. 2-8 in PSAR	Refer to PSAR 2.4.4 Sec. 2.4.5 p. 2-8	Sec. 2.4.4 p. 2-8	Sec. 5.1.3.2 p. 5-18	Refer to Sec. 2.5, p. 2-8, in PSAR	and Sec. 2.6 2-9	p. 5-12 Fig. 5-10

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded carbon and stainless steel assemblies:	1.0	$Y=1/\phi(1.0D+1.0P+1.0T+E')$ $Y=1/\phi(1.05D+1.25P+1.0T+1.25E \text{ or } W)$	ACI 318-63 ACI 301
Steel framed structures:	2.0	$Y=1/\phi(1.05D+1.5P+1.0T)$ $Y=1/\phi(1.0D+1.0W_t+1.0P_1)$ for tornado forces	ASME, PVBC, Sec. III, VIII, IX
Reinforced concrete equipment supports:	2.0	Y=required yield strength of structure D=dead loads P=design accident pressure T=thermal load E=seismic load based on design earthquake E'=seismic load based on maximum hypothetical earthquake W=wind load P ₁ =stress due to differential pressure φ=capacity reduction factor	
Reinforced concrete frames and buildings:	5.0		
Prestressed concrete structures (i) under design earthquake forces	2.0		
(ii) under maximum hypothetical earthquake	5.0		
Sec. 5A.2.2 p. 5A-3		For further details refer to Sec. 5A.2.2, p. 5A-2	Sec. 5.1.2.1 p. 5-4

SEISMIC REVIEW TABLE

MECHANICAL & PIPING

DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping: Sec. 5A.2.2 p. 5A-3	0.5	Analytical	<p>(A) piping:</p> <p>I. Design loads + design earthquake loads $P_m \leq 1.0S_m$ $P_L + P_b \leq 1.5S_m$</p> <p>II. Design loads + maximum hypothetical earthquake loads $P_m \leq 1.2S_m$ $P_L + P_b \leq 1.2(1.5S_m)$</p> <p>III. Design loads + pipe rupture loads $P_m \leq 1.2S_m$ $P_L + P_b \leq 1.2(1.5S_m)$</p> <p>IV. Design loads + maximum hypothetical earthquake loads + pipe rupture loads $P_m \leq 2/3S_u$ $P_L + P_b \leq 2/3S_u$</p> <p>P = Primary local membrane stress intensity P_L = Primary bending stress intensity P_b = Primary general membrane stress intensity S_m = Allowable membrane stress intensity S_u = Ultimate stress</p> <p>p. 4-4</p> <p>For piping: Nuclear power piping code USAS B31.7, Sec. 1C.3, p. 1C-3</p> <p>Mechanical components: -ASME, Sec. III for nuclear vessels. -S_m values Table N-421 of ASME code.</p> <p>Sec. 4.1.2.5.1 Sec. 4.1.2.5.2 p. 4-3</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Analytical and tests.	Not available.	No detailed information available. Refer to Table 8.8 for some seismic considerations.

Table 8.8
p. 8-36

p. 8-36

SEISMIC REVIEW TABLE *

Docket Number
50-219

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	ORE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Oyster Creek Nuclear Power Station Unit 1 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Burns & Roe, Inc.	0.11	0.073	VII	0.22	0.147	Not used	2 components: Horizontal and vertical added directly and linearly for: Reactor building. Control room/turbine building, rad. waste building. Horizontal only for intake structure.	SRSS	Housner spectra used for analysis of reactor building, ventilation stack, control room, rad- waste bldg. Equivalent static method for intake structure, suction header, spent fuel pool	No floor response spectra: Seismic Design curves for FWCI piping and equip- ment.
12-64/4-69	Sec. V.3 p. V-3-1	Sec. V.3 p. V-3-5		Sec. V.3 p. V-3-5	Sec. V.3 p. V-3-5			Amend.11 Quest. IV-2-1	Question IV. 2 Amend. 11, Sec. V-3-1.2, FDSAR, Sec. 3.5.1	p. 5-11, 12 Amend. 38

*Information from BNL Docket search and SEP-B Report "Seismic Review of
Oyster Creek Nuclear Power Plant for SEP"; Phase I Report.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Mat foundation Grade: + 23 ft MSL Foundation: -11 ft MSL 									

SEISMIC REVIEW TABLE

STRUCTURES				
DAMPING OBE/SSE (% critical damping)		DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Reinforced concrete structures (reactor building)	10.0	Reactor building., Control Room., Battery Room., Intake Structure.* 1. DL + LL + OL + E (0.11g) 2. DL + LL + OL + W 3. DL + LL + OL + E' (0.22g)	Reinforcing Steel Max. Tension 1. $0.5 F_y$ 2. $0.667 F_y$ 3. $0.90 F_y$	Concrete Max. Allowable Compression $0.45 f'_c$ $0.60 f'_c$ $0.90 f'_c$
steel frame structures	2.0			
welded assemblies	1.0			
bolted and riveted assemblies	2.0	Reactor Concrete Pedestal** 1. DL + equipment + jet load + temperature + OBE 2. DL + equipment + jet load + temperature + SSE	1. $0.25 F_y$ 2. $0.25 F_y$	$0.133 f'_c$ (bending) $0.267 f'_c$ (bending)
reinforced concrete stack	5.0	Drywell Concrete Shield*** 1. DL + LL + over pressure + max. temp. + OBE 2. DL + LL + over pressure + max. temp. + SSE 3. DL + LL + max. temp. + OBE + jet force	1. $0.50 F_y$ 2. $0.50 F_y$ 3. $0.667 F_y$	$0.45 f'_c$ $0.45 f'_c$ $0.60 f'_c$
Sec. V.3, p. Table V-3-1				

*Table V-3-3, Table 1-A-4, Amend. 22

**Table 1-A-2, Amend. 22

***Table 1-A-1, Amend. 22

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
1. Bolted and riveted assemblies	2.0	Not available	<u>Class I piping*</u> Thermal MOL + SL MOL + 2(SL) MOL = Max. operating loads SL = Seismic loads due to OBE $S_A = f(1.25 S_c + 0.25 S_H)$ f = stress range reduction factor S_c, S_H = allowable stress, ASA B31.1	<u>Allowable stress</u> S_A S_H Safe shutdown can be achieved	See load combinations and Supplement 6, Amend. 68, Appendix 6.
2. Welded assemblies	1.0		<u>Reactor vessel supports*</u> Seismic - Seismic + jet - 2(seismic) -	 Normal AISC allowables 150% of normal AISC allowables 150% of normal AISC allowables	
3. Vital piping	0.5		<u>Primary containment **</u> DL + operating + LOCA + E DL + operating + LOCA + E'	 ASME Sec. VIII Code case 1272N-5	
Table V-3-1 Sec. V.3 p. V-3-2			* Ques. IV. 1, Amend. 11 ** Table V-3-2, Sec. 3.8.1		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE (% Critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	<p>Quoted from answer to Question IV.1, Amend 11</p> <p>"The control room panels and auxiliary racks are usually shipped assembled and therefore these units must be designed for normal shipping shock which is in the order of several g's acceleration. Certain components are removed and padded to reduce vibration effect and excessive acceleration. In all cases, however; the design analysis is made of the panels and instruments. All relays in safety circuits are energized; and since they are capable of closing against 1.0g, they can certainly maintain contact during an acceleration of 0.22g."</p> <p>Question IV.1, Amend. 11</p>	

SEISMIC REVIEW TABLE[★]

Docket Number

50-255

NAME AND NSSS TYPE OF THE PLANT		EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
		OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
CP/OL	ISSUE DATE										
Palisades Nuclear Generating Plant Unit 1		0.10	0.067	VII	0.20	0.13	Containment design Housner spectra. For floor response spec- tra generation and for equipment and piping the 1952 TAFT earthquake was used, whose R-S envelopes the Housner spectra.	Maximum horizontal component with ver- tical com- ponent simul- taneously.	SRSS - response spectra method for structural modes and piping.	Housner design spectrum	Not clear - it appears that TAFT 1952 earthquake was used to generate floor response spectra. Then from lumped-mass model, the accelerations at each floor level were obtained and the TAFT response spectra were scaled to those valves. Static method used for piping with frequency > 20 Hz. For vertical R-S, 2/3 of horizontal ground spectrum Ref. 3.Q.5.8 and Q.5.6.
Reactor type: PWR Containment type: 6 buttresses with shallow dome (prestressed con- crete) NSSS Manufacturer: Combustion Engineering Architect Engineer: Bechtel											
3-67/3-71		p. 2-16	Sec. A.2 p. A-7		p. 2-16	Sec. A.2 p. A-7		Sec. A.2 p. A-7		Question 5.13 p. 5.13-1	

*Information obtained from BNL Docket search and SEPB Report, "Seismic Review of Palisades NPP Unit No. 1".

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete slab 8 1/2 to 13 ft. thick Sec. 5.1.2 p. 5-2	Loose dune sand overlies about 30 ft. of well-compacted, gray silty sand. Below this is about 90 ft. of compact till. Bedrock, Mississippian Coldwater Shale, is reached at a depth of about 150 ft. below lake level. It is composed of blue, gray or red shale.**		5400 fps for lake deposits	10 ft. from ground surface Sec. 2.4.1, p. 2-14, p. 5.10-21	Not available	Containment: lumped mass, spring model. Determining horizontal spring constant and vertical springs which provide rotational restraint. "Building FNDT. interaction effects". 10-66, ASCE Engr. Mech.	Not available	Not available	Not available
6700 fps for glacial till									
10,000 fps for bedrock									

Sec. 2.3.1

p. 2-10 to p. 2-11

** Type and thickness of bearing information are presented together.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Welded steel framed structures 2.0/2.0	Final design (SSE) for Class I structures except the containment shell 1. $Y = 1/\phi (1.25D + 1.0R + 1.25E)$ 2. $Y = 1/\phi (1.25D + 1.25H + 1.25E)$ 3. $Y = 1/\phi (1.25D + 1.25H + 1.25E)$ (0.9 D is used where dead load subtracts from critical stress in the above two equations) 4. $Y = 1/\phi (1.0D + 1.0R + 1.0E')$ 5. $Y = 1/\phi (1.0D + 1.0H + 1.0E')$	ACI 318-63 Code Ultimate strength design Sec. A.2, p. A-3, Appendix A
2. Bolted steel framed structures 2.0/2.0		
3. Reinforced concrete: structures on soil including structural damping 5.0/7.5		
4. Prestressed concrete: containment structure on soil including structural damping 4.0/7.5	Final design (SSE) of the containment structure ($.7 < \phi < .9$) a) $Y = 1/\phi (1.05D + 1.5P + 1.0T_A + 1.0F)$ b) $Y = 1/\phi (1.05D + 1.25P + 1.0T_A + 1.25H + 1.25E + 1.0F)$ c) $Y = 1/\phi (1.05D + 1.25H + 1.0R_A + 1.0F + 1.25E + 1.0T_o)$ d) $Y = 1/\phi (1.05D + 1.0F + 1.25H + 1.25W + 1.0T_o)$ e) $Y = 1/\phi (1.0D + 1.0P + 1.0T_A + 1.0H + 1.0E' + 1.0T_o)$ f) $Y = 1/\phi (1.0D + 1.0H + 1.0R_A + 1.0E' + 1.0F + 1.0T_o)$	Sec. B.1.6 p. B-5, Appendix B <u>Containment Working Stress:</u> a. $D + L + F + T_o$ b. $D + L + F + T_A + E$ (or W) c. $P' = 1.15P$ FSAR App. B.1
Y = Required yield strength of the structures D = Dead load of structure and equipment + any other permanent loads contributing stress, such as soil or hydrostatic loads R = Force or pressure on structure due to rupture of any one pipe H = Force on structure due to thermal expansion of pipes under operating conditions. E = Design seismic load for Class I structures E' = Maximum seismic load for Class I structures W = Wind load for Class I structures, tornado load for containment ϕ = Capacity reduction factor (Defined in B.1.7) P = Design accident pressure loads F = Effective prestress loads T = Thermal loads due to temperature gradient through wall during operating conditions T _o = Thermal loads due to temperature gradient through the wall and expansion		
Sec. A.2, p. A-8, Appendix A		

37-3

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1) Welded steel plate assemblies 1.0/1.0	Analytical method DC control centers 250V-test	<u>Critical reactor vessel internal structural</u> 1. Design loading + design earthquake forces $P_m \leq S_m$ $P_B + P_L \leq 1.5 S_m$	P_L, P_m, S_m, S_y are defined in the ASME Boiler and Pressure Vessel Codes, Section III, Article 4.
2) Concrete equipment supports on another structures 2.0/2.0		2. Normal operating loadings + hypothetical earthquake forces $P_m \leq S_D$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_D})^2] S_D$	ASA B31.1
3) Steel piping 0.5/0.5		3. Normal operating loadings + hypothetical earthquake forces + pipe rupture loadings $P_m \leq S_L$ $P_B \leq 1.5 [1 - (\frac{P_m}{S_L})^2] S_L$	"USA Standard Code for pressure piping power piping." Piping: FSAR App. A
		S_u = Minimum tensile strength of material at temperature $S_L = S_y + (1/3) (S_u - S_y)$ S_D = Design stress = $1.2 S_m$	Q.5.12, Q.5.7 Sec. 3.2 p. 3.6
Sec. A.2 Appendix A	Question 5.8 p. 5.8-3	<u>Class 1 systems and equipment design (including piping)</u> 1. MOL + PTT + SL 1. Applicable code allowable stress 2. MOL + MTT + SL 2. Minimum yield stress at temperature 3. MOL + MTT + 2SL 3. Minimum yield stress at temperature no more than + 10% MOL = Maximum normal operating load including design pressure, design temperature + piping and support reactions PTT = Normal planned thermal transients associated with expected transients such as start-up, shutdown and load swings	may be exceed but limited to plant normal operating

MTT = Maximum thermal transients in the systems functioning during plant emergency conditions such as full power reactor trip turbine generator trip, loss of auxiliary power and the DBA

SL = Design seismic load resulting from a seismic ground surface acceleration of 0.1g

2SL = Hypothetical seismic load resulting from a seismic ground surface acceleration of 0.2g

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number
50-277, 278

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE Peach Bottom Atomic Power Station, Unit 2 and 3 Reactor type: BWR Containment type: Mark I (steel) NSSS Manufacturer: General Electric Architect Engineer: Bechtel	0.05	0.033	VII	0.12	0.08	Synthetic time- history.	2 com- ponents H+V simultan- eous	Absolute sum (Response spectrum analysis)	Housner OBE: Fig. C.3.1 SSE: Fig. C.3.2 Max. acceleration = 0.15g @ 2% damping	Time-history method using an earthquake time- history whose raw spectrum response curve is greater than or equal to the site design response spectrum curve.
Unit 2: 1-68/8-73 Unit 3: 1-68/7-74	p.C.2-1	p.C.2-2	Sec. 2.5. 3.1.1, p.2.5-12	p.C.2-2	p.C.2-2		p. C.4-1 Sec. C.2.2 Sec. C.3.3	Sec. C.3.3 p. C.3-3	p. C.3-2,	Sec. C.3.3 p. C.3-3

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Class I structures: Spread or mat foundation on fresh rock Peters Creek Schist. Depth: Not available Auxiliary building: Steel H bearing pile foundation.	Residual soils. Weathered Peters Creek Schist. Fresh Peters Creek Schist.	0 to 40 ft. below surface. 25 to 65 ft. in thickness. 15 to 80 ft. below surface.	Not available	Varies from 12 to 15 ft. near and upstream. Reaches 100 ft. one mile downstream.	Site is 9 miles above Conowingo Dam; 6 miles below Holtwood Dam	Fig. C.3.3 indicates fixed base stick model.	Not available	Not available	Not available
p. 2.7-3, p. 2.7.4	p. 2.5-14	p.2.5-14		p. 2.5-10	p. 2.5-10	p. C.3.3			

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSB (% critical damping)	DESIGN CRITERIA		
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Reinforced concrete structures	2.0/5.0	1. D + E	AISC for structural steel
Steel framed structures	2.0/5.0	2. D + E'	ACI 318-63 for reinforced concrete
Weld steel assemblies	1.0/2.0	3. D + W	Maximum allowable stresses
Bolted and riveted assemblies	2.0/5.0	4. D + W'	Steel - .9 yield strength
		5. D + E + T	Concrete - .85 compressive strength
		6. D + E' + T	Reinforcement - .9 yield strength
		7. D + F	
	where D = Dead load W = Wind load W' = Tornado load E = OBE	E' = DBE T = Thermal F = Flood	See Codes on p. C.2-8.
p. C.2-2	p. C.2-6 p. C.2-7 For further reference, refer Appendix C		p. C.2-6

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Welded steel assemblies 1.0/2.0</p> <p>Bolted and riveted assemblies 2.0/5.0</p> <p>Seismic Class I Piping System 0.5/0.5</p>	<p>Analysis and tests</p>	<p>Normal and upset:</p> <ol style="list-style-type: none"> 1. D. W. + pressure 2. D. W. + pressure + OBE 3. D. W. + pressure + thermal 4. D. W. + pressure + OBE + thermal <p>Emergency:</p> <ol style="list-style-type: none"> 1. D. W. + DBE <p>Faulted:</p> <ol style="list-style-type: none"> 1. D. W. + DBE + Jet reaction forces 	<p><u>Reactor Vessel</u></p> <p>ASME BPVC III</p> <p><u>Piping</u></p> <p>USAS B 31.1.0</p>
p. C.2-2	p. C.5-1	For further details refer to Table C.5.6, Table C.5.7	<p>Table C.5.6</p> <p>Table C.5.7</p>

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number

50-293

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Pilgrim Nuclear Power Station Unit No. 1 Reactor type: BWR Containment type: Reinforced Concrete NSSS Manufacturer: General Electric Architect Engineer: Bechtel	0.08	0.053	VII	0.15	0.10	Taft Earthquake, July 21, 1952 nor- malized to 0.08g and 0.15g ground acceler- ate was used for com- puter analysis and results compared a- gainst those from smothed response spectra method.	Horizontal component and verti- cal com- ponent were acting simultane- ously.	For piping system: SRSS For struct: not a- vailable.	Housner	Time-history method using Taft record. Then each curve was compared to the ground re- sponse spectrum and corrected to fall below the ground spectrum curve.
8-68/6-72	Sec. 2.5.3.2 p. 2.5-6	App. C, Sec. C.2.2 p. C.0-1	Sec. 2.5.3.2 p. 2.5-6	Sec. 2.5.3.2 p. 2.5-6	App. C, Sec. C.2.2 p. C.0-1	Sec. 12.2.3.5.2 p. 12.2-5	Comment 12.2.4 p. 2-26	App. C, Sec. C.3.3 p. C.0-7	Fig. 2.5-5 Fig. 2.5-6	Sec. 12.2.3.5.2, p. 12.2-6 Comment: 12.2.2 p. 2-22

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Heavily reinforced concrete mat 8 ft. depth <									

Sec. 2.5.2.4.2
and Sec. 2.5.2.4.3
p. 2.5-4

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(% criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete building	5.0/7.5	1. Dead load + OBE.	1. Stresses according AISC. and ACI Codes.
Internal concrete structures and equipment supports	2.0/3.0	2. Dead load + wind loading.	2. Maximum allowable stress increased 1/3 above nor- mal code-allowable stress.
Steel frame structures	2.0/5.0	3. Dead load + jet forces and pressure and temperature transient with rupture of single pipe + OBE.	3. Normal code-allowable stress.
Bolted steel assemblies	2.0/5.0	4. Dead load + R + SSE	4. Steel - 15% of AISC Code allowable stress concrete -0.75 f' _c where "working stress design" method is used. Reinforcement = 0.9 f _y when "ultimate strength design" method is used. Load factor of 9.0 is used with appropriate reduction factor as in ACI-318-63.
Welded assemblies	1.0/2.0	R= Jet forces and pressure and temperature transient with rupture of single pipe.	
Table 12.2.3, p. 12.2-6		Details: See C.2.3, App. C, p. C.0-2	Details: See C.2.3, App. C, p. C.0-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Class I Piping System 0.5/1.0</p> <p>Table 12.2.3, p. 12.2-6 Table 12.2.3-2</p>	<p>Both analytical and empirical (testing)</p> <p>App. C, C.3.1, p. C.0-5</p>	<p>Load combinations are presented as tables. Per ASME Code.</p> <p><u>Drywell membrane stresses:</u> D + R + E stress intensities are defined per code D + R + flood paragraph N-413 and their limits as per code N-413.</p> <p>Table C-9 Table C-20</p>	<p>ASME BPVC Section III</p> <p>Sec. C.3.4, App. C, p. C.0-7</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number
50-266, 301

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Point Beach Nuclear Plant Unit No. 1 & 2 Reactor type: PWR Containment type: 6 buttresses with shallow dome (prestressed con- crete) NSSS Manufacturer: Westinghouse Architect Engineer: Bechtel	0.06	0.04	NOT AVAILABLE	0.18	0.08	NOT AVAILABLE	Horizontal & Vertical Components Combined Simultan- eously	SRSS	Housner Spectra	Olympia, Washing- ton N80E on April 13, 1949 Earthquake normalized to .06g was used for this analysis.
Unit 1: 7-67/10-70 Unit 2: 7-68/11-71	Sec. 5.1 p. 5.1-41			Sec. 5.1 p. 5.1-41			Append. A p. A-3	Sec. 5.1.2.4 p. 5.1-52	Q. 5.2 p. 5.2-2 Fig. A-1 & A-2	Append. A. p. A-18

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For containment building: Reinforced concrete foundation slab which is supported by steel H-piles Depth is not available 									

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded Steel Framed Structures 2.0/2.0 Bolted Steel Framed Structures 2.5/5.0 Reinforced Concrete Structures on Soils 5.0/7.5 Prestressed Concrete Containment Structures on Piles 2.0/5.0	<p>For Containment Structures:</p> <p>a) $Y = 1/\phi (1.05D + 1.5p + 1.0TA + 1.0F)$ b) $Y = 1/\phi (1.05D + 1.25p + 1.0TA + 1.25H = 1.25E + 1.0F)$ c) $Y = 1/\phi (1.05D + 1.25H + 1.0R + 1.0F + 1.25E + 1.0To)$ d) $Y = 1/\phi (1.05D + 1.0F + 1.25H + 1.0W + 1.0To)$ e) $Y = 1/\phi (1.0D + 1.0p + 1.0TA + 1.0H + 1.0E' + 1.0F)$ f) $Y = 1/\phi (1.0D + 1.0H + 1.0R + 1.0E' + 1.0F + 1.0To)$</p> <p>Note: 0.95D is used instead of 1.05D where dead load subtracts critical stress.</p>	<p>For Concrete Structures of the Reactor Containment: ACI-318-63.</p> <p>For further details refer to Sec. 5.1 p. 5.1-8</p>
Append. A p. A-5 Table A.1-1	Sec. 5.1 p. 5.1-26	Sec. 5.1 p. 5.1-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Pressure Vessel	Piping	
Interior Concrete Equip. Supports 2.0/2.0 Vital Piping Systems 0.5/0.5 Welded Steel Plate Assemblies 1.0/2.0	Analytical & Testing	Normal Conditions	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ (c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	For pressure piping: ASME BPVC, USAS B31.3 For reactor vessel: ASME Sec. III, Class A
		Upset Conditions	(a) $P_m \leq S_m$ (b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ (c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	
		(Normal + OBE)		
		Emergency Conditions	(a) $P_m \leq 1.2 S_m$ or $P_m \leq S_y$ whichever is larger (b) $P_m \text{ (or } P_L) + P_B \leq 1.5 (1.2 S_m)$ or $P_m \text{ (or } P_L) + P_B \leq 1.5 (S_y)$ whichever is larger	
		Faulted Conditions	Design Limit Curves of WCAP-5890, Rev. 1 as Modified by Note 1 of This Appendix	
		(Normal + DBE, Normal + DBA, Normal + DBE + DBA')	Same as Pressure Vessel	
Append. A p. A-5 Table A.1-1	Append. A p. A-3 & Vol. 2 Sec. 5.1 p. 5.1-41	P = Primary general membrane stress intensity P_m = Primary local membrane stress intensity P_L = Primary bending stress intensity Q = Secondary stress intensity S_m = Stress intensity from ASME BPVC III Code S_y = Minimum specified material yield		Append. A p. A-3 Sec. 4 Table 4.1-9
		DBA' = Steady-state Portion of Design Basis Acciden		
		Append. A, Table A.3-1		
		40-4		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
NOT AVAILABLE	Testing as per WCAP 7397-1.	NOT AVAILABLE	NOT AVAILABLE

Q.5.2
p. 5.2-2

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Plant grade is at Elv. 693.5 1. Mat foundation at Elv. 674 App. A-1, p. 5.12 Because of problem with liquefaction of soils above Elv. 645 due to ground acceleration, the soil above Elv. 645 is densified to a minimum relative density of 85%. For further details refer to App. A1, Sec. 5	Overburden materials are permeable sandy Alluvial soils from glacial outwash and recent river deposits. The bedrock is sandstone of Franconia formation of <180 feet in thickness. Sec. 2.9.4 p. 2.9-46	Structures are founded on densified sandy Alluvial soils of dense 158 to 185 feet. Elv. 470 0-20 ft/sec loose sand Elv. 2150 20-50 ft/sec med dense Elv. 2860 50-180 ft/sec very dense Elv. 5020 180-4100 ft/sec Sandstone App. A Sec. 4 Plate 4.1	Ground water table is 5 ft to 20 ft of the ground surface of the site and slope southwest from the Mississippi River toward Vermillion River. Sec. 2.7.1 p. 2.7-1	Lock and dam number 2 is 17 miles upstream of plant site. It is 3250 ft long dike, 2 single-lift locks with chambers 110'x600' and 110'x500'; and a spillway section of 20-30 ft. Amend. 22 Sec. 2.7.3 p. 2.7-8C	Stick model with soil springs. App. B Sec. B6.3 p. 3.6-6	Not available.	5% of critical damping. Amend. 12 App. B Table B.6-5	Not available.	

SEISMIC REVIEW TABLE

STRUCTURES					
DAMPING OBE/SSE (% criti- cal damping)		DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Reactor building containment vessel:	1.0/1.0	L. C. Normal operating OBE	Class 1 D + L + (W or S) D + L + DBA + greater of the OBE + (W or S)	R/C ACI 318-63 "	Steel AISC "
Reactor building shield structure:	2.0/2.0				
Reactor building internal concrete construction:	5.0/5.0	DBE	D + L + S + DBA + DBE	1 1/2 times ACI 318-63 1 1/2 AISC	
Steel framed structures:	2.0/2.0	Tornado	D + L + tornado + tornado missiles	$f_c = 0.85 f'_c$	$f_s = 0.9 F_y$
Reinforced concrete construction:	2.0/2.0			$f_s = 0.9 F_y$	
		Other	Jet forces, rupture loads, flood wherever applicable		
Amend. 12 (11-15-71) App. B Table B.6-5		For details refer to App. B, Sec. B.6.1, p. B.6-1 and Table B.6-1.		App. B Sec. B.3 p. B.3-1	

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE (% criti- cal damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Piping systems: 0.5/0.5	Analytical and testing.	1. Normal condition (D.L. thermal and pressure)	Vessel	Piping	ASME, BPVC, Section III ANSI B31.1, 1967 (App. B., Table B.7-3) p. 5.2-11 App. B Table B.7-3
Mechanical equipment: 2.0/2.0			(a) $P_m \leq S_m$		
			(b) $P_m \text{ (or } P_L) + P_B \leq 1.5S_m$	$P \leq S$	
			(c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$		
	2. Upset condition (normal and OBE)	(a) $P_m \leq S_m$		$P \leq 1.2S$	
			(b) $P_m \text{ (or } P_L) + P_B \leq 1.5S_m$		
			(c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$		
		3. Emergency condition	(a) $P_m \leq 1.2S_m$ or S_y whichever is larger	$P \leq 1.5(1.2S)$	LOAD COMBINATION(cont.) P_m =Primary general membrane stress intensity P_L =Primary local membrane stress intensity P_B =Primary bending stress intensity Q =Secondary stress intensity S_m =Allowable stress intensity value from ASME, BPVC S_y =Maximum specified material yield strength Amend. 24 (10-6-72) Table 5.2-1 P =Stress S =Allowable stress from ANSI B31.1 code for power piping
			(b) $P_m \text{ (or } P_L) + P_B \leq 1.5(1.2S_m)$ or $1.5S_y$ whichever is larger		
		4. Faulted condition (Normal+DBE+pipe rupture)	(a) $P_m \leq 1.5S_m$ or $1.2S_y$ whichever is larger	$P \leq S_y$ or	
			(b) $P_m \text{ (or } P_L) + P_B \leq 2.25S_m$ or $1.875S_y$ whichever is larger	$1.8S$	
Amend. 12 (11-15-71) App. B Table B.6-5	App. B Sec. B.7(i) p. B.7-9 p. B.7-14	S_y =Minimum specified yield strength (ASME, BPVC Code, Sec. III) Amend. 11, App. B., Table B.7-2 and Table B.7-3			

App. B, Table B.7-3.
p. 5.2-11

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-254, 265

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
Quad - Cities Station Unit 1 and 2 Reactor type: BWR Containment type: Mark I(Steel) NSSS Manufacturer: General Electric Architect Engineer: Sargent & Lundy, Engineers	0.12	0.08	VII	0.24	0.16	South-East component of San Francisco Golden Gate 1952 earthquake normalized to a maximum ground acceleration.	Horizon- tal and vertical components combined simulta- neously.	SRSS	Ground response spectra for the Golden Gate Park earthquake as well as the Housner spectra.	Normalized Golden Gate 1952 earthquake was used for the Time History Method.
Unit 1: 2-67/9-71 Unit 2: 2-67/3-72	Sec. 2.6 p. 2.6-1	Sec. 12.1.1.3 p. 12.1-6	Sec. 12.1.1.3 p. 2.6-1	Sec. 2.6 p. 2.6-1	Sec. 12.1.1.3 p. 12.1-6	Append. C p. E-1	Sec. 12.1.2 p. 12.1-9	Sec. 12.1.2 p. 12.1-9	Amend. 13, Sec. 12, p. 12.1-1, Fig. 12.1-1	Sec. 12, Amend. 13 p. 12.3-8

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reactor building: Reinforced concrete foundation. 297 ft.-0 by 150 ft.-0 <									

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% criti- cal damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reinforced concrete structure	5.0 [*]	AISC - For structure steel ACI - 318 - 63
Steel frame structure	2.0	
Welded assemblies	1.0	
Bolted and riveted assemblies	2.0	
*(For both O.B.E and D.B.E.)		
Primary containment (including penetrations) =		Amend. 13, Sec. 12, p. 12.13-1
a) D + P + H + T + E		
b) D + P + H + T + E'		
c) D + P + H + T + E''		
Class I structure =		
D + R + E		
D + R + E'		
D + L		
D = Dead load; L = Wind live load		
P = Pressure due to loss-of-coolant accident		
R = Jet force or pressure on structure due to rupture of any one pipe		
H = Force on structure due to thermal expansion of pipes under operating conditions		
T = Thermal loads on containment, reactor vessel, and internals due to loss-of-coolant accident.		
E = Design earthquake load, ground horizontal g = 0.12, vertical g = 0.68		
E' = Maximum earthquake load, ground horizontal g = 0.24, vertical g = 0.16		
Amend. Sec. 12, p. 12.1-3 & p. 12.1-6		
Sec. 12.1.1.3, Table 12.1.1, p. 12.1-6 and p. 12.2-4		

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
<p>Vital Piping Systems 0.5</p> <p>(For both O.B.E. and D.B.E. except for the standby gas treatment system, where 1% of critical damping was used).</p> <p>Sec. 12.1.1.3, Table 12.1.1 p. 12.1-6</p>	<p>Analytical</p> <p>Amend. Sec. 12 p. 12.2-14</p>	<p>Reactor primary vessel supports =</p> <p>a) $D + H + E$ b) $D + H + R + E$ c) $D + H + E'$</p> <p>Reactor primary vessel internals =</p> <p>a) $D + E$ b) $D + E'$ c) $P + D + T$</p> <p>Other major Class 1 equipment =</p> <p>a) $D + T + M + E$ b) $D + T + M + E'$</p> <p>For designations refer to previous page.</p> <p>Amend. 13, Sec. 12, p. 12.3-10</p>	<p>For reactor pressure vessel: ASME Boil and Pressure Code, Sec. III, 1963 and Summer 1964, Append. A.</p> <p>Class I piping: USAS B31.1</p> <p>Append. C p. 11, Amend. Sec. 12, p. 12.1-4</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number
50-312

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Rancho Seco Nuclear Generating Station Unit No. 1 Reactor type: PWR Containment type: 3 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Babcock and Wilcox Architect Engineer: Bechtel	0.13	0.09	VI	0.25	0.17	1952 Taft Earthquake	Three earthquake components: two horizontal and one vertical. Results for each horizontal earthquake were added separately on absolute basis to those from vertical earthquake; yielding two distinct seismic loading cases.	SRSS both for structures and piping.	Accelerogram of Taft Earthquake 1952. The response spectra are broadened in their range of peak responses.	Time-history acceleration method
10-68/8-74	p. 5.1-2	p. 5.1-2		p. 5.1-2	p. 5.1-2	Appendix 5B p. 5B-4	Question AEC 5-51 p. 5A-51	Question AEC 5-51 p. 5A-51	Appendix 5B p. 5B-4, Figs. SK6292-S-59 and	Appendix B p. 5B-4

SK6292-S-62

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
<p>Circular reinforced concrete mat 8 ft thickness</p> <p>Foundation is found about 35 ft below grade surface.</p> <p>Sec. 5.2.1 p. 5.2-1 Appendix 2E p. 2E-1</p>	<p>The granite & metamorphic basement is overlain in the site by 1500 to 2000 ft tertiary or older sediments. The surface unit is pliocene laguna formation of firm siltstone, sand, gravel.</p> <p>The surface unit of pliocene laguna formation is about 126 ft.</p> <p>Appendix 2C, Table 2C-7, Table 2C-1.2 Sec. 2.5</p>		<p>Not available.</p>	<p>150 ft below original ground surface.</p> <p>p. 2.4-1</p>	<p>1. Data on reservoirs and lakes within 50-mile radius are given in Table 2.4-1. 2. Plot of on-site dam, Question AEC No. 2.14.</p> <p>Appendix 2A p. 2A-132</p>	<p>Stick model with soil springs.</p> <p>Sec. 5.2.1.3.6 p. 5.2-18</p>	<p>Not available</p>	<p>10% for design basis earthquake.</p> <p>Appendix 5B p. 5B-6</p>	<p>Not available</p>

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE		DESIGN CRITERIA
	(% critical damping)	LOAD COMBINATION
Stress level:		
1. a) Welded structural steel, reinforced or prestressed concrete, no cracking, no joint slip.	0.5/1.0	A) $\phi C = (1+0.05) D + 1.5 P + 1.0 T_A + 1.0 F$ B) $\phi C = (1+0.05) D + 1.25 P + 1.0 T_A + 1.25 H + 1.25 E + 1.0 F$ C) $\phi C = (1+0.05) D + 1.25 H + 1.0 R + 1.0 F + 1.25 E + 1.0 T_c$ D) $\phi C = 1.0 D + 1.0 P + 1.0 T_A + 1.0 E' + 1.0 F + 1.0 H$ E) $\phi C = 1.0 D + 1.0 H + 1.0 R + 1.0 E' + 1.0 F + 1.0 T_o$
2. a) Welded structural steel, reinforced and prestressed concrete (only slight cracking).	2.0	ϕ = Capacity reduction factor. D = Dead loads of structures and equipment plus any other permanent loading contribution stress, such as hydrostatic or soil.
b) Reinforced concrete with considerable cracking.	3.0/5.0	P = Design accident pressure load.
c) Bolted and/or riveted steel.	5.0/7.0	F = Effective prestress loads.
3. a) Welded structural steel, prestressed concrete (without complete loss in prestress).	5.0	R = Force or pressure on structure due to rupture of any one pipe.
b) Prestressed concrete with no prestress left.	7.0	H = Force on structure due to thermal expansion or contraction of pipes due to design conditions.
c) Reinforced concrete.	7.0/10.0	T _o = Thermal loads due to the temperature gradient during operating conditions.
d) Bolted and/or riveted steel.	10.0/15.0	T = Thermal loads due to the temperature gradient.
Rocking of entire structure	5.0/9.0	T _A = OBE
Translation of entire structure	30 (OBE, SSE)	C = Required capacity to resist factored loads.
* NOTE. Stress level 1 = low, well below proportional limit. Stress below 1/4 yield point.		E' = DBE
Stress level 2 = Working stress		
Stress level 3 = At or just below yield point		
Stress level 4 = Varies		
Appendix 5B		p. 5.1-6 and p. 5.2-7
p. 5B-7		
		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		1. ACI-318-63 Ultimate strength method Question AEC 5.23, p. 5A-25
		2. AISC (Sixth Edition) Sec. 5.1.3, p. 5.1-4
		NOTE: 1. Normal working stress. Design methods are used for design load case. 2. Factored load case--to check the capacity to withstand accident conditions.
		Sec. 5.1.4, p. 5.1-4a For details see: Sec. 5.2.1.3 p. 5.2-11

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping systems or equipment.	Dynamic analysis	I. Design loads + OBE loads	Nuclear vessels: ASME BPVC 1967, Section III Piping: USAS I, B31.7
Low, well below proportional limit, stress below 1/4 yield point.	0.5 Testing	II. Design loads + DBE loads	
Working stress, no more than point.	0.5/1.0	III. Design loads plus pipe rupture load	
At or just below point.	0.5/2.0	IV. Design loads + DBE + pipe + rupture loads	
p. 5B-7	Question AEC 5.49 p. 5A-49	$P_m \leq 1.0 S_m$ $P_L + P_B \leq 1.5 S_m$ $P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$ $S_m \leq 2/3 S_U$ $P_L + P_B \leq 2/3 S_U$ $P_m \leq 2/3 S_U$ $P_L + P_B \leq 2/3 S_U$ P_L = Primary local membrane stress intensity. P_m = Primary general membrane stress intensity. P_B = Primary bending stress intensity. S_m = Allowable membrane stress intensity. S_U = Ultimate stress for unirradiated material at operating temperature.	p. 4.1-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Test data/or calculations of equipment to with-stand OBE and DBE are provided by vendors. Question AEC 5.67 p. 5A-62	Not available.	Not available.

SEISMIC REVIEW TABLE *

Docket Number
50-244

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Robert Emmett Ginna Nuclear Power Plant, Unit No. 1 Reactor type: PWR Containment type: cylindrical without buttresses (prestressed concrete) NSSS Manufacturer: Westinghouse Architect Engineer: Gilbert	0.08	0.08	V	0.20	0.20	None used	Two comp., larger horizontal plus ver- tical, com- bined via "direct addition" vertical component is assumed unampli- fied due to high axial stiffness of the con- tainment.	None (Contain- ment analyzed as single degree of freedom).	Housner	Equivalent static approach based on Housner ground spectra. Multimode response spectrum analysis used to check con- tainment vessel and RHRS pipeline from RCS loop to con- tainment.
4-66/9-69	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 2.9 p. 2.9-1	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15					

*Information was obtained from BNL Docket Search and SEPB Report
 "Seismic Review of Ginna Nuclear Power Station Unit No. 1 for SEP, Phase 1 Report".

SEISMIC REVIEW TABLE *

Docket Number
50-244

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Robert Emmett Ginna Nuclear Power Plant, Unit No. 1 Reactor type: PWR Containment type: cylindrical without buttresses (prestressed concrete) NSSS Manufacturer: Westinghouse Architect Engineer: Gilbert	0.08	0.08	V	0.20	0.20	None used	Two comp., larger horizontal plus ver- tical, com- bined via "direct addition" vertical component is assumed unampli- fied due to high axial stiffness of the con- tainment.	None (Contain- ment analyzed as single degree of freedom).	Housner	Equivalent static approach based on Housner ground spectra. Multimode response spectrum analysis used to check con- tainment vessel and RHRS pipeline from RCS loop to con- tainment.
4-66/9-69	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 2.9 p. 2.9-1	Sec. 5.1.2.4 p. 5.1.2-15	Sec. 5.1.2.4 p. 5.1.2-15					

*Information was obtained from BNL Docket Search and SEP8 Report
 "Seismic Review of Ginna Nuclear Power Station Unit No. 1 for SEP, Phase 1 Report".

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Containment structure (prestressed cylindrical wall) 2.0	<u>Containment Structure Loading Combinations:</u> <u>Normal</u> - 12 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_S + 2.0 \text{ E}$ <u>Test</u> - 4 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_W + 1.15 \text{ IP}$ <u>Accident Pressure</u> - Cond. "d" - 12 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_W + 1.0 \text{ IP} + 1.0 \text{ AT}_{60} + 0.8 \text{ E}$ (a=0.1g) Cond. "a" - 4 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_W + 1.5 \text{ IP} + 1.0 \text{ AT}_{90}$ Cond. "b" - 8 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_W + 1.25 \text{ IP} + 1.0 \text{ AT}_{90} + \text{E}$ Cond. "c" - 8 load combinations, example $1.0 \text{ DL} + 1.17 \text{ VP} + 1.0 \text{ OT}_S + 1.0 \text{ IP} + 1.0 \text{ AT}_{60} + 2.0 \text{ E}$ DL = Dead load VP = Vertical prestress OT _{W,S} = Operating temp. winter, summer App. 5D, Table 5.1.2-4I FSAR IP = Internal pressure (p=60 psig) AT ₆₀ = Accident pressure + temperature (p = 60 psig, T = 286°F) E = Design earthquake (a=0.1g)	ACT-318 AISC - 63 State of New York Building Construction Code, 1961 (Class III structures)
2. Concrete support structure for reactor vessel and steam generator 2.0		
3. Steel assemblies a) Bolted or riveted 2.5 b) Welded 1.0		
4. Other concrete above ground 5.0		

Table 5.1.2-1

5.1.2.3
FSAR 5.1.2.4, 7.2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
1. Vital Piping System 0.5	Analytical and Testing	Loading Combination	Vessels and Reactor Internals	Piping
		1. Normal + OBE	$P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$
		2. Normal + SSE	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2(1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2(1.5 S)$
		3. Normal + Pipe rupture loads	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2(1.5 S)$
Table 5.1.2-1	Amend. 2, Question 5	P_m = Primary general membrane stress; or stress intensity P_L = Primary local membrane stress; or stress intensity P_B = Primary bending stress; or stress intensity S_m = Stress intensity value from ASME B and PV Code Sec. III S = Allowable stress from USAS B31.1 Code for pressure piping		
		FSAR 5.1.2, FSAR App. 4-A, Table 1		
		ASME BPVC Sec. III, USAS B31.1 <u>Supports</u> Working stress within yield after load redistribution within yield after load redistribution		
		Fuel Pool Racks: Reg. guides 1.13, 26, 28, 38, 60, 61 ANSI N 18.2 - 1973 ANSI N 45.2.2 - 1972 ANSI N 45.2.13 - 1974 Structural Welding Code AWS Spec. D1.1 Rev. 2-74 ASME BPV Code, Sec. III, Sec. VIII, and IX, 1974 AISC - 1974 FSAR 9.5, App. 14A		

Equipment: FSAR Table 3.2.3-2 through 3.2.3-7

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Testing	<p><u>Class I instrumentation:</u> <u>Control Room:</u></p> <p>Racks have been assembled and the mounting and wiring of all components has been designed such that the functions of the circuits or equipment will perform in accordance with pre-scribed limits when subjected to seismic accelerations of 0.21g in the horizontal and vertical direction simultaneously.</p> <p><u>Control room, containment, and auxiliary bldg:</u></p> <p>Mounting and wiring of all components has been done such that simultaneous accelerations of 0.52g in the horizontal and vertical planes will not dislodge, cause relative movement or result in any loss or change of function of circuits or equipment.</p>	Not available
	Amend. 2 Question 5	Section 5.1.2.4, 7.2	

SEISMIC REVIEW TABLE

Docket Number

50-272, 311

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA						METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Salem Nuclear Generating Station Units 1 and 2 New Jersey Reactor type: PWR Containment type: Atmospheric (reinforced concrete) NSSS Manufacturer: Westinghouse Architect Engineer: United Engineers and Constructors Unit #1: 12-66/8-71 Unit #2: 10-67/8-71	0.10 Sec. 2.9 p. 2.9-1	0.067 Sec. 2.9 p. 2.9-1	VII Sec. 2.9 p. 2.9-1	0.20 Sec. 2.9 p. 2.9-1	.133 Sec. 2.9 p. 2.9-1	EI Centro (N-S) May 18, 1940 normalized to 0.10g to 0.20g for OBE and DBE respectively was used for containment structure analysis by step by step integration method. Sec. 5.2.4.2 p. 5.2-17	The vertical com- ponent was considered to be acting simultane- ously with the hori- zontal motion. Sec. 5.2. 4.2 p. 5.2-17	1.Response spectra analysis: Sq root of sum. of squares but if < 3 modes→ absolute sum of maximum values. 2.Time history analysis (finite element method): summing of signif- icant modes. App. C Sec. C.3.3 p. C.3-2	1. For freq > 0.33 cps: Aug spectra developed by Housner. 2. For freq < 0.33 cps: Utilized data suggested by Newmark. Fig. IIC-3a Fig. IIC-3b App. B p. IIC-10	Time history method. App. C Sec. C.3.3 p. C.3-2

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Circular concrete mat Depth 16 ft Sec. 5.6.2 See Table 5.6-1	1800 feet of sediments Upper 35 feet includes hydraulic fill and Quaternary alluvium of clay silt and some sand and gravel. Vincen-town formation is encountered at about 70 feet. App. B p. IIC-9	Founda-tions are estab-lished directly in Paleocene silty sands of Vincen-town formation or upon compacted fill extended to Vincen-town. Depth of Vincen-town is 90 feet. App. B p. IIC-9	3500 ft./sec App. B. p. IIC-9	Water level is about 20' from surface, but ground water move-ment thru acqui-fiers is quite low due to low permea-bility. The direc-tion is going into Delaware River. App. B p. IIB-14 Table IIB-2	Not avail-able.	Two methods were used: 1. Lumped mass model analysis using aug resp. spectra 2. Finite element modal analysis, for structure and soil. The most conser-vative results are used. Sec. 5.2.4.2 p. 5.2-17	Not available.	2%--OBE 5%--DBE Sec. 5.2.4.2 p. 5.2-17	Not avail-able.

See Plate IIC-1, App. B

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	(% critical damping)	DESIGN CRITERIA
		LOAD COMBINATION ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Concrete structures:	2.0/5.0	1. Operating + DBA + OBE $C=1.0D+0.05D+1.25P+1.0(T'+TL')+1.25E+1.0B$ 2. Operating + DBA + DBE $C=1.0D+0.05D+1.0P+1.0(T'+TL')+1.0E'+1.0B$ 3. Operating + DBE $C=1.0D+0.05D+1.0T'''+1.0E'+1.0B$ C = Required load capacity of section D = Dead load P = Accident pressure load T' = Load due to maximum temperature gradient based upon temperature associated with 1.25 times accident pressure T'' = Load due to maximum temperature gradient based upon temperature associated with accident pressure T''' = Load due to operating temperature gradient thru the steel liner, concrete shell and mat E = Load from OBE E' = Load from DBE TL' = Load exerted by liner based upon temperature with 1.25 times accident pressure TL'' = Load exerted by liner based upon temperature associated with accident pressure. Sec. 5.2.3 p. 5.2-7 to 5.2-8
Structural steel: Bolted or riveted Welded	2.5 1.0	ACI 318-63 AISC Manual, 6th edition Note: (a) For normal operating + OBE "Working Stress Design" ACI 318-63 and the allowable stresses are 1/3 above the normal applicable code working stresses. (b) For normal load + DBE: "Ultimate Strength Design" ACI 318-63 Sec. 5.6.3 p. 5.6-2
App. C Sec. C.3.2 p. C.3-1		

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital piping system: 0.5	Not available.	<p align="center">Vessel Piping</p> <p>1. Normal condition: (a) $P_m \leq S_m$ (a) $P_m \leq S$ (b) $P_m \text{ or } (P_L) + P_b \leq 1.5S_m$ (b) $P_m \text{ or } (P_L) + P_b \leq S$ (c) $P_m (P_L) + P_b + Q \leq 3.0S_m$</p> <p>2. Upset condition: (a) $P_m \leq S_m$ (a) $P_m \leq 1.2S$ (b) $P_m (P_L) + P_b \leq 1.5S_m$ (b) $P_m \text{ or } (P_L) + P_b \leq 1.5(1.2S)$ (c) $P_m (P_L) + P_b + Q \leq 3.0S_m$</p> <p>3. Emergency condition: (a) $P_m \leq 1.2S_m$ or S_y (a) $P_m \leq 1.2S$ whichever is larger (b) $P_m (P_L) + P_b \leq 1.5(1.2S_m)$ or $1.5S_y$ whichever is larger (b) $P_m \text{ or } (P_L) + P_b \leq 1.5(1.2S)$</p> <p>4. Faulted condition: Design limit curves* Design limit curves*</p> <p>NOTE: P_m = primary general membrane stress, P_L = primary local membrane stress, P_b = primary bending stress, S_m = stress value for ASME, BPVC code, Section III, nuclear vessels, S_y = minimum specified material yield, S = allowable stress from USASI, B31.1 code for press piping. App. C, Table C.4-2</p>	<p>ASME Nuclear Vessel Code Section III</p> <p>ANSI B31.1 for piping</p> <p>Sec. 5.2.8.3 p. 5.2-53</p>

App. C
Sec. C.3.2
p. C.3-1

*Design limit curves developed using 50% of ultimate strain as maximum allowable membrane strain.

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE *

Docket Number
50-206

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
San Onofre Nuclear Generating Station Unit 1 Reactor type: PWR Containment type: Dry containment- spherical (steel) NSSS Manufacturer: Westinghouse Architect Engineer: Bechtel 3-64/3-67	0.25 0.25g for Cat. A, 0.20g for Cat. B, UBC for Cat. C.	0.167	Not avail- able	0.50 0.50g for initial design, 0.67g for reevaluation of reactor bldg, NSSS, containment sphere, con- crete sphere enclosure, foundation and cradle and diesel gen. bldg. (0.44g for re-evaluation)	0.33	A synthetic time history was generated so that it's response spectra envelop the Housner spectra at 2% damping. 3.7.1.1-1 System Analysis Reactor bldg. Res. Spec. 3comp. R.G. 1.92 D.G. Bldg. Res. Spec. 3comp. R.G. 1.92 Steel Con- Res. Spec. 3comp. SRSS tainment sphere RCL piping Time his- 3comp. algebraic Direct and equipment tory RCL supports Time his- 3comp. algebraic Direct Concrete sphere tory enclosure Res. Spec. 3comp. SRSS Diesel Gen. Res. Spec. 3comp. R.G. 1.92 R.G. 1.92 Bldg. Main bldg. Res. Spec. 3comp. Absolute Absolute Intake struct., Res. Spec. 2comp. Absolute N/A Aux. bldg., battery rm. Housner spectra used in original design and 1972-75 re-evaluation except that a site specific spectra was used for the concrete sphere enclosure and the deisel generator bldg.	3.7.1.1	3.7.1.1	Floor response spectra by time history method for re-evaluation of RCL piping, equipment, and NSSS supports. All other Category "A" piping and equipment (ECCS, ACS, SIS, feedwater lines, CVC) - 1.0g and 0.67g for horizontal and vertical, 0.5g, Housner spectra for equipment.	

*Information from BNL Docket search and SEP8 Report No. EDAC-175-166,01,
August '79, "Seismic Design Bases and Criteria for San Onofre Nuclear
Generating Station, Unit 1".

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
P. The foundation of the containment-reactor building is in the shape of a spherical segment extending from the ground surface to a depth of 40 ft. 3.7.1-6 The supporting medium is San Mateo sand. Bedrock is at a depth of 1000 ft.	1. Quaternary terrace deposits: Consist of clayey or silty, fine to coarse sand with some cobbles. Average thickness is 40 ft. 2. San Mateo formation: Massive, well-graded, fine to coarse sand with gravel and occasional lenses of thin beded gray shale or siltstone. Approx. 1000 ft. thick.	Surface terrace deposit San Mateo sand Capistrano siltstones Monterey shale San Onofre Breccia undifferentiated sediments	400 and 1250 fps 765 fps 2000 fps 2160 fps 5000 fps 3,900 fps	Average level of ground water is 15 ft. below original grade (El + 5ft. MLLW Datum), and the gradient is 17 ft. per mile toward the ocean. Sec. 1.1.4 p. 1-10	Not avail- able	Soil-structure interaction is represented by a set of six frequency-independent interaction springs attached to the reactor building structure at the center of gravity of the base mat. "SHAKE" program used.	Not available	Soil horizontal translation - 12% Soil vertical translation - 18% Soil rocking - 10% These values include radiation and material damping.	Not avail- able

Sec. 1.3.2
p. 1-56

p. 3.7.2-4

Table 3.7.1-3

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% critical damping)		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reactor vessel internals (stainless steel core support structure)		<u>Concrete structures</u> (concrete sphere enclosure)	Concrete sphere enclosure, Reactor bldg. (concrete in- ternals), foundation and cradle, diesel generation bldg. - ACI 318 - 71, AISC 1971
(a) welded assemblies	1.0	$u = 1.4 D + 1.7 L$	
(b) bolted assemblies	2.0	$u = 1.4 D + 1.7 L + 1.9 E$ $u = D + L + T_o + R_o + E'$	
2. Reinforced concrete reactor support	4.0	$u = D + L + T_A + R_A + 1.0 P_A + (Y_R + Y_J + Y_M) + E'$ (9 additional L.C.)	Main building, intake structures, auxiliary bldg., battery rm., turbine pedestal - ACI 318 - 63 - AISC 1963 - UBC 1964
3. Steel containment vessel and foundation	4.0	<u>Steel structures</u>	
4. Framed steel structures	2.5	$S = D + L$ $1.6S = D + L + T + R + E'$ $1.6S = D + L + T_A^O + R_A^O + P_A + 1.0 (Y_R + Y_J + Y_M) + E$ (8 additional L.C.)	
5. Concrete structures above ground		<u>Reactor building and foundation and cradle support</u>	Refueling Water Stg. Tank-API publication for storage tank.
(a) shear wall type	7.0	$u = 1.0 D + 1.0 L + 1.0 (DBE)$	
(b) rigid frame type	5.0	$0.9Y = 1.0 D + 1.0 L + 1.0 (DBE)$ $Y = \text{ultimate strength of section}$	

Sec. 9.2.2
Table 9.1
p. 9-10

SEISMIC REVIEW TABLE.

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Vital Piping Systems	0.5	Not Available	<p><u>Containment sphere</u> Primary membrane and bending stresses are evaluated at:</p> <p>A). Basic shell thickness under combined dead weight, design pressure and seismic loads</p> <p>B). Shell to base mat juncture under combined deadweight, design pressure and seismic loads.</p> <p>C). Shell in vicinity of equipment hatch and personnel lock</p> <p>D). Main feedwater penetration under combined dead weight, internal pressure, seismic, and piping.</p>

Sec. 9.2.2
Table 9.1
p. 9-10

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	<p>Tested or evaluated to determine that the instruments would withstand 1.0g without misoperation.</p> <p>Amend. 10, Suppl. 1, Quest. 14</p>	Not available	Not available

SEISMIC REVIEW TABLE

Docket Number

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g				
CP/OL ISSUE DATE Shippingport Project 129 Reactor type: PWR Containment type: Dry containment- spherical (steel) NSSS Manufacturer: Westinghouse Architect Engineer: Burns and Roe, Inc. also Stone and Webster Engineering Corp.				Not available					

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
				← Not Available →					

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	<p>ASME Code Sec. VIII 1952 Ed.</p> <p>P.A. Regulations for pressure vessels 1954 ed.</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Not Available	

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Not Available	

SEISMIC REVIEW TABLE

Docket Number
50-335

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OSE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. S	VERT. S	INTENSITY MM	HOR. S	VERT. S					
CP/OL ISSUE DATE										
St. Lucie Plant, Unit No. 1. Reactor type: PWR Containment type: Dry containment- cylindrical (steel) NSSS Manufacturer: Combustion Engineering Architect Engineer: Ebasco	0.05	0.033 for shield building	VI	0.10	0.067 for shield building	Synthetic time- history	Each horizontal combined with the vertical on an absolute sum basis. Resulting two load cases.	SRSS	Housner spectra	Time-history method using synthetic time history
7-70/ 3-76	Sec. 2.5 p. 2.5- 25a	Sec. 3.8. 2.2, p. 3.8-67, Amend. 32	Sec. 2.5 p. 2.5-27		Sec. 3.8 2.2, p. 3.8-67, Amend. 32	Sec. 2.5.3 p. 2.5-28	Sec. 3.7. 3.2.4, p. 3.7-43a	Sec. 3.7. 2, p. 3.7- 19	Fig. 2.5-23 and 24 Fig. 3.7-1 and 2	Sec. 3.7 p. 3.7-36 Sec. 3.7 p. 3.7-3 Rev. 16

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For reactor building: Rigid foundation mat.	Loose sand with small amounts of silt and clay, containing isolated pockets of shell fragments and limestone nodules.	50' to 60'	Not available	Shallow non-artesian aquifer extends to a depth of about 150 ft. below land surface	"No dams are located within the hydrological influence of Hutchinson Island."	Stick model with soil springs.	Generally utilize shear shear moduli ranging from ranging from 16,700 psi to 14,000 psi.	Not available	Not available
p. 2.5-1	More dense contains a greater percentage of fines (material finer than the no. 200 sieve) and has very few pockets of limestone nodules and *	60' to 150'	Sec. 2.5-36 p. 2.5-38	Vol. 1, Sec. 2.4 p. 2.4-20		Sec. 2.4, p. 2.4-7a	Sec. 3.7.2.1.1 p. 3.7-6	Sec. 2.5, p. 2.5-38	p. 2.5-19

(Note: Due to space the columns for Type and Depth had to be continued here....)

* shell fragments
more clayey than the
material above, does not 150' to at least 400'
contain pockets of shells
and limestone, and is dense
in consistency. Vol. 1, Sec. 2.5, p. 2.5-8

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (Z critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel framed structure 2.0/2.0	Shield Building $(1.0 \pm 0.05)(D + T) + 1.25 \text{ LOCA} + 1.25 \text{ OBE}$ $(1.0 \pm 0.05)(D + T) + 1.25 \text{ OBE}$ $(1.0 \pm 0.05)(D + T) + 1.0 \text{ LOCA} + 1.0 \text{ DBE}$ $(1.0 \pm 0.05)(D + T) + 1.0 \text{ DBE}$ For further details refer to Sec. 3.8.2.2 p. 3.8-68 of Amend. 32-9/6/74.	AIC 318-63 ϕ Yield capacity reduction factors are used. Sec. 3.8.2.2.8 p. 3.8-71
Bolted or riveted steel framed structure 2.5/2.5		AISC -1969 Sec. 3.8 p. 3.8-2,3
Reinforced concrete frames and buildings 2.0/5.0		
Steel containment vessel 2.0/2.0		
Sec. 3.7 p. 3.7-3a		

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Welded steel plate assemblies	1.0/1.0	Analytical and Testing	<u>Containment Vessel</u> LOCA + OBE: $P_M \leq 1.0 S_m$ $P_L + P_B \leq 1.5 S_m$ $P_L + P_B + Q \leq 3.0 S_m$ LOCA + DBE: $P_M \leq 0.9 S_y$ $P_L + P_B \leq 0.9 S_u$ OBE + Pipe rupture: $P_M \leq 1.0 S_m$ $P_L + P_B \leq 1.5 S_m$ $P_L + P_B + Q \leq 3.0 S_m$ DBE + Pipe rupture: $P_M \leq 0.9 S_y$ $P_L + P_B \leq 0.9 S_u$ OBE + Thermal + Seismic loads on piping: $P_M \leq 1.0 S_m$ $P_L + P_B \leq 1.5 S_m$ $P_L + P_B + Q \leq 3.0 S_m$ LOCA + DBE with pressure & thermal + seismic loads on	<u>Piping</u> Design: $P_m \leq S_m$ $P_L + P_b \leq 1.5 S_m$ $P_L + P_b + P_e + Q \leq 3.0 S_m$ Normal: $P_L + P_b + P_e + Q + F$ = S_p (use fatigue curve) Upset: $P_L + P_b + P_e + Q \leq 3.0 S_m$ (Press + Wt. + $P_L + P_b + P_e + Q + F = S_p$ OBE + VT) (use fatigue curve) Emergency: Max press ≤ 1.5 de- sign press (Press + Wt. + DBE) $P_L + P_b \leq 2.25 S_m$ Faulted: Max press ≤ 2.0 design press: (Press + Wt. + DBE + rupture) $P_L + P_b \leq 3.0 S_m$	ASME BPVC Sec. III
Reinforced concrete equipment supports	2.0/5.0				
Steel piping	0.5/0.5				
		Sec. 3.7, p. 3.7-36,43a Sec. 3.9 p. 3.9-1		Table 3.9-3 p. 3.9-18 Amend. 38	Sec. 3.8 p. 3.8-14 Rev. 13, 7-15-73 ANSI B31.7 Sec. 3.9 Table 3.9-3 p. 3.9-18
Sec. 3.7 p. 3.7-3a					

piping:
 $P_M \leq 0.9 S_y$
 $P_L + P_B \leq 0.9 S_u$

Table 3.8-7
 p. 3.8-30
 Amend. 32

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Testing and Inspection	<p>Type II - 600 v penetration assembly. A steel plate barrier has been erected inside the containment in the electrical system penetrations:</p> $D + P_R \leq 90 \text{ percent of material yield strength}$ $D + OBE \leq \text{normal AISC working stress}$ $D + DBE \leq 90 \text{ percent of material yield strength}$	<p>IEEE - 317, April 1971 Standard for electrical assemblies in containment structure for nuclear fueled power generating stations.</p> <p>Sec. 3.8, p. 3.8-33, Rev. 15, 10-11-73.</p> <p>IEEE -279 (Aug. 1968) IEEE -308 (Nov. 1970)</p> <p>Sec. 8.1, p. 8.1-2</p>
	Sec. 8.3 p. 8.3-23	Vol. 2 Sec. 3.8 p. 3.8-33, Rev. 15 (10-11-73)	

SEISMIC REVIEW TABLE

Docket Number

50-280, 281

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g					
CP/OL ISSUE DATE	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g					
Surry Power Station Unit 1 & 2 Reactor type: PWR Containment type: sub-atmospheric (reinforced concrete) NSSS Manufacturer: Westinghouse Architect Engineer: Stone and Webster	0.07	0.046	VII	0.15	0.10	Synthetic time-history	For Class 1 Structures Hor. & Vert. Combined simultaneously	SRSS Sup. Vol. 1 2.4.10 p. S4.10-2 10-15-70 & Sup. Vol. 1 Q.4.12 p. S4.12-2 10-15-70	1) For frequencies higher than 2 cycles/sec. Housner Spectra 2) Frequency range between 0.3 cycles/sec. Housner Average Spectra have been normalized to a max. ground velocity of about 4"/sec for O.B.E. and 9"/sec for P.B.E. 3) For frequencies lower than about 0.3 cycles/sec. using data suggested by Dr. Newmark & Hall. Sec. 2.5.5 p. 2.5.5-9 Fig. 2.5-4, 2.5-5	The floor response spectra are encompassed by the umbrella spectrum used in the dynamic analyses of Westinghouse supplied equipment. RCL analysis done with floor response spectra
Unit 1: 6-68/5-72 Unit 2: 6-68/1-73	Sec. 2.5.4 p. 2.5.4-1 2-13-70		Sec. 2.5 p. 2.5.5-5 2-13-70	Sec. 2.5.5 p. 2.5.5-1 p. 2.5.5-7 12-1-69		Q4.23, Supp. 1	p. 15.2-16 B.1-1			App. B, p. B.3-1 Supp. Vol. 1 Q.4.10, Q 5.10, 4.12

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For Major Class I Struct. (except for the fuel building and main steam valve enclosure struct.); MAT Foundation. 10 ft. thick	Surface Deposits Consist of sand, silty sand thin layers of iron oxide-cement sands and clays of Norfolk Estuarine Formation	50' 80'	Not available Sec. 2.5 p. 2.5.5-2	18 wells within a five mile radius of the site. Depth from 280'~799' 4 operating water wells on the site obtain water from the Eocene sediments at depth about 400'	NOT AVAILABLE	STICK MODEL with soil springs	NOT AVAILABLE	O.B.E/S.S.E. 0.05/0.10	O.B.E/S.S.E 0.02/0.05
Pile foundation: turbine foundation, spent fuel pit, mainsteam shielding, RWST	Below this lies clays, compact sand and silt members, and shell fragments of the Chesapeake Formation	240' thickness varying from -16 msl to -47 msl *	TYPE - THICKNESS (cont.) * Below this thickness lie formations of Eocene 45' Paleocene 55' Cretaceous 800' Crystal-line Bedrock. Estimated at a depth of about 1300'					This is an overall value which includes the damping in both the reinforced concrete structure and the damping.	
Sec. 15.4 p. 15.4-8 Sec. 15.5 p. 15.5.1-1 p. 2.4.6-1			Sec. 2.4 p. 2.4.2-2	Part B Vol. 1 Sec. 2.3		p. 15.5.1.4-2 Append. B Sec. B.2 p. B.3-1		Sec. 15.5 p. 15.5.1.4-2 & p. 15.5.1.4-3	Supp. Vol.1 Q. 5.22 p. S5.22-1

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% of Crit. Damping)		DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1) Containment Struct. & Foundation	5.0/10.0	1. Operating + DBA = $(1.0 \pm 0.05) D + 1.5P + 1.0 (T + TL)$	For Containment Struct. ACI 318-63 Part IV-B
2) Steel Framed Struct. Including Supporting Struct. and Foundations		2. Operating + DBA + OBE = $(1.0 \pm 0.05) D + 1.0P + 1.0 (T + TL) + 1.5E$	
a) Bolted	2.5	3. Operating + DBA + DBE = $(1.0 \pm 0.05) D + 1.0P + 1.0 (T + TL) + 1.0HE$	
b) Welded	1.0	4. Operating + 1.25DBA + 1.25OBE = $(1.0 \pm 0.05) D + (1.25p) + (T' + TL) + 1.25E$	
3) Concrete Struct. Aboveground		5. Operating + Tornado Loading = $(1.0 \pm 0.05) D + 1.0T' + 1.0C$	
a) Shear-wall type	5.0		
b) Rigid-frame type	5.0		
Sec. 15.3 & Supp. Vol. 1 p. 15.5.1.4-3 Q. 5.12 Sec. 15.2 P. S5.12-1 Table 15.2.4-1 p. 15.2-19		Sec. 15.5 Table 15.5.1.2-1 p. 15.5.1.2-4 4-15-70	Sec. 15.5 p. 15.5.1.2-2

SEISMIC REVIEW TABLE

MECHANICAL & PIPING					
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA			
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
(% Critical Damping)		PRESSURE VESSELS	PIPINGS		
Reactor Vessel Internals of Control Rod Assembly Drives:	Analytical & Testing	Normal Conditions:	$P_m \leq S_m$	$P_m \leq S$	ASME BPVC SEC. III USAS B31.1
a) Welded assemblies 1.0			$P_m \text{ (or } P_L) + P_B \leq 1.5S_m$		
b) Bolted assemblies 2.0			$P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$		
Vital Piping Systems:		Upset Conditions:	$P_m \leq S_m$	$P_m \leq 1.2S$	
a) Carbon steel 0.5/1.0			$P_m \text{ (or } P_L) + P_B \leq 1.5S_m$		
b) Stainless steel 0.5/1.0			$P_m \text{ (or } P_L) + P_B + Q \leq 3.0S_m$		
Reinforced concrete reactor support structure including the reactor vessel 5.0		Emergency Conditions:	$P_m \leq 1.2S_m$ or	$P_m \leq 1.2S$	
Mechanical equipment, including pumps, fans, and similar items 2.0			$P_m \leq S_y$ whichever is larger		
			$P_m \text{ (or } P_L) + P_B \leq 1.5(1.2S_m)$ or $P_m \text{ (or } P_L) + P_B \leq 1.5(S_y)$ whichever is larger		
Sec. 15.2		Sec. B.5	Faulted Conditions:	Design Limit Curves of WCAP-5890	
Table 15.2.4-1	p. b.5-1	-----			
p. 15.2-19	Table B.5-1				
Supp. Vol. 1	Supp. Vol. 1				
Q5.12	Q 4.10				
p. S5.12-1	p. S4.10-1				
		P = Primary general membrane stress intensity P_m^L = Primary local membrane stress intensity P_B^L = Primary bending stress intensity Q = Secondary stress intensity			
					App. B p. B.2-8 p. B.2-10 p. B.2-13

S = Stress intensity value from ASME BPVC III

S^m = Minimum specified material yield

^yFor further details refer to App. B, Table B.2-1, p. B.2-6

SEISMIC REVIEW TABLE

[illegible]

SEISMIC REVIEW TABLE

Docket Number
50-289

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA	
	HOR. g	VERT. g	INTENSITY MM	HOR. g						VERT. g
CP/OL ISSUE DATE										
Three Mile Island Unit 1 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Babcock and Wilcox Architect Engineer: Gilbert	0.06	0.04	VI	0.12	0.08	1957 Golden Gate Park - Average smooth revised with 1940 El Centro - nor- malized to ground acceleration of 0.06g Synthetic time- history for floor response spectra	Horizon- tal and vertical combined by abso- lute sum.	Piping: SRSS and modes 10% within each other are added absolutely.	Actual spectra en- velops Golden Gate and El Centro earthquake time histories.	Time-history method. Gilbert Topical Report # 1729 "Dynamic Analysis of Vital Piping Systems Sub- jected to Seismic Motion."
5-68/4-74	Sec. 5.1.2.1.1 p. 5-10	Sec. 5.1.2.1.1 p. 5-10	Sec. 2.8.1 p. 2-41	Sec. 5.1.2.1.1 p. 5-10	Sec. 5.1.2.1.1 1 p. 5-10	Sec. 2.7.1, p. 2-31 Sec. 2.8.2, p. 2-42	Sec. 5.2.4.1.2 p. 5-52	Sec. 5.4.5.1 p. 5-76a p. 5-52	Sec. 2-7, p. 2-31 Fig. 2-24 Fig 5-48	Sec. 5.4.5.1 p. 5-76a Fig. 5-49 through 5.54

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete mat foundation bearing on rock. 9 ft. thick with a 2 ft. thick concrete slab. Above the bottom liner plate. <									

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor Building: 2.0/2.0	a) $C = (1.0 \pm 0.05) D + 1.5P + 1.0T$ b) $C = (1.0 \pm 0.05) D + 1.25P + 1.0T + 1.25E$ c) $C = (1.0 \pm 0.05) D + 1.0P + 1.0T + 1.0E$ d) $C = (1.0 \pm 0.05) D + 1.0W_t + 1.0 P_t$	Reactor Building:
Concrete Equipment Supports: 2.0/3.0		ACI 318-63
Steel Framed Structure:		ACI 301-66 (modified)
a) Bolted or riveted 2.5/2.5		AISC Manual of Steel Construction
b) Welded 1.0/1.0		ASME BPVC Sect. III, VIII and IX
Prestressed concrete structures 2.0/5.0		ASA N 6.2-1965
Sec. 5.2.1.2.11 p. 5-18a	Sec. 5.2.3.2 p. 5-40	Sec. 5.2.3.1, p. 5-39 Sec. 5.2.2.4.1, p. 5-31

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)		METHOD OF QUALIFICATION	DESIGN CRITERIA	
			LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Vital Piping	0.5/0.5	Analytical and Testing	Design loads + DBE loads	ASME BPVC Sec. III USAS B31.1.0 USAS B31.7
Welded Steel Plate Assemblies	1.0/1.0		Design loads + SSE loads	
			Design loads + SSE loads + Pipe rupture	
			$P_m \leq S_m$ $P_L + P_b \leq 1.5 S_m$ $P_m + P_b \leq 1.2(1.5 S_m)$	
			$P_m \leq 2/3 S_u$ $P_L + P_b \leq 2/3 S_u$	
Sec. 5.2.1.2.11, p. 5-18a		p. 5-10 p. 5-76b	Sec. 4.1.2.5, p. 4-3	Table 4-2 , p. 4-38; and Sec. 4.1.3, p.4-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Not available.	Not available.	Not available.

SEISMIC REVIEW TABLE

Docket Number

50-320

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Three Mile Island Nuclear Station Unit 2 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS manufacturer: Babcock and Wilcox Architect Engineer: Burns and Roe	0.06	0.04	VII	0.12	0.08	Golden Gate, 1957 El Centro, 1940 Synthetic time- history for floor response spectra	Vertical & Horizontal spaced Components modes com- were con- sidered di- rectly to act simultan- eously	SRSS. Closely spaced modes com- bined di- rectly	Acceleration response Spectra for 1/2 SSE were partially devel- oped from "Golden Gate Park S.F. March 1957" Earthqk. Then it is modified in the low frequency region by the 1940 El Centro Earth- quake - normalized to basic ground mo- tion of 0.06g (OBE)	Time-History Method Using simulated ground motion.
Unit 2: 11-69/5-78	Sec 3.7.1.1 p. 3.7-1	Sec 3.7.2.8 p. 3.7-5		Sec 3.7.1.1 p. 3.7-1	Sec 3.7.2.9 p. 3.7-5	Sec 3.7.1.2 p. 3.7-1	Sec 3.7.2.9 p. 3.7-5	Sec 3.7.3.4 p. 3.7-8	p. 2.5-11 Fig. 2.5-8 Sec. 3.7.1.2 p. 3.7-1	Sec. 3.7.2.6 p. 3.7-5

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
The foundation slab is mild-steel reinforced circular mat Depth: 11 feet	The station is founded on un-weathered shales and sandstones of Gettysburg Formation.	NOT AVAILABLE	NOT AVAILABLE	Water levels occurred generally at a depth in excess of 15 ft & ranged from 14 to ft. The ground water level occurred at a max. 6.2 ft above the top of rock with less than one ft of head above the soil-rock interface at one pt. of observation.	No large dams exist immediately upstream of the site.	Stick model with rock springs	NOT AVAILABLE	NOT AVAILABLE	NOT AVAILABLE
Sec. 1.2.3.1.1 p. 1.2-3	Sec 2.5.1.2.9 p. 2.5-7			Sec 2.4.13.2 p. 2.4-26	Sec 2.4.4 p. 2.4-12	Sec 3.7.1.6 p. 3.7-3,4			

SEISMIC REVIEW TABLE

STRUCTURES										
DAMPING ONE/SSE (% of critical damping)		DESIGN CRITERIA								
		LOAD COMBINATION							ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
Welded steel plate assemblies		1.0/1.0							1. ACI 318-63 ACI 318-71 2. AISC-1965	
Welded steel framed structures		2.0/2.0								
Bolted steel framed structures(riveted)		2.5/2.5								
Reinforced concrete equipment supports		2.0/3.0								
Reinforced concrete frames & buildings		3.0/5.0								
Prestressed concrete structures		2.0/5.0								
Cable Tray Hangers (lateral direction)		5.0/10.0							Sec. 3.8.1.2 p. 3.8-2	
		Unit Load	A	B	C	D	E	F		G
		Dead load	0.95	0.90	0.95	0.87	0.95	0.95		0.90
		Int. pres.	1.50	1.25	1.25	1.00	-	1.00		1.00
		Prestress	1.0	1.0	1.0	1.0	1.0	1.0		1.0
		Wind load	-	-	1.25	-	-	-		-
		Tornado load	-	-	-	-	1.25	-		-
		Earthquake	-	0.81	-	1.0	-	-		0.81
		Thermal norm	1.25	1.25	1.25	1.25	1.25	1.25		1.25
		Accident	1.00	1.00	1.00	1.00	-	1.00		1.00
		Thermal incr.								
Table 3.7-1 p. 3.7-13		Table 3.8.-1,-2								

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA				
		LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
(% of critical damping)						
Steel Piping	0.5/0.5	Analytical procedure	I. Max Operating Loads + 1/2 SSE (upset)	Components $P_m \leq 1.0S_m$ $P_L + P_b \leq 1.5S_m$	Piping $P_m \leq S_m$ $P_L + P_b \leq 1.5S_m$	1. ASME, B&PV Code Section III 2. ANSI B31.7
		1. Equivalent Static Load Method	II. Max Operating Loads + SSE (emergency)	$P_m \leq 1.2S_m$ $P_L + P_b \leq 1.2(1.5S_m)$	$P_m \leq 1.2S_m$ or S_y $P_L \leq 1.8S_m$ or $1.5S_y$ $P_L + P_b \leq 1.8S_m$ or $1.5S_y$	
		2. Dynamic Analysis Method	III. Max Operating + SEE + Pipe Rupture Loads Faulted	$P_m \leq 2/3S_u$ $P_L + P_b \leq 2/3S_u$ $P_L + P_b \leq$	$P_m \leq$ $P_L \leq 2/3S_u$	
			P = Primary bending stress P _n = Primary local membrane stress P _L = Primary general membrane stress S _m = Allowable stress S _y = Minimum yield strength at temp. S _u = Ultimate strength of material at temp. For components: Table 3.6-1, p. 3.6-5 Table 5.2-4, p. 5.2-34 For piping: Table 5.2-3, p. 5.2-33			
Table 3.7-1 p. 3.7-13	Sec 3.9.1.2.1 p. 3.9-1,-2					Table 3.6-1 p. 3.6-5

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
NOT AVAILABLE	TESTING	NOT AVAILABLE	NOT AVAILABLE

SEISMIC REVIEW TABLE

Docket Number
50-344

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA	
	OBE		SSE		EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g				
CP/OL ISSUE DATE Trojan Nuclear Plant, Unit No. 1 Reactor type: PWR Containment type: 3 buttresses with hemispherical dome (prestressed con- crete) NSSS Manufacturer: Westinghouse Architect Engineer: Bechtel	0.15	0.10	VIII	0.25	0.17	Synthetic time history	Horizontal combined with verti- cal com- ponent combined absolutely	SRSS	Developed by Dr. I. M. Idriss for 2% critical damping. For other damping values Newmark's amplification factors were used. For Westinghouse equipment: horizontal and ver- tical seismic were used. They were compared with the horizontal and vertical floor response spectra developed by Bechtel Corporation. Time-history used to generate re- sponse spectra BC-TOP-4
2-71/ 11-75	Sec. 2.5 p. 2.5 -19 Sec. 3.7 p. 3.7-1	Sec. 3.7 p. 3.7-1	Sec. 2.5 p. 2.5-19	Sec. 3.7 p. 3.7-1	Sec. 3 .7 p. 3.7 -1	Sec. 3.7 p. 3.7-3	Sec. 3.7 p. 3.7-8 p. 3.7-12	Sec. 3.7 p. 3.7-22	Sec. 3.7 p. 3.7-2 Fig. 3.7-1 & 3.7-2 Sec. 3.7 p. 3.7-31

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For containment: Rigid base mat foundation. Depth is not available. Administration building supported by steel H-piles which go to rock 15 ft to 53 ft below grade. Sec. 3.7,p. 3.7-9 Sec. 3.7,p. 3.7-4	The site is underlain by bedrock and recent alluvium. The bedrock is volcanic in origin and consists principally of tuffs, breccias, agglomerates, and basalt flow. Alluvium consists of soft to very	The thickness of the alluvium is considered to be close to 280ft. The upper approx. 80 to 100 ft of the alluvium: soft to very soft clayed silt. At 50 ft depth range: decomposed wood fragments and vegetation**	4500 fps to 5000 fps. Sec. 2.5 p. 2.5-15 DEPTH(cont.) ** upper 25 ft to 35 ft. Predominately silty fine sand. All holes in the alluvium encountered principally soft clayed silt between 30 ft to 90 ft.	Wells vary in depth from 50 feet to over 200 feet. Sec. 2.4 p. 2.4-54	Grand Coulee Dam at Columbia River mile 597. Sec. 2.4 p. 2.4-33	The dynamic analysis was performed using stick model with fixed-base assumption. Results were compared with respect to flexible-base model and found to be conservative. Sec. 3.7 p. 3.7-6	0.7 x 10 ⁶ psi Sec. 2.5 p. 2.5-12	Not available.	Not available.
TYPE (cont.) * soft clayed silt to silty clay with varying amounts of intermixed fine sand and layers of silty fine sand. Sec. 2.5, p. 2.5-9									

Sec. 2.5,
p. 2.5-9

SEISMIC REVIEW TABLE

STRUCTURES					
DAMPING OBE/SSE				DESIGN CRITERIA	
				LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
	Stress Level			$C=1/\phi \{ (1.0 \pm 0.05)D + 1.5P + 1.0T_A + 1.0F \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.25P + 1.0T_A + 1.0H_A + 1.25E + 1.0F \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.25P + 1.0T_O + 1.25H_O + 1.25E + 1.0F \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.0H_A + 1.0R + 1.0F + 1.25E + 1.0T_A \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.25H_O + 1.0R + 1.0F + 1.25E + 1.0T_O \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.0P + 1.0T_A + 1.0H_A + 1.0E' + 1.0F \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.0P + 1.0T_O + 1.25H_O + 1.0E' + 1.0F \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.0H_A + 1.0R + 1.0E' + 1.0F + 1.0T_A \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.25H_O + 1.0R + 1.0E' + 1.0F + 1.0T_O \}$ $C=1/\phi \{ (1.0 \pm 0.05)D + 1.0A + 1.0F + 1.0T_O \}$	ACI 315-65 ACI 318-63 AISC 6th edition (1967) ASCE paper no. 3269
	Low	Working	At yield point		
Steel Structure					
Prestressed concrete	1.0	2.0	5.0		
Reinforced concrete					
For the combinations of category I structures other than containment refer to p. 3.8-13.					
Sec. 3.7 Table 3.7-1 p. 3.7-3				Sec. 3.8 p. 3.8-38	Sec. 3.8 p. 3.8-12, 33

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES	
			Stress Level Low Working At yield point	
Vital piping:	Analytical and testing.	For reactor vessel internals: Normal+OBE < ASME, BPVC Code, Sec. III for upset condition. For ANSI B31.7 Class II and III and ANSI B31.1.0 seismic category I piping systems: --For O.B.E.: $S_T = S_{OBE} + S_{lp} + S_{WT} \leq 1.2S_h$ where: S_T = maximum total longitudinal stress S_{OBE} = maximum bending stress due to O.B.E. S_{lp} = longitudinal pressure stress S_{WT} = bending stress due to weight effect S_h = basic material allowable stress at maximum (hot) temperature --For S.S.E.: $S_{T(S.S.E.)} = S_{SSE} + S_{lp} + S_{WT} \leq 1.8S_h$ where: $S_{T(S.S.E.)}$ = maximum longitudinal stress S_{SSE} = maximum bending stress due to SSE Sec. 3.7; p. 3.7-12; p. 3.7-26.	For reactor vessel internals: ASME, BPVC Code, Section III For piping: ANSI B31.7 and ANSI B31.1.0 Sec. 3.7; p. 3.7-12 Sec. 3.7; p. 3.7-26	
Sec. 3.7 Table 3.7-1				

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Analytical and Testing	Not available.	IEEE 344-1971
	Sec. 3.10 p. 3.10-1	Sec. 3.10 p. 3.10-2	Sec. 3.10 p. 3.10-1

SEISMIC REVIEW TABLE

Docket Number

50-250,251

NAME AND NSSS TYPE OF THE PLANT CP/OL ISSUE DATE	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY mm	HOR. g	VERT. g					
Turkey Point Plant Unit No. 3 & 4 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Westinghouse Architect Engineer: Bechtel Unit 3: 4-67/7-72 Unit 4: 4-67/4-73	0.05	0.033	VII	0.15	0.10	Synthetic time history 				

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL % Critical Damping	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
For containment: reinforced concrete slab. Thickness: 10 ½ feet	Organic, Mangrove swamp soils overlies the Miami oolite bedrock formation which extends to about 20' below sea level (site elevation less than 10') Small voids and solution channels are present.	4ft to 8ft of swamp soils overlies the Miami oolite bedrock formation..	NOT AVAILABLE	UNCLEAR INFORMATION	NOT AVAILABLE	FIG. 5.1-13 indicates stick model with soil springs	NOT AVAILABLE	O.B.E./S.S.E. Soil: 5.0/10.0	Composite with Soil: 5.0/7.5
Sec. 5.1 p. 5.1.2-1	Below this are the Fort Thompson*	Extends to 70ft below sea level	<div>TYPE THICKNESS (cont.)</div> <div>* Formation (Limestone and calcareous sandstone)</div> <div>The Tamiami Formation (clayey and calcareous marl indurated locally to limestone with beds of silty and shell sands) and the Hawthorne and Tampa Formations</div>	Sec. 2.10 p. 2.10-1		p. 5.1.3-13		Vol. 1 Append. 5A p. 5A-13	

Vol. 1, Sec. 2.9
p. 2.9-4

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE	(X criti- cal damping)	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded steel framed structure:	2.0/2.0	For class I structure outside the containment structure: $Y=1/\phi(1.25D+1.25E)$ $Y=1/\phi(1.25D+1.0R)$ $Y=1/\phi(1.25D+1.25H+1.25E)$ $Y=1/\phi(1.0D+1.0E')$ where: Y = regular D yield strength of the structure. D = dead load of structure and equipment plus any other permanent loads contributing stress. In addition, a portion of "live load" is added when such load is expected to be present when the unit is operating. R = force or pressure on structure due to rupture of any one pipe. H = force on structure due to restrained thermal expansion of pipes under operating conditions. E = design earthquake load. E' = maximum earthquake load. W = wind load. (to replace E in the above load equation whenever it produces higher stresses than E does) $\phi = 0.9$ for R.C. in flexure. $\phi = 0.85$ for tension, shear, bond, and anchorage in R.C. $\phi = 0.75$ for spirally R.C. comp. members (cont.)	ACI 318-63
Bolted steel framed structure:	2.0/2.0		AISC Manual of Steel Construction (6th edition)
Concrete equipment supports on another structure:	2.0/2.0		
Prestressed concrete containment structure:	2.0/5.0		
Prestressed containment including interior concrete and soil composite:	3.5/7.5		Append. 5A, p. 5A-5 Sec. 5.1, p. 5.1.8-1
R.C. frames and buildings:	3.0/5.0		
Append. 5A p. 5A-13			LOAD COMBINATION (cont.) $\phi = 0.70$ for tied comp. members. $\phi = 0.9$ for fabricated structure of steel. Vol. 1, Append. 5A p. 5A-5

SEISMIC REVIEW TABLE

MECHANICAL & PIPING						
DAMPING OBE/SSE (% of Critical Damping)		METHOD OF QUALIFICATION	DESIGN CRITERIA			
			LOAD COMBINATION			ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Welded Steel Plate Assemblies	1.0/1.0	For Class I - Analysis and testing	LOADING COMBINATIONS			ASME BPVC Sec. III USAS B 31.1 Code for piping.
Steel Piping	0.5/0.5			VESSELS	PIPING	
			Normal Loads	$P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq S_m$ $P_L + P_B \leq S$	
			Normal + Design Earthquake Loads	$P_m \leq S_m$ $P_L + P_B \leq 1.5 S_m$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$	
			Normal + Maximum Potential Earthquake Loads	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$	
		Normal + Pipe Rupture Loads	$P_m \leq 1.2 S_m$ $P_L + P_B \leq 1.2 (1.5 S_m)$	$P_m \leq 1.2 S$ $P_L + P_B \leq 1.2 S$		
Append. 5A p. 5A-13		Vol. 1 Append. 5A p. 5A-12 p. 5A-17	Append. 5A p. 5A-6, Table 5A-1			Append. 5A, Table 5A-1 p. 5A-8

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available.	Tests and inspections.	<p>"Electrical cable trays and DC battery racks are being checked for 'g' loadings obtained from the spectrum curves of the supporting floors. Motor control center and load centers have been shaker table tested to demonstrate no-loss-of-function capability under the maximum hypothetical earthquake. Mechanical and electrical equipment has been purchased under specifications that include a description of the seismic design criteria for the plant."</p>	
	Vol. 2 Sec. 8.5 p. 8.5-1 & p. 8.5-2	p. 5A-16, B-37	

Docket Number
50-271

54-1

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Concrete mat. depth is not available. All Class I structures except main stack are founded on bedrock. The main stack rests on end bearing steel piles which transfer the loads to the bedrock. 									

SEISMIC REVIEW TABLE

STRUCTURES			
DAMPING OBE/SSE (% critical damping)		DESIGN CRITERIA	
		LOAD COMBINATION (Allowable Stress)	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
1. Reinforced concrete structures	5.0	1. $D + L + E$	1. ACI 318-63 2. AISC (1963) "Allowable Stress Design."
2. Steel frame structure	2.0		
3. Bolted or riveted assembly	2.0	2. $D + L + R + E'$ $D + L + W'$	
		1. Normal allowable code stresses are used. No increase in design stresses for the load combinations considered is premitted. 2. Yield stresses for ductile materials 0.85 times of ultimate strength concrete.	
		D = Dead load , L = Live load E = OBE E' = DBE	
		R = Jet force or pressure due to rupture of one pipe Sec. 12.2.1, p. 12.2-2	
		Note that no load factors were applied to the equations above because no plastic strength design for steel structures or ultimate strength design for concrete was used. "Allowable stress design."	
Sec. 12.2.1.2.1, p. 12.2-6		Question 12.15, App. I, p. 1.2-66	Sec. 12.2.1, p. 12.2-1

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
-Welded assembly (Equipment and supports) 1.0 -Vital Piping System 0.5	1. Analytical 2. Testing	<p><u>Primary containment</u></p> <p><u>L.C.</u></p> <p>Normal & Upset</p> <ol style="list-style-type: none"> 1. DL 2. Design pressure 3. Design temperature 4. Piping and mechanical loads 5. Design basis earthquake <p>Emergency condition loads</p> <ol style="list-style-type: none"> 1. Dead load 2. Design pressure 3. Design temperature 4. Piping and mechanical loads 5. Maximum hypothetical earthquake <p>For flooded containment condition</p> <ol style="list-style-type: none"> 1. Dead weight 2. Design basis earthquake 3. Flooding water load <p>App. C. pg. C.2-30</p>	<p><u>Stress Limit</u></p> <p>ASME B&PV Code, Sect. III, Subsection B.</p> <p>Membrane stress intensity $S_A = 1.0 S_M = 17,500 \text{ psi}$</p> <p>Primary local membrane and bending:</p> <p>$S_{\text{limit}} = 1.5 S_M = 26,250 \text{ psi}$</p> <p>Membrane plus secondary bending</p> <p>$S_{\text{limit}} = 3.0 S_M = 52,500 \text{ psi}$</p> <p>Primary local stress = 90% of yield strength @ design temperature</p> <p>$S_A = 0.90 \times 33,700 = 30,330 \text{ psi}$</p> <p>Primary local stress = 90% of yield strength @ 100°F</p> <p>$S_A = 0.90 \times 38,000 = 34,200 \text{ psi}$</p>
Sec. 12.2.1.2.1, p. 12.2-6	App. C		

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

SEISMIC REVIEW TABLE*

Docket Number
50-29

[illegible]

* Remarks: Information obtained from BNL Docket Search and SEPB Report by LLL "Seismic Design Bases and Criteria for Yankee Rowe Generating Station", EDAC 175-130.02, January 1979.

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT					SOIL - STRUCTURE INTERACTION				
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
"All structures and equipment should be founded on spread footings. Where there is possibility of heaving due to frost action, footings should be carried to a minimum depth of 5'-0" below ground surface"- summary of Stone and Webster's structural design requirements 10-17-57. General design of turbine generator foundation conform to "GEI-1749A"- "turbine generator foundations" and Stone and Webster Reinforcing Standard for Turbine Supports ' 4-20-48 "The plant is situated on medium to fine sands with some clay and silt, cobbles and boulders".		Not available	Not available	Not available	Sherman Dam	← No soil-structure Interaction analysis →			

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	"Neither structures nor equipment were classified into seismic categories, e.g., seismic category I or equivalent, but instead were classified as safety related or non-safety related. These systems were designed and analyzed in accordance with the design codes in effect in 1955. For structures, the design of lateral load restraint systems was dictated by wind requirements. No lateral force provisions were made for internal structures or equipment."	<p>AISC American Standard Building Code requirements A58.1-1955</p> <p>ACI 318-56</p> <p>ASTM - specifications for structural steel for bridges.</p> <p>ASA A56.1 - 1952</p> <p>Stone and Webster "Summary of Structural Design Requirements Yankee Atomic Electric Co." J. O. No. 9699, October 1957.</p>

SEISMIC REVIEW TABLE

MECHANICAL & PIPING			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	None used	Not available	<p>ASME B and PV Code, Section VIII "Unfired Pressure Vessels" 1955 and code case 1226</p> <p>ASTM specification for A300 (Class A201, Grade B, Firebox Quality)</p>

SEISMIC REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
None used	None	"Electrical penetrations, control room systems, etc, were designed based on nuclear, mechanical and functional criteria. No provisions for lateral loads."	Not available

SEISMIC REVIEW TABLE

Docket Number
50 - 295, 304

NAME AND NSSS TYPE OF THE PLANT	EARTHQUAKE DATA					METHOD OF COMBINATION		DESIGN SPECTRA		
	OBE		SSE			EARTHQUAKE TIME HISTORY	NO. OF EARTH. COMP. USED AND ITS COMB.	MODAL COMB.	TYPE OF GROUND DESIGN SPECTRA	METHOD OF GENERATION OF FLOOR RESPONSE SPECTRA
	HOR. g	VERT. g	INTENSITY MM	HOR. g	VERT. g					
CP/OL ISSUE DATE										
Zion Nuclear Plant Unit 1 and 2 Reactor type: PWR Containment type: 6 buttresses with shallow dome (pre- stressed concrete) NSSS Manufacturer: Westinghouse Architect Engineer: Sargent and Lundy Engineers Unit 1: 12-68/4-73 Unit 2: 12-68/11-73	0.08	0.05	VII	0.17	0.11	Compared with the 1940 El Centro (N-S) earthquake record with maximum ac- celeration of 0.08g.	Each hor- izontal was com- bined with the verti- cal com- ponents simulta- neously.	SRSS with closely spaced modes com- bined by absolute sum method (response spectrum)	Design response spectra using 1940 El Centro (N-S) earthquake record with maximum ac- celeration of 0.08g at the rock level.	Time-history method using 1940 El Centro (N-S) earthquake record.
	p.2.11-2	p.2.11-2	Q.2.26-1	p.2.11-3	p.2.11-3	Amend. 18 Q.5.79	Amend. 14 Q.4.23	Amend. 14 Q.4.23	Amend. 19 Q.5.83	Amend. 14, Q. 4.25 Amend. 19, Q. 5.83

SEISMIC REVIEW TABLE

FOUNDATION AND LIQUEFACTION ASSESSMENT						SOIL - STRUCTURE INTERACTION			
TYPE OF FOUNDATION AND ITS DEPTH	BEARING INFORMATION			GROUND WATER TABLE	DAM	METHOD OF MODELLING	G _s PROFILE	MATERIAL DAMPING OF SOIL	LIMITATION ON MODAL DAMPING
	TYPE	THICKNESS	V _s PROFILE						
Reinforced concrete slab 9ft thick p. 5.1-5	The plant will be founded on relatively firm partly preconsolidated. Pleistocene glacial deposits. Formations below the site consist of: 1) 24-33 ft. of lake deposits-sand, gravel and pockets of peat and organic material. 2) Glacial deposits extending to a depth of 102-116 ft. below the surface - silt, clay, sand and gravel. 3) Niagara dolomite is 250' thick 4) Lower bedrock formations consists of sandstone and dolomite, some shale and siltstone layers. Several thousands of ft. thick. 5) Precambrian basement.*		Not available	Ground water is near the surface over much of the site area p. 2.9-5	Not available	Aux. building was modelled as fixed base assumptions with lumped mass building model. Reactor building model has a rocking soil spring only. A comparison study was made with a soil model by finite element mesh. Amend. 18 Q. 5.79 Amend. 14 Q.5.3,Q.4.23	Not available	Soil % critical damping: OBE 2 DBE 5 Q. 5.80	Not available

p. 2.9-4

* Type and thickness of bearing information are presented together.

SEISMIC REVIEW TABLE

STRUCTURES		
DAMPING OBE/SSE (% critical damping)	DESIGN CRITERIA	
	LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Reactor containment: 0.5/2.0	<p>1) $C = (1/\phi) (1.05 D + 1.25 P + 1.0 T + 1.25 E)$</p> <p>2) $C = (1/\phi) (1.05 D + 1.5 P + 1.0 T)$</p> <p>3) $C = (1/\phi) (1.05 D + 1.0 P + 1.0 T + E')$</p> <p>C = Required yield strength of the structure as defined below D = Dead loads P = Design accident pressure T = Thermal loads due to the temperature gradient through the wall and expansion of the liner and based on a temperature corresponding to the factored design accident pressure E = Operating basis earthquake (OBE) load E' = Design basis earthquake (DBE) load W = Wind load ϕ = Capacity reduction factor</p>	<p>ACI Code 318-63 refer to page 5.1-41 for ϕ values.</p> <p>AISC Manual of Steel Construction (6th Edition)</p>
Q. 4.23	p. 5.1-38	p. 5.1-41

SEISMIC REVIEW TABLE

MECHANICAL & PIPING				
DAMPING OBE/SSE (% critical damping)	METHOD OF QUALIFICATION	DESIGN CRITERIA		
		LOAD COMBINATION		ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
		Pressure Vessels	Pressure Piping	
Piping OBE = 0.5	Analytical and Testing	1) Normal condition a) $P_m \leq S_m$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	a) $P_m \leq S$ b) $P_m \text{ (or } P_L) + P_B \leq S$	ASME B&PV Code Section III, Nuclear Vessels for limit curves: WCAP 5890, Rev. 1
		2) Upset condition a) $P_m \leq S_m$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 S_m$ c) $P_m \text{ (or } P_L) + P_B + Q \leq 3.0 S_m$	a) $P_m \leq 1.2 S$ b) $P_m \text{ (or } P_L) + P_B \leq 1.2 S$	
		3) Emergency condition a) $P_m \leq 1.2 S_m \text{ or } S_y$ whichever is larger b) $P_m \text{ (or } P_L) + P_B \leq 1.5 (1.2 S_m) \text{ or } 1.5 S_y$ whichever is larger	a) $P_m \leq 1.2 S$ b) $P_m \text{ (or } P_L) + P_B \leq 1.5 (1.2 S)$	
		4) Faulted condition Design limit curves as discussed in the text	Design limit curves as discussed in the text	
P. Q. §.32-1	Appendix D Amend. 14 Q. 4.23 p. Q4.23-3	P_m = Primary general membrane stress intensity P_L = Primary local membrane stress intensity P_B = Primary bending stress intensity		Appendix D

Q = Secondary stress intensity
 S_m = Stress intensity from ASME B&PV Code, Section III, nuclear vessels
 S_y = Minimum specified material yield (ASME B&PV Code, Section III, Table N-421 or equivalent)
 S = Allowable stress from USASI B31.1 Code for pressure piping. Table B1-2, Appendix D

SEISMIC-REVIEW TABLE

ELECTRICAL EQUIPMENT			
DAMPING OBE/SSE	METHOD OF QUALIFICATION	DESIGN CRITERIA	
		LOAD COMBINATION	ACCEPTANCE CRITERIA & ALLOWABLE STRESSES
Not available	Not available	Not available	Not available

NRC FORM 335 (7-77)		U.S. NUCLEAR REGULATORY COMMISSION BIBLIOGRAPHIC DATA SHEET		1. REPORT NUMBER (Assigned by DDC) NUREG/CR-1429	
4. TITLE AND SUBTITLE (Add Volume No., if appropriate) Seismic Review Table				2. (Leave blank)	
7. AUTHOR(S) M. Subudhi, J. Lane, M. Reich, B. Koplik				3. RECIPIENT'S ACCESSION NO.	
9. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code) Brookhaven National Lab Upton, N.Y. 11973				5. DATE REPORT COMPLETED MONTH YEAR April 1980	
12. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code) U.S. Nuclear Regulatory Commission Division of Operating Reactors Seismic Review Group Washington, D. C. 20555				DATE REPORT ISSUED MONTH YEAR May 1980	
13. TYPE OF REPORT Final				6. (Leave blank)	
15. SUPPLEMENTARY NOTES				8. (Leave blank)	
16. ABSTRACT (200 words or less) The Seismic Review Table is a summary of Engineering Design parameters that were employed in the seismic analysis and design of nuclear power plants. The table covers 71 reactors licensed to operate by the U.S.N.R.C. The information contained is listed plant by plant and consists of <u>OBE and SSE "g" level and Modified Mercalli Intensity; Earthquake Time History</u> used to develop the ground response spectra or as input in the dynamic analysis; <u>Number of Earthquake Components used and Method of Combining Them; Method of Modal Combination; Type of Ground Design Spectra; Method of Generation of Floor Response Spectra; Type of Foundation and Depth; Type, Thickness, Shear Wave Velocity and Shear Modulus Profile of the Surrounding Sub-grade Soil and Bedrock; Ground Water Table Depth; nearby Dams; Modelling Method used for soil-structure interaction; Material Damping of Soil; Limitation on Modal Damping. Damping Values; and Loading Combinations, and Acceptance Criteria for Category I Structures, Mechanical Equipment, Piping, and Electrical systems.</u> The goal of the Seismic Review Table is to provide a reference of the available information relevant to the seismic design of currently licensed nuclear power plants.				10. PROJECT/TASK/WORK UNIT NO.	
17. KEY WORDS AND DOCUMENT ANALYSIS seismic data, earthquake design, dynamic analysis, soil-structure interaction load combinations, design criteria				11. CONTRACT NO. FIN No. A3326	
17b. IDENTIFIERS/OPEN-ENDED TERMS				14. (Leave blank)	
18. AVAILABILITY STATEMENT Unlimited		19. SECURITY CLASS (This report) unclassified		21. NO. OF PAGES	
		20. SECURITY CLASS (This page) unclassified		22. PRICE S	

Lee, Richard

From: Powers, Dana A [dapower@sandia.gov]
Sent: Friday, April 01, 2011 3:24 PM
To: Lee, Richard
Subject: conference phone call at 4:30 EDT

Richard I think you said the phone call today was at 4:30 EDT. Dana

4/30/11

Lee, Richard

From: Powers, Dana A [dapower@sandia.gov]
Sent: Friday, April 01, 2011 4:36 PM
To: Lee, Richard
Subject: call today

I have received nothing either.

4/308

Lee, Richard

From: Richard L Garwin [rlg2@us.ibm.com]
Sent: Friday, April 01, 2011 7:03 PM
To: Adams, Ian
Cc: Brinkman, Bill; Narendra, Blake; Hurlbut, Brandon; Sheron, Brian; Butnitz, Bob (pacbell.net); Smith, Haley; McFarlane, Harold; Kelly, John E (NE); Grossenbacher, John (INL); Pitzer, Karrie S.; Chambers, Megan (S4); Owens, Missy; Miller, Neile; Fitzgerald, Paige; Peterson, Per; Lyons, Peter; Finck, Phillip; Garwin, Dick (EOP); Lee, Richard; Budnitz, Bob; Szilard, Ronaldo; Steve Fetter; Aoki, Steven; Binkley, Steve; Mustin, Tracy
Subject: Shippable tanks are tiny compared with the need.

A 16,000 gallon tank is bout 60,000 liters, or 60 tons of water.

The torus of Unit 1 holds 5000 tons of water. Need 80 tanks.

Dick Garwin

4/2009

Public

Bonaccorso, Amy

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr. [backflow.prevention@verizon.net]
Sent: Saturday, April 02, 2011 4:09 PM
To: NRC Allegation
Subject: Fw: EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container.



FYI NRC.

-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.
Date: 4/2/2011 11:59:55 AM
To: cgjak@alaska.com; info@cgjapanatlanta.org; infocul@cgibos.org; ryoji@japancc.org; jic@japancc.org; cgid-pr@quest.net; japaninfo@ggjsf.org; info@cgjapansea.org; jet@ws.mofa.go.jp
Subject: Fw: EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container.



FYI. URGENT FOR JAPAN !

-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.
Date: 4/2/2011 11:21:26 AM
To: POTUS Office Of The President; rick.scott@eog.myflorida.com; Senator Bill Nelson; Senator John McCain; Rep. Paul; APFN; APFN-1; mailto:thechief@cnn.com; Dlind49@aol.com; leurenmoret@yahoo.com
Cc: Gordhan N. Patel; Albrodsky@aol.com; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckeel@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov; will.weatherford@myfloridahouse.gov
Subject: EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container.

4/3/11



Ladies and Gentlemen:

Storage of spent rods deep in the Salt Water Ocean some 3,000 feet might find the temperature staying at 40 degrees F continuous. Same of your refrigerator at home perhaps. I have been provided with 8 NEW RADStickers from the Inventor Gordhan Patel at J.P. Labs for use by any of your personnel who will be working at the plant and these stickers attach to ID's or Drivers Licenses so the radiation levels can be measured daily, weekly and monthly. Would also recommend placing some eventually on ALL equipment then a log started to see how much radiation the equipment plus personnel are subjected to in the line of work completed at the sites now or in the future. RADTRIAGE units work inside or outside as suggested but the RADSticker can be read after each shift if necessary for workers.

Remember STORAGE OF RODS SPENT OR REMOVED FROM REACTORS means WATER WITH DRY ICE COOLING FOR TRIP TO SEA THEN DROPPING RODS going to 12,000 feet depth in THE BATHYPELAGIC ZONE below the 3,000 feet to say 12,000 FEET might find 36 degrees F. Each is suitable perhaps for storage of spent fuel rods in very deep sections of sea water. Such no doubt was the bulk of laughter when it was recommended that spent rods be deep six stored rather than underground in areas like the scrubbed YUCCA MOUNTAIN storage which might now be for members of Congress and their families to live in any Nuclear Emergency in the USA. Wonder if SUPER THICK MILL PLASTIC SHEATING WOULD ALLOW SEALING FROM SALT WATER YET LET COLD GO THROUGH TO KEEP RODS SAFE ? Check with NRC personnel on this NEW STORAGE METHOD " DEEP SIX " IDEA !

As a State of Florida Certified Plumbing Contractor let me tell you that SOLAR ENERGY/DIESEL GENERATORS should be the backup system for batteries and generators running pumps for cooling near ALL NUCLEAR POWER PLANTS AND EARTHQUAKE PROOF BLADDERS AND TANKS SHOULD HOUSE EXTRA FRESH WATER NEAR NUCLEAR REACTORS for just such an emergency. DRY ICE CAN BE DROPPED INTO THE POOLS AS WELL AS LOX OR LIQUID NITROGEN PUSHED THROUGH STEEL PIPING SUBMERGED AND EXPOSED IN THE WATER TO ALLOW COOLING BUT HOSPITALS HAVE LARGE TANKS WHICH CAN BE RELOADED WHEN RUNNING OUT LIKE I FOUND AT TAMPA GENERAL HOSPITAL when working there for 8.5 years.

Why CNN does not show super tankers pulled or pushed loaded with fresh water from even CHINA if necessary into the harbor near the stricken plants or cities to supply fresh potable water for drinking and bathing is still a mystery. 100 foot coils of black plastic piping coiled and attached to tanks with shower handles and ball valve would allow any WORKERS to be decontaminated with fresh warm water or showers but I still like the DECONTAMINATION PROCEDURES WRITTEN BY DR. DOUG ROKKE FOR THE U.S. MILITARY.

Roads should have 100 tankers with fresh water coming into the area like milk trucks to let the people fill gallon zip lock bags which can be doubling as latrine items storing urine and fecal matter to be picked up and burned. COLD WEATHER SIGNALS USE OF DRUM LINERS TWO PER PERSON STEP INSIDE THEN PULL ONE OVER YOUR HEAD AND SLEEP WARM CAMP JAPAN CAN MAKE IT !

Don't start on not having fuel when there are thousands upon thousands of vehicles with gasoline tanks still containing gas sitting everywhere plus trucks and boats using diesel

would power super generators which have not arrived for reasons unknown. SNAP LIGHTS or shake and snap which last 12 hours giving off light could be used by people inside rolling latrines over 55 gallon drums with seal top lids LEFT OPEN for pickup on barges and dropping or washing contents off barges at sea to make fish food. People cringed when I recommended taking the dead to barges, having a prayer service then taking barges to sea, chopping up the dead with SUPER STRONG WOOD CHIPPERs then washing down the barges after all are made into FISH FOOD. What are you going to do ? Burn the bodies releasing RADIOACTIVE PARTICLES INTO THE JAPANESE AIR, WATER, SAND AND SOIL OR ON PLANTS AS IT FALLS BACK TO THE GROUND WHILE BODIES ARE CREMATED ? Now that is smart !

See <http://www.scribd.com/ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved including digging perhaps less than 2 hours on site. HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. STOP THE LEAK - ABSOLUTELY. Prevent further cracks if there is an explosion MAYBE NOT but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR

CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, THEN PLANT OR POUND THICK STEEL PLATES INTO THE GROUND TO ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS PUSHING THE PLATE OVER THE PATCH OF RUBBER ONLY TO STOP THE LEAK BEFORE CRACKING MORE THEN SEAL ALL IN HYDRAULIC CEMENT ! How long does that take and you have stopped the leak or crack ! HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !

Think of Japan building a SEAWALL when they pound special plates in the ground then sealing same they POUR CEMENT FOOTERS after sealing the sea water away with pumps DE WATERING the area for a few hours at least. HOW HARD CAN THAT BE TO VISUALIZE.

Now think of 10 mil thick 3 FT SQUARE BAGS then find barges of Concrete in 80 pound bags, Take a few tanker trucks with cement trucks and load the cement trucks with the proper mixture and you have a CEMENT PLANT. Due to the radiation the CEMENT might have to come from inland in those trucks but CEMENT PUMPS like HI-RISE BUILDERS use pouring flooring UP will push the slurry mix any height required and it is CRITICAL to verify FRESH WATER and proper mixture of HYDRAULIC CEMENT to make it set up quickly.

Professionally submitted FREE to the NRC and people of Japan.

Ralph Charles Whitley, Sr. CFC0326321
Tampa Phone : (813-286-2333) SKYPE: ralphwhitleysr
040211 @ 11:21 AM Eastern Saturday



Ralph Charles Whitley, Sr. CFC032631
Backflow Prevention, Inc.
4532 W. Kennedy Blvd. PMB-276
Tampa, Florida 33609-2042 USA
Phone: (813-286-2333)

SCRIBID ID: ralphwhitleysr
SKYPE ID: ralphwhitleysr

SCRIBD WEB PAGE: <http://www.scribd.com/ralphwhitleysr>

(backflow.prevention@verizon.net) 6

FREE Animations for your email - by IncrediMail!

Click Here!



Bonaccorso, Amy

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr. [backflow.prevention@verizon.net]
Sent: Sunday, April 03, 2011 12:06 PM
To: cgjak@alaska.com; info@cgjapanatlanta.org; infocul@cgjbos.org; ryoji@japancc.org; jic@japancc.org; cgjd-pr@quest.net; japaninfo@ggjsf.org; info@cgjapansea.org; jet@ws.mofa.go.jp; APFN; APFN-1; tilo@socom.mil
Cc: POTUS_Office Of The President; mailtothechief@cnn.com; Senator Bill Nelson; Rep. Paul; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckeel@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov; will.weatherford@myfloridahouse.gov; rick.scott@eog.myflorida.com; NRC Allegation
Subject: NEW EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container THEN DAMAGE CONTROL TECHNIQUE FOLLOWED SEALING THE ...
Importance: High



LADIES AND GENTLEMEN:

NOT TOO MANY OF YOU NUCLEAR POWER PLANT OPERATORS OR OWNERS HAVE WORKED WITH FLOWING WATER FROM CRACKS IN EARTH/STEEL BULKHEADS OR EVEN POOLS OR CONCRETE ENCLOSURES UNDERGROUND.

Make no mistake, AMERICA and other Nations are at risk should US PROFESSIONALS NOT PROVIDE SOUND VERIFIABLE METHODS TO SOLVE ODD PROBLEMS YOUR NUCLEAR POWER PEOPLE DO NOT ENCOUNTER. Check with any City, State or County SEWER OR WATER DEPARTMENT PROFESSIONALS and they will confirm the information shown below to be sound and will work every single time. Key is only provide enough pressure to STOP THE LEAK not cause further failure of damaged concrete sections but allow extra rubberized seals like one would use on top of canning jars except these will be 1 inch thick but compressible rubber to seal the leak until a full pour can be accomplished with HYDRAULIC CEMENT not average cement.

FLOWING WATER CANNOT BE STOPPED WITH CEMENT POUR EVEN IN THE CONCRETE VAULTS PRESSURE WOULD PUSH IT OUT AND YOU CAN JACKHAMMER THE CEMENT WHICH WILL LIFT AWAY FROM THE FLOW OF CONCRETE THEN PREPARE THE AREA PROPERLY AND APPLY THE PILLOW OF RUBBERIZED MATERIAL THEN PLATE OF STEEL THEN PRESS FROM THE OTHER SIDE AGAINST THE PLATE WITH ITEMS YOU HAVE SEEN NAVAL PERSONNEL FIGHT WATER LEAKING THROUGH HULLS ON SUBMARINES TO SHIPS OF THE FLEET. ASK THE NAVY PERSONNEL WITH DAMAGE CONTROL HOW TO STOP THE LEAK AND THEN POUR HYDRAULIC CEMENT TO STOP ANY FURTHER EXPANSION OF THE CRACK. THEY ARE THE EXPERTS MR. PRESIDENT AND JAPANESE EMBASSY STAFF. USE THEM AND THEIR KNOWLEDGE PLUS THEY MAY EVEN LOAN YOU THE EQUIPMENT SO YOU CAN WATCH A FLICK AND DO IT EVERY TIME !

U.S. NAVY HAS DONE THIS IN DAMAGE CONTROL SCHOOLS AND SHIPBOARD FOR OVER 100 YEARS.

See <http://www.scribd.com/ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of **QUICKRETE HYDRAULIC CEMENT** which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. **CHECK WITH THE EXPERTS IN JAPAN** since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete **WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE !** Time involved including digging perhaps less than 2 hours on site. **HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA** that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. **STOP THE LEAK - ABSOLUTELY.** Prevent further cracks if there is an explosion **MAYBE NOT** but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

[[[REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, NO STEEL AS YOU HAVE ANOTHER SIDE WHERE PLATE CAN BE ATTACHED OR HELD IN PLACE WHILE WORKERS ATTACH SPECIAL SCREW BOLTS TO PRESS AGAINST THE PLATE AND RUBBER TO SEAL THE LEAK WITHOUT CAUSING

FRACTURE OF MORE. ONCE WATER IS STOPPED THEN AND ONLY THEN FILL THE ENTIRE AREA WITH HYDRAULIC CEMENT IN THAT CONCRETE UNDERGROUND FOUR WALLED CONTAINER USING ONLY FRESH WATER AFTER PUMPING DOWN ALL WATER REMAINING IN THE CEMENT PIT USED FOR ELECTRICAL CONNECTIONS AND FEEDING THE WATER TO THE SEA.

REMEMBER ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS EVEN SCREW JACKS ONLY PUSHING THE PLATE OVER THE PATCH OF RUBBER ENOUGH TO ONLY STOP THE LEAK BEFORE CAUSING MORE PRESSURE CRACKING MORE OF DAMAGED CONCRETE THEN SEAL ALL IN HYDRAULIC CEMENT !

**How long does that take and you have stopped the leak or crack !
HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !]]]**

Professionally submitted FREE to the NRC and people of Japan Sunday April 3, 2011 as I fear not giving you the information could risk MASSIVE NUCLEAR EXPLOSIONS AT THE PLANT AND ENDANGER AMERICA AS WELL AS THE ENTIRE PLANET.

Have passport and medications for four weeks Mr. President and Japanese Embassy Staff should I be needed there. Japan Airlines can bring me to your Nation if necessary as this inability to follow professional recommendations is unbelievable. WHERE IS THE MAN TO HOLD HIS HAND OVER THE WATER FLOW LIKE PUTTING A FINGER IN A RESERVOIR LEAK ? IS THAT PROFESSIONALISM DROPPING CONCRETE ONTO A FIRE HYDRANT FLOW OF WATER IN A CONCRETE BOX IN THE GROUND ? 1 POUND OF WATER PRESSURE PER HOW MANY INCHES COLUMN OF WATER STORED ? I WAS TAUGHT 14.7 INCHES COLUMNAR EQUALS 1 POUND. How tall is the building and how many pounds of pressure will be pushing water through the crack. THIS IS NOT A FISH TANK FOLKS ! CHECK WITH THE NAVAL SUBMARINE SERVICE AND SHIPS OF THE NAVY....JAPANESE NAVY GOES THROUGH SIMILAR TRAINING BUT YOU HAVE A BASE IN JAPAN PLUS FLEET OFFSHORE TO DRAW INFORMATION FROM..... BORROW THEIR EQUIPMENT AND SCREW JACKS FOR THAT CEMENT SECTION.

**Ralph Charles Whitley, Sr. CFC032631
Backflow Prevention, Inc.
Phone: 813-286-2333
Tampa**

040311 @ 12:05 PM Eastern Sunday

Remember:

Storage of spent rods deep in the Salt Water Ocean some 3,000 feet might find the temperature staying at 40 degrees F continuous. Same of your refrigerator at home perhaps. I have been provided with 8 NEW RADStickers from the Inventor Gordhan Patel at J.P. Labs for use by any of your personnel who will be working at the plant and these stickers attach to ID's or Drivers Licenses so the radiation levels can be measured daily, weekly and monthly. Would also recommend placing some eventually on ALL equipment then a log started to see how much radiation the equipment plus personnel are subjected to in the line of work completed at the sites now or in the future. RADTRIAGE units work inside or outside as suggested but the RADSticker can be read after each shift if necessary for workers.

Remember STORAGE OF RODS SPENT OR REMOVED FROM REACTORS means WATER WITH DRY ICE COOLING FOR TRIP TO SEA THEN DROPPING RODS going to 12,000 feet depth in THE BATHYPELAGIC ZONE below the 3,000 feet to say 12,000 FEET might find 36 degrees F. Each is suitable perhaps for storage of spent fuel rods in very deep sections of sea water. Such no doubt was the bulk of laughter when it was recommended that spent rods be deep six stored rather than underground in areas like the scrubbed YUCCA MOUNTAIN storage which might now be for members of Congress and their families to live in any Nuclear Emergency in the USA. Wonder if SUPER THICK MILL PLASTIC SHEATING WOULD ALLOW SEALING FROM SALT WATER YET LET COLD GO THROUGH TO KEEP RODS SAFE ? Check with NRC personnel on this NEW STORAGE METHOD " DEEP SIX " IDEA !

As a State of Florida Certified Plumbing Contractor let me tell you that SOLAR ENERGY/DIESEL GENERATORS should be the backup system for batteries and generators running pumps for cooling near ALL NUCLEAR POWER PLANTS AND EARTHQUAKE PROOF BLADDERS AND TANKS SHOULD HOUSE EXTRA FRESH WATER NEAR NUCLEAR REACTORS for just such an emergency. DRY ICE CAN BE DROPPED INTO THE POOLS AS WELL AS LOX OR LIQUID NITROGEN PUSHED THROUGH STEEL PIPING SUBMERGED AND EXPOSED IN THE WATER TO ALLOW COOLING BUT HOSPITALS HAVE LARGE TANKS WHICH CAN BE RELOADED WHEN RUNNING OUT LIKE I FOUND AT TAMPA GENERAL HOSPITAL when working there for 8.5 years.

Why CNN does not show super tankers pulled or pushed loaded with fresh water from even CHINA if necessary into the harbor near the stricken plants or cities to supply fresh potable water for drinking and bathing is still a mystery. 100 foot coils of black plastic piping coiled and attached to tanks with shower handles and ball valve would allow any WORKERS to be decontaminated with fresh warm water or showers but I still like the DECONTAMINATION PROCEDURES WRITTEN BY DR. DOUG ROKKE FOR THE U.S. MILITARY.

Roads should have 100 tankers with fresh water coming into the area like milk trucks to let the people fill gallon zip lock bags which can be doubling as latrine items storing urine and fecal matter to be picked up and burned. COLD WEATHER SIGNALS USE OF DRUM LINERS TWO PER PERSON STEP INSIDE THEN PULL ONE OVER YOUR HEAD AND SLEEP WARM CAMP JAPAN CAN MAKE IT!

Don't start on not having fuel when there are thousands upon thousands of vehicles with

gasoline tanks still containing gas sitting everywhere plus trucks and boats using diesel would power super generators which have not arrived for reasons unknown. SNAP LIGHTS or shake and snap which last 12 hours giving off light could be used by people inside rolling latrines over 55 gallon drums with seal top lids LEFT OPEN for pickup on barges and dropping or washing contents off barges at sea to make fish food. People cringed when I recommended taking the dead to barges, having a prayer service then taking barges to sea, chopping up the dead with SUPER STRONG WOOD CHIPPERS then washing down the barges after all are made into FISH FOOD. What are you going to do ? Burn the bodies releasing RADIOACTIVE PARTICLES INTO THE JAPANESE AIR, WATER, SAND AND SOIL OR ON PLANTS AS IT FALLS BACK TO THE GROUND WHILE BODIES ARE CREMATED ? Now that is smart !

See <http://www.scribd.com.ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved including digging perhaps less than 2 hours on site. HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. STOP THE LEAK - ABSOLUTELY. Prevent further cracks if there is an explosion MAYBE NOT but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, THEN PLANT OR POUND THICK STEEL PLATES INTO THE GROUND TO ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS PUSHING THE PLATE OVER THE PATCH OF RUBBER ONLY TO STOP THE LEAK BEFORE CRACKING MORE THEN SEAL ALL IN HYDRAULIC CEMENT ! How long does that take and you have stopped the leak or crack ! HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !

Think of Japan building a SEAWALL when they pound special plates in the ground then sealing same they POUR CEMENT FOOTERS after sealing the sea water away with pumps DE WATERING the area for a few hours at least. HOW HARD CAN THAT BE TO VISUALIZE.

Now think of 10 mil thick 3 FT SQUARE BAGS then find barges of Concrete in 80 pound bags, Take a few tanker trucks with cement trucks and load the cement trucks with the proper mixture and you have a CEMENT PLANT. Due to the radiation the CEMENT might have to come from inland in those trucks but CEMENT PUMPS like HI-RISE BUILDERS use pouring flooring UP will push the slurry mix any height required and it is CRITICAL to verify FRESH WATER and proper mixture of HYDRAULIC CEMENT to make it set up quickly.

Professionally submitted FREE to the NRC and people of Japan.

**Ralph Charles Whitley, Sr. CFC0326321
Tampa Phone : (813-286-2333) SKYPE: ralphwhitleysr
040211 @ 11:21 AM Eastern Saturday**



**Ralph Charles Whitley, Sr. CFC032631
Backflow Prevention, Inc.
4532 W. Kennedy Blvd. PMB-276
Tampa, Florida 33609-2042 USA
Phone: (813-286-2333)**

**SCRIBID ID: ralphwhitleysr
SKYPE ID: ralphwhitleysr**

SCRIBD WEB PAGE: <http://www.scribd.com/ralphwhitleysr>

(backflow.prevention@verizon.net)6



FREE Animations for your email - by IncrediMail!

Click Here!

Bel

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.
To: Bonaccorso, Amy; NRC Allegation; Senator Bill Nelson; rick.scott@eog.myflorida.com; mailtothechief@cnn.com; cjak@alaska.com; info@cglapanatlanta.org; info@who.int; Inquiries; tyoji@japancc.org; Dljnd49@aol.com; leurenmoret@yahoo.com
Cc: tobin.jennifer@nrc.gov; deavers.ron@nrc.gov; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; jovner.athenia.web@fisenate.gov; latvala.jack.web@fisenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckee@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@fisenate.gov; will.weatherford@myfloridahouse.gov
Subject: Fw: ADDITIONAL INFORMATION Re: NEW EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container THEN DAMAGE CONTROL ...
Date: Sunday, April 03, 2011 9:57:10 PM
Attachments: SENDER_EMAILbackflow@prevention@verizon@net.png
image0021.png
Importance: High



Amy Bonaccorso and others:

The problem in Japan can go INTERNATIONAL in a flash without people contacting professionals as indicated below. Thank you for your kind response to the OLD MAN WHO APPEARS TO BE EXPRESSING A "RANT" when in actual Truth the man is a Professional Injured from Cancer, recovering from Surgery with a large SKIN GRAFT DEEP ON RIGHT FOREARM, Scar behind Left Ear and bleeding yet advising Dr. Doug Rokke and Dr. Leuren Moret plus the President that I would GLADLY at 70 years old replace a young worker inside that facility.

SEE YOUR RESPONSE TO THOSE WORKING FOR NRC THEN REVIEW WHAT TRAINING I HAD AND HOW A DECORATED AMERICAN VETERAN AND PLANKOWNER FOR THE U.S.S. ENTERPRISE CVAN-65 COULD POSSIBLY KNOW ANYTHING ABOUT NUCLEAR RADIATION AND ACCIDENTS OR HOW TO STOP THE RADIATION LEAKS WHICH ANY STATE OF FLORIDA CERTIFIED PLUMBING CONTRACTOR WOULD KNOW!

I will, for information, attach your message BELOW FOR REVIEW. Right now this information is SUPER CRITICAL as all of the PLANET could suffer because someone throws away the messages as from a man with a RANT ? I even gave ALL ACROSS THE PLANET THE OPEN SOLUTION TO SELECT A SUPER DEEP ABYSS AND STORE THE SPENT FUEL FROM ALL NATIONS IN A CONTROLLED TEMPERATURE...even if you loose the opportunity to make ballast or Depleted Uranium Munitions from same. Remember NRC that YUCCA MOUNTAIN SPENT BILLIONS and has been closed down for storage. Where YOU will store all of the contaminated SAND FROM IRAQ, AFGHANISTAN, PAKISTAN and perhaps LIBYA is a mystery.

I say DEEP SIX IT....12,000 feet abyss is my first choice. You do not know what it means to offer YOUR LIFE to a young person so they can survive!

I remember a PO2 Monsoor who was with EOD Unit 2 who threw himself on a grenade at a young age to save his team. DID HE RANT TOO ? No Dragon Skin Body Armor but instead wore plate vests from Interceptor. Pinnacle Armor makes Dragon Skin Body Armor and they have never had a penetration from IED or bullet fired. Gee....what is the problem there... General's have stock in Interceptor ? I carry and have carried a ballistic clipboard since 1960's in law enforcement. Latest LEVEL III clipboards were donated to Tampa Police and Hillsborough County Sheriff's Office Tactical Response Team or Special Weapons And Tactics team members. Stupid RANT again ? Imagine every military person with such protection which would save lives. My Clipboards are about \$50 to manufacture and the hardest part is sealing and painting the FIBERGLASS 1/2 INCH THICK sections. BLAME UNCLE AND LAW ENFORCEMENT as they trained me along with the Shipyard when building U.S.S. Enterprise CVAN-65 as I am a PLANK OWNER !

4/3/12

DO READ AND REVIEW THE RANT BELOW AND THEN GET THOSE SPECIALISTS USING PROPER TECHNIQUES SINCE THEY HAVE LANDED IN TOKYO ! I KNOW YOU DO WANT TO STOP THE RADIATION WATER GOING INTO THE WATER AROUND THE PLANT. IF YOU GO THERE WEAR SPECIAL NAIL PROOF BOOTS !

**Ralph Charles Whitley, Sr.
040311 @ 9:55 PM Eastern Tampa**

-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.

Date: 4/3/2011 1:10:16 PM

To: news@worldnetdaily.com; Reporter Bob Unruh WND; WorldNetDaily

Subject: Fw: ADDITIONAL INFORMATION Re: NEW EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container THEN DAMAGE CONTROL TECHNIQUE FOLLOWED SEALING THE LEAK BEFORE POURING CONCRETE OR HYDRAULIC CEMENT..



Even the Japanese NAVY know how to solve the water leaking through that crack in electrical vault piping.

Ralph

-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.

Date: 4/3/2011 12:33:25 PM

To: cgjak@alaska.com; info@cgiapanatlanta.org; infocul@cgibos.org; ryoji@japancc.org; jic@japancc.org; cgjd-pr@quest.net; japaninfo@ggjsf.org; info@cgiapansea.org; jet@ws.mofa.go.jp; APFN; APFN-1; tilo@socom.mil

Cc: POTUS Office Of The President; mailto:thechief@cnn.com; Senator Bill Nelson; Rep. Paul; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckeel@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov; will.weatherford@myfloridahouse.gov; rick.scott@eog.myflorida.com; NRC Allegation

Subject: ADDITIONAL INFORMATION Re: NEW EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container THEN DAMAGE CONTROL TECHNIQUE FOLLOWED SEALING THE LEAK BEFORE POURING CONCRETE OR HYDRAULIC CEMENT..



REMEMBER:

ONE POUND PER SQUARE INCH EQUALS 2.3 FEET HIGH COLUMN OF WATER OR 28 INCHES COLUMN.

HOW TALL WAS YOUR BUILDING IN INCHES FROM TOP OF WATER TO UNDERGROUND CRACK AREA ?

FIRE HYDRANT PRESSURE TAKES SPECIAL SEALING FOLKS AND IF IT WAS A FLOW OF WATER YOU HAVE TO MATCH THE PRESSURE PLUS 5 PSI PERHAPS TO STOP THE FLOW FROM THE CRACK. Thinking 14.7 PSI atmospheric pressure does NOTHING when figuring WATER COLUMN AND THEN FIGURE SEA WATER COLUMN WHICH MAY BE DIFFERENT ALTOGETHER !

Atmospheric Pressure 14.7 PSI will support a column of water 33.9 feet high. Understanding 1 psi X 1ft/0.433 psi = 2.3 ft (or 28 inches)

Now measure the exterior upper level of the container where water TOP might be then figure in inches then divide by 28 to get pounds per square inch perhaps at the slit in the cement in the pit. Hope that illustrates what your problem may be. NOW remember apply ONLY ENOUGH PRESSURE on the rubber via the plate of steel and screws to STOP THE LEAK. Then pour the hydraulic cement.

NAVAL DAMAGE CONTROL HAVE THE TRAINING, FILMS AND EQUIPMENT TO STOP THAT LEAK IN 2 HOURS FLAT !

JAPANESE NAVY AND U.S. NAVY ALL PRACTICE THIS PROBLEM, ESPECIALLY ON SUBMARINES !

**Ralph Charles Whitley, Sr. CFC032631
Backflow Prevention, Inc.
Phone: 813-286-2333
040311 @ 12:32 PM Eastern**



-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.

Date: 4/3/2011 12:05:57 PM

To: cgjak@alaska.com; info@cgjapanatlanta.org; infocul@cgibos.org; ryoji@japancc.org; jic@japancc.org; cgjd-pr@quest.net; japaninfo@ggjsf.org; info@cgjapansea.org; jet@ws.mofa.go.jp; APFN; APFN-1; tilo@socom.mil

Cc: POTUS Office Of The President; mailtothechief@cnn.com; Senator Bill Nelson; Rep. Paul; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckeel@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov; will.weatherford@myfloridahouse.gov; rick.scott@eog.myflorida.com; NRC Allegation

Subject: NEW EMERGENCY REVIEW FOR JAPAN NUCLEAR POWER PLANT CRISIS --- Deep Sea Water Temperatures for Cooling Rods Spent or Used. Special HYDRAULIC CEMENT to seal leak after Salt Water removed from container THEN DAMAGE CONTROL TECHNIQUE FOLLOWED SEALING THE LEAK BEFORE POURING CONCRETE OR HYDRAULIC CEMENT..



LADIES AND GENTLEMEN:

NOT TOO MANY OF YOU NUCLEAR POWER PLANT OPERATORS OR OWNERS HAVE WORKED WITH FLOWING WATER FROM CRACKS IN EARTH/STEEL BULKHEADS OR EVEN POOLS OR CONCRETE ENCLOSURES UNDERGROUND.

Make no mistake, AMERICA and other Nations are at risk should US PROFESSIONALS NOT PROVIDE SOUND VERIFIABLE METHODS TO SOLVE ODD PROBLEMS YOUR NUCLEAR POWER PEOPLE DO NOT ENCOUNTER. Check with any City, State or County SEWER OR WATER DEPARTMENT PROFESSIONALS and they will confirm the information shown below to be sound and will work every single time. Key is only provide enough pressure to STOP THE LEAK not cause further failure of damaged concrete sections but allow extra rubberized seals like one would use on top of canning jars except these will be 1 inch thick but compressible rubber to seal the leak until a full pour can be accomplished with HYDRAULIC CEMENT not average cement.

FLOWING WATER CANNOT BE STOPPED WITH CEMENT POUR EVEN IN THE CONCRETE VAULTS PRESSURE WOULD PUSH IT OUT AND YOU CAN JACKHAMMER THE CEMENT WHICH WILL LIFT AWAY FROM THE FLOW OF CONCRETE THEN PREPARE THE AREA PROPERLY AND APPLY THE PILLOW OF RUBBERIZED MATERIAL THEN PLATE OF STEEL THEN PRESS FROM THE OTHER SIDE AGAINST THE PLATE WITH ITEMS YOU HAVE SEEN NAVAL PERSONNEL FIGHT WATER LEAKING THROUGH HULLS ON SUBMARINES TO SHIPS OF THE FLEET. ASK THE NAVY PERSONNEL WITH DAMAGE CONTROL HOW TO STOP THE LEAK AND THEN POUR HYDRAULIC CEMENT TO STOP ANY FURTHER EXPANSION OF THE CRACK. THEY ARE THE EXPERTS MR. PRESIDENT AND JAPANESE EMBASSY STAFF. USE THEM AND THEIR KNOWLEDGE PLUS THEY MAY EVEN LOAN YOU THE EQUIPMENT SO YOU CAN WATCH A FLICK AND DO IT EVERY TIME !

U.S. NAVY HAS DONE THIS IN DAMAGE CONTROL SCHOOLS AND SHIPBOARD FOR OVER 100 YEARS.

See <http://www.scribd.com/ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved including digging perhaps less than 2 hours on site. HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER

CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. **STOP THE LEAK - ABSOLUTELY.** Prevent further cracks if there is an explosion **MAYBE NOT** but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

[[[REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, NO STEEL AS YOU HAVE ANOTHER SIDE WHERE PLATE CAN BE ATTACHED OR HELD IN PLACE WHILE WORKERS ATTACH SPECIAL SCREW BOLTS TO PRESS AGAINST THE PLATE AND RUBBER TO SEAL THE LEAK WITHOUT CAUSING FRACTURE OF MORE. ONCE WATER IS STOPPED THEN AND ONLY THEN FILL THE ENTIRE AREA WITH HYDRAULIC CEMENT IN THAT CONCRETE UNDERGROUND FOUR WALLED CONTAINER USING ONLY FRESH WATER AFTER PUMPING DOWN ALL WATER REMAINING IN THE CEMENT PIT USED FOR ELECTRICAL CONNECTIONS AND FEEDING THE WATER TO THE SEA.

REMEMBER ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS EVEN SCREW JACKS ONLY PUSHING THE PLATE OVER THE PATCH OF RUBBER ENOUGH TO ONLY STOP THE LEAK BEFORE CAUSING MORE PRESSURE CRACKING MORE OF DAMAGED CONCRETE THEN SEAL ALL IN HYDRAULIC CEMENT !

How long does that take and you have stopped the leak or crack ! HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT

WATER OR IT WILL FAIL !]]]

Professionally submitted FREE to the NRC and people of Japan Sunday April 3, 2011 as I fear not giving you the information could risk MASSIVE NUCLEAR EXPLOSIONS AT THE PLANT AND ENDANGER AMERICA AS WELL AS THE ENTIRE PLANET.

Have passport and medications for four weeks Mr. President and Japanese Embassy Staff should I be needed there. Japan Airlines can bring me to your Nation if necessary as this inability to follow professional recommendations is unbelievable. WHERE IS THE MAN TO HOLD HIS HAND OVER THE WATER FLOW LIKE PUTTING A FINGER IN A RESERVOIR LEAK ? IS THAT PROFESSIONALISM DROPPING CONCRETE ONTO A FIRE HYDRANT FLOW OF WATER IN A CONCRETE BOX IN THE GROUND ? 1 POUND OF WATER PRESSURE PER HOW MANY INCHES COLUMN OF WATER STORED ? I WAS TAUGHT 14.7 INCHES COLUMNAR EQUALS 1 POUND. How tall is the building and how many pounds of pressure will be pushing water through the crack. THIS IS NOT A FISH TANK FOLKS ! CHECK WITH THE NAVAL SUBMARINE SERVICE AND SHIPS OF THE NAVY.....JAPANESE NAVY GOES THROUGH SIMILAR TRAINING BUT YOU HAVE A BASE IN JAPAN PLUS FLEET OFFSHORE TO DRAW INFORMATION FROM..... BORROW THEIR EQUIPMENT AND SCREW JACKS FOR THAT CEMENT SECTION.

Ralph Charles Whitley, Sr. CFC032631

Backflow Prevention, Inc.

Phone: 813-286-2333
Tampa



040311 @ 12:05 PM Eastern Sunday

Remember:

Storage of spent rods deep in the Salt Water Ocean some 3,000 feet might find the temperature staying at 40 degrees F continuous. Same of your refrigerator at home perhaps. I have been provided with 8 NEW RADStickers from the Inventor Gordhan Patel at J.P. Labs for use by any of your personnel who will be working at the plant and these stickers attach to ID's or Drivers Licenses so the radiation levels can be measured daily, weekly and monthly. Would also recommend placing some eventually on ALL equipment then a log started to see how much radiation the equipment plus personnel are subjected to in the line of work completed at the sites now or in the future. RADTRIAGE units work inside or outside as suggested but the RADSticker can be read after each shift if necessary for workers.

Remember STORAGE OF RODS SPENT OR REMOVED FROM REACTORS means WATER WITH DRY ICE COOLING FOR TRIP TO SEA THEN DROPPING RODS going to 12,000 feet depth in THE BATHYPELAGIC ZONE below the 3,000 feet to say 12,000 FEET might find 36 degrees F. Each is suitable perhaps for storage of spent fuel rods in very deep sections of sea water. Such no doubt was the bulk of laughter when it was recommended that spent rods be deep six stored rather than underground in areas like the scrubbed YUCCA MOUNTAIN storage which might now be for members of Congress and their families to live in any Nuclear Emergency in the USA. Wonder if SUPER THICK MILL PLASTIC SHEATING WOULD ALLOW SEALING FROM SALT WATER YET LET COLD GO THROUGH TO KEEP RODS SAFE ? Check with NRC personnel on this NEW STORAGE METHOD " DEEP

SIX " IDEA !

As a State of Florida Certified Plumbing Contractor let me tell you that SOLAR ENERGY/DIESEL GENERATORS should be the backup system for batteries and generators running pumps for cooling near ALL NUCLEAR POWER PLANTS AND EARTHQUAKE PROOF BLADDERS AND TANKS SHOULD HOUSE EXTRA FRESH WATER NEAR NUCLEAR REACTORS for just such an emergency. DRY ICE CAN BE DROPPED INTO THE POOLS AS WELL AS LOX OR LIQUID NITROGEN PUSHED THROUGH STEEL PIPING SUBMERGED AND EXPOSED IN THE WATER TO ALLOW COOLING BUT HOSPITALS HAVE LARGE TANKS WHICH CAN BE RELOADED WHEN RUNNING OUT LIKE I FOUND AT TAMPA GENERAL HOSPITAL when working there for 8.5 years.

Why CNN does not show super tankers pulled or pushed loaded with fresh water from even CHINA if necessary into the harbor near the stricken plants or cities to supply fresh potable water for drinking and bathing is still a mystery. 100 foot coils of black plastic piping coiled and attached to tanks with shower handles and ball valve would allow any WORKERS to be decontaminated with fresh warm water or showers but I still like the DECONTAMINATION PROCEDURES WRITTEN BY DR. DOUG ROKKE FOR THE U.S. MILITARY.

Roads should have 100 tankers with fresh water coming into the area like milk trucks to let the people fill gallon zip lock bags which can be doubling as latrine items storing urine and fecal matter to be picked up and burned. COLD WEATHER SIGNALS USE OF DRUM LINERS TWO PER PERSON STEP INSIDE THEN PULL ONE OVER YOUR HEAD AND SLEEP WARM CAMP JAPAN CAN MAKE IT !

Don't start on not having fuel when there are thousands upon thousands of vehicles with gasoline tanks still containing gas sitting everywhere plus trucks and boats using diesel would power super generators which have not arrived for reasons unknown. SNAP LIGHTS or shake and snap which last 12 hours giving off light could be used by people inside rolling latrines over 55 gallon drums with seal top lids LEFT OPEN for pickup on barges and dropping or washing contents off barges at sea to make fish food. People cringed when I recommended taking the dead to barges, having a prayer service then taking barges to sea, chopping up the dead with SUPER STRONG WOOD CHIPPERs then washing down the barges after all are made into FISH FOOD. What are you going to do ? Burn the bodies releasing RADIOACTIVE PARTICLES INTO THE JAPANESE AIR, WATER, SAND AND SOIL OR ON PLANTS AS IT FALLS BACK TO THE GROUND WHILE BODIES ARE CREMATED ? Now that is smart !

See <http://www.scribd.com/ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved

including digging perhaps less than 2 hours on site. **HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA** that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. **STOP THE LEAK - ABSOLUTELY.** Prevent further cracks if there is an explosion **MAYBE NOT** but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, THEN PLANT OR POUND THICK STEEL PLATES INTO THE GROUND TO ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS PUSHING THE PLATE OVER THE PATCH OF RUBBER ONLY TO STOP THE LEAK BEFORE CRACKING MORE THEN SEAL ALL IN HYDRAULIC CEMENT ! How long does that take and you have stopped the leak or crack ! **HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !**

Think of Japan building a **SEAWALL** when they pound special plates in the ground then sealing same they **POUR CEMENT FOOTERS** after sealing the sea water away with pumps **DE WATERING** the area for a few hours at least. **HOW HARD CAN THAT BE TO VISUALIZE.**

Now think of 10 mil thick 3 FT SQUARE BAGS then find barges of Concrete in 80 pound bags, Take a few tanker trucks with cement trucks and load the cement trucks with the proper mixture and you have a **CEMENT PLANT.** Due to the radiation the **CEMENT** might have to come from inland in those trucks but **CEMENT PUMPS** like **HI-RISE BUILDERS** use pouring flooring UP will push the slurry mix any height required and it is **CRITICAL** to verify **FRESH WATER** and proper mixture of **HYDRAULIC CEMENT** to make it set up quickly.

Professionally submitted **FREE** to the NRC and people of Japan.

Ralph Charles Whitley, Sr. CFC0326321
Tampa Phone 1/813-286-2333, SKYPE: ralphwhitleysr
040211 @ 11:21 AM Eastern Saturday



Hello Mr. Whitley:

Thank you for your offer to help with the crisis in Japan. It's reassuring to see how helpful and dedicated private citizens have been in light of this disaster.

At this time, the NRC is not accepting volunteers, but you may want to check with your local Red Cross.

Amy

From: Tobin, Jennifer
Sent: Monday, March 21, 2011 4:14 PM
To: Bonaccorso, Amy
Cc: Deavers, Ron
Subject: RE: Reply to Dr. Doug Rokke comments and information for Dr. Leuren Moret Re: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING ---EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MI

Amy/Ron,

If you read down, he wants to offer himself instead of the lives of young Japanese workers. You could send him the standard response for volunteer helpers. I hope that helps!

Jenny (Tobin) Wollenweber
Export Licensing Officer
Office of International Programs
Office: 301-415-2328

From: Bonaccorso, Amy
Sent: Monday, March 21, 2011 4:10 PM
To: Tobin, Jennifer
Cc: Deavers, Ron
Subject: FW: Reply to Dr. Doug Rokke comments and information for Dr. Leuren Moret Re: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING ---EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MI
Importance: High

Not sure if this person needs a response or not....it seems like a rant.

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr. [mailto:backflow.prevention@verizon.net]
Sent: Saturday, March 19, 2011 12:17 PM
To: dlind49@aol.com; leurenmoret@yahoo.com; cgjak@alaska.com; info@cgjapanatlanta.org; infocul@cgjbos.org; ryoji@japancc.org; info@cgimia.org; jet@embjapan.org; NRC Allegation; POTUS_Office Of The President; mailtothechief@cnr.com; Senator Bill Nelson; Senator John McCain; Rep. Paul
Subject: Reply to Dr. Doug Rokke comments and information for Dr. Leuren Moret Re: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING ---EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MIG...
Importance: High



Dr. Rokke and Dr. Moret:

I have the 28 SEP 90 revised TB 9-1300-278 which was revised in July 1996 perhaps and now we leave it up to the experts such as yourself and Dr. Moret to give advice on decontaminating people and equipment at the plants or even extending times on site with added safety using shields or SPACE SUITS since Japan has similar programs.

Should Depleted Uranium Munitions be used by ALLIES to attack Libya forces then more problems will surface with decontamination from particles.

Explosions involving Nuclear Power plants has a new danger for people and that is also RELEASE OF ASBESTOS OR OTHER FIBER CONTAMINATES WHICH WILL ENTER LUNGS AND LUNGS ENCAPSULATE PARTICLES THEN SCAR TISSUE CUTS DOWN LUNG CAPACITY IN A MESOTHELEOMA TYPE DISEASE LIKE ASBESTOSIS WHICH WILL KILL CHILDREN AND ADULTS SOME 20-30 YEARS LATER.

Having ILD or Interstitial Lung Disease personally from Asbestos Exposure work in the U.S. Navy at Shipyards and in Boiler areas plus Welding in same, I can tell you the loss of lung capacity is like throwing marbles over a fiber rug then trying to blow air through the rug from underneath then increasing the marbles thickness until you can only get a small amount of AIR through the rug to the surface. SMOTHERING is best describing results Same applies to particles inhaled and encapsulated by Lung protective measures. Where do you get NEW LUNGS ?

The SPACE SUIT with external tank modifications for use in vehicles IMHO would have allowed placement of many monitors plus even directing flow of water cannons, targeting dosimeters readings with a zoom lens or directing work anticipated since the rods and storage areas are not full of steel shot or lead shot let alone covered with lead sheeting or blankets like hospitals use to stop radiation escaping.

I remember the AIRCRAFT which were amphibious and landed on salt water pulling in a load then flying OFF the water to drop super amounts of water on FOREST FIRES. Too bay those special aircraft were not BROUGHT OVER ON CARRIERS OR BARGES THEN UNLOADED NEAR AN AIRFIELD TO BE USED DROPPING UNLIMITED TONS OF SEA WATER ONTO THE ENTIRE PLANT AREAS to not only load compartments but also to wash off or decontaminate ground and buildings. But WHAT does any 70 year old former Navy and Army Veteran know of such problems and solutions ?

Had the CATTLE AND ANIMALS needed FEED dropped on fields by air drops low level over JAPAN they would have been done. NOW IS THE TIME TO USE AIR DROPS OF FOOD AND WATER, EVEN RAMEN NOODLES AND WATER IN PALLETS ALONG WITH TOILET PAPER, ZIP LOCK BAGS, DRUM LINERS AND OTHER CLEAR PLASTIC BAGS FOR USE GETTING FRESH WATER FROM PLANT LEAVES VIA TRANSPIRATION OR SOLAR STILL TECHNIQUES SINCE THOUSANDS OF CONTAINERS <CLEAR PLASTIC BOXES AND GLASS BOXES> ARE THERE TO USE SOLAR STILL TECHNIQUES WHICH THE KIDS WILL SET UP IN THE SUNLIGHT ALL OVER ON ROOFS, PATIO AND OPEN FIELDS GETTING ALL OF THE FRESH WATER

THEY CAN HANDLE PLUS THE FUEL IN THOSE STRANDED VEHICLES CAN BE PLACED IN CONTAINERS TO BURN WATER CONTAINERS TO MAKE SOUPS.....OR RAMEN NOODLES CAN BE EATEN RAW OUT OF THE PACKAGE ONE PACK PER MEAL WILL KEEP PEOPLE ALIVE !

CAMP JAPAN WILL LEARN TO GET INSIDE PLASTIC CLEAR DRUM LINERS THEN PULL ANOTHER OVER THEIR HEADS AND TUCK COVER OVER BODY COVERINGS TO KEEP WARM IN THIS EMERGENCY !

THE MOST IMPORTANT ITEM STILL IS UNANSWERED RELATIVE TO USE OF IRIIDIUM 9555 SAT PHONES AND LAPTOPS TO COUPLE THEM WITH S.P.O.T. GPS LOCATORS TO ALLOW REPORTING OF ALL THE NAMES AND FORMER ADDRESSES OF ALL SURVIVORS SO THEIR FAMILIES CAN RELAX KNOWING THEY ARE SAFE. JAPAN SHOULD HAVE A WEB SITE WITH THIS INFORMATION FOR ALL WHO DESIRE TO SEE THE NAMES OF SURVIVORS TO STOP PEOPLE FROM ANXIETY ATTACKS !

300,000 BODY BAGS OR 6 MIL THICK CONTRACTOR BAGS WITH STICK ON ITEMS FOR WRITING NAMES OR IDENTIFICATION WILL BE NECESSARY FOR THIS MASSIVE DISASTER WHICH CAN GO SUPER HIGH IF FRESH WATER IS NOT OBTAINED VIA TANKERS TO THE PLANT OFFSHORE LOCATION THE BARGES CAN BRING THE MATERIAL OVER TO THE SHORE AND DRAW OFF CONCRETE MIXING POINTS FOR PLACING OR PUMPING SEVERAL STORIES HIGH INTO SUPER ROUND TALL STEEL CIRCULAR ITEMS WHICH SHOULD BE IN THE PROCESS AT A SHIPYARD WELDING SHOP AND TRANSFERRED TO BARGES THEN BROUGHT TO SHORE AND MOVED BY HELICOPTER WITH WELDERS OR PERHAPS SPECIAL HINGES MADE IN THE SHIPYARD ALLOWING THEM TO BE SET AROUND BUILDINGS SEALING THEM WITH CONCRETE AS FAR OUT AND AS HIGH AS THEY DESIRE.

OLD PLUMBING TRICK ! EVEN wood with steel straps can do the same thing and be light enough a large helicopter can set it down on the earth then concrete pouring started as STEEL RODS placed 3 or 4 feet in length into ground will allow pushing down and keeping it in position. HINT !

TWO MEN or TWO WOMEN can take a bag of concrete mix, use a specific amount of water, pour into a special 6 mil thick bag and roll the bag back and forth on the ground sealed to allow nothing to escape and it can be used to make a POUR quality amount. Use of SUPER CEMENT TRUCKS with barges of cement or bringing cement from plants to the plant of the same consistency with FRESH WATER MIX would allow dropping loads into pumper units run by generators like used in giant building footers and decks pouring even at several stories high.....with the form in place the cement could be poured making a round or square cement containment which once set up should smother any FIRE and the only problem would be since no rebar is used the water must be fresh and with sea water on rods that must be replaced with FRESH WATER or the items could really stop the pour or cause explosions if gasses built up.



I prefer to think steel shot or lead shot pellets should be dropped IF lead and steel would help then pour fresh water and see if the situation can be corrected and IF NOT sealing with CONCRETE MIGHT BE THE ONLY OPTION but remember the warning on SALT WATER MIXING WITH CONCRETE WILL NOT MAKE IT WORK SO LEAD OR STEEL SHOT 4-6 FEET THICK MIGHT BE REQUIRED BEFORE ADDING PLASTIC PELLETS TO SEAL STEEL FROM FRESH CONCRETE SUPER HEAVY 5,000 PSI HYDRAULIC CEMENT QUALITY WHICH WILL SET UP IN SOME WATER.

Instant communications via CB RADIO with SPEAKER and Magnetic Mount Antenna is my best form of communications for many miles using one on top of a building. Fresh water from WELLS went way over the heads of people in Japan with the agricultural wells not even being considered and quite frankly ONLY YOU have sent back anything direct to me from all of the messages forwarded Dr. Rokke. Tells me something about the OTHER PROFESSIONALS IN JAPAN AND OUR GOVERNMENT.

Sadly people may think of using Salt Water for mixing concrete and pouring or pumping same into any containers which could be round and lightweight to hold the concrete but again SALT WATER DOES NOT MIX WELL WITH CONCRETE AND MAY STOP IT FROM SETTING UP PROPERLY CAUSING FRACTURES WHICH COULD BE DEADLY. That said we have backed off sending any advice to the embassy staff at phone 202-328-2187 FAX or 202-328-2184 FAX lines for Japanese Embassy in Washington nor do we communicate with the Embassies via Internet cgjak@alaska.com info@cgjapanatlant.org infocul@cgjbos.org ryoji@japancc.org infor@cgima.org jet@embjapan.org since NO ONE ANSWERS !

As one recovering from Cancer Surgery with an huge 4 inch X 4 inch deep wound with skin graft on left forearm PLUS neck cutting area on left ear behind ear I am limited and in pain or WE would have tried to come to the site. The Left Thigh 4 x 4 area where they took the right arm graft is still healing after surgery 03/28/11 and constant daily changes of bandages might prevent this 70 year old from being on any crews Have SKYPE can be there visually but no one called or asked.





**My personal pain level and medications from the James A Haley VA HOSPITAL
would
NOT stop me from volunteering to assist as at 70 years old I could replace someone
YOUNGER working at or near the plant who might receive a fatal dose of radiation.**

Ralph Charles Whitley, Sr.
Tampa 813-286-2333
SKYPE: ralphwhitleysr

CP

031911 @ 12:15 PM Eastern

-----Original Message-----

From: dlind49@aol.com
Date: 3/18/2011 1:56:14 PM
To: backflow.prevention@verizon.net
Subject: Re: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING --- EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MIGHT HELP IN JAPAN.....Re: SEA WATER SPRAYED BY FIRE PROTECTION PRESSU

the personal decon procedures are in tb 9-1300-278 you should have that from before

doug

-----Original Message-----

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr. <backflow.prevention@verizon.net>
To: rick.scott@eog.myflorida.com; jennifer.carroll@eog.myflorida.com; CFO Jeff Atwater <CFO.Jeff.Atwater@myfloridacfo.com>; pam.iorio@tampagov.net; tampacitycouncil@tampagov.net; Beckner, Kevin <BecknerK@HillsboroughCounty.ORG>; higginbothama@hillsboroughcounty.org
Sent: Fri, Mar 18, 2011 9:36 am
Subject: Fw: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING ---EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MIGHT HELP IN JAPAN.....Re: SEA WATER SPRAYED BY FIRE PROTECTION PRESSU



FYI

-----Original Message-----


From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.
Date: 3/18/2011 9:23:46 AM
To: mailto:tothechief@cnn.com; POTUS Office Of The President; Senator Bill Nelson; Senator John McCain; Rep. Paul; APFN; APFN-1
Cc: tilo@socom.mil; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rousou@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckee@myfloridahouse.gov

shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov;
will.weatherford@myfloridahouse.gov; [Gordhan N. Patel](#); Albrodsky@aol.com

Subject: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER....Re: REMOTE MONITORS FOR RADIATION AT PLANT SAT TRANSMITTING --- EMERGENCY REVIEW - SPACE SUIT FOR SPACE WALK MIGHT HELP IN JAPAN.....Re: SEA WATER SPRAYED BY FIRE PROTECTION PRESSURE UNITS CAN GO TO THE TOP EASILY IN JAPAN

Ladies and Gentlemen: FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER !

RECOMMEND IMMEDIATE VIEWING OF "SILKWOOD" FROM 1983 AS YOUR WORKERS ARE NOT PROPERLY DECONTAMINATED DAILY AND SADLY ONLY THE MILITARY MAY KNOW OF THE MEASURES WHICH MUST BE TAKEN.....AMERICAN MILITARY KNOW FROM YEARS OF PRACTICE AND WORKING ALL OVER THE PLANET !



The MOVIE AVAILABLE ON NETFLIX NO DOUBT OR DIRECT is the story of Karen Silkwood, a metallurgy worker at a plutonium processing plant who was purposefully contaminated, psychologically tortured and possibly murdered to prevent her from exposing blatant worker safety violations at the plant. Meryl Streep, Kurt Russell and CHER plus others provided a glimpse of what decontamination MUST TAKE PLACE for workers out and about exposed to radiation. Nothing similar is apparently being considered for those brave men and women who work in the plant NOR are the proper DOSIMETER'S WORN OR IN PLACE TO REALLY ALLOW READINGS DAILY AT ALL SITES !

Professionally I have attempted to contact members of the Government of the United States plus Japan with little or no effect as not one PALLET OF WATER, COKE, DR. PEPPER, FOOD, TOILET PAPER, DISPOSABLE CLOTHING, CLEAR PLASTIC DRUM LINERS AND MEDICINES HAVE APPARENTLY BEEN AIR LIFTED AND PARACHUTE DELIVERY DROPPED LOW ALTITUDE ON THOUSANDS OF ACRES OF FARM LAND TO BE PICKED UP AND DISTRIBUTED TO THE PEOPLE.

**AMERICAN AND JAPANESE SPACE WALK SUITS
WOULD PROTECT WORKERS !
SAME SPACE SUIT MODIFIED TO ACCEPT TANKS OF**

OXYGEN ON VEHICLES WOULD ALLOW LONG STAYS OUT IN SUSPECTED CONTAMINATION AREAS THEN RECORDINGS TAKEN BUT DECONTAMINATION MUST OCCUR BY FIRE TRUCK SPRAYING WATER ON EQUIPMENT AND SPACE SUITS BEFORE SAME ARRIVE AT DECONTAMINATION AREAS, GET OUT AND GO THROUGH SPECIAL PROCEDURES TO CHANGE CLOTHING, WASH, BE CHECKED AND THEN GO TO SLEEP BEFORE THE NEXT CREW ENTER, REMOVE STREET CLOTHING AND DON SPACE WALK SUITS LEFT FROM THE PRIOR CREWS AND PROCESS KEEPS GOING OVER AND OVER ALLOWING ALL TO DRIVE AWAY FROM PLANT LONG DISTANCES TO DECONTAMINATION AREAS LIKE MILITARY DO HERE IN AMERICA !

NOT EVEN AMERICAN OR JAPANESE SPACE WALK SUITS HAVE BEEN ISSUED TO WORKERS FOR ASSISTING ON THE OUTSIDE OF THE PLANTS AS I BELIEVE THOSE SUITS CAN BE MODIFIED TO ACCEPT AND USE TANK AFTER TANK OF OXYGEN STRAPPED TO EVEN LARGE GOLF CARTS IF NOT OPEN JEEPS OR HUMVEE TO ALLOW PEOPLE TO GO FOR LONG PERIODS INTO THE REACTOR AREAS TO ATTACH DOSIMETERS, READ RADIATION, PLANT MORE DOSIMETERS TO TRANSMIT READINGS IF NECESSARY THEN THOSE SAME PEOPLE COULD RETURN TO SPECIAL AREAS TO BE WASHED DOWN WITH SOAP AND WATER, TAKEN THROUGH SECURE DECONTAMINATION WHERE THEY ARE SCRUBBED WITH FRESH WELL WATER, SOAPED AND DRIED WITH TOWELS GOING INTO SEALED RADIATION CONTAINERS, CHANGE ALL CLOTHING AND SHOES OR BOOTS WHICH ARE THEN BAGGED IN SPECIAL CONTAINERS, ISSUED NEW STREET CLOTHES LIKE DOCTOR GOWNS, TAKEN TO SLEEP OR EAT AND REST AREAS THEN GO THROUGH THE SAME PROCESS IN REVERSE PREPARING FOR THE NEXT DAYS WORK. SPACE SUITS WITH BACKPACKS AND CONNECTORS ALLOWING USE OF LARGE OXYGEN CONTAINERS STRAPPED TO OPEN JEEPS OR HUMVEES TO ALLOW THEM TO GO BACK INTO THE WORK AREA DAILY DECONTAMINATED !

SADLY THE FRESH WATER TANKERS FROM EVEN 50 MILES AWAY ARE NOT RUMBLING IN TO THE DISASTER AREAS SUPPLYING UNLIMITED DRINKING WATER FOR THOSE RESIDENTS TRAPPED IN AREAS WITH LITTLE OR NO FOOD. DEEP WATER WELLS, PALLET AFTER PALLET OF CANNED FOOD, SODA, TOILET PAPER, PLASTIC OR PAPER CLOTHING THROWAWAY TYPES COULD BE ON ALL LOCATIONS. DRUM LINERS 55 GALLON WITH 60 OR MORE PER CONTAINER COULD ALLOW PEOPLE TO STEP INTO ONE DRUM LINER CLOTHED, PLACE ANOTHER DRUM LINER OVER THEIR HEAD AND BE PROTECTED FROM THE COLD WEATHER AND ABLE TO SLEEP WITHOUT TAKING AWAY OXYGEN. WHERE ARE THESE NEEDED SUPPLIES FOR THOSE ISOLATED FROM TOKYO NEAR THE EVACUATED PEOPLE TAKING REFUGE AND WHERE IN THE HELL ARE THE AIR DROPS FROM CHINA, KOREA, AMERICA AND YES EVEN JAPAN LET ALONE TRUCK AFTER TRUCK OF SUPPLIES AND WATER CRITICAL TO

EVERYONE IN THE AREA.

MY RECOMMENDATIONS FOR PLANT TRANSPIRATION, SOLAR STILL, CB RADIO WITH MAGNETIC MOUNT ANTENNAE AND SPEAKERS TO PLAY MESSAGES HOT WIRED OR USED WITH CIGARETTE LIGHTER POWER CONNECTIONS TO PLAY MESSAGES AND MUSIC ARE NOT THERE FOLKS. PEOPLE NEED MEDICINES, AREAS NEED TO GET LISTS OF MEDICINES AND WITH GPS S.P.O.T. LOCATORS THE HELICOPTERS CAN DROP MEDICINES ORDERED BY PHYSICIANS BEFORE THE PEOPLE REALLY START DYING AND YOU HAVE TO INCREASE THE BODY BAGS TO 1,000,000 OR MORE SIMPLY BECAUSE THE PEOPLE DO NOT HAVE FOOD, WATER, MEDICINES AND WHO IN THE HELL IS NOT COLLECTING THE GASOLINE PUMPING FROM STRANDED VEHICLES INTO TANKERS OR 5 GALLON GAS CANS TO ALLOW GENERATORS TO BE RUNNING THESE TEMPORARY FACILITIES HOUSING MANY THOUSANDS OF PEOPLE.

KEEP IN MIND BODIES CAN WASH WITH SEA WATER AND SPECIAL SOAPS ARE AVAILABLE TO KEEP PEOPLE CLEAN. COMMODES AND URINALS CAN BE REPLACED WITH LATRINES ON WHEELS OVER 55 GALLON CONTAINERS WHICH CAN BE MOVED ON WHEELS. FREE TOILET PAPER, SPECIAL SOLAR OR BATTERY POWER LIGHTING OR EVEN SNAP LIGHTS WOULD ALLOW PRIVACY AREAS WHERE MEN, WOMEN AND CHILDREN COULD USE THE LATRINES, GO TO THE AREAS AND WASH THEIR HANDS AND BODIES PLUS CHANGE INTO PAPER CLOTHING DISPOSABLE UNTIL EVERYTHING GETS BACK TO NORMAL AND THE CLOTHING CAN BE BAGGED WITH DRUM LINERS, MARKED WITH NAMES AND IDENTIFICATION WHILE THE PEOPLE HAVE ACCESS TO IRIDIUM 9555 SAT PHONES WHICH ALLOW COMPUTERS TO HOOK UP AND TRANSMIT VIA LAPTOP THEIR EXACT LOCATION TO THE JAPANESE AUTHORITIES WHO CAN SET UP A WEB SITE FOR ADDING NAMES OF THOSE UNABLE TO COMMUNICATE WITH FAMILY MEMBERS WORLDWIDE. HERE IN AMERICA I WOULD PRAY THIS GOVERNMENT WOULD RELAX ALL REGULATIONS AND ALLOW DISH NETWORK TO SET UP MOBILE CONNECTIONS TO THE INTERNET TO ALLOW TV AND INTERNET USE BY LAPTOP COMPUTERS.

BEFORE YOU RULE OUT CB RADIO 40 CHANNEL WITH MAGNETIC MOUNT ANTENNAE AND SPEAKERS FOR HAILING OR ANNOUNCEMENTS DO REMEMBER ONE UNIT ON THE HIGHEST BUILDING POSSIBLE CAN ZONE AN ENTIRE CITY FOR TRANSMISSION WELL OVER 5 MILES IN EACH DIRECTION. CHECK WITH JAPANESE RADIO AMATEUR FOLKS WHO USE SAME PLUS CB SINCE 1950'S.

AGAIN. NO ONE HAS COMMUNICATED NOR ASKED ANY QUESTIONS AND VERY LITTLE INDICATIONS ANYONE IS RECEIVING THESE MESSAGES SO THIS WILL INDEED BE MY FINAL MESSAGE SENT ON THE PROBLEMS IN JAPAN !

Remember that LEAD PELLETS like in shotgun shells were filled with, which are still available to seal the reactor areas, could have been poured into any area to seal radiation perhaps but I still pray you people will start bringing FRESH WATER from lakes, rivers, streams, UNDERGROUND IRRIGATION WELLS to give the people and plants fresh water.

Good LUCK with protecting your plants, workers and those living IN JAPAN because someone is not reading every message sent then RESPONDING YOU HAVE RECEIVED SAME and checking with NRC or Japan Equivalent to the Nuclear Regulatory Commission and MILITARY on same. No one LOOKED AT SILKWOOD IN THEIR LIFETIME ? NO ONE EVER SAW A WATER WASHDOWN SYSTEM ON A DESTROYER !

Visit the SITE IDENTIFIED BELOW and see what Dr. Leuren Moret and Dr. Doug Rokke say about your RADIATION EXPOSURE PROBLEM !

Ralph Charles Whitley, Sr. CFC032631
Tampa, Florida
031811 @ 9:23 AM Eastern



Go visit www.apfn.org/apfn/du.htm I donated this ITEM to another Veteran !

FINAL MESSAGE FROM A FORMER U.S. NAVY NBC WARFARE PETTY OFFICER !

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.



Ralph Charles Whitley, Sr. CFC032631
Backflow Prevention, Inc.
4532 W. Kennedy Blvd. PMB-276
Tampa, Florida 33609-2042 USA
Phone: 813-286-2333

SCRIBID ID: ralphwhitleysr
SKYPE ID: ralphwhitleysr

SCRIBD WEB PAGE: <http://www.scribd.com/ralphwhitleysr>

Rel

From: Ruth DeLaMater Bundy or Ralph Charles Whitley, Sr.
To: NRC Allegation; mailto:thechief@cnn.com; POTUS Office Of The President; Senator Bill Nelson; tilo@socom.mil; rick.scott@eog.myflorida.com
Cc: Harry Smith; Harry Lee Coe; betty.reed@myfloridahouse.gov; CristV@hillsboroughcounty.org; dana.young@myfloridahouse.gov; darryl.rouson@myfloridahouse.gov; greg.steube@myfloridahouse.gov; james.grant@myfloridahouse.gov; janet.cruz@myfloridahouse.gov; jim.boyd@myfloridahouse.gov; joyner.athenia.web@flsenate.gov; latvala.jack.web@flsenate.gov; rachel.burgin@myfloridahouse.gov; rachel@willienelson.com; rich.glorioso@myfloridahouse.gov; seth.mckee@myfloridahouse.gov; shawn.harrison@myfloridahouse.gov; storms.ronda.web@flsenate.gov; will.weatherford@myfloridahouse.gov
Subject: WHICH REACTOR IS LEAKING ? USE A FEW GALLONS OF FOOD DYE IN VARIOUS COLORS INSERTED IN THE REACTOR BY COLOR.
Date: Monday, April 04, 2011 9:49:04 AM
Attachments: SENDER_EMAILbackflow@@prevention@verizon@@net.png
Importance: High



FYI. Problem can go INTERNATIONAL quickly then those with tickets on the next NASA FLIGHT may have to land on the MOON FOREVER.

Why they do not use a few gallons of RED FOOD DYE to see which reactor is leaking that water is beyond me. Plumbers USE FOOD DYE to see if a commode is leaking, should work easily on boiling water in any plant....DUMP AND RUN then wait to see if the concrete pit shows RED, GREEN, BLUE.....ORANGE..... Then they locate the leaking item for further work.

SEE: http://en.wikipedia.org/wiki/Food_coloring BRILLIANT BLUE, BRILLIANT RED, BRILLIANT GREEN, ORANGE....four choices at least.

Still believe that trench wall can be sealed or shored up with 1 inch thick rubber mat steel plate and pressure from the other side. THOUSANDS OF CARS AND TRUCKS means thousands of JACKS WITH HANDLES AVAILABLE INSTANTLY plus cutting bars of steel to put in that space before jacking pressure UNTIL IT STOP LEAKING ONLY. Then wrap everything with plastic and POUR HYDRAULIC CEMENT TO SEAL ! Hard....yes in radiation. Will it work to show leaking section or Nuclear Reactor leaking by COLOR A B S O L U T E L Y ! Works every day in America !

County CREWS and CITY SEWER AND WATER CREWS ARE EXPERTS IN SEALING LEAKS IN CONCRETE !

So are Military DAMAGE CONTROL SPECIALISTS ! Military RADIATION MONITOR SPECIALISTS ARE IN JAPAN. Hope the SUBMARINE and FLEET DAMAGE CONTROL PEOPLE ARE ASKED !

NOT MY JOB ! HAVE SKYPE CAN TRAVEL VIA INTERNET IF CALLED OR NOTIFIED OF TIME EASTERN TO BE ONLINE

My skype account is ralphwhitleysr !

Rel

**Ralph
040411 @ 9:48 AM Eastern TICK TOCK TICK TOCK**

4/3/12



REMEMBER:

ONE POUND PER SQUARE INCH EQUALS 2.3 FEET HIGH COLUMN OF WATER OR 28 INCHES COLUMN.

HOW TALL WAS YOUR BUILDING IN INCHES FROM TOP OF WATER TO UNDERGROUND CRACK AREA ?

FIRE HYDRANT PRESSURE TAKES SPECIAL SEALING FOLKS AND IF IT WAS A FLOW OF WATER YOU HAVE TO MATCH THE PRESSURE PLUS 5 PSI PERHAPS TO STOP THE FLOW FROM THE CRACK. Thinking 14.7 PSI atmospheric pressure does NOTHING when figuring WATER COLUMN AND THEN FIGURE SEA WATER COLUMN WHICH MAY BE DIFFERENT ALTOGETHER !

Atmospheric Pressure 14.7 PSI will support a column of water 33.9 feet high. Understanding $1 \text{ psi} \times 1 \text{ ft} / 0.433 \text{ psi} = 2.3 \text{ ft}$ (or 28 inches)

Now measure the exterior upper level of the container where water TOP might be then figure in inches then divide by 28 to get pounds per square inch perhaps at the slit in the cement in the pit. Hope that illustrates what your problem may be. NOW remember apply ONLY ENOUGH PRESSURE on the rubber via the plate of steel and screws to STOP THE LEAK. Then pour the hydraulic cement.

NAVAL DAMAGE CONTROL HAVE THE TRAINING, FILMS AND EQUIPMENT TO STOP THAT LEAK IN 2 HOURS FLAT !

JAPANESE NAVY AND U.S. NAVY ALL PRACTICE THIS PROBLEM, ESPECIALLY ON SUBMARINES !

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION: Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved including digging perhaps less than 2 hours on site. HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA that is why we recommended using a rubber section and steel

supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. **STOP THE LEAK - ABSOLUTELY.** Prevent further cracks if there is an explosion **MAYBE NOT** but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

[[[REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, NO STEEL AS YOU HAVE ANOTHER SIDE WHERE PLATE CAN BE ATTACHED OR HELD IN PLACE WHILE WORKERS ATTACH SPECIAL SCREW BOLTS TO PRESS AGAINST THE PLATE AND RUBBER TO SEAL THE LEAK WITHOUT CAUSING FRACTURE OF MORE. ONCE WATER IS STOPPED THEN AND ONLY THEN FILL THE ENTIRE AREA WITH HYDRAULIC CEMENT IN THAT CONCRETE UNDERGROUND FOUR WALLED CONTAINER USING ONLY FRESH WATER AFTER PUMPING DOWN ALL WATER REMAINING IN THE CEMENT PIT USED FOR ELECTRICAL CONNECTIONS AND FEEDING THE

WATER TO THE SEA.

REMEMBER ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS EVEN SCREW JACKS ONLY PUSHING THE PLATE OVER THE PATCH OF RUBBER ENOUGH TO ONLY STOP THE LEAK BEFORE CAUSING MORE PRESSURE CRACKING MORE OF DAMAGED CONCRETE THEN SEAL ALL IN HYDRAULIC CEMENT !

How long does that take and you have stopped the leak or crack ! HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !]]]

Professionally submitted FREE to the NRC and people of Japan Sunday April 3, 2011 as I fear not giving you the information could risk MASSIVE NUCLEAR EXPLOSIONS AT THE PLANT AND ENDANGER AMERICA AS WELL AS THE ENTIRE PLANET.

Have passport and medications for four weeks Mr. President and Japanese Embassy Staff should I be needed there. Japan Airlines can bring me to your Nation if necessary as this inability to follow professional recommendations is unbelievable. WHERE IS THE MAN TO HOLD HIS HAND OVER THE WATER FLOW LIKE PUTTING A FINGER IN A RESERVOIR LEAK ? IS THAT PROFESSIONALISM DROPPING CONCRETE ONTO A FIRE HYDRANT FLOW OF WATER IN A CONCRETE BOX IN THE GROUND ? 1 POUND OF WATER PRESSURE PER HOW MANY INCHES COLUMN OF WATER STORED ? I WAS TAUGHT 14.7 INCHES COLUMNAR EQUALS 1 POUND. How tall is the building and how many pounds of pressure will be pushing water through the crack. THIS IS NOT A FISH TANK FOLKS ! CHECK WITH THE NAVAL SUBMARINE SERVICE AND SHIPS OF THE NAVY.....JAPANESE NAVY GOES THROUGH SIMILAR TRAINING BUT YOU HAVE A BASE IN JAPAN PLUS FLEET OFFSHORE TO DRAW INFORMATION FROM..... BORROW THEIR EQUIPMENT AND SCREW JACKS FOR THAT CEMENT SECTION.

Remember:

Storage of spent rods deep in the Salt Water Ocean some 3,000 feet might find the temperature staying at 40 degrees F continuous. Same of your refrigerator at home perhaps. I have been provided with 8 NEW RADStickers from the Inventor Gordhan Patel at J.P. Labs for use by any of your personnel who will be working at the plant and these stickers attach to ID's or Drivers Licenses so the radiation levels can be measured daily, weekly and monthly. Would also recommend placing some eventually on ALL equipment then a log started to see how much radiation the equipment plus personnel are subjected to in the line of work completed at the sites now or in the future. RADTRIAGE units work inside or outside as suggested but the RADSticker can be read after each shift if necessary for workers.

Remember STORAGE OF RODS SPENT OR REMOVED FROM REACTORS means WATER WITH DRY ICE COOLING FOR TRIP TO SEA THEN DROPPING RODS going to 12,000 feet depth in THE BATHYPELAGIC ZONE below the 3,000 feet to say 12,000 FEET might find 36 degrees F. Each is suitable perhaps for storage of spent fuel rods in very deep sections of sea water. Such no doubt was the bulk of laughter when it was recommended that spent rods be deep six stored rather than underground in areas like the scrubbed YUCCA MOUNTAIN storage which might now be for members of Congress and their families to live in any Nuclear Emergency in the USA. Wonder if SUPER THICK MILL PLASTIC SHEATING WOULD ALLOW SEALING FROM SALT WATER YET LET COLD GO THROUGH TO KEEP RODS SAFE ? Check with NRC personnel on this NEW STORAGE METHOD " DEEP SIX " IDEA !

As a State of Florida Certified Plumbing Contractor let me tell you that SOLAR ENERGY/DIESEL GENERATORS should be the backup system for batteries and generators running pumps for cooling near ALL NUCLEAR POWER PLANTS AND EARTHQUAKE PROOF BLADDERS AND TANKS SHOULD HOUSE EXTRA FRESH WATER NEAR NUCLEAR REACTORS for just such an emergency. DRY ICE CAN BE DROPPED INTO THE POOLS AS WELL AS LOX OR LIQUID NITROGEN PUSHED THROUGH STEEL PIPING SUBMERGED AND EXPOSED IN THE WATER TO ALLOW COOLING BUT HOSPITALS HAVE LARGE TANKS WHICH CAN BE RELOADED WHEN RUNNING OUT LIKE I FOUND AT TAMPA GENERAL HOSPITAL when working there for 8.5 years.

Why CNN does not show super tankers pulled or pushed loaded with fresh water from even CHINA if necessary into the harbor near the stricken plants or cities to supply fresh potable water for drinking and bathing is still a mystery. 100 foot coils of black plastic piping coiled and attached to tanks with shower handles and ball valve would allow any WORKERS to be decontaminated with fresh warm water or showers but I still like the DECONTAMINATION PROCEDURES WRITTEN BY DR. DOUG ROKKE FOR THE U.S. MILITARY.

Roads should have 100 tankers with fresh water coming into the area like milk trucks to let the people fill gallon zip lock bags which can be doubling as latrine items storing urine and fecal matter to be picked up and burned. COLD WEATHER SIGNALS USE OF DRUM LINERS TWO PER PERSON STEP INSIDE THEN PULL ONE OVER YOUR HEAD AND

SLEEP WARM CAMP JAPAN CAN MAKE IT !

Don't start on not having fuel when there are thousands upon thousands of vehicles with gasoline tanks still containing gas sitting everywhere plus trucks and boats using diesel would power super generators which have not arrived for reasons unknown. SNAP LIGHTS or shake and snap which last 12 hours giving off light could be used by people inside rolling latrines over 55 gallon drums with seal top lids LEFT OPEN for pickup on barges and dropping or washing contents off barges at sea to make fish food. People cringed when I recommended taking the dead to barges, having a prayer service then taking barges to sea, chopping up the dead with SUPER STRONG WOOD CHIPPERs then washing down the barges after all are made into FISH FOOD. What are you going to do ? Burn the bodies releasing RADIOACTIVE PARTICLES INTO THE JAPANESE AIR, WATER, SAND AND SOIL OR ON PLANTS AS IT FALLS BACK TO THE GROUND WHILE BODIES ARE CREMATED ? Now that is smart !

See <http://www.scribd.com/ralphwhitleysr> as these items needed NOW in Japan were provided on the Internet for the earthquake in Haiti from a Florida Contractor!

NOW FOR NUCLEAR REACTOR LEAK WITH WATER CONTAMINATION:
Ever hear of QUICKRETE HYDRAULIC CEMENT which almost sets up in water which can be poured outside a container area with a crack while de-watering through pumps and special piping with filters occurs keeping the area dry until a few cement trucks can pull up and the entire load forced into a hole which will also cause cement to seal the crack and come inside the container a small amount. Plumbing Contractors USE hydraulic cement for leaks with septic tanks which are concrete and steel. CHECK WITH THE EXPERTS IN JAPAN since WE have to mix only what we will use in 3 minutes so several people with those 10 mil thick bags or super powerful mixing items can allow mixing and pouring quickly into the hole sealing the crack then cement trucks with different cement mixture can apply a concrete WEDGE WITH STEEL SUPPORT PILINGS TO KEEP IT ALL IN PLACE ! Time involved including digging perhaps less than 2 hours on site. HYDRAULIC CEMENT MUST BE PLACED QUICKLY INTO THE AREA that is why we recommended using a rubber section and steel supported by pilings and plate with hydraulic jacks. Gives you a little more time to work out the problems stopping the water flow and allowing de-watering of the soil.

<http://www.quikrete.com/ProductLines/HydraulicWaterStopCementPro.asp>

http://www.quikrete.com/PDFs/DATA_SHEET-Hydraulic%20Water-Stop%20Cement%201126.pdf

FIRST REQUIREMENT STOP THE LEAK WITH MATTING AND THEN POUR CONCRETE, EVEN HYDRAULIC INSIDE IF DESIRED AND THE LEVEL OF WATER CAN BE BROUGHT DOWN IN THE CONTAINER:

No need to try to worry when one can place even thick rubberized matting over a crack then reinforce the outer crack with steel and use 12 inch wide steel sections pounded into the ground then apply pressure over the plate with jacks before pouring all in concrete. **STOP THE LEAK - ABSOLUTELY.** Prevent further cracks if there is an explosion **MAYBE NOT** but then one can use the huge circular container welded in place where you would seal same all around building then pour concrete over the top some 20 feet high and buried some 10 feet in the ground or more sealing everything ! Read what was recommended then check it out immediately.

REMEMBER 1 FOOT THICK RUBBER MAT CUT X FEET SQUARE OVER CRACK IN WALL OR CONTAINER ALLOWING 12 INCHES UP, SIDES AND DOWN FOR FUTURE CRACKS, THEN PLANT OR POUND THICK STEEL PLATES INTO THE GROUND TO ALLOW A FORMED CUT SECTION OF STEEL TO BE LOWERED THEN HYDRAULIC JACKS PUSHING THE PLATE OVER THE PATCH OF RUBBER ONLY TO STOP THE LEAK BEFORE CRACKING MORE THEN SEAL ALL IN HYDRAULIC CEMENT ! How long does that take and you have stopped the leak or crack ! **HYDRAULIC CEMENT MUST ONLY BE MIXED WITH FRESH WATER FOLKS.....NO SALT WATER OR IT WILL FAIL !**

Think of Japan building a **SEAWALL** when they pound special plates in the ground then sealing same they **POUR CEMENT FOOTERS** after sealing the sea water away with pumps **DE WATERING** the area for a few hours at least. **HOW HARD CAN THAT BE TO VISUALIZE.**

Now think of 10 mil thick 3 FT SQUARE BAGS then find barges of Concrete in 80 pound bags, Take a few tanker trucks with cement trucks and load the cement trucks with the proper mixture and you have a **CEMENT PLANT.** Due to the radiation the **CEMENT** might have to come from inland in those trucks but **CEMENT PUMPS** like **HI-RISE BUILDERS** use pouring flooring **UP** will push the slurry mix any height required and it is **CRITICAL** to verify **FRESH WATER** and proper mixture of **HYDRAULIC CEMENT** to make it set up quickly.

Professionally submitted FREE to the NRC and people of Japan.



FREE Animations for your email - by IncrediMail!

Click Here!

Lee, Richard

From: Larzelere, Alex [alex.larzelere@nuclear.energy.gov]
Sent: Monday, April 04, 2011 4:29 PM
To: DL-NITSolutions
Subject: Slides for Today's Call
Attachments: image001.jpg; 0404 S-1 Briefing rev 1.pptx

Everyone,

Here is the material for today's call.

Alex

Alex R. Larzelere
Director, Advanced Modeling and Simulation Office
Office of Nuclear Energy (NE-71)
U.S. Department of Energy
202-586-1906
Alex.Larzelere@nuclear.energy.gov



4/3/14

Coyne, Kevin

From: Coyne, Kevin
Sent: Tuesday, April 05, 2011 12:31 PM
To: Stutzke, Martin
Cc: Hudson, Daniel; Correia, Richard
Subject: FW: SOARCA likely to be referenced, questioned tomorrow
Attachments: Level 3 PRA RIC_hudson-d-h.pdf

Importance: High

Marty -

I have attached the Level 3 RIC presentation. If you could add a bit more commentary and context to the following bullets and forward to Rich I'd very much appreciate it (e.g., is there any context to add to WASH-1400, NUREG-1150, etc...). Also feel free to revise, edit, or collapse the bullets:

- A Level 3 Probabilistic Risk Assessment (PRA) considers:
 - A range of initiating event categories (e.g., fires, flooding, seismic, and plant equipment failures)
 - Plant response to postulated
 - Core damage progression
 - Radiological release, weather, evacuation, and public health consequences
 - Goal is to quantify risk in a systematic manner
- Prior studies estimating nuclear power plant risk to public
 - WASH-740 (March 1957)
 - WASH-1400 (October 1975)
 - NUREG-1150 (December 1990)
- NRC staff initiative for a comprehensive site Level 3 PRA based on:
 - PRA and technical advances since NUREG-1150
 - Interest in site accident risk versus reactor accident risk
 - Desire to use a more integrated and consistent analysis approach
 - Enhance NRC staff PRA capability by developing in-house risk expertise
- Commission tasking (SRM M100218)
 - Engage internal and external stakeholders in formulating plan and scope for future actions
 - Commission provided conditional support for Level 3 PRA related activities
 - Requested the staff to provide options for proceeding with Level 3 PRA (staff plans to provide an options SECY paper to Commission in July)
- Potential uses of a Level 3 PRA
 - Inform policymaking and rulemaking
 - Focus NRC's inspection program
 - Resolution of generic safety issues
 - Prioritization of safety research programs

From: Santiago, Patricia
Sent: Tuesday, April 05, 2011 11:31 AM
To: Coyne, Kevin; Stutzke, Martin
Cc: Correia, Richard; Wagner, Katie; Lee, Richard
Subject: FW: SOARCA likely to be referenced, questioned tomorrow
Importance: High

FYI

I know Dan and Doug are out and wanted to make sure you had the request. It is related to the congressional briefings that Brian has been doing related to Japan.

thanks

From: Sheron, Brian

Sent: Tuesday, April 05, 2011 11:24 AM

To: Santiago, Patricia; Correia, Richard

Cc: Uhle, Jennifer; Gibson, Kathy

Subject: FW: SOARCA likely to be referenced, questioned tomorrow

See below. Can I get some background bullets on SOARCA and level 3 PRA within a couple of hours?

From: Rihm, Roger

Sent: Tuesday, April 05, 2011 11:17 AM

To: Sheron, Brian

Subject: FW: SOARCA likely to be referenced, questioned tomorrow

It seems this hearing is going everywhere. I know you are sending over some material on dry cask storage. Can you also provide a limited amount of background material on SOARCA and level 3 PRAs? I have the one pagers from NUREG 1925 to start with. Thx.

From: Powell, Amy

Sent: Tuesday, April 05, 2011 11:10 AM

To: Virgilio, Martin

Cc: Rihm, Roger; Shane, Raeann; Schmidt, Rebecca; Sheron, Brian

Subject: SOARCA likely to be referenced, questioned tomorrow

Marty –

OCA got a heads up from Mr. Waxman's staff that he and Rep. DeGette may reference the concept of SOARCA, work to date, and ask related questions at tomorrow's hearing. Dr. Sheron did a briefing for a number of House Energy and Commerce staffers that referenced ongoing work on this; staff was impressed so encouraged their bosses to ask about it (understanding that it is evolving, draft, preliminary, etc.).

Amy

Amy Powell

Associate Director

U. S. Nuclear Regulatory Commission

Office of Congressional Affairs

Phone: 301-415-1673



RIC 2011
Comprehensive Site Level 3
Probabilistic Risk Assessment (PRA)

Dan Hudson
Office of Nuclear Regulatory Research
March 8, 2011




Presentation Objectives

- Provide updated information to external stakeholders about this evolving NRC staff initiative.
- Encourage external stakeholder engagement and participation in upcoming activities.

2



Importance of Level 3 PRAs



Risk Characterization:

Level 1 PRA
Level 2 PRA
Level 3 PRA

Key Message:

A Level 3 PRA is required to estimate the integrated risk to the public from all hazards.

3



Historical Perspective

- **Prior studies estimating risk to public**
 - WASH-740 (March 1957)
 - WASH-1400 (October 1975)
 - NUREG-1150 (December 1990)
- **PRA Policy Statement (August 1995)**
 - Implementation of risk-informed regulation

Key Message: Even before implementation of risk-informed regulation, the NRC set a precedent for periodically updating its understanding of nuclear reactor accident risk.

4



Comprehensive Site Level 3 PRA

- **NRC staff initiative based on:**
 - Advances since NUREG-1150
 - Interest in site accident risk versus reactor accident risk
- **Commission tasking**
 - Engage internal and external stakeholders in formulating plan
 - Provide options for proceeding with Level 3 PRA activities

Key Message: The NRC staff believes it is time to conduct a new site Level 3 PRA to update and improve our understanding of nuclear site accident risk.

5



Comprehensive Site Level 3 PRA (cont.)

- **Phase 1 – Scoping Study (FY2010-FY2011)**
- **Phase 2 – Pilot Study (start in FY2012)**
- **Phase 3 – Follow-on studies (as needed)**

Key Message: To optimize cost-benefit, the NRC staff is using a three-phased approach to conducting new Level 3 PRA activities.

6



Scoping Study Objectives

- Develop options for the following aspects of a potential site Level 3 PRA pilot study:
 - Scope of the analysis and PRA technology to be used
 - Perspectives on future uses of results
 - Site selection attributes
 - Resource estimates
- Identify NRC staff's recommendation for the pilot study
- Obtain external stakeholder support

7



Potential Pilot Study Objectives

- Update and improve our understanding of nuclear site accident risk by:
 - Incorporating advances since NUREG-1150
 - Using a more integrated and consistent analysis approach
- Enhance our PRA capability by:
 - Integrating and bridging gaps between existing analytical tools
 - Developing risk analysis expertise

Key Message: This initiative is primarily an incremental improvement to existing analytical tools – not a large-scale developmental effort.

8



Potential Pilot Study Objectives (cont.)


- Demonstrate feasibility of conducting lower cost integrated Level 3 PRAs
- Evaluate the need for follow-on studies

Key Message: This initiative is primarily an incremental improvement to existing analytical tools – not a large-scale developmental effort.

9



Potential Pilot Study Scope



Key Message: The NRC staff is considering a more complete analysis using a better integrated and consistent approach.

10



Some Potential Future Uses

- Inform policymaking and rulemaking
- Focus NRC's inspection program
- Resolution of generic safety issues
- Prioritization of safety research programs

Key Message: Much like the NUREG-1150 PRAs, the results of a new site Level 3 PRA may be used to inform a variety of future regulatory activities.

11



Upcoming Important Activities

- Public meeting (March 21)
- Advisory Committee on Reactor Safeguards (ACRS) Full Committee Meeting (April 7-9)
- Commission paper submission (July 7)

Key Message: External stakeholder engagement and support are needed for this important NRC staff initiative to succeed.

12



Contact Information

Project Manager

Dan Hudson, RES/DRA
Daniel.Hudson@nrc.gov

Work: 301-251-7919
Fax: 301-251-7424

Mail Stop: C4A07M

Technical Monitor

Marty Stutzke, RES/DRA
Martin.Stutzke@nrc.gov

Work: 301-251-7614
Fax: 301-251-7424

Mail Stop: C4A07M

13



Acronyms and Abbreviations

ACRS	Advisory Committee on Reactor Safeguards
DRA	Division of Risk Analysis
NRC	U.S. Nuclear Regulatory Commission
PRA	Probabilistic Risk Assessment
RES	Office of Nuclear Regulatory Research
RIC	Regulatory Information Conference

14

From: OECD Nuclear Energy Agency [nea@oecd-nea.org]
Sent: Tuesday, April 05, 2011 12:32 PM
To: OECD Nuclear Energy Agency
Subject: OECD Nuclear Energy Agency: Monthly News Bulletin - April 2011



NEA MONTHLY NEWS BULLETIN

Nuclear Energy Agency



April 2011 | www.oecd-nea.org

New at the NEA

Nuclear safety and regulation

Radiological protection

Nuclear law

Nuclear science

New publications


Data Bank



New at the NEA

Responding to the nuclear accident at Fukushima


On 11 March 2011, Japan experienced a major earthquake followed by a tsunami of cataclysmic magnitude. The OECD Nuclear Energy Agency (NEA) wishes to express its condolences to all those who have been affected by this disaster. It has offered its assistance to the Japanese authorities as they address the very challenging situation at the Fukushima nuclear power plant. The NEA will be playing a key role in the evaluation of the accident and the dissemination of lessons learnt based on its various areas of expertise and its competence in addressing emergency and accident management issues. The following updates provide initial insights into some of the steps being taken by the NEA.



Nuclear safety and regulation

Flashnews activated to share accurate emergency information among nuclear regulators

On 11 March the NEA Working Group on Public Communication of Nuclear Regulatory Organisations (WGPC) activated the Flashnews system in response to the Fukushima accident. Flashnews allows for the fast exchange of information among national nuclear regulators and is used to help inform the public about nuclear events occurring around the world.




New and existing nuclear safety groups consider Fukushima implications

The NEA Committee on Nuclear Regulatory Activities (CNRA) will establish a senior-level task group to exchange information, co-ordinate activities and examine implications in relation to the Fukushima accident. Once established, members of the group will immediately begin exchanging information prior to the first meeting to be held in Paris in early May. The NEA Committee on the Safety of Nuclear Installations (CSNI) will focus on the technical aspects of safety questions raised by the accident. It will identify issues that could require in-depth evaluation by existing or new nuclear safety task groups. The Fukushima accident will be a special topic for discussion during the June CNRA and CSNI meetings and subsequent working group sessions. Please visit the [NEA website](http://www.oecd-nea.org) for more information on nuclear safety.

Radiological protection

INEX-4 and CRPPH meetings present opportunities to discuss Fukushima

The Fukushima accident will have a significant impact on NEA work in radiological protection. A meeting of the Working party on Nuclear Emergency Matters (WPNEM) on May 3-4 that inter alia will discuss the 4th International Nuclear Emergency Exercise (INEX-4) and the annual meeting of the Committee on Radiation Protection and Public Health (CRPPH) on 17-19 May will present the first international opportunities for experts in this field to discuss the preliminary feedback from emergency measures taken in Japan. A further INEX workshop is planned for 6-7 December 2011. During the May meeting, the CRPPH will submit for




4/3/11

approval a report summarising the resources needed to implement the International Commission on Radiological Protection (ICRP) Publication 60 recommendations into national law and an assessment of the resources that will be needed to implement the new ICRP 103 recommendations. This will provide member countries with information important for implementing these new recommendations as detailed in the International Basic Safety Standards for Protection Against Ionizing Radiation and for the Safety of Radiation Sources. More on NEA work in radiological protection can be found here.

Nuclear law

The legal aspects of the Fukushima accident


NEA Legal Affairs will dedicate a special session of the Nuclear Law Committee (NLC) on 15-16 June to discuss the accident at Fukushima and how the Japanese government intends to deal with liability and compensation for the resulting nuclear damage. In its capacity as secretariat, the NEA is prepared to accommodate discussions on member country initiatives in the field of third party liability for nuclear damage, especially where signatories to the 2004 protocols enhance their efforts for the entry into force of those protocols to provide better protection to potential victims of a nuclear accident. Legal questions related to the accident will be addressed in the June issue of the Nuclear Law Bulletin. Furthermore, the 2011 session of the International School of Nuclear Law will provide an opportunity for the most renowned international nuclear lawyers to exchange on the impacts, lessons learnt and consequences of this accident as it relates to international nuclear law. More information on nuclear law can be found here.



Nuclear science

Nuclear science groups prepared to reassess predictive capabilities

NEA nuclear science working parties and expert groups carry out technical studies in the areas of fuel cycle physics and chemistry, reactor physics, criticality safety, materials performance and radiation shielding. A key focus in each area is on the development, application and validation of modelling tools and their associated nuclear data. These tools are used by the nuclear industry in the design, operation and safety assessment of nuclear facilities including commercial nuclear power plants (NPPs). As details of the Fukushima accident emerge, and as the safety cases and emergency procedures for NPPs are reappraised, NEA nuclear science working parties and expert groups may be required to analyse new scenarios which characterise the evolution of the reactor core and the spent fuel ponds during such an event. Some of these scenarios might challenge the predictive capability of current modelling methods. In that case, new activities could be proposed and discussed by various nuclear science technical groups with the aim of targeting any shortfall in predictive capability, identifying possible methods developments to address the shortfall and providing the means to assess the accuracy of new methods developed. For more information on nuclear science, please visit the NEA website.



New publications

Free publications are available at this link. Paper copies may be requested by sending an e-mail.

The Nuclear Regulator's Role in Assessing Licensee Oversight of Vendor and Other Contracted Services
ISBN: 978-92-64-99157-6, 38 pages.

Publications on sale can be ordered at the OECD bookshop.

Data Bank

NEA Data Bank newsletter

Computer program services

New computer programs available

31-MAR-11	<u>CSNI2017</u>	MCCI-2 PROJECT, Melt Coolability and Concrete Interaction Phase 2 Project (Arrived)
29-MAR-11	<u>NEA-1857</u>	PHITS-2.24, Particle and Heavy Ion Transport code System (Tested)
28-MAR-11	<u>CCC-0295</u>	ELGATL, Calculation of Energy Spectra from Coupled Electron-Photon Slowing Down (Arrived)

22-MAR-11	<u>USCD1240</u>	VIM_NC, VIM color syntax for Nuclear Codes: NJOY, DRAGON, PARTISN, TORT, MONK, and MCNP (Tested)
16-MAR-11	<u>IAEA1287</u>	SHIELD, Monte-Carlo Code for Simulating Interaction of High Energy Hadrons with Complex Macroscopic Targets (Tested)
16-MAR-11	<u>IAEA0970</u>	STOPOW, Stopping Power of Fast Ions in Matter (Tested)
15-MAR-11	<u>USCD1238</u>	ALICE2011, Particle Spectra from HMS precompound Nucleus Decay (Tested)
07-MAR-11	<u>CCC-0767</u>	SWORD 3.2, SoftWare for Optimization of Radiation Detectors (Arrived)
03-MAR-11	<u>NEA-1856</u>	VESTA 2.0.3, Monte Carlo depletion interface code (Arrived)
03-MAR-11	<u>NEA-1210</u>	ZZ HATCHES-19, Database for radiochemical modelling (Tested)

About the NEA

NEA membership consists of 29 OECD countries. The mission of the NEA is to assist its member countries in maintaining and further developing, through international co-operation, the scientific, technological and legal bases required for a safe, environmentally friendly and economical use of nuclear energy for peaceful purposes. It provides authoritative assessments and forges common understandings on key issues, as input to government decisions on nuclear energy policy and to broader OECD policy analyses in areas such as energy and sustainable development. The information, data and analyses it provides draw on one of the best international networks of technical experts.

To unsubscribe from this bulletin, **please use this link**.

Lee, Richard

From: Kelly, John E (NE) [JohnE.Kelly@Nuclear.Energy.Gov]
Sent: Tuesday, April 05, 2011 4:13 PM
To: Lee, Richard
Subject: Re: Call to Japan

No calls scheduled
John E Kelly

From: Lee, Richard (NRC)
To: Kelly, John E (NE)
Sent: Tue Apr 05 15:41:15 2011
Subject: Call to Japan

Hi, John:

Do you a call to Japan today?. If yes, what time is it scheduled for?

Thx, Richard

4/3/11

Lee, Richard

From: Larzelere, Alex [alex.larzelere@nuclear.energy.gov]
Sent: Tuesday, April 05, 2011 4:30 PM
To: Lee, Richard; Adams, Ian
Cc: Kelly, John E (NE)
Subject: RE: today DOE Science Council and call to Japan

Richard,

Sorry for the delay in my response – my email box is full to overflowing. The call with the Science expert will occur at 5pm EDT today. I am not sure about the call with Japan, but will find out and get an answer out to you as soon as possible.

Regards,

Alex

From: Lee, Richard (NRC)
Sent: Tuesday, April 05, 2011 9:02 AM
To: Adams, Ian; Larzelere, Alex
Cc: Kelly, John E (NE)
Subject: today DOE Science Council and call to Japan

Dear Ian and Alex:

I believe the Science Council call is at 5:00pm for today and tomorrow. I do not know when the call to Japan will take place for today and tomorrow. Please let me know.

Thx, Richard

4/3/8

Lee, Richard

From: Kelly, John E (NE) [JohnE.Kelly@Nuclear.Energy.Gov]
Sent: Tuesday, April 05, 2011 5:39 PM
To: Lee, Richard
Subject: Re: handsout for today meeting

Did you get them
John E Kelly

From: Lee, Richard (NRC)
To: Kelly, John E (NE)
Cc: Binder, Jeff
Sent: Tue Apr 05 17:12:17 2011
Subject: handsout for today meeting

Hi John or Jeff:

Please send me the VGs for today conf. call.

Thx, Richard

4/3/11

From: RMTPACTSU_INC [RMTPACTSU_INC@ofda.gov]
Sent: Wednesday, April 06, 2011 9:04 AM
To: RMT_PACTSU; DART_PACTSU; Fleming, James(DCHA/OFDA) [USAID]; Bartolini, Mark (DCHA/OFDA) [USAID]
Subject: Japan News (NY Times): U.S. Sees Array of New Threats at Japan's Nuclear Plant

Source: NY Times

April 5, 2011

U.S. Sees Array of New Threats at Japan's Nuclear Plant

By JAMES GLANZ and WILLIAM J. BROAD

United States government engineers sent to help with the crisis in Japan are warning that the troubled nuclear plant there is facing a wide array of fresh threats that could persist indefinitely, and that in some cases are expected to increase as a result of the very measures being taken to keep the plant stable, according to a confidential assessment prepared by the Nuclear Regulatory Commission.

Among the new threats that were cited in the assessment, dated March 26, are the mounting stresses placed on the containment structures as they fill with radioactive cooling water, making them more vulnerable to rupture in one of the aftershocks rattling the site after the earthquake and tsunami of March 11. The document also cites the possibility of explosions inside the containment structures due to the release of hydrogen and oxygen from seawater pumped into the reactors, and offers new details on how semimolten fuel rods and salt buildup are impeding the flow of fresh water meant to cool the nuclear cores.

In recent days, workers have grappled with several side effects of the emergency measures taken to keep nuclear fuel at the plant from overheating, including leaks of radioactive water at the site and radiation burns to workers who step into the water. The assessment, as well as interviews with officials familiar with it, points to a new panoply of complex challenges that water creates for the safety of workers and the recovery and long-term stability of the reactors.

While the assessment does not speculate on the likelihood of new explosions or damage from an aftershock, either could lead to a breach of the containment structures in one or more of the crippled reactors, the last barriers that prevent a much more serious release of radiation from the nuclear core. If the fuel continues to heat and melt because of ineffective cooling, some nuclear experts say, that could also leave a radioactive mass that could stay molten for an extended period.

The document, which was obtained by The New York Times, provides a more detailed technical assessment than Japanese officials have provided of the conundrum facing the Japanese as they struggle to prevent more fuel from melting at the Fukushima Daiichi plant. But it appears to rely largely on data shared with American experts by the Japanese.

Among other problems, the document raises new questions about whether pouring water on nuclear fuel in the absence of functioning cooling systems can be sustained indefinitely. Experts have said the Japanese need to continue to keep the fuel cool for many months until the plant can be stabilized, but there is growing awareness that the risks of pumping water on the fuel present a whole new category of challenges that the nuclear industry is only beginning to comprehend.

The document also suggests that fragments or particles of nuclear fuel from spent fuel pools above the reactors were blown "up to one mile from the units," and that pieces of highly radioactive material fell between two units and had to be "bulldozed over," presumably to

protect workers at the site. The ejection of nuclear material, which may have occurred during one of the earlier hydrogen explosions, may indicate more extensive damage to the extremely radioactive pools than previously disclosed.

David A. Lochbaum, a nuclear engineer who worked on the kinds of General Electric reactors used in Japan and now directs the nuclear safety project at the Union of Concerned Scientists, said that the welter of problems revealed in the document at three separate reactors made a successful outcome even more uncertain.

"I thought they were, not out of the woods, but at least at the edge of the woods," said Mr. Lochbaum, who was not involved in preparing the document. "This paints a very different picture, and suggests that things are a lot worse. They could still have more damage in a big way if some of these things don't work out for them."

The steps recommended by the nuclear commission include injecting nitrogen, an inert gas, into the containment structures in an attempt to purge them of hydrogen and oxygen, which could combine to produce explosions. On Wednesday, the Tokyo Electric Power Company, which owns the plant, said it was preparing to take such a step and to inject nitrogen into one of the reactor containment vessels.

The document also recommends that engineers continue adding boron to cooling water to help prevent the cores from restarting the nuclear reaction, a process known as criticality.

Even so, the engineers who prepared the document do not believe that a resumption of criticality is an immediate likelihood, Neil Wilmschurst, vice president of the nuclear sector at the Electric Power Research Institute, said when contacted about the document. "I have seen no data to suggest that there is criticality ongoing," said Mr. Wilmschurst, who was involved in the assessment.

The document was prepared for the commission's Reactor Safety Team, which is assisting the Japanese government and the Tokyo Electric Power Company. It says it is based on the "most recent available data" from numerous Japanese and American organizations, including the electric power company, the Japan Atomic Industrial Forum, the United States Department of Energy, General Electric and the Electric Power Research Institute, an independent, nonprofit group.

The document contains detailed assessments of each of the plant's six reactors along with recommendations for action. Nuclear experts familiar with the assessment said that it was regularly updated but that over all, the March 26 version closely reflected current thinking.

The assessment provides graphic new detail on the conditions of the damaged cores in reactors 1, 2 and 3. Because slumping fuel and salt from seawater that had been used as a coolant is probably blocking circulation pathways, the water flow in No. 1 "is severely restricted and likely blocked." Inside the core itself, "there is likely no water level," the assessment says, adding that as a result, "it is difficult to determine how much cooling is getting to the fuel." Similar problems exist in No. 2 and No. 3, although the blockage is probably less severe, the assessment says.

Some of the salt may have been washed away in the past week with the switch from seawater to fresh water cooling, nuclear experts said.

A rise in the water level of the containment structures has often been depicted as a possible way to immerse and cool the fuel. The assessment, however, warns that “when flooding containment, consider the implications of water weight on seismic capability of containment.”

Experts in nuclear plant design say that this warning refers to the enormous stress put on the containment structures by the rising water. The more water in the structures, the more easily a large aftershock could rupture one of them.

Margaret Harding, a former reactor designer for General Electric, warned of aftershocks and said, “If I were in the Japanese’s shoes, I’d be very reluctant to have tons and tons of water sitting in a containment whose structural integrity hasn’t been checked since the earthquake.”

The N.R.C. document also expressed concern about the potential for a “hazardous atmosphere” in the concrete-and-steel containment structures because of the release of hydrogen and oxygen from the seawater in a highly radioactive environment.

Hydrogen explosions in the first few days of the disaster heavily damaged several reactor buildings and in one case may have damaged a containment structure. That hydrogen was produced by a mechanism involving the metal cladding of the nuclear fuel. The document urged that Japanese operators restore the ability to purge the structures of these gases and fill them with stable nitrogen gas, a capability lost after the quake and tsunami.

Nuclear experts say that radiation from the core of a reactor can split water molecules in two, releasing hydrogen. Mr. Wilmshurst said that since the March 26 document, engineers had calculated that the amount of hydrogen produced would be small. But Jay A. LaVerne, a physicist at Notre Dame, said that at least near the fuel rods, some hydrogen would in fact be produced, and could react with oxygen. “If so,” Mr. LaVerne said in an interview, “you have an explosive mixture being formed near the fuel rods.”

Nuclear engineers have warned in recent days that the pools outside the containment buildings that hold spent fuel rods could pose an even greater danger than the melted reactor cores. The pools, which sit atop the reactor buildings and are meant to keep spent fuel submerged in water, have lost their cooling systems.


The N.R.C. report suggests that the fuel pool of the No. 4 reactor suffered a hydrogen explosion early in the Japanese crisis and could have shed much radioactive material into the environment, what it calls “a major source term release.”

Experts worry about the fuel pools because explosions have torn away their roofs and exposed their radioactive contents. By contrast, reactors have strong containment vessels that stand a better chance of bottling up radiation from a meltdown of the fuel in the reactor core.

“Even the best juggler in the world can get too many balls up in the air,” Mr. Lochbaum said of the multiplicity of problems at the plant. “They’ve got a lot of nasty things to negotiate in the future, and one missed step could make the situation much, much worse.”


Henry Fountain contributed reporting from New York, and Matthew L. Wald from Washington.

“ Pacific Tsunami and Japan Earthquake Response Management Team
RMTPACTSU_INC@ofda.gov
202-712-0039




In this March 20, 2011 aerial photo taken by a small unmanned drone and released by AIR PHOTO SERVICE, the crippled Fukushima Dai-ichi nuclear power plant are seen in Okumamachi, Fukushima. From left: Unit 1, partially seen; Unit 2, Unit 3 and Unit 4. (Air Photo Service Co. Ltd., Japan)

20 March 2011



In this March 20, 2011 aerial photo taken by a small unmanned drone and released by AIR PHOTO SERVICE, the crippled Fukushima Dai-ichi nuclear power plant is seen in Okumamachi, Fukushima. From right to left: Unit 1, Unit 2 and Unit 3. (Air Photo Service Co. Ltd., Japan)

20 March 2011



In this March 20, 2011 aerial photo taken by a small unmanned drone and released by AIR PHOTO SERVICE, the crippled Fukushima Dai-ichi nuclear power plant is seen in Okumamachi, Fukushima. From right to left: Unit 1, Unit 2, Unit 3 and Unit 4. (Air Photo Service Co. Ltd., Japan)

Helton, Donald

From: Helton, Donald
Sent: Wednesday, April 06, 2011 1:29 PM
To: Marksberry, Don
Subject: FW: ti for fukushima

FYI

From: Coyne, Kevin
Sent: Wednesday, April 06, 2011 9:58 AM
To: Helton, Donald
Subject: ti for fukushima

<http://pbadupws.nrc.gov/docs/ML1107/ML11077A007.pdf>

4/321

Lee, Richard

From: Busby, Jeremy T. [busbyjt@ornl.gov]
Sent: Thursday, April 07, 2011 9:59 AM
To: Binder, Jeffrey L.; Lee, Richard
Cc: 'Doug Burns'
Subject: RE: yesterday DOE conf.call hnadsout
Attachments: 0406 S-1 Briefing rev 1.pptx

Hi Richard,

We'll get you added. Here are the slides from yesterday.

Best regards,
Jeremy

From: Binder, Jeffrey L.
Sent: Thursday, April 07, 2011 9:47 AM
To: 'Richard.Lee@nrc.gov'
Cc: 'Doug Burns'; Busby, Jeremy T.
Subject: RE: yesterday DOE conf.call hnadsout

Doug/Jeremy

Can you get Richard on the list? Thanks.

Jeff

-----Original Message-----

From: Lee, Richard [<mailto:Richard.Lee@nrc.gov>]
Sent: Thursday, April 07, 2011 09:43 AM Eastern Standard Time
To: Binder, Jeffrey L.
Subject: yesterday DOE conf.call hnadsout

Jeff:

Do you have VGS from yesterday DOE Sci. Council. Conf. call? I do not know what distribution list DOE is using to distribute them ahead of the conf. call. I am not getting it.

Thanks, Richard

Lee, Richard

From: Kelly, John E (NE) [JohnE.Kelly@Nuclear.Energy.Gov]
Sent: Thursday, April 07, 2011 5:36 PM
To: Lee, Richard
Subject: Re: today's handout

My staff said they sent. Let's test before the meeting
John E Kelly

From: Lee, Richard (NRC)
To: Kelly, John E (NE)
Sent: Thu Apr 07 17:08:14 2011
Subject: today's handout

John:

I have not been receiving any VGs before the meeting for today and the same problems for the previous days. Appreciate it if you can ask someone to send it. This morning, Jeremy sent me the one from yesterday.

Richard

W/323

Bensi, Michelle

From: Bensi, Michelle
Sent: Thursday, April 07, 2011 6:25 PM
To: Kauffman, John
Subject: RE: Reminder--OEGIB Weekly Activities Input due by noon tomorrow, Friday 4/8/2011. [eom]

Thanks,
Shelby

Last week activities

- Seismic Q&A document in response to events in Japan
- Presentation (and Prep) for Japan Near-Term Evaluation Task Force Task Force Briefing
- FOIA
- Out-of-office Friday (CHU)

Next week activities

- Seismic Q&A document
- Conference M-W
- Revisions to screening report and other associated misc activities

From: Kauffman, John
Sent: Thursday, April 07, 2011 7:07 AM
To: Bensi, Michelle; Criscione, Lawrence; Ibarra, Jose; Killian, Lauren; Lane, John; Reisifard, Mehdi; Perkins, Richard; Salomon, Arthur; Smith, April; Wegner, Mary
Subject: Reminder--OEGIB Weekly Activities Input due by noon tomorrow, Friday 4/8/2011. [eom]

4/324

Bensi, Michelle

From: Bensi, Michelle
Sent: Friday, April 08, 2011 12:28 PM
To: Beasley, Benjamin
Subject: public FAQ document

Ben,

With regard to the NRR FAQ document that took seismic questions from an older version of the public FAQ document (which may still be the only one posted online, but is not the most recent version sent to OPA).

I don't have the most updated version of the public FAQs that Annie send to OPA. I will ask her to forward it to you so that you can forward them to NRR to update the seismic questions they pulled from the older version of the document. Please let me know if you object.

Thanks,

Shelby

4/325

Howell, Art

From: Spitzberg, Blair
Sent: Monday, April 11, 2011 9:11 AM
To: Howell, Art
Subject: RE: HUGE FILE ATTACHED - FUKUSHIMA SLIDE SHOW FROM NISA
Attachments: March 11 tsunami hit reactors.jpg *unable to print*

This is the image recently released of the tsunami actually hitting the plant. Note height appears to be above the top of the reactor buildings.

- Blair

From: Howell, Art
Sent: Monday, April 11, 2011 8:04 AM
To: Spitzberg, Blair
Subject: FW: HUGE FILE ATTACHED - FUKUSHIMA SLIDE SHOW FROM NISA

From: Maier, Bill
Sent: Saturday, April 09, 2011 1:12 PM
To: Howell, Art; Howell, Linda
Subject: HUGE FILE ATTACHED - FUKUSHIMA SLIDE SHOW FROM NISA

Art/Linda,

Don't know if you've seen this or not, but it's very comprehensive. 4MB pdf format.

Bill

Bensi, Michelle

From: Bensi, Michelle
Sent: Monday, April 11, 2011 8:39 PM
To: Kammerer, Annie
Cc: Beasley, Benjamin
Subject: updated public FAQs for NRR

Annie,

As you know, NRR has put together a Sharepoint site with FAQs related to the Japan events. The intent is to make these publically available.

It appears that many of the seismic-related questions came from the public FAQ document that was posted on the public website. I do not think the answers they are using are consistent with the most recent update to the Public FAQs. I believe the older version of the document contains outdated information (e.g. it says that we don't know the GM at the Fukushima plants). I recall that you sent an updated version of the FAQs to OPA, but I don't know if they ever posted it online. Do you think there's value in sending NRR the updated version (if cleared by OPA)?

I don't have the most updated version that you sent to OPA. If appropriate, would you please send the document to Ben (CC'ed on this email) to forward to NRR so that they are using the most updated version of the questions/answers?

Thanks,
Shelby

4/327

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Tuesday, April 12, 2011 4:41 PM
To: Kauffman, John
Subject: FW: List of Issues and Research Areas from Japanese Event
Attachments: Potential Long term Issues Rev1.docx

Please handle this. I will be looking at your draft email on solar storms this afternoon or tomorrow morning.

Ben

From: Correia, Richard
Sent: Tuesday, April 12, 2011 8:55 AM
To: Barnes, Valerie; Beasley, Benjamin; Coe, Doug; Coyne, Kevin; Demoss, Gary; Hudson, Daniel; Ott, William; Peters, Sean; Salley, MarkHenry; Hudson, Daniel; Nicholson, Thomas; Siu, Nathan; Stutzke, Martin
Subject: FW: List of Issues and Research Areas from Japanese Event

All,

Brett Rini has compiled and sorted RES staff input (attached) for the Japan events task force's consideration. Please take a look at his list and annotate any changes/corrections/clarifications keeping in mind how the task force will interpret what will be sending them (i.e., will they understand what we are asking them to consider).

Please send your comments/additions/clarifications back to me and Doug.

thanks

Richard Correia, PE
Director, Division of Risk Analysis
Office of Nuclear Regulatory Research
US NRC

richard.correia@nrc.gov

From: Rini, Brett
Sent: Monday, April 11, 2011 5:27 PM
To: Case, Michael; Richards, Stuart; Correia, Richard; Coe, Doug; Gibson, Kathy; Scott, Michael; Valentin, Andrea
Cc: Sheron, Brian; Uhle, Jennifer
Subject: List of Issues and Research Areas from Japanese Event

Division Directors,

Please find attached a list of possible issues and research areas to follow-up on as a result of the Japanese earthquake. I compiled the input I received from your divisions along with a document that Brian sent me and classified the recommendations into various areas (e.g., electrical, severe accidents, external events).

Please review the attached document and let me know if you have any additional thoughts or changes.

Thanks,

Brett

Brett A. Rini

Technical Assistant

Office of Nuclear Regulatory Research

U.S. Nuclear Regulatory Commission

(301)251-7615

Brett.Rini@nrc.gov

Potential Long term Issues & Research Areas as a Result of Japanese Earthquake/Tsunami and Impact on Nuclear Power Plants

Electrical Power / Station Black-out

- Assess plant response to long-term loss of onsite and offsite electrical power, as well as capabilities for mitigation (DE)
- Evaluate battery discharge duration when operated under light load (DE)
- Do we need to revisit the need for non-AC dependent hydrogen igniters on IC plants?
- Do we need AC-powered (with battery backup) hydrogen igniters in reactor buildings and/or in the vicinity of SFPs?
- Do plants have EDGs and their associated fuel tanks sufficiently protected from natural phenomena, especially floods?
- Assess the feasibility of licensees developing procedures to bring in portable electric generators to the site to a prepared location, and connecting the generators to the plant electric system. (DE)
- Assess the feasibility of developing procedures to bring in a 125 VDC battery bank and connect it to the plant DC system. (DE)
- Re-assess SBO capabilities at U.S. plants (DE)
- Should SBO coping strategies be seismically qualified to help mitigate beyond design basis seismic events where restoration of offsite power could be delayed beyond the coping time.

Instrumentation & Controls

- Do we have sufficient instrumentation in plants to accurately assess plant conditions following an accident, including severe accidents (e.g., water levels at various locations)? Is the instrumentation sufficiently robust to survive in the accident conditions?
- Is there additional instrumentation that would be of use to help manage a severe accident, such as hydrogen sensors, and would additional measures be necessary to ensure they are viable during a severe accident.
- Consider the need for additional severe accident monitoring instrumentation. Consideration should be given to providing for remote readings from the instrumentation at locations away from the unit. Wireless technology could potentially minimize the cost involved. (DE)
- Reassessment of instrumentation that can provide details on the progression of a severe accident; include remote monitoring of temperatures, pressures and radiation levels using high-capacity (long term) batteries (DE)

Reactor Pressure Vessel & Reactor Coolant System

- Performance issues of degraded/aged components: (DE)
 - Thermal loading: thermal shock, thermal transients
 - Pressure loading: explosive loadings, from thermal transients
- Components/Structures/Materials Performance in Severe or Beyond Design Basis Accidents: (DE)
 - Pumps/Valves
 - Seismic loading
- Weld Residual Stress Compendia: (DE)
 - Database of residual stresses of nuclear components: measurements & model results

- Materials research on the impact of lake/river/sea water used as makeup water to the reactor coolant system and SFP during an accident and impact on subsequent establishment of recirculation. (DE)

Containment

- PWR Containments do not have filtered vents. It is also not clear if they have vents that can be operated without AC power. Consider evaluating the benefits of putting a filtered vent on a PWR containment, along with vents that can be actuated without AC power (e.g. compressed air).
- reevaluate the need for filtered containment venting (DE)
- GSI-191 impact from seawater (DE)
- Assess coatings in the severe accident environment (DE)

Severe Accidents & Mitigation

- Effectiveness of SAMGs and EDMGs provisions (including operator training) (DRA)
- Develop SAMGs that include procedures for a containment breach (DE)
- Assess effects of high general radiation levels from a core melt on the ability for personnel to man control rooms and implement SAMGs (DE)
- Assess the need for additional regulatory guidance for severe accidents (DE)
- Review Severe Accident Management Guidelines/Emergency Operations Plans (DE)
 - Check core and spent fuel cooling procedures
 - Identify any materials issues with the cooling procedures (use of salt/river water in an emergency)
- Do U.S. plants have the capability to inject ultimate heat sink water? How much time do plants with cooling ponds, like Palo Verde, have if they injected their ponds? Does that affect long term cooling strategies?
- Emergency H₂ venting and whether current US plant configurations could lead to pockets of H₂ in areas not covered by H₂ igniters or recombiners, that give rise to explosive power sufficient to damage BWR secondary containments. (DRA) Adequacy and placement of hydrogen recombiners/igniters (DE)
- Are there accident management strategies in place for lower vessel flooding, and how well do we understand whether lower vessel flooding will work to retain a molten core inside the vessel?
- Fukushima 3 had several MOX fuel assemblies in it. How would a core with more or a full load of MOX assemblies affect the outcome of severe accidents?

Spent Fuel Pools / Independent Spent Fuel Storage Installations

- Is there a justifiable cost-benefit to off-loading from spent fuel pools all of the fuel that can be safely stored in dry casks? Removing all of the fuel that can be safely loaded in casks will not substantially reduce the heat load in the pool, but removing the fuel will increase the water volume in the pool. This will provide more time to boil off and uncover in an SBO. Also, spreading the fuel out in the pool will enhance cooling in the event of an uncover (e.g., no radiation heat source from adjacent assemblies) and may prevent or substantially delay melting.
- Develop a code which would consider the fuel loaded into a SFP, the location of the fuel within the SFP, the fuel burn-up and the decay time of each bundle, and then calculate

whether exposure of the fuel to air would result in heat-up sufficient to result in fission product release to the environment. (DE)

- Assess the practicality of requiring a water makeup line to the SFP which would include a standpipe some distance remote from the plant power block. Assess the practicality of adding boron to this makeup source. (DE)
- Assess alternate means available for adding cooling water to spent fuel pools at all U.S. plants, including time frames, assuming loss of all electrical power (DE)
- Spent Fuel Pool accident phenomenology (similar to core damage accident research) and the effectiveness of B.5.b provisions (DRA)
- Spent fuel pool liner/cooling systems performance - degraded conditions & seismic (DE)
- Evaluate impact of using "dirty water" in spent fuel pools (DE)
- Are there natural phenomena that can damage dry casks? Dry casks are designed for earthquakes. Do we know how well they can withstand a beyond DBA earthquake? Performance of spent fuel pools and casks in BDBAs (DE)
- Reconsider the earliest timeframe in which fuel can be moved into dry storage, particularly for SFPs not at or below grade level. (DE)

Internal Events

- Assess (or reassess) the potential impact of a major hydrogen leak from the turbine-generator, or from the hydrogen cooling system, including the hydrogen storage tanks. (DE)
- Reassess the response of licensees to in-plant fires, particularly where successful response requires a number of manual actions in a relatively short period of time. If called upon on a mid-shift with no warning, do we have assurance that the required timeline could be met? (DE)

Earthquake / Tsunami

- Revisit the scope of on-going earthquake and tsunami research. (DE)
- Response to aftershocks following a design or beyond-design basis earthquake.
- How well can we predict tsunami wave height? Can scale model testing help improve models?
- Tsunami Study—The purpose of this study would be to use modern models and techniques to assess the tsunami hazard for existing sites including ISFIs, not otherwise assessed in new reactor reviews. The study would confirm that the tsunami hazard for facilities is either appropriately considered in the licensing basis, is bounded by other natural events, or needs additional site specific bathymetric data. The study would also consider the need to validate the current NOAA model for tsunami, if necessary. (DE)

Other External Events

- Assess adequacy of current regulatory guidance for external events (DE)
- Are flooding measures, such as seals, inspected thoroughly and at an appropriate frequency based on their susceptibility to age-related degradation?
- Revisit natural disasters to confirm that plant licensing bases are still enveloped by the current science in the area. For example tornados, flooding from severe weather, etc. (DE)
- Revisit flooding from dams. Questions involving Oconee have already resulted in this area being revisited. Should we do more on dam failures and modeling the resulting flooding hazards? (DE)

- Are East and Gulf coast plants adequately protected from natural phenomena? There are reports that say that global warming is heating up the oceans, and this, in turn, spawns more violent hurricanes (e.g., Katrina). Have we conservatively estimated the storm surges associated with worst-case hurricanes that could hit the coasts, and are the plants along those coasts adequately protected from those storm surges and associated flooding?
- There are licensees on gulf and east coast sites (e.g., Waterford) that are or may be near other industrial facilities. How well are these facilities protected against extreme environmental events, and could failures (e.g. toxic gas release, explosions of flammable liquids and gases) at these facilities due to extreme environmental events render the control room at adjacent nuclear facilities uninhabitable?
- Revisit the impact of man-made disasters on plants. For example, plants located near industrial facilities such as petro-chemical. Do we remain confident that a major disaster at a nearby industrial facility will not have adverse impacts on the nuclear plant? If industrial processes at nearby facilities have changed since plant licensing, and have become more hazardous, how would we know? The impact of possible train or truck accidents involving hazardous materials is a related example. (DE)

Plant Siting

- Should plant siting consider space between units to ensure that adequate space is provided for severe accident mitigation using external equipment, such as the Bechtel pumping rig.
- For multi-unit sites, licensees are only required to mitigate the security related event at one unit under B.5.b. As a result, there may only be one piece of critical equipment to serve two or more units. Furthermore, each unit may need to carry out several strategies, such as core and spent fuel pool so the equipment may only support one strategy at a time. The B.5.b equipment including the water sources are not seismically qualified. Are additional requirements warranted?

Dose Assessment

- The Fukushima event seemed to bring out shortcomings of our dose assessment codes, particularly RASCAL. Should we re-evaluate the need for improved, easy to use radiological dose assessment codes? Evaluate other issues related to radiation protection actions and health effects (DSA)
- Review of tools and information available for making evacuation recommendations, including assessment of impacts on population of the evacuation (DE)
- Ground water contamination/transport. (DRA)

Risk Assessment

- Pursue Level III PRA (DRA)
- Common cause failure frequencies (DRA)
- Re-examination of the concept of credible event to which a facility is designed, and a cost-benefit analysis to determine if designing to lower probability events than is currently the practice would increase safety at a reasonable cost. (DSA)
- Multi-unit site risk including spent fuel (wet and dry) and consequential (linked) multiple initiating events (e.g. seismic with induced tsunami and fire, plus damage to fire suppression and safety systems from either seismic or tsunami), i.e. a Level III PRA including human reliability aspects. (DRA)

- The Fukushima event highlights those events that are considered of relatively low probability, but potentially of high consequence; particularly events for which the uncertainties of occurrence and response are relatively large. One such area may be shutdown risk. Shutdown operations involve a wide variety of unusual conditions, to which operators are not often exposed due to high capacity factors and short refueling outages. Under electric deregulation, many licensees are now very focused on completing outages on schedule. This pressure may be felt by all levels of staff at the plant. In the past, the agency elected to allow the industry to address this area via industry initiatives under the umbrella of NEI. The NRC might elect to revisit this area based on the uncertainties and the voluntary nature of past actions to address this area. (DE)

Human Factors

- SAMG Procedure Adequacy (DRA)
- Risk Communication (DRA)
- Decisionmaking (DRA)
- B.5.b Human Action credit – lowered staffing (DRA)
- Prolonged Fatigue (DRA)
- Human Action reliability (DRA)
- Safety Culture (DRA)
- Human perception of risk as incorporated into the design basis and regulations (DRA)
- Construction HRA (DRA)
- Reexamination of design basis events (DRA)
- Control room staffing and plant staffing for severe accidents (DRA)
- Reliance on automation/overriding automation (DRA)
- Have we adequately considered the human factors aspects of a severe accident. In the Fukushima case, the event has been on-going for several days, and it appears that the event will continue to require considerable licensee resources for some time. (DE)
 - What level of stress does this put on the plant responders over time and how does it affect their ability to carry out their duties? (DE)
 - For US licensees with a single nuclear unit, will they have the human resources to respond to a severe accident, which extends over weeks or months at a high intensity level? (DE)
 - Are there ways to mitigate human factors issues, such as cooperative support agreements with other utilities with units of a similar design? (DE)
- Consider what pre-planned actions should be in place if plant staff are required to evacuate the plant. (DE)

Incident Response / Coordination

- Emergency response given large area wide catastrophe and what can be expected (DRA)
- Assess onsite and offsite responder capabilities at U.S. plants (beyond B.5.b) (DE)
- Create organizational requirements and tools for reporting information during significant nuclear events internationally, perhaps as part of CNS or IAEA led effort. (DE)
- Assess NRC timing and procedures for manning NRC Ops Center in response to significant international events, perhaps using the INES scale for perspective on significance (DE)
- Assess NRC office procedures for supporting the NRC Ops Center in first few days of a crises, as well as for events of longer duration (DE)

- During the evolution of the accident at Fukushima, there was not a lot of coordination (at least initially) among various agencies (e.g., DOE and NRC). Concern was that everyone was advising the Japanese, with no coordination. In the event of another reactor accident outside of the U.S., should U.S. agencies have worked out plans for coordination beforehand? Does the international community need to coordinate better?
- It took a while before we called in industry and got an industry consortium going to interact directly with their Japanese counterparts (TEPCO). Should we encourage industry to create a standing consortium that would be poised to move in the event of another accident? Is this really a role for WANO?
- Given overwhelming media interest, define the role of NRC in communicating general information on nuclear energy to the public even if incidents occur at foreign nuclear plants (DE)

Esmaili, Hossein

From: Esmaili, Hossein
Sent: Tuesday, April 12, 2011 5:21 PM
To: Marksberry, Don
Subject: FW: FYI: Staff Presentation hosted by Mike Scott

Maybe we want to attend this tomorrow.

From: Kardaras, Tom
Sent: Thursday, April 07, 2011 12:02 PM
To: RES Distribution
Subject: FYI: Staff Presentation hosted by Mike Scott

Michael Scott, Deputy Director of DSA, will be giving a presentation to RES staff on his travels and experiences while assisting in the Japanese Tsunami/Nuclear disaster from 10 –11am on Wednesday, April 13 in Room 6B-01. In case of overflow in the main conference room, the presentation will also be simultaneously broadcast via VTC in Room 2C-19.

Regards,
Tom Kardaras, Deputy Director (Acting)
Program Management, Policy Development and Analysis Staff
Office of Nuclear Regulatory Research
(o) 301-251-7667

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Wednesday, April 13, 2011 6:52 AM
To: Kauffman, John
Subject: FW: Some Additional Items
Attachments: Potential Long term Issues Rev1.docx; Potential Long term Issues.docx

From: Coe, Doug
Sent: Tuesday, April 12, 2011 5:34 PM
To: Barnes, Valerie; Beasley, Benjamin; Coyne, Kevin; Demoss, Gary; Nicholson, Thomas; Ott, William; Peters, Sean; Salley, MarkHenry; Siu, Nathan; Stutzke, Martin
Cc: Correia, Richard
Subject: FW: Some Additional Items

All,
FYI – Here's the consolidated list of possible research topics Brian sent forward to the near-term Task Force this afternoon.

Ben,
See the rev 1 document first category (SBO). Seems like this input to the Task Force pretty well covers the ground you had discussed. If there is something your staff would like to add to this list, please let me know.

Nathan – I've forwarded your input along to Brett Rini with a request to add it.

Mark – the items you forwarded look more like DSA research items. I'll forward them to DSA for consideration.

Doug

From: Sheron, Brian
Sent: Tuesday, April 12, 2011 2:42 PM
To: Miller, Charles
Cc: Holahan, Gary; Grobe, Jack; Dorman, Dan; Sanfilippo, Nathan; Rini, Brett; Weber, Michael; Virgilio, Martin; Case, Michael; Coe, Doug; Correia, Richard; Gibson, Kathy; Richards, Stuart; Scott, Michael; Uhle, Jennifer; Valentin, Andrea
Subject: Some Additional Items

Charlie, I asked my staff, particularly the staff that have been involved in responding to the Fukushima event, to put their thoughts on paper about areas they believe potentially warrant further study. My TA, Brett Rini, collected the information and I am attaching it for you and your team's consideration. Some of the items are duplicates of the ones I have already sent you, some are self-explanatory, and others just identify a general area of concern. In the interest of time, I have not attempted to edit their thoughts. If you have any questions about any of these suggestions, contact me or Brett Rini, and we can get a clarification for you.

I have also added one additional item to the list I originally sent you (item #22) and this is attached as well.

Potential Long term Issues & Research Areas as a Result of Japanese Earthquake/Tsunami and Impact on Nuclear Power Plants

Electrical Power / Station Black-out

- Assess plant response to long-term loss of onsite and offsite electrical power, as well as capabilities for mitigation (DE)
- Evaluate battery discharge duration when operated under light load (DE)
- Do we need to revisit the need for non-AC dependent hydrogen igniters on IC plants?
- Do we need AC-powered (with battery backup) hydrogen igniters in reactor buildings and/or in the vicinity of SFPs?
- Do plants have EDGs and their associated fuel tanks sufficiently protected from natural phenomena, especially floods?
- Assess the feasibility of licensees developing procedures to bring in portable electric generators to the site to a prepared location, and connecting the generators to the plant electric system. (DE)
- Assess the feasibility of developing procedures to bring in a 125 VDC battery bank and connect it to the plant DC system. (DE)
- Re-assess SBO capabilities at U.S. plants (DE)
- Should SBO coping strategies be seismically qualified to help mitigate beyond design basis seismic events where restoration of offsite power could be delayed beyond the coping time.

Instrumentation & Controls

- Do we have sufficient instrumentation in plants to accurately assess plant conditions following an accident, including severe accidents (e.g., water levels at various locations)? Is the instrumentation sufficiently robust to survive in the accident conditions?
- Is there additional instrumentation that would be of use to help manage a severe accident, such as hydrogen sensors, and would additional measures be necessary to ensure they are viable during a severe accident.
- Consider the need for additional severe accident monitoring instrumentation. Consideration should be given to providing for remote readings from the instrumentation at locations away from the unit. Wireless technology could potentially minimize the cost involved. (DE)
- Reassessment of instrumentation that can provide details on the progression of a severe accident; include remote monitoring of temperatures, pressures and radiation levels using high-capacity (long term) batteries (DE)

Reactor Pressure Vessel & Reactor Coolant System

- Performance issues of degraded/aged components: (DE)
 - Thermal loading: thermal shock, thermal transients
 - Pressure loading: explosive loadings, from thermal transients
- Components/Structures/Materials Performance in Severe or Beyond Design Basis Accidents: (DE)
 - Pumps/Valves
 - Seismic loading
- Weld Residual Stress Compendia: (DE)
 - Database of residual stresses of nuclear components: measurements & model results

- Materials research on the impact of lake/river/sea water used as makeup water to the reactor coolant system and SFP during an accident and impact on subsequent establishment of recirculation. (DE)

Containment

- PWR Containments do not have filtered vents. It is also not clear if they have vents that can be operated without AC power. Consider evaluating the benefits of putting a filtered vent on a PWR containment, along with vents that can be actuated without AC power (e.g. compressed air).
- reevaluate the need for filtered containment venting (DE)
- GSI-191 impact from seawater (DE)
- Assess coatings in the severe accident environment (DE)

Severe Accidents & Mitigation

- Effectiveness of SAMGs and EDMGs provisions (including operator training) (DRA)
- Develop SAMGs that include procedures for a containment breach (DE)
- Assess effects of high general radiation levels from a core melt on the ability for personnel to man control rooms and implement SAMGs (DE)
- Assess the need for additional regulatory guidance for severe accidents (DE)
- Review Severe Accident Management Guidelines/Emergency Operations Plans (DE)
 - Check core and spent fuel cooling procedures
 - Identify any materials issues with the cooling procedures (use of salt/river water in an emergency)
- Do U.S. plants have the capability to inject ultimate heat sink water? How much time do plants with cooling ponds, like Palo Verde, have if they injected their ponds? Does that affect long term cooling strategies?
- Emergency H₂ venting and whether current US plant configurations could lead to pockets of H₂ in areas not covered by H₂ igniters or recombiners, that give rise to explosive power sufficient to damage BWR secondary containments. (DRA) Adequacy and placement of hydrogen recombiners/igniters (DE)
- Are there accident management strategies in place for lower vessel flooding, and how well do we understand whether lower vessel flooding will work to retain a molten core inside the vessel?
- Fukushima 3 had several MOX fuel assemblies in it. How would a core with more or a full load of MOX assemblies affect the outcome of severe accidents?

Spent Fuel Pools / Independent Spent Fuel Storage Installations

- Is there a justifiable cost-benefit to off-loading from spent fuel pools all of the fuel that can be safely stored in dry casks? Removing all of the fuel that can be safely loaded in casks will not substantially reduce the heat load in the pool, but removing the fuel will increase the water volume in the pool. This will provide more time to boil off and uncover in an SBO. Also, spreading the fuel out in the pool will enhance cooling in the event of an uncover (e.g., no radiation heat source from adjacent assemblies) and may prevent or substantially delay melting.
- Develop a code which would consider the fuel loaded into a SFP, the location of the fuel within the SFP, the fuel burn-up and the decay time of each bundle, and then calculate

whether exposure of the fuel to air would result in heat-up sufficient to result in fission product release to the environment. (DE)

- Assess the practicality of requiring a water makeup line to the SFP which would include a standpipe some distance remote from the plant power block. Assess the practicality of adding boron to this makeup source. (DE)
- Assess alternate means available for adding cooling water to spent fuel pools at all U.S. plants, including time frames, assuming loss of all electrical power (DE)
- Spent Fuel Pool accident phenomenology (similar to core damage accident research) and the effectiveness of B.5.b provisions (DRA)
- Spent fuel pool liner/cooling systems performance - degraded conditions & seismic (DE)
- Evaluate impact of using "dirty water" in spent fuel pools (DE)
- Are there natural phenomena that can damage dry casks? Dry casks are designed for earthquakes. Do we know how well they can withstand a beyond DBA earthquake? Performance of spent fuel pools and casks in BDBAs (DE)
- Reconsider the earliest timeframe in which fuel can be moved into dry storage, particularly for SFPs not at or below grade level. (DE)

Internal Events

- Assess (or reassess) the potential impact of a major hydrogen leak from the turbine-generator, or from the hydrogen cooling system, including the hydrogen storage tanks. (DE)
- Reassess the response of licensees to in-plant fires, particularly where successful response requires a number of manual actions in a relatively short period of time. If called upon on a mid-shift with no warning, do we have assurance that the required timeline could be met? (DE)

Earthquake / Tsunami

- Revisit the scope of on-going earthquake and tsunami research. (DE)
- Response to aftershocks following a design or beyond-design basis earthquake.
- How well can we predict tsunami wave height? Can scale model testing help improve models?
- Tsunami Study—The purpose of this study would be to use modern models and techniques to assess the tsunami hazard for existing sites including ISFIs, not otherwise assessed in new reactor reviews. The study would confirm that the tsunami hazard for facilities is either appropriately considered in the licensing basis, is bounded by other natural events, or needs additional site specific bathymetric data. The study would also consider the need to validate the current NOAA model for tsunami, if necessary. (DE)

Other External Events

- Assess adequacy of current regulatory guidance for external events (DE)
- Are flooding measures, such as seals, inspected thoroughly and at an appropriate frequency based on their susceptibility to age-related degradation?
- Revisit natural disasters to confirm that plant licensing bases are still enveloped by the current science in the area. For example tornados, flooding from severe weather, etc. (DE)
- Revisit flooding from dams. Questions involving Oconee have already resulted in this area being revisited. Should we do more on dam failures and modeling the resulting flooding hazards? (DE)

- Are East and Gulf coast plants adequately protected from natural phenomena? There are reports that say that global warming is heating up the oceans, and this, in turn, spawns more violent hurricanes (e.g., Katrina). Have we conservatively estimated the storm surges associated with worst-case hurricanes that could hit the coasts, and are the plants along those coasts adequately protected from those storm surges and associated flooding?
- There are licensees on gulf and east coast sites (e.g., Waterford) that are or may be near other industrial facilities. How well are these facilities protected against extreme environmental events, and could failures (e.g. toxic gas release, explosions of flammable liquids and gases) at these facilities due to extreme environmental events render the control room at adjacent nuclear facilities uninhabitable?
- Revisit the impact of man-made disasters on plants. For example, plants located near industrial facilities such as petro-chemical. Do we remain confident that a major disaster at a nearby industrial facility will not have adverse impacts on the nuclear plant? If industrial processes at nearby facilities have changed since plant licensing, and have become more hazardous, how would we know? The impact of possible train or truck accidents involving hazardous materials is a related example. (DE)

Plant Siting

- Should plant siting consider space between units to ensure that adequate space is provided for severe accident mitigation using external equipment, such as the Bechtel pumping rig.
- For multi-unit sites, licensees are only required to mitigate the security related event at one unit under B.5.b. As a result, there may only be one piece of critical equipment to serve two or more units. Furthermore, each unit may need to carry out several strategies, such as core and spent fuel pool so the equipment may only support one strategy at a time. The B.5.b equipment including the water sources are not seismically qualified. Are additional requirements warranted?

Dose Assessment

- The Fukushima event seemed to bring out shortcomings of our dose assessment codes, particularly RASCAL. Should we re-evaluate the need for improved, easy to use radiological dose assessment codes? Evaluate other issues related to radiation protection actions and health effects (DSA)
- Review of tools and information available for making evacuation recommendations, including assessment of impacts on population of the evacuation (DE)
- Ground water contamination/transport. (DRA)

Risk Assessment

- Pursue Level III PRA (DRA)
- Common cause failure frequencies (DRA)
- Re-examination of the concept of credible event to which a facility is designed, and a cost-benefit analysis to determine if designing to lower probability events than is currently the practice would increase safety at a reasonable cost. (DSA)
- Multi-unit site risk including spent fuel (wet and dry) and consequential (linked) multiple initiating events (e.g. seismic with induced tsunami and fire, plus damage to fire suppression and safety systems from either seismic or tsunami), i.e. a Level III PRA including human reliability aspects. (DRA)

- The Fukushima event highlights those events that are considered of relatively low probability, but potentially of high consequence; particularly events for which the uncertainties of occurrence and response are relatively large. One such area may be shutdown risk. Shutdown operations involve a wide variety of unusual conditions, to which operators are not often exposed due to high capacity factors and short refueling outages. Under electric deregulation, many licensees are now very focused on completing outages on schedule. This pressure may be felt by all levels of staff at the plant. In the past, the agency elected to allow the industry to address this area via industry initiatives under the umbrella of NEI. The NRC might elect to revisit this area based on the uncertainties and the voluntary nature of past actions to address this area. (DE)

Human Factors

- SAMG Procedure Adequacy (DRA)
- Risk Communication (DRA)
- Decisionmaking (DRA)
- B.5.b Human Action credit – lowered staffing (DRA)
- Prolonged Fatigue (DRA)
- Human Action reliability (DRA)
- Safety Culture (DRA)
- Human perception of risk as incorporated into the design basis and regulations (DRA)
- Construction HRA (DRA)
- Reexamination of design basis events (DRA)
- Control room staffing and plant staffing for severe accidents (DRA)
- Reliance on automation/overriding automation (DRA)
- Have we adequately considered the human factors aspects of a severe accident. In the Fukushima case, the event has been on-going for several days, and it appears that the event will continue to require considerable licensee resources for some time. (DE)
 - What level of stress does this put on the plant responders over time and how does it affect their ability to carry out their duties? (DE)
 - For US licensees with a single nuclear unit, will they have the human resources to respond to a severe accident, which extends over weeks or months at a high intensity level? (DE)
 - Are there ways to mitigate human factors issues, such as cooperative support agreements with other utilities with units of a similar design? (DE)
- Consider what pre-planned actions should be in place if plant staff are required to evacuate the plant. (DE)

Incident Response / Coordination

- Emergency response given large area wide catastrophe and what can be expected (DRA)
- Assess onsite and offsite responder capabilities at U.S. plants (beyond B.5.b) (DE)
- Create organizational requirements and tools for reporting information during significant nuclear events internationally, perhaps as part of CNS or IAEA led effort. (DE)
- Assess NRC timing and procedures for manning NRC Ops Center in response to significant international events, perhaps using the INES scale for perspective on significance (DE)
- Assess NRC office procedures for supporting the NRC Ops Center in first few days of a crises, as well as for events of longer duration (DE)

- During the evolution of the accident at Fukushima, there was not a lot of coordination (at least initially) among various agencies (e.g., DOE and NRC). Concern was that everyone was advising the Japanese, with no coordination. In the event of another reactor accident outside of the U.S., should U.S. agencies have worked out plans for coordination beforehand? Does the international community need to coordinate better?
- It took a while before we called in industry and got an industry consortium going to interact directly with their Japanese counterparts (TEPCO). Should we encourage industry to create a standing consortium that would be poised to move in the event of another accident? Is this really a role for WANO?
- Given overwhelming media interest, define the role of NRC in communicating general information on nuclear energy to the public even if incidents occur at foreign nuclear plants (DE)

Potential Long term Issues

- 1.) Is there a justifiable cost-benefit to off-loading from spent fuel pools all of the fuel that can be safely stored in dry casks? Removing all of the fuel that can be safely loaded in casks will not substantially reduce the heat load in the pool, but removing the fuel will increase the water volume in the pool. This will provide more time to boil off and uncover in a SBO. Also, spreading the fuel out in the pool will enhance cooling in the event of an uncover (e.g., no radiation heat source from adjacent assemblies) and may prevent or substantially delay melting.
- 2.) Are East and Gulf coast plants adequately protected from natural phenomena? There are reports that say that global warming is heating up the oceans, and this, in turn, spawns more violent hurricanes (e.g., Katrina). Have we conservatively estimated the storm surges associated with worst-case hurricanes that could hit the coasts, and are the plants along those coasts adequately protected from those storm surges and associated flooding?
- 3.) PWR Containments do not have filtered vents. It is also not clear if they have vents that can be operated without AC power. The benefits of putting a filtered vent on a PWR containment, along with vents that can be actuated without AC power (e.g. compressed air) should be evaluated.
- 4.) Do we need to revisit the need for non-AC dependent hydrogen igniters on IC plants?
- 5.) Are their accident management strategies in place for lower vessel flooding, and how well do we understand whether lower vessel flooding will work to retain a molten core inside the vessel?
- 6.) How well can we predict tsunami wave height? Can scale model testing help improve models?
- 7.) Do U.S. plants have the capability to inject ultimate heat sink water? How much time do plants with cooling ponds, like Palo Verde, have if they injected their ponds. Does that affect long term cooling strategies?
- 8.) Do plants have EDGs and their associated fuel tanks sufficiently protected from natural phenomena, especially floods?
- 9.) Do we need AC powered (with battery backup) hydrogen igniters in reactor buildings and/or in the vicinity of SFPs?
- 10.) Are there natural phenomena that can damage dry casks? Dry casks are designed for earthquakes. Do we know how well they can withstand a beyond DBA earthquake?
- 11.) Fukushima 3 had several MOX fuel assemblies in it. How would a core with more or a full load of MOX assemblies affect the outcome of severe accidents?

12.) Do we have sufficient instrumentation in plants to accurately assess plant conditions following an accident, including severe accidents (e.g., water levels at various locations)? Is the instrumentation sufficiently robust to survive in the accident conditions?

13.) The Fukushima event seemed to bring out shortcomings of our dose assessment codes, particularly RASCAL. Should we re-evaluate the need for improved, easy to use radiological dose assessment codes?

14.) During the evolution of the accident at Fukushima, there was not a lot of coordination (at least initially) among various agencies (e.g., DOE and NRC). Concern was that everyone was advising the Japanese, with no coordination. In the event of another reactor accident outside of the U.S., should U.S. agencies have worked out plans for coordination beforehand? Does the international community need to coordinate better?

15) It took a while before we called in industry and got an industry consortium going to interact directly with their Japanese counterparts (TEPCO). Should we encourage industry to create a standing consortium that would be poised to move in the event of another accident? Is this really a role for WANO?

16.) There are licensees on gulf and east coast sites (e.g., Waterford) that are or may be near other industrial facilities. How well are these facilities protected against extreme environmental events, and could failures (e.g. toxic gas release, explosions of flammable liquids and gases) at these facilities due to extreme environmental events render the control room at adjacent nuclear facilities uninhabitable?

17) Are there additional instrumentation that would be of use to help manage a severe accident, such as hydrogen sensors, and would additional measures be necessary to ensure they are viable during a severe accident.

18) Are flooding measures, such as seals, inspected thoroughly and at an appropriate frequency based on their susceptibility to age-related degradation.

19) Should plant siting consider space between units to ensure that adequate space is provided for severe accident mitigation using external equipment, such as the Bechtel pumping rig.

20) Should SBO coping strategies be seismically qualified to help mitigate beyond design basis seismic events where restoration of offsite power could be delayed beyond the coping time.

21) For multi-unit sites, licensees are only required to mitigate the security related event at one unit under B.5.b. As a result, there may only be one piece of critical equipment to serve two or more units. Furthermore, each unit may need to carry out several strategies, such as core and spent fuel pool so the equipment may only support one strategy at a time. The

B.5.b equipment including the water sources are not seismically qualified. Are additional requirements warranted?

22.) Tsunami Study—The purpose of this study would be to use modern models and techniques to assess the tsunami hazard for existing sites including ISFIs, not otherwise assessed in new reactor reviews. The study would confirm that the tsunami hazard for facilities is either appropriately considered in the licensing basis, is bounded by other natural events, or needs additional site specific bathymetric data. The study would also consider the need to validate the current NOAA model for tsunami, if necessary.

23.) Price-Anderson – Current Price-Anderson provides about \$10B+ coverage in the event of a nuclear accident. Based on what occurred at Fukushima, is the current Price-Anderson coverage still considered adequate?

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Wednesday, April 13, 2011 7:15 AM
To: Kauffman, John
Subject: RE: Draft e-mail

This is great stuff.

Even though SBO has been sent to the Task Force, I would like to forward this to Rich/Doug as additional information. The only question I have is the need for a reference (or to clearly identify it) for the EMP Attack paragraph.

Ben

From: Kauffman, John
Sent: Tuesday, April 12, 2011 10:15 AM
To: Beasley, Benjamin
Subject: Draft e-mail

Ben,

I suggest we send something like the following to the Near-Term Task Force.

One of the areas the Near-Term Task Force is charted to evaluate, based on the recent Fukushima Daiichi events, is Station Blackout.

In addition to improving NPP station blackout "coping times," we believe that minimizing the occurrence of extended duration losses of offsite power events (LOOP) (a necessary pre-condition to an extended station blackout), and enhancing the NPPs capabilities to cope with extended LOOPS are prudent. We base this conclusion on selected operating experience and information (provided below) that we have collected in the Generic Issues Program. The Operating Experience information below shows that LOOPS are typically precursor events (risk significant), and that extended duration LOOPS can result from grid collapse or severe natural events such as hurricanes, ice storms, and tornadoes; in addition to earthquakes/flooding as occurred at Fukushima Daiichi. Although the NRC does not regulate the grid, the Generic Issues Program information shows there the grid is vulnerable to Electromagnetic Pulse (EMP) attacks (act of war) and geomagnetic storms potentially causing lengthy, large loss of the grid events. Because there are numerous ways for extended LOOPS/SBOs to occur, it is important that their occurrence be minimized and that NPPs (reactors and spent fuel storage) can cope with such events if they do happen.

Selected Operating Experience Documents on External Events

Effect of Hurricane Andrew on the Turkey Point Nuclear Generating Station from August 20 - 30, 1992
(extended LOOP) ADAMS ML063550235

Accident Sequence Precursor (ASP) Significant Precursors

[http://nrcweb.nrc.gov:8600/RES/projects/ASP/documents/Library/Significant%20Precursors/Significant%20Precursors%20\(Date\).pdf](http://nrcweb.nrc.gov:8600/RES/projects/ASP/documents/Library/Significant%20Precursors/Significant%20Precursors%20(Date).pdf) 4 Of 34 significant precursors involved LOOP, or partial LOOP (Items 2, 13, 21, and 28)

ASP LOOP Precursors (from FY2010 ASP SECY

<http://nrcweb.nrc.gov:8600/RES/projects/ASP/documents/Library/Past%20ASP%20SECY%20Papers/SECY-10-0125.pdf>) 25 LOOP ASP precursors between FY2001 and FY2009. Typically all LOOPS are ASP precursors.

IN 92-042, Failure of Electrical Power Equipment Due to Solar Magnetic Disturbances
<http://www.nrc.gov/reading-rm/doc-collections/gen-comm/info-notices/1990/in90042.html>

2003 Northeast Blackout <https://reports.energy.gov/BlackoutFinal-Web.pdf>

Generic Letter 2006-02 Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power
<http://www.nrc.gov/reading-rm/doc-collections/gen-comm/gen-letters/2006/gl200602.pdf>

Selected Information from Generic Issues Program activities

<http://www.narucmeetings.org/Presentations/NARUC%20EMP%20Presentation.pdf> (see page 8 for effects and page 13 for cost estimates)

EMP attack – potentially 70 to 90 % of U.S. population “unsustainable” (long term blackout, breakdown of transportation, water, energy infrastructure) Both EMP attack and electromagnetic storms can destroy large numbers of big transformers, which have limited manufacturing capacity and long-lead times (1-2 years) to replace.

Additional background information: Pre-GI-005 EMP Attack Threat
<http://www.internal.nrc.gov/RES/projects/GIP/Pre-GenericiIssues.html>

EMP Commission Report http://www.empcommission.org/docs/A2473-EMP_Commission-7MB.pdf

Information on Geomagnetic Storms

100-year Solar Flare – potential long term blackout affecting > 130 million people
http://science.nasa.gov/science-news/science-at-nasa/2009/21jan_severespaceweather/

Bensi, Michelle

From: Bensi, Michelle
Sent: Wednesday, April 13, 2011 3:35 PM
To: Beasley, Benjamin
Subject: FW: ACTION: FAQ repository for Public Distribution

From: Ibarra, Jose
Sent: Wednesday, April 13, 2011 2:50 PM
To: Bensi, Michelle; Killian, Michelle
Subject: FW: ACTION: FAQ repository for Public Distribution

Shelby and Michelle,

I understand that OEGIB has worked on Japanese Nuclear Event Q&As. Please see OEDO effort to put all the Japanese Nuclear Event into a Share Point site. I have sent this information to John Kauffman. See me if you have any questions. Thanks. Jose

From: Rini, Brett
Sent: Wednesday, April 06, 2011 6:01 PM
To: Ramirez, Annie; Ibarra, Jose; Rivera-Lugo, Richard
Subject: ACTION: FAQ repository for Public Distribution

TAs,

The action on this ticket is to determine if your divisions have generated any Q&As that aren't listed at the site below. If they aren't listed, we need to compile them and send them to OPA. If they are listed, then we don't have any actions.

I would think this applies to all the divisions. Can you provide me input by next Wednesday?

Thanks,
Brett

From: Case, Michael
Sent: Wednesday, April 06, 2011 10:34 AM
To: Sheron, Brian; RidsResOd Resource; Uhle, Jennifer; Valentin, Andrea; RidsResPmdaMail Resource
Cc: Rini, Brett; Coe, Doug; Correia, Richard; Gibson, Kathy; Richards, Stuart; Scott, Michael
Subject: RE: FOR TICKETING?? FW: FAQ repository in NRR

I think they already did. I checked a couple (Indian Point seismic and did the Japanese underestimate) and they are the answers that were in Annie's Q&A set.

From: Sheron, Brian
Sent: Wednesday, April 06, 2011 10:01 AM
To: RidsResOd Resource; Uhle, Jennifer; Valentin, Andrea; RidsResPmdaMail Resource
Cc: Rini, Brett; Case, Michael; Coe, Doug; Correia, Richard; Gibson, Kathy; Richards, Stuart; Scott, Michael
Subject: RE: FOR TICKETING?? FW: FAQ repository in NRR

Please ticket to Brett. Brett, please work with Divisions on this.

• Mike, do we/can we post Annie's seismic FAQs on this site?

From: Flory, Shirley **On Behalf Of** RidsResOd Resource
Sent: Wednesday, April 06, 2011 9:18 AM
To: Sheron, Brian; Uhle, Jennifer; Valentin, Andrea; RidsResPmdaMail Resource
Subject: FOR TICKETING?? FW: FAQ repository in NRR

Brian: Should this be ticketed?

Thanks - Shirley

From: Muessle, Mary
Sent: Tuesday, April 05, 2011 6:47 PM
To: RidsNmssOd Resource; RidsResOd Resource; RidsFsmeOd Resource; RidsNroOd Resource; RidsNsirOd Resource
Cc: Schum, Constance; Pulliam, Timothy; Valentin, Andrea; Webber, Robert; Brenner, Eliot; Hayden, Elizabeth; Rothschild, Trip; Leeds, Eric; Nelson, Robert; Markley, Michael; Oesterle, Eric; Rihm, Roger; Ellmers, Glenn; Andersen, James; Landau, Mindy; Frazier, Alan; Sealing, Donna; Ficks, Ben; Holonich, Joseph; Bowman, Gregory; Rheaume, Cynthia
Subject: FAQ repository in NRR

As you may know, NRR has established a very comprehensive SharePoint site for Frequently Asked Questions regarding the Japan event. These questions were initially intended to be used internally so that all staff responding to questions from stakeholders could provide a consistent response and so that similar questions would not have to be researched several times over. The site is located at: <http://portal.nrc.gov/edo/nrr/dorl/japan/Shared%20Documents/Questions%20and%20Answers.aspx>

We would like to make this FAQ site available to the public as the primary consolidated site for all FAQs related to the event. To this end, I am asking your assistance by notifying us as to whether FAQs have been gathered in your office and would be appropriate for the public site. The FAQs should be sufficiently "high-level" so that they would typically be asked by a member of the public. We are not seeking very technical, detailed FAQs. They should also be FAQs that do not already appear on the SharePoint site. If your office has developed such FAQs, please send them to Beth Hayden, in OPA, who has agreed to review them to ensure they are appropriate for public release. You should then forward the OPA-approved FAQs to NRR (Eric Oesterle) for incorporation on to the SharePoint site.

Our goal is to make the site available over the course of the next week or so and then incorporate any additional OPA-vetted FAQs on to the site as soon as practicable.

Please let Mindy Landau or I know if you have any questions and thank you for your assistance and thank to NRR for this outstanding initiative!

Mary

Lee, Richard

From: Lee, Richard
Sent: Thursday, April 14, 2011 6:41 PM
To: Salay, Michael
Subject: RE: are you returning on 04/16

O.k. Have a safe trip.

From: Salay, Michael
Sent: Thursday, April 14, 2011 5:01 PM
To: Lee, Richard
Subject: RE: are you returning on 04/16

Yes. I haven't heard otherwise.

-Mike

From: Lee, Richard
Sent: Thursday, April 14, 2011 4:56 PM
To: Salay, Michael
Subject: are you returning on 04/16

Mikey-san:

Are you returning on 4/16?

Richard

4/333

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Monday, April 18, 2011 11:31 AM
To: Kauffman, John
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs
Attachments: ATT00001..gif; ATT00002..gif

Your thoughts?

From: Sheron, Brian
Sent: Monday, April 18, 2011 11:20 AM
To: Beasley, Benjamin
Cc: Correia, Richard; Coe, Doug
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

See below. Would this likely pass a cost-benefit backfit test?


From: Richard L Garwin [<mailto:rlg2@us.ibm.com>]
Sent: Sunday, April 17, 2011 4:25 PM
To: Larzelere, Alex
Cc: Caponiti, Alice; Busby, Jeremy T; DL-NITSolutions; Schneider, Steve
Subject: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Dear Colleagues,


<http://allthingsnuclear.org> of April 14 has a very useful presentation of the Fukushima Dai-ichi problem.

I attach the first slide and also a detail of the steam-driven "isolation turbine and pump," and provide also a SUGGESTION by Bill Press.

4/334



Reactor Core Isolation Co



Bill Press (William H. Press, University of Texas at Austin, and LANL) asks why the RCIC turbine/pump does not have a "magneto" on the shaft, like that on a piston-driven aircraft engine, so that whenever the pump is running there is electrical power generated for the RCIC valves and other emergency loads. This might well be used to charge the batteries, too, and operate the control room indicators and lights.

This seems to me an eminently practical suggestion, which I am passing on for communication to NE and NRC.

Dick Garwin

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Monday, April 18, 2011 5:07 PM
To: Correia, Richard; Coe, Doug
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs
Attachments: ATT00001..gif; ATT00002..gif

Rich and Doug,

John Kauffman and I discussed this idea today. We will have a proposed response for your comment tomorrow or Wednesday.

Ben

From: Sheron, Brian
Sent: Monday, April 18, 2011 11:20 AM
To: Beasley, Benjamin
Cc: Correia, Richard; Coe, Doug
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


See below. Would this likely pass a cost-benefit backfit test?

From: Richard L Garwin [<mailto:rlg2@us.ibm.com>]
Sent: Sunday, April 17, 2011 4:25 PM
To: Larzelere, Alex
Cc: Caponiti, Alice; Busby, Jeremy T; DL-NITSolutions; Schneider, Steve
Subject: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


Dear Colleagues,

<http://allthingsnuclear.org> of April 14 has a very useful presentation of the Fukushima Dai-ichi problem.

I attach the first slide and also a detail of the steam-driven "isolation turbine and pump," and provide also a SUGGESTION by Bill Press.



Reactor Core Isolation Co



Bill Press (William H. Press, University of Texas at Austin, and LANL) asks why the RCIC turbine/pump does not have a "magneto" on the shaft, like that on a piston-driven aircraft engine, so that whenever the pump is running there is electrical power generated for the RCIC valves and other emergency loads. This might well be used to charge the batteries, too, and operate the control room indicators and lights.

This seems to me an eminently practical suggestion, which I am passing on for communication to NE and NRC.

Dick Garwin

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Tuesday, April 19, 2011 5:12 PM
To: Correia, Richard; Coe, Doug
Cc: Kauffman, John
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs
Attachments: image001.gif; image002.gif

Rich and Doug,

Below are our thoughts on the RCIC generator idea. Feel free to edit and forward this to Brian when you are ready.

Ben

From: Kauffman, John
Sent: Tuesday, April 19, 2011 2:59 PM
To: Beasley, Benjamin
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben,

As we discussed, this is an interesting idea...good outside the box thinking! That said, I think the answer to Brian's question is probably "no," as discussed below. You may want to have Marty or Gary check my PRA numbers/logic. Plants might voluntarily want to develop ways to use RCS energy and decay heat to generate electrical power in a long-term, "non-recoverable SBO," rather than just being helpless.

Risk Discussion

From the latest update to NUREG/CR-5750, the initiating event frequency for LOOP has an industry mean of $3.5\text{E-}02$ per year. From the latest update to NUREG/CR-5500, Vol. 5, the industry-wide average failure probability for not completing the 8-hour emergency power system (EPS) mission time is $9\text{E-}04$ per year.

So the probability of a LOOP followed by failure of the onsite EPS roughly $3\text{E-}5$ per year. Typically, under the agency's Regulatory Analysis Guidelines (page 14), an item cannot pass backfit if the estimated risk reduction in CDF is less than $1\text{E-}05$ per year. The LOOP IE frequency and EPS 8-hour failure probability do not credit grid recovery actions, or alternate AC capabilities (SBO or B5B diesels). When expecting severe weather, some plants shutdown and pre-position skid-mounted EDGs. Therefore, the CDF due to station blackout is probably less than $1\text{E-}05$.

That said, as evinced by the recent Japanese earthquake and tsunami, the grid and EPS are vulnerable to common cause failures due to extreme external events (most notably seismic and flooding)

In summary; our sense is that any backfits in this area will need to use an adequate protection justification.

Systems Discussion

RCIC is a small system (typically 400 gpm (larger on higher MW plants))...don't know how much electricity it could generate.

In a LOOP event, RCIC typically runs (along with HPCI/HPCS to restore/maintain reactor water level). However, these systems have more capacity than is needed and either trip on high level or require operator

- intervention to throttle them back. The point is that RCIC only runs intermittently. It also does not run at constant speed, which would be problematic for making stable, useable AC. (It could be useful for keeping batteries charged.)

Connecting a magneto to RCIC would create a "load," so it seems that RCIC would either need to draw more steam to produce the same injection flow or be de-rated. If the RCIC turbine were run continuously, it could depressurize the RCS, causing a loss of motive force. A separate turbine or a generator connected to the RCIC turbine only when RCIC is not injecting would address the de-rating issue but not the depressurization issue. Either of these would likely be more costly than alternatives.

In summary; our sense is that this idea would present challenging hurdles to implement. A more straight-forward approach would be to have pre-arranged ways to connect temporary (pre-arranged) AC sources, e.g. skid mounted EDGs, to the station's emergency/vital buses.

From: Sheron, Brian
Sent: Monday, April 18, 2011 11:20 AM
To: Beasley, Benjamin
Cc: Correia, Richard; Coe, Doug
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


See below. Would this likely pass a cost-benefit backfit test?

From: Richard L Garwin [<mailto:rlg2@us.ibm.com>]
Sent: Sunday, April 17, 2011 4:25 PM
To: Larzelere, Alex
Cc: Caponiti, Alice; Busby, Jeremy T; DL-NITSolutions; Schneider, Steve
Subject: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


Dear Colleagues,

<http://allthingsnuclear.org> of April 14 has a very useful presentation of the Fukushima Dai-ichi problem.

I attach the first slide and also a detail of the steam-driven "isolation turbine and pump," and provide also
a SUGGESTION by Bill Press.



Reactor Core Isolation Co



Bill Press (William H. Press, University of Texas at Austin, and LANL) asks why the RCIC turbine/pump does not have a "magneto" on the shaft, like that on a piston-driven aircraft engine, so that whenever the pump is running there is electrical power generated for the RCIC valves and other emergency loads. This might well be used to charge the batteries, too, and operate the control room indicators and lights.

This seems to me an eminently practical suggestion, which I am passing on for communication to NE and NRC.

Dick Garwin

54

Huffert, Anthony

From: Huffert, Anthony
Sent: Wednesday, April 20, 2011 2:32 AM
To: Meighan, Sean; Gepford, Heather; Conatser, Richard
Cc: Huffert, Anthony
Subject: "Manual for Measuring Radioactivity of Foods in Case of Emergency" dated May 9, 2002

Here is the link to the "Manual for Measuring Radioactivity of Foods in Case of Emergency" dated May 9, 2002
<http://www.mhlw.go.jp/stf/houdou/2r9852000001558e-img/2r98520000015cf6.pdf>
<http://www.mhlw.go.jp/stf/houdou/2r9852000001558e-img/2r98520000015cfn.pdf>

4/337



Huffert, Anthony

From: Huffert, Anthony
Sent: Wednesday, April 20, 2011 4:51 AM
To: Gepford, Heather; Meighan, Sean
Subject: REMINDER: Questions from PMT for task

From: Hoc, PMT12
Sent: Thursday, April 14, 2011 1:42 PM
To: RST01 Hoc; Huffert, Anthony
Cc: Hart, Michelle; Watson, Bruce; OST01 HOC
Subject: Questions from PMT for task

Hello RST and Japan Team,

Can you please respond to these two questions to assist the staff in answering a question from NARAC on the development of new source terms. Please respond to all. NRC staff points of contact are Bruce Watson and Michelle Hart. This is not an action, just a question – we are just looking for information.

- Do we have anyone recreating the source term from the reactors and SFP based on plant conditions or field measurement readings?
- Are there updates on releases or degree of core damage based on plant data?

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Wednesday, April 20, 2011 7:35 AM
To: Correia, Richard; Coe, Doug
Cc: Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs
Attachments: image001.gif; image002.gif

I am satisfied. John used the same sources that Gary would. We could quibble over using the mean versus the 95% number, but the difference is small.

Ben

From: Correia, Richard
Sent: Wednesday, April 20, 2011 7:07 AM
To: Beasley, Benjamin; Coe, Doug
Cc: Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben,

John asked to have Marty or Gary check his PRA logic/numbers. Are you satisfied they are accurate? John discussion and system performance seems reasonable to me.

thx

Richard Correia, PE
Director, Division of Risk Analysis
Office of Nuclear Regulatory Research
US NRC

richard.correia@nrc.gov

From: Beasley, Benjamin
Sent: Tuesday, April 19, 2011 5:12 PM
To: Correia, Richard; Coe, Doug
Cc: Kauffman, John
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Rich and Doug,

Below are our thoughts on the RCIC generator idea. Feel free to edit and forward this to Brian when you are ready.

Ben

From: Kauffman, John
Sent: Tuesday, April 19, 2011 2:59 PM
To: Beasley, Benjamin

Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben,

As we discussed, this is an interesting idea...good outside the box thinking! That said, I think the answer to Brian's question is probably "no," as discussed below. You may want to have Marty or Gary check my PRA numbers/logic. Plants might voluntarily want to develop ways to use RCS energy and decay heat to generate electrical power in a long-term, "non-recoverable SBO," rather than just being helpless.

Risk Discussion

From the latest update to NUREG/CR-5750, the initiating event frequency for LOOP has an industry mean of $3.5\text{E-}02$ per year. From the latest update to NUREG/CR-5500, Vol. 5, the industry-wide average failure probability for not completing the 8-hour emergency power system (EPS) mission time is $9\text{E-}04$ per year.

So the probability of a LOOP followed by failure of the onsite EPS roughly $3\text{E-}5$ per year. Typically, under the agency's Regulatory Analysis Guidelines (page 14), an item cannot pass backfit if the estimated risk reduction in CDF is less than $1\text{E-}05$ per year. The LOOP IE frequency and EPS 8-hour failure probability do not credit grid recovery actions, or alternate AC capabilities (SBO or B5B diesels). When expecting severe weather, some plants shutdown and pre-position skid-mounted EDGs. Therefore, the CDF due to station blackout is probably less than $1\text{E-}05$.

That said, as evinced by the recent Japanese earthquake and tsunami, the grid and EPS are vulnerable to common cause failures due to extreme external events (most notably seismic and flooding)

In summary; our sense is that any backfits in this area will need to use an adequate protection justification.

Systems Discussion

RCIC is a small system (typically 400 gpm (larger on higher MW plants))...don't know how much electricity it could generate.

In a LOOP event, RCIC typically runs (along with HPCI/HPCS to restore/maintain reactor water level). However, these systems have more capacity than is needed and either trip on high level or require operator intervention to throttle them back. The point is that RCIC only runs intermittently. It also does not run at constant speed, which would be problematic for making stable, useable AC. (It could be useful for keeping batteries charged.)

Connecting a magneto to RCIC would create a "load," so it seems that RCIC would either need to draw more steam to produce the same injection flow or be de-rated. If the RCIC turbine were run continuously, it could depressurize the RCS, causing a loss of motive force. A separate turbine or a generator connected to the RCIC turbine only when RCIC is not injecting would address the de-rating issue but not the depressurization issue. Either of these would likely be more costly than alternatives.

In summary; our sense is that this idea would present challenging hurdles to implement. A more straight-forward approach would be to have pre-arranged ways to connect temporary (pre-arranged) AC sources, e.g. skid mounted EDGs, to the station's emergency/vital buses.

From: Sheron, Brian
Sent: Monday, April 18, 2011 11:20 AM
To: Beasley, Benjamin
Cc: Correia, Richard; Coe, Doug

Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

See below. Would this likely pass a cost-benefit backfit test?

From: Richard L Garwin [mailto:rlg2@us.ibm.com]

Sent: Sunday, April 17, 2011 4:25 PM

To: Larzelere, Alex


Cc: Caponiti, Alice; Busby, Jeremy T; DL-NITSolutions; Schneider, Steve

Subject: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


Dear Colleagues,

<http://allthingsnuclear.org> of April 14 has a very useful presentation of the Fukushima Dai-ichi problem.

I attach the first slide and also a detail of the steam-driven "isolation turbine and pump," and provide also
a SUGGESTION by Bill Press.



Reactor Core Isolation Co



Bill Press (William H. Press, University of Texas at Austin, and LANL) asks why the RCIC turbine/pump does not have a "magneto" on the shaft, like that on a piston-driven aircraft engine, so that whenever the pump is running there is electrical power generated for the RCIC valves and other emergency loads. This might well be used to charge the batteries, too, and operate the control room indicators and lights.

This seems to me an eminently practical suggestion, which I am passing on for communication to NE and NRC.

Dick Garwin

Beasley, Benjamin

From: Beasley, Benjamin
Sent: Wednesday, April 20, 2011 10:38 AM
To: Coe, Doug; Correia, Richard; Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs
Attachments: image001.gif; image002.gif; image003.png


Doug,

You are correct that consequences are used to establish the cost-benefit. But the guidance says that the item can be dismissed if the risk numbers are below a certain level. In the chart below, for BWR Mark1 plants, we would use a conditional containment failure probability of E-1. With the delta CDF below E-5, we are in the zone of "Management decision whether to proceed." If we consider other things that may have driven the risk numbers down, like B5B, etc., then we could be below E-6 and in the "No action" zone altogether.

I agree with you regarding zeroing in on particular solutions. There would be much to consider before pursuing a solution like this. We were responding under the assumption that Brian was asking about regulatory feasibility, but we felt it worth pointing out some of the system implications.

We will consolidate our thoughts and send a response to Brian.

Ben



From: Coe, Doug
Sent: Wednesday, April 20, 2011 8:30 AM
To: Beasley, Benjamin; Correia, Richard; Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben/Rich/John,

Two reactions:

1. My initial reaction to Brian's question was: *you need to do the analysis* and shouldn't SWAG this. As I read the discussion below, it is focused on core damage, whereas the reg analysis must consider consequences (i.e. person-rem avoided). The core damage piece doesn't apparently consider SBO coping equipment/procedures (I'm not sure why) and the reg analysis guidelines do not (I believe) address multi-unit severe external events. So.... back to 'you shouldn't SWAG this.'
2. Second, I would resist zeroing in on specific 'solutions' without a full and integrated review of how any/all 'solutions' would impact the overall reactor plant system and its risk profile. Adding any new backfit carries the potential for creating new vulnerabilities even as you are attempting to resolve known vulnerabilities. I would advocate continuing to collect ideas such as this one, but not to do any 'cost-benefit' or similar analysis until we can look at them in an integrated manner.

From: Beasley, Benjamin
Sent: Wednesday, April 20, 2011 7:35 AM
To: Correia, Richard; Coe, Doug
Cc: Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

I am satisfied. John used the same sources that Gary would. We could quibble over using the mean versus the 95% number, but the difference is small.

Ben

From: Correia, Richard
Sent: Wednesday, April 20, 2011 7:07 AM
To: Beasley, Benjamin; Coe, Doug
Cc: Kauffman, John
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben,

John asked to have Marty or Gary check his PRA logic/numbers. Are you satisfied they are accurate? John discussion and system performance seems reasonable to me.

thx

Richard Correia, PE
Director, Division of Risk Analysis
Office of Nuclear Regulatory Research
US NRC

richard.correia@nrc.gov

From: Beasley, Benjamin
Sent: Tuesday, April 19, 2011 5:12 PM
To: Correia, Richard; Coe, Doug
Cc: Kauffman, John
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Rich and Doug,

Below are our thoughts on the RCIC generator idea. Feel free to edit and forward this to Brian when you are ready.

Ben

From: Kauffman, John
Sent: Tuesday, April 19, 2011 2:59 PM
To: Beasley, Benjamin
Subject: RE: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs

Ben,

As we discussed, this is an interesting idea...good outside the box thinking! That said, I think the answer to Brian's question is probably "no," as discussed below. You may want to have Marty or Gary check my PRA numbers/logic. Plants might voluntarily want to develop ways to use RCS energy and decay heat to generate electrical power in a long-term, "non-recoverable SBO," rather than just being helpless.

Risk Discussion

From the latest update to NUREG/CR-5750, the initiating event frequency for LOOP has an industry mean of $3.5E-02$ per year. From the latest update to NUREG/CR-5500, Vol. 5, the industry-wide average failure probability for not completing the 8-hour emergency power system (EPS) mission time is $9E-04$ per year.

So the probability of a LOOP followed by failure of the onsite EPS roughly $3E-5$ per year. Typically, under the agency's Regulatory Analysis Guidelines (page 14), an item cannot pass backfit if the estimated risk reduction in CDF is less than $1E-05$ per year. The LOOP IE frequency and EPS 8-hour failure probability do not credit grid recovery actions, or alternate AC capabilities (SBO or B5B diesels). When expecting severe weather, some plants shutdown and pre-position skid-mounted EDGs. Therefore, the CDF due to station blackout is probably less than $1E-05$.

That said, as evinced by the recent Japanese earthquake and tsunami, the grid and EPS are vulnerable to common cause failures due to extreme external events (most notably seismic and flooding)

In summary; our sense is that any backfits in this area will need to use an adequate protection justification.

Systems Discussion

RCIC is a small system (typically 400 gpm (larger on higher MW plants))...don't know how much electricity it could generate.

In a LOOP event, RCIC typically runs (along with HPCI/HPCS to restore/maintain reactor water level). However, these systems have more capacity than is needed and either trip on high level or require operator intervention to throttle them back. The point is that RCIC only runs intermittently. It also does not run at constant speed, which would be problematic for making stable, useable AC. (It could be useful for keeping batteries charged.)

Connecting a magneto to RCIC would create a "load," so it seems that RCIC would either need to draw more steam to produce the same injection flow or be de-rated. If the RCIC turbine were run continuously, it could depressurize the RCS, causing a loss of motive force. A separate turbine or a generator connected to the RCIC turbine only when RCIC is not injecting would address the de-rating issue but not the depressurization issue. Either of these would likely be more costly than alternatives.

In summary; our sense is that this idea would present challenging hurdles to implement. A more straight-forward approach would be to have pre-arranged ways to connect temporary (pre-arranged) AC sources, e.g. skid mounted EDGs, to the station's emergency/vital buses.

From: Sheron, Brian
Sent: Monday, April 18, 2011 11:20 AM
To: Beasley, Benjamin
Cc: Correia, Richard; Coe, Doug
Subject: FW: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


See below. Would this likely pass a cost-benefit backfit test?

From: Richard L Garwin [<mailto:rlg2@us.ibm.com>]
Sent: Sunday, April 17, 2011 4:25 PM
To: Larzelere, Alex
Cc: Caponiti, Alice; Busby, Jeremy T; DL-NITSolutions; Schneider, Steve
Subject: Useful presentation from <http://allthingsnuclear.org> of April 14, and a SUGGESTION for improving our BWRs


Dear Colleagues,

<http://allthingsnuclear.org> of April 14 has a very useful presentation of the Fukushima Dai-ichi problem.

I attach the first slide and also a detail of the steam-driven "isolation turbine and pump," and provide also
a SUGGESTION by Bill Press.



Reactor Core Isolation Co



Bill Press (William H. Press, University of Texas at Austin, and LANL) asks why the RCIC turbine/pump does not have a "magneto" on the shaft, like that on a piston-driven aircraft engine, so that whenever the pump is running there is electrical power generated for the RCIC valves and other emergency loads. This might well be used to charge the batteries, too, and operate the control room indicators and lights.

This seems to me an eminently practical suggestion, which I am passing on for communication to NE and NRC.

Dick Garwin