

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8006090346 DOC. DATE: 80/06/02 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 DUBOST, E.L. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: Updated 78-021/03X-1; on 780417, during performance of preventive main, tan control rod drive hydraulic control unit water level switches would not respond. Caused by switch plastic float becoming stuck.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	05 BC <u>ORB #3</u>	4	4			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	15 NOVAK/KNIEL	1	1	16 EEB	1	1
	17 AD FOR ENGR	1	1	18 PLANT SYS BR	1	1
	19 I&C SYS BR	1	1	20 AD PLANT SYS	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACIDENT ANLYS	1	1	29 AUX SYS BR	1	1
	AD/ORP-DOR	1	1	AEOD	10	10
	BERLINGER, C.	3	3	DOUG MAY-TERA	1	1
	HANAUER, S.	1	1	JORDAN, E./IE	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

JUN 10 1980

NOTE
GP