

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8006170665 DOC.DATE: 80/06/09 NOTARIZED: NO DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 DUBOST,E. Iowa Electric Light & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: Updated LER 79-014/01X-1: on 790703, results of testing re
 IE Bulletin 79-02 indicated potential generic problem
 w/anchor bolts not meeting seismic design criteria. Caused by
 faulty installation & inadequate design.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
 TITLE: Incident Reports

NOTES: _____

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
	BC IPPOLITO, T.05	4	4			
INTERNAL:	A/D RAD PROT	1	1	A/D REACT SYS	1	1
	A/D TECHNOLOGY	1	1	AEOD	10	10
	AUX SYS BR	1	1	CHEM ENG BR	1	1
	CONT SYS BR	1	1	EISENHUT, D.	1	1
	EMERG PREP	1	1	EQUIP QUAL BR	1	1
	HANAUER, S.	1	1	I&C SYS BR	1	1
	I&E 09	2	2	JORDAN, E./IE	1	1
	MPA 11	3	3	NRC PDR 02	1	1
	OP EX EVAL BR	1	1	OPER LIC BR 27	1	1
	OR ASSESS BR	1	1	PPAS	1	1
	QA BR	1	1	<u>REG FILE</u> 01	1	1
	SIT ANAL BR	1	1	SYS INTERAC BR	1	1
	TERA: DOUG MAY	1	1			
EXTERNAL:	ACRS	16	16	LPDR 03	1	1
	NSIC 04	1	1			

JUN 10 1980

JUN 18 1980

AOI
4
60