

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8006270274 DOC. DATE: 80/06/20 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 DUBOST, E. Iowa Electric Light & Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: Updated LER 79-004/03X-1: on 790311, subsequent to startup, drywell to suppression chamber differential pressure failed to achieve psid within required time. Caused by leakage through containment purge butterfly valve.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES: _____

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	BC <u>IPPOLITO, T</u> 05	1	1	PM <u>KEVERN, T</u> 06	2	2
INTERNAL:	A/D CORE & CS	1	1	A/D RAD PROT	1	1
	A/D REACT SYS	1	1	A/D TECHNOLOGY	1	1
	AEOD	10	10	AUX SYS BR	1	1
	CHEM ENG BR	1	1	CONT SYS BR	1	1
	CORE PERF BR	1	1	EMERG PREP	1	1
	EQUIP QUAL BR	1	1	HANAUER, S.	1	1
	I&C SYS BR	1	1	I&E	09	2
	JORDAN, E./IE	1	1	MOORE, V.		1
	MPA 11	3	3	NRC PDR	02	1
	OP EX EVAL BR	3	3	OR ASSESS BR		1
	PPAS	1	1	QA BR		1
	<u>REG FILE</u> 01	1	1	SIT ANAL BR		1
	SYS INTERAC BR	1	1	TERA: DOUG MAY		1
EXTERNAL:	ACRS	16	16	LPDR	03	1
	NSIC 04	1	1			

JUN 30 1980

271
A0/E
4
50

TOTAL NUMBER OF COPIES REQUIRED: LTR 61 ENCL 61

