

Iowa Electric Light and Power Company

July 23, 1980

DAEC-80-341

Mr. James G. Keppler, Director
Office of Inspection and Enforcement - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Prompt Notification of a
Reportable Occurrence

File: A-118a

Dear Mr. Keppler:

This letter, telecopied to your office, is intended to satisfy the requirement for prompt notification of a Reportable Occurrence in accordance with Specification 6.11.2.a of the Duane Arnold Energy Center Technical Specifications.

Technical Specification paragraph(s) violated:

Description Occurrence: During surveillance testing on July 22, 1980, Traveling Screen 1F-36B on the "B" River Water Supply (RWS) System was found inoperable. The "B" RWS System was declared inoperable and, due to the "A" RWS System being made inoperable earlier in the day for preventive maintenance, a 24 hour LCO was entered. The power supply breaker for the screen motor was reseated and 1F-36B returned to normal operation. The "B" RWS System was declared operable and the 24 hour LCO cancelled.

Very truly yours,



Daniel L. Mineck
Chief Engineer
Duane Arnold Energy Center

cc: Director, Management Information and Program Control (2)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D. C. 20555

A002
S
1/0

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8008050170 DOC. DATE: 80/07/23 NOTIFIED: NO DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 MINECK,D,L. Iowa Electric Light & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: RO: on 800722, during surveillance testing, Traveling Screen
 1F-36B on B river water supply sys found inoperable, A sys
 made inoperable earlier in day for preventative maint, Power
 supply breaker for motor reseted & 1F-36B returned to SVC.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Incident Reports

NOTES:

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	IPPOLITO, T. 05	1		KEVERN, T. 06	2	
INTERNAL:	A/D COMP&STRUCT	1		A/D ENV TECH	1	
	A/D MATL & QUAL	1		A/D OP. REACTORS	1	
	A/D PLANT SYS	1		A/D RAD PROT	1	
	A/D SFTY ASSESS	1		A/D TECHNOLOGY	1	
	ACC EVAL BR	1		AEOD	10	10
	AUX SYS BR	1		CHEM ENG. BR	1	
	CONT SYS BR	1		CORE PERF BR	1	
	D/DIR, HUM FAC S	1		DIR, ENGINEERING	1	
	DIR, HUM FAC SFY	1		DIR, SYS INTEG	1	
	EFF TR SYS BR	1		EMERG PREP	1	
	EQUIP QUAL BR	1		GEOSCIENCES	1	
	HUM FACT ENG BR	1		HYD/GEO BR	1	
	I&C SYS BR	1		I&E 09	2	
	JORDAN, E./IE	1		LIC GUID BR	1	
	LIC QUAL BR	1		MATL ENG BR	1	
	MECH ENG BR	1		MPA 11	3	
	NRC PDR 02	1		OP EX EVAL BR	3	
	OR ASSESS BR	1		POWER SYS BR	1	
	PROC/TST REV BR	1		QA BR	1	
	RAD ASSESS BR	1		REACT SYS BR	1	
	REG FILE 01	1		REL & RISK A BR	1	
	SFTY PROG EVAL	1		SIT ANAL BR	1	
	STRUCT ENG BR	1		SYS INTERAC BR	1	
EXTERNAL:	ACRS	16	16	LPDR 03	1	
	NSIC 04	1		TERA: DOUG MAY	1	

AUG 6 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 82 ENCL 0

ADLI
60