REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8008190581 DOC.DATE: 80/08/11 NOTARIZED: NO DOCKET #
FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
AUTH.NAME AUTHOR AFFILIATION
VANSICKEL,J. Iowa Electric Light & Power Co.
RECIP.NAME RECIPIENT AFFILIATION
Region 3, Chicago, Office of the Director

SUBJECT: LER 80-034/03L-0:on 800712,during shutdown for testing & maint,monthly surveillance testing of recirculation pump trip sys found not completed for Apr-Jun 1980.Caused by inadequate coordination between depts.Testing completed.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+1
TITLE: Incident Reports

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
ACTION:	IPPOLITO,T.	3	3			
INTERNAL:	A/D COMP&STRUCT	1	1	A/D ENV TECH	1	1
	A/D MATL & QUAL	1	1	A/D OP REACTORS	1	1
	A/D PLANT SYS	1	1	A/D RAD PROT	1	1
	A/D SFTY ASSESS	1	1	A/D TECHNOLOGY	1	1
	ACC EVAL BR	1	1	AEOD	10	10
	AUX SYS BR	1	1	CHEM ENG BR	1	1
	CONT SYS BR	1	1	CORE PERF BR	1	1
	D/DIR,HUM FAC S	1	1	DIR,ENGINEERING	1	1
	DIR,HUM FAC SFY	1	1	DIR,SYS INTEG	1	1
	EFF TR SYS BR	1	1	EMERG PREP	1	1
	EQUIP QUAL BR	1	1	GEOSCIENCES	1	1
	HUM FACT ENG BR	1	1	HYD/GEO BR	1	1
	I&C SYS BR	1	1	I&E 09	2	2
	JORDAN,E./IE	1	1	LIC GUID BR	1	1
	LIC QUAL BR	1	1	MATL ENG BR	1	1
	MECH ENG BR	1	1	MPA 11	3	3
	NRC PDR 02	1	1	OP EX EVAL BR	3	3
	OR ASSESS BR	1	1	POWER SYS BR	1	1
	PROC/TST REV BR	1	1	QA BR	1	1
	RAD ASSESS BR	1	1	REACT SYS BR	1	1
	[redacted] FILE 01	1	1	REL & RISK A BR	1	1
	SFTY PROG EVAL	1	1	SIT ANAL BR	1	1
	STRUCT ENG BR	1	1	SYS INTERAC BR	1	1
EXTERNAL:	ACRS	16	16	LPDR 03	1	1
	NSIC 04	1	1	TERA:DOUG MAY	1	1

AUG 20 1980

ADI 4

TOTAL NUMBER OF COPIES REQUIRED: LTTR 82 ENCL 82

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: I A D A C 1 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T

01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 3 3 1 (7) | EVENT DATE: 0 7 1 2 8 0 (8) | REPORT DATE: 0 8 1 1 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While shutdown for testing and maintenance it was determined that the mo
03 nthly surveillance testing of the recirculation pump trip system was not
04 completed as required by Technical Specification 4.2.G. The months affec
05 ted included April, May and June of 1980. However, during startup testin
06 g of the recirculation pump trip system in April, all of the essential e
07 lements of the surveillance test were performed. The RPT test requiremen
08 ts were added to Tech. Spec. in April 1980.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	R B (11)	A (12)	X (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 3 4	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
G (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The appropriate surveillance test procedures were not revised to reflect
11 the new surveillance reqmts. due to inadequate coordination between t
12 he responsible departments. The surv. tests were modified and the requir
13 ed testing successfully completed on 7/21/80. Resp personnel to be advi
14 sed of the need for better coor. on matters involving T.S. surv reqmts.

15 | FACILITY STATUS: G (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: Z (31) | DISCOVERY DESCRIPTION (32): NA

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES

17 | NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES

18 | NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)

19 | TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY

20 | ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

8008190581

NAME OF PREPARER: J. VanSickel PHONE: 319-851-5611