

Central Files

Iowa Electric Light and Power Company

July 28, 1980
LDR-80-209

LARRY D. ROOT
ASSISTANT VICE PRESIDENT
NUCLEAR GENERATION

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

This letter is our response to IE Bulletin 80-16 concerning potential misapplication of Rosemount Inc., Models 1151 and 1152 pressure transmitters with either "A" or "D" output codes.

As a result of our review, it has been determined that we have neither installed, nor do we plan to install said pressure transmitters in safety-related equipment at the Duane Arnold Energy Center.

Very truly yours,

Larry D. Root

Larry D. Root
Assistant Vice President
Nuclear Generation

LDR/RFS/mz

- cc: R. Salmon
- D. Arnold
- L. Liu
- S. Tuthill
- K. Meyer
- D. Mineck
- J. Van Sickle
- K. Eccleston (NRC)
- File: A-101a, BN 8016

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

*AOI/E
2*

JUL 31 1980

8009020170 *Q*

SD

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8008040133 DOC. DATE: 80/07/25 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 ROOT, L.D. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 KEPPLER, J.G. Region 3, Chicago, Office of the Director

SUBJECT: Responds to IE Bulletin 80-17, Suppl 2, "Failure of 76 of 185 Control Rods to Fully Insert During Scram at BWR." Util preparing design change to extend uncapped vent line to suitable point of discharge within reactor bldg.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	IPPOLITO, T. 05	1 1	KEVERN, T.	12 12
INTERNAL:	D/DIR, HUM FAC S	1 1	DIR, HUM FAC SFY	1 1
	I&E 12	2 2	NRC PDR 02	1 1
	OEFD 14	1 0	OR ASSESS BR 19	1 0
	<u>REG FILE</u> 01	1 1		
EXTERNAL:	ACRS 20	16 16	LPDR 03	1 1
	NSIC 04	1 1		

AUG 6 1980

60

A0/I
2

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 37