

Central 50/331  
Files

Iowa Electric Light and Power Company

August 29, 1980  
LDR-80-248

LARRY D. ROOT  
ASSISTANT VICE PRESIDENT  
NUCLEAR GENERATION

Mr. James G. Keppler, Director  
Office of Inspection and Enforcement  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, ILL 60137

Dear Mr. Keppler:

This letter is our response to IE Bulletin No. 80-19 concerning the use of mercury-wetted relays in Reactor Protection Systems. We have determined that no such relays are used in the Duane Arnold Energy Center RPS.

Approximately 24 man-hours were required to make this determination.

Very truly yours,

*Philip D. Root*

Larry D. Root FOR  
Assistant Vice President  
Nuclear Generation

LDR/RFS/mz

- cc: R. Salmon
- D. Arnold
- L. Liu
- S. Tuthill
- K. Meyer
- D. Mineck
- J. Van Sickle
- K. Eccleston (NRC)
- File: A-101a, BN 80-19

Director  
Division of Reactor Operations Inspection  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

AO  
2

SEP 02 1980

630

8009120555

Q