

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8011180316 DOC. DATE: 80/11/11 NOTARIZED: NO DOCKET #  
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331  
 AUTH. NAME AUTHOR AFFILIATION  
 MINECK, D.L. Iowa Electric Light & Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 KEPPLER, J.G. Region 3, Chicago, Office of the Director

A0/4

SUBJECT: R0: following reactor transient from low power involving  
 stuck open relief valve, average rate of reactor coolant  
 temp change was observed to be 120 F for first hour. Temp  
 dropped from 520 F to 418 F. Normal rates established.

DISTRIBUTION CODE: M007S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: LER (Backfit)

## NOTES:

RECIPIENT ID CODE/NAME.	COPIES LTR ENCL	RECIPIENT ID CODE/NAME.	COPIES LTR ENCL
----------------------------	--------------------	----------------------------	--------------------

INTERNAL: AEOD	2	ASLBP/J. HARD	1
I&E	2	MPA	1
NRC PDR	1	OP EX EVAL BR	1
REG FILE	1		
EXTERNAL: LPDR	1	NSIC	1

NOV 19 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 0

J

1980 NOV 17 PM 2 21

US NRC  
DISTRIBUTION SERVICES  
BRANCH

Iowa Electric Light and Power Company

November 11, 1980  
DAEC-80-494

Mr. James G. Keppler, Director  
Office of Inspection and Enforcement - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Subject: Prompt Notification of a  
Reportable Occurrence

File: A-118a

Dear Mr. Keppler:


This letter, telecopied to your office, is intended to satisfy the requirement for prompt notification of a Reportable Occurrence in accordance with Specification 6.11.2.a of the Duane Arnold Energy Center Technical Specifications.

Technical Specification paragraph(s) violated: 3.6.A.1

Description Occurrence:

Following a reactor transient from low power involving a stuck open relief valve, the average rate of reactor coolant temperature change was observed to be 102°F per hour for the first hour following the transient. Technical Specification 3.6.A.1 limits the rate of coolant temperature change to 100°F per hour during normal heatup and cooldown. Reactor coolant temperature dropped from 520°F at the beginning of the transient to 418°F. Normal cooldown rates were established and the reactor placed in cold shutdown.

Very truly yours,



Daniel L. Mineck  
Chief Engineer  
Duane Arnold Energy Center

DLM/JVS/pl

cc: Director, Management Information and Program Control (2)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

U. S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D. C. 20555

8011180 316

Duane Arnold Energy Center • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/851-5611

NRC Resident Inspector

Mod 7  
5/10