

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8806280242 DOC. DATE: 88/06/17 NOTARIZED: NO DOCKET #  
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331  
 AUTH. NAME AUTHOR AFFILIATION  
 ROTHERT, W. C. Iowa Electric Light & Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MURLEY, T. E. Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards summary listing of reactor coolant pressure boundary insp scheduled for Cycle 9/10 refueling outage, per NRC request. Outage scheduled to begin on 880929.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD3-3 LA	1	0	PD3-3 PD	5	5
	HALL, J. R.	1	1			
INTERNAL:	ACRS	10	10	AEOD/DOA	1	1
	AEOD/DSP/TPAB	1	1	ARM/DAF/LFMB	1	0
	NRR/DEST/MEB 9H	1	1	NRR/DEST/MTB 9H	1	1
	<del>NUDDS</del> ABSTRACT	1	1	OGC 15-B-18	1	0
	<u>REG FILE</u> 01	1	1	RES/DE/EIB	1	1
EXTERNAL:	EG&G ROCKHOLD, H	1	1	LPDR	1	1
	NL 007 HEMMING	1	1	NRC PDR	1	1
	NSIC	1	1			

Iowa Electric Light and Power Company

June 17, 1988

NG-88-1756

Dr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Duane Arnold Energy Center  
Docket No: 50-331  
Op. License No: DPR-49  
Plans for Inspection of Reactor Coolant  
Pressure Boundary Piping During Cycle 9/10  
Refueling Outage

Reference: 1) Letter from M. Virgilio (NRC) to L. Liu  
(Iowa Electric) dated May 22, 1987  
2) Letter from A. Cappucci (NRC) to L. Liu  
(Iowa Electric) dated August 26, 1987

File: A-107a, A-286, B-31c, SpF-118

Dear Dr. Murley:

In the referenced letters, the NRC staff stated they had reviewed and approved our piping inspection program for the Duane Arnold Energy Center (DAEC) conducted during the Cycle 8/9 refueling outage (March 12 through June 28, 1987). The staff also requested that we apprise them of our plans for future inspections and/or modifications of the reactor coolant pressure boundary piping system at least three months prior to the next scheduled refueling outage.

Attachment 1 to this letter provides a summary listing of the reactor coolant pressure boundary piping inspections scheduled for the Cycle 9/10 refueling outage. This outage is currently scheduled to begin on September 29, 1988. The attachment lists the systems to be inspected, piping diameter, weld type, and number of welds to be inspected during the Cycle 9/10 refueling outage. The comparable number of welds inspected during the preceding outage is also stated.

8806280242 880617  
PDR ADOCK 05000331  
Q PDR

A047  
11

Dr. Thomas E. Murley  
NG-88-1756  
June 17, 1988  
Page Two

Should you have any additional questions or concerns regarding this submittal, please contact this office.

Very truly yours,

  
William C. Rothert  
Manager, Nuclear Division

WCR/NKP/pjv+

Attachment: 1) Summary of Intergranular Stress Corrosion Cracking (IGSCC) Susceptible Welds Scheduled for Ultrasonic Examination During Cycle 9/10 Refueling Outage

cc: N. Peterson  
L. Liu  
L. Root  
R. McGaughy  
J. R. Hall (NRC-NRR)  
A. Bert Davis (Region III)  
NRC Resident Office  
Commitment Control No. 870130, 870248

## Summary of Intergranular Stress Corrosion Cracking (IGSCC) Susceptible Welds Scheduled for Ultrasonic Examination During the Cycle 9/10 Refueling Outage

System	Dia. (in.)	Total IGSCC Category Welds By System/ Category	Dissimilar Metal Welds Scheduled	Stainless Steel Welds Scheduled	IGSCC Category	Total Examined Cycle 8/9 Outage	Comments
Core Spray Loop A	8	4	3	1	D	4	
Core Spray Loop B	8	4	3	1	D	4	
Reactor Water Cleanup Suction	4	18	-	13	D	5	
Reactor Water Cleanup Discharge	4	13	1	12	D	0	
Residual Heat Removal 18B	18	2	1	-	C	1	
			-	1	E	1	overlay
Residual Heat Removal 20A	20	2	1	1	C	2	
Residual Heat Removal 20B	20	2	1	1	C	2	
Recirc. Pump A-Suction	22	18	-	2	C	18	
	22	1	1	-	D	1	
Recirc. Bypass A	4	9	-	6	D	3	
Recirc. Manifold A	10	4	-	0	C	4	
	16	4	-	1	C	4	
	22	1	-	1	C	1	
Recirc. Riser E	10	4	1	-	C	3	
	10	1	1	-	D	1	
	10	1	-	1	E	1	overlay

## Summary of Intergranular Stress Corrosion Cracking (IGSCC) Susceptible Welds Scheduled for Ultrasonic Examination During the Cycle 9/10 Refueling Outage

System	Dia. (in.)	Total IGSCC Category Welds By System/ Category	Dissimilar Metal Welds Scheduled	Stainless Steel Welds Scheduled	IGSCC Category	Total Examined Cycle 8/9 Outage	Comments
Recirc. Riser F	10	4	1	-	C	4	overlay
	10	1	1	-	D	1	
	10	1	-	1	E	1	
Recirc. Riser G	10	4	1	-	C	4	overlay
	10	1	1	-	D	1	
	10	1	-	1	E	1	
Recirc. Riser H	10	4	1	-	C	4	overlay
	10	1	1	-	D	1	
	10	1	-	1	E	1	
Recirc. Pump B-Suction	22	18	-	2	C	18	
	22	1	1	-	D	1	
Recirc. Bypass B	4	9	-	6	D	3	
Recirc. Manifold B	10	4	-	-	C	4	
	16	4	-	1	C	4	
	22	1	-	1	C	1	
Recirc. Riser A	10	4	1	-	C	4	overlay
	10	1	1	-	D	1	
	10	1	-	1	E	1	

Summary of Intergranular Stress Corrosion Cracking (IGSCC) Susceptible Welds Scheduled for Ultrasonic Examination During the Cycle 9/10 Refueling Outage

System	Dia. (in.)	Total IGSCC Category Welds By System/ Category	Dissimilar Metal Welds Scheduled	Stainless Steel Welds Scheduled	Total IGSCC Category	Examined 1987 RFO	Comments
Recirc. Riser B	10	4	1	-	C	4	overlay
	10	1	1	-	D	1	
	10	1	-	1	E	1	
Recirc. Riser C	10	6	1	2	C	6	
	10	1	1	-	D	1	
Recirc. Riser D	10	3	1	-	C	3	overlays
	10	1	1	-	D	1	
	10	2	-	2	E	2	
Jet Pump Instr.-A	4	2	-	-	D	2	
Jet Pump Instr.-B	4	2	-	-	D	2	
Totals	N/A	172	28	60	N/A	130	N/A