

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8901240283 DOC.DATE: 89/01/17 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 ROTHERT, W. Iowa Electric Light & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 DAVIS, A.B. Region 3, Ofc of the Director

SUBJECT: Documents util commitment re main steam isolation valve leak rate testing.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD3-3	LA	1	0		PD3-3	PD	5	5
	HALL, J.R.		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/PSB 8D		1	1		NUDOCS ABSTRACT		1	1
	OGC/HDS2		1	1		<u>REG FILE</u> 01		1	1
	RES TELFORD, J		1	1		RES/DE/SEB		1	1
	RES/DSIR/SAIB		1	1		RES/DSR/RPSB		1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

R
I
D
S
/
A
D
D
S

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 23

R
I
D
S
/
A
D
D
S

Iowa Electric Light and Power Company

NG-89-0196
January 17, 1989

Mr. A. Bert Davis
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-19
Main Steam Isolation Valve Leak
Rate Testing
File: A-103

Dear Mr. Davis:

In response to discussions with Mr. William Axelson, and Mr. Geoffrey Wright, and others of your staff on January 17, 1989, Iowa Electric would like to formally document our commitment to schedule a plant shutdown for Leak Rate Testing of Main Steam Isolation Valves during Cycle 10 operation. The target date for this shutdown and testing will be the months of October or November, 1989. Should an unscheduled plant shutdown occur or other scheduling conflicts arise, the shutdown and testing of the valves may occur as early as September 1, 1989. A minimum of three Main Steam Isolation Valves shall be tested to include the 'A' main steam line inboard and outboard isolation valves and the 'C' main steam line outboard isolation valve (CV-4412, CV-4413, and CV-4419). If any of the valves are found to have excessive leakage, the leaking valve will be repaired and all eight Main Steam Isolation Valves tested and repaired as appropriate. Your staff will be informed of the exact testing schedule and results as they become available.

If you have any further questions regarding this subject, feel free to contact me at (319) 398-7202 or Mr. Jeff Thorsteinson of my staff at (319) 851-7238.

Very truly yours,



William Rothert
Manager, Nuclear Division

WR/KP/sb

cc: U.S. Document Control Desk
L. Liu
R. McGaughy
J.R. Hall (NRR)
NRC Resident Inspector - DAEC
K. Putnam

8901240283 890117
PDR ADDCK 05000331
P FCC

A017
/10