

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8904260071 DOC. DATE: 89/04/17 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 MINECK, D.L. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards response to station blackout rule, per 10CFR50.63.

DISTRIBUTION CODE: A050D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: OR Submittal: Station Blackout (USI A-44) 10CFR50.63, MPA A-22

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-3 PD		1	1		HALL, J.R.		1	1
INTERNAL:	ACRS		1	1		NRR PD1-4PM TAM		1	1
	NRR/DEST/ESB		2	2		NRR/DEST/PSB		2	2
	NRR/DEST/RSB		1	1		NUDOCS-ABSTRACT		1	1
	<u>REG FILE</u> 01		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

m/A-4

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

Iowa Electric Light and Power Company

April 17, 1989

NG-89-0923

Dr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-49
10 CFR 50.63, "Loss of All Alternating Current Power"
Information Submittal
File: A-106a, A-107c, R-10

Dear Dr. Murley:

In accordance with the requirements of 10 CFR Part 50.63 (c)(1), please find Iowa Electric's station blackout information submittal attached for your review.

Very truly yours,



Daniel L. Mineck
Manager, Nuclear Division

DLM/BJH/pjv+

Attachment

cc: B. Johnson
L. Liu
L. Root
R. McGaughy
B. Lee, Jr. (NUMARC)
J. R. Hall (NRC-NRR)
A. Bert Davis (Region III)
NRC Resident Office
Commitment Control 860185

8904260071 890417
PDR ADOCK 05000331
F FDC

A050
5/11

Iowa Electric Light and Power Company

Duane Arnold Energy Center

Response to Station Blackout Rule

Effective July 21, 1988, the Nuclear Regulatory Commission (NRC) amended its regulations by adding a new section 50.63 which requires that each light-water-cooled nuclear power plant be able to withstand and recover from a station blackout (SBO) of a specified duration. Utilities are expected to have available for NRC review the baseline assumptions, analyses and related information used in their coping evaluation. Section 50.63 requires that the plant be capable of maintaining core cooling and appropriate containment integrity during an SBO of a specified duration and identifies the factors that must be considered in determining that duration. Section 50.63 further requires that each licensee submit the following information:

1. A proposed station blackout duration including a justification for the selection based on the redundancy and reliability of the onsite emergency AC power sources, the expected frequency of loss of offsite power (LOOP), and the probable time needed to restore offsite power;
2. A description of the procedures that will be implemented for station blackout events for the duration (as determined in 1 above) and for recovery therefrom; and
3. A list of modifications to equipment and associated procedures necessary to withstand the specified SBO duration and a proposed schedule for implementing these modifications.

The NRC has issued Regulatory Guide (RG) 1.155, "Station Blackout," which describes a means acceptable to the NRC Staff for meeting the requirements of 10 C.F.R. 50.63. RG 1.155 states that the NRC Staff has concluded that NUMARC 87-00, "Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout At Light Water Reactors," also provides guidance that is in large part identical to the RG 1.155 guidance and is acceptable to the NRC Staff for meeting these requirements.

Table 1 to RG 1.155 provides a cross-reference between RG 1.155 and NUMARC 87-00 and notes where the RG takes precedence.

Iowa Electric Light and Power Company (IELP) has evaluated the Duane Arnold Energy Center (DAEC) against the requirements of the SBO rule using guidance from NUMARC 87-00 except where use of RG 1.155 is required. The results of this evaluation are detailed below. (Reference to NUMARC 87-00 Sections are shown in the parentheses.)

A. Proposed Station Blackout Duration

NUMARC 87-00, Section 3 was used to determine the proposed SBO duration of four hours. No modifications were required to attain this proposed coping duration category.

The following plant factors were used to determine the proposed station blackout:

1. AC Power Design Characteristic Group is P1 based on:
 - a. Expected frequency of grid-related LOOPS does not exceed once per 20 years (Section 3.2.1, Part 1A, p. 3-3);
 - b. Estimated frequency of LOOPS due to extremely severe weather places the plant in ESW Group 2 (Section 3.2.1, Part 1B, p. 3-4);
 - c. Estimated frequency of LOOPS due to severe weather places the plant in SW Group 2 (Section 3.2.1, Part 1C, p. 3-7);
 - d. The offsite power system is in the I1/2 Group (Section 3.2.1, Part 1D, p. 3-10).
2. The emergency AC power configuration group is C based on: (Section 3.2.2, Part 2C, p. 3-13):
 - a. There are two emergency AC power supplies not credited as alternate AC power sources (Section 3.2.2, Part 2A, p. 3-15);
 - b. One emergency AC power supply is necessary to operate safe shutdown equipment following a loss of offsite power (Section 3.2.2, Part 2B, p. 3-15).
3. The target EDG reliability is .95.

A target EDG reliability of .95 was selected based on having a nuclear unit average EDG reliability for the last 100 demands greater than 0.95 consistent with NUMARC 87-00, Section 3.2.4.

B. Procedure Description

Plant procedures have been reviewed and will be modified to meet the guidelines in NUMARC 87-00, Section 4 in the following areas.

1. AC power restoration per NUMARC 87-00, Section 4.2.2:
 - a. DAEC Abnormal Operating Procedure (AOP) 301 - Loss of Essential Electrical Power.
 - b. DAEC Annunciator Response Procedure (ARP) 1C08A/B/C - Electrical Power Distribution System Alarms.
 - c. DAEC Operating Instruction (OI) 304.2 - 4160v/480v Essential Electrical Distribution System.

2. Severe weather per NUMARC 87-00, Section 4.2.3:

- a. DAEC Abnormal Operating Procedure (AOP) 903 - Tornado.

Plant procedures have been reviewed and changes necessary to meet NUMARC 87-00 will be implemented in the following areas:

1. Station blackout response per NUMARC 87-00, Section 4.2.1.

C. Proposed Modifications

The ability of DAEC to cope with a station blackout for four hours in accordance with NUMARC 87-00, Section 3.2.5 and as determined in Section "A" above; was assessed using NUMARC 87-00, Section 7. This preliminary assessment has indicated that no plant modifications are required to cope with an SBO duration of four hours. In addition, a more detailed review will be performed to validate the baseline assumptions set forth in NUMARC 87-00, Section 2 on a plant specific basis for DAEC. IELP will ensure that the Commission is advised of unforeseen plant modifications necessary for coping with an SBO of the proposed four hour duration in a timely manner. The preliminary coping assessment was completed with the following results:

1. Condensate Inventory For Decay Heat Removal (Section 7.2.1)

It has been determined from Section 7.2.1 of NUMARC 87-00 that 36,675 gallons of water are required for decay heat removal for the required coping duration of four hours. By design, the condensate storage tanks maintain an approximate total reserve of 75,000 gallons of water for use under emergency conditions, which exceeds the required quantity for coping with a four hour station blackout. No plant modifications or procedure changes are needed to utilize this water source.

2. Class 1E Battery Capacity (Section 7.2.2)

A battery capacity calculation has been performed pursuant to NUMARC 87-00, Section 7.2.2, to verify that the Class 1E batteries have sufficient capacity to meet station blackout loads for four hours.

3. Compressed Air (Section 7.2.3)

Air-operated valves relied upon to cope with a station blackout for four hours can either be operated manually or have sufficient backup sources independent of the preferred and blacked out unit's Class 1E power supply. Valves requiring manual operation or that need backup sources for operation will be identified in plant procedures.

4. Effects of Loss of Ventilation (Section 7.2.4)

- a. The steady state ambient air temperature has been calculated for the following dominant areas of concern:

<u>Area</u>	<u>Temperature</u>
HPCI Room	151°F
RCIC Room	128°F
Steam Tunnel	240°F
Essential Switchgear Room	115°F

- b. The assumption in NUMARC 87-00, Section 2.7.1 that the control room will not exceed 120°F during a station blackout has been assessed.

The control room at DAEC will not exceed 120°F during a station blackout. Therefore, the control room is not a dominant area of concern.

Reasonable assurance of the operability of station blackout response equipment in the above dominant areas of concern has been assessed using Appendix F to NUMARC 87-00, the Topical Report, and NUREG/CR-4442. No modifications or associated procedures are required to provide reasonable assurance for equipment operability.

5. Containment Isolation (Section 7.2.5)

The plant list of containment isolation valves has been reviewed to verify that valves which must be capable of being closed or that must be operated (cycled) under station blackout conditions can be positioned (with indication) independent of the preferred and blacked-out unit's Class 1E power supplies. No plant modifications and/or associated procedure changes were determined to be required to ensure that appropriate containment integrity can be provided under SBO conditions.

6. Reactor Coolant Inventory (Section 2.5)

The ability to maintain adequate reactor coolant system inventory to ensure that the core is cooled has been assessed for the required four hour coping duration. A plant-specific analysis was used for this assessment. The expected rates of reactor coolant inventory loss under SBO conditions do not result in more than a momentary core uncover in an SBO of four hours. Therefore, makeup systems in addition to those currently available under SBO conditions are not required to maintain core cooling under natural circulation.

D. Schedule for Implementation

Within thirty days after the Director, Office of Nuclear Reactor Regulation, notifies IELP of his conclusions regarding the adequacy of the proposed station blackout duration and procedure changes identified in Parts A, B, and C above, IELP will advise the NRC, in accordance with the Integrated Plan, of the schedule for implementation at DAEC.