

CCNPP3COLA PEmails

From: Arora, Surinder
Sent: Wednesday, August 03, 2011 1:52 PM
To: Robert.Poche@unistarnuclear.com
Cc: Chakrabarti, Samir; Miernicki, Michael; Ford, Tanya; CCNPP3COL Resource; Wilson, Anthony
Subject: RAI 315 clarification call attendees

The NRC participants for this clarification call (held on August 2, 2011 at 1:00 PM, EST) were:

Surinder Arora
Mike Miernicki
Samir Chakrabarti
David Foster

During the call, the following clarifications relative to Question No. 03.07.02-63 were provided in response to the UniStar's request for clarification:

1. UniStar should provide information about how the seismic inputs are determined for each seismic category II structure with due consideration of effects from adjacent structures.
2. UniStar should describe methods used to determine seismic stability including providing stability evaluation results for each category II structure based on the conceptual design of these structures.
3. UniStar should describe analysis and design methodology of each category II structure in sufficient detail that demonstrates that the design will provide a margin of safety equivalent to those of category I structures, with an ITAAC that will confirm that the as-built structure is analyzed and designed as described in the FSAR.

It was also agreed upon by all participants that the draft question as written in the RAI did not require any changes and RAI can be issued as Final.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

From: Poche, Robert [<mailto:robert.poche@unistarnuclear.com>]
Sent: Wednesday, August 03, 2011 9:53 AM
To: Arora, Surinder
Subject: RAI 315 clarification call attendees

Surinder,

The following individuals were on the RAI 315 clarification teleconference representing UniStar:

[UniStar](#)
Robert Poche
Antonio Fernandez
Jay Leininger

AREVA

Calvin Wong
Todd Oswald
Dan Fisher
Martin Owens
Ray Lewis

Robert Poche
Regulatory Affairs Project Manager
Calvert Cliffs Nuclear Power Plant Unit 3
(410) 470-5530 Office
(509) 528-5513 Cell
robert.poche@unistarnuclear.com
rpoche1@aol.com

Disclaimer: This e-mail and any attachments are confidential, may contain legal, professional or other privileged information, and are intended solely for the addressee. If you are not the intended recipient, do not use the information in this e-mail in any way, delete this e-mail and notify the sender.

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 2698

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED7E46365613)

Subject: RAI 315 clarification call attendees
Sent Date: 8/3/2011 1:51:46 PM
Received Date: 8/3/2011 1:52:01 PM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"Chakrabarti, Samir" <Samir.Chakrabarti@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Ford, Tanya" <Tanya.Ford@nrc.gov>
Tracking Status: None
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Wilson, Anthony" <Anthony.Wilson@nrc.gov>
Tracking Status: None
"Robert.Poche@unistarnuclear.com" <Robert.Poche@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	2504	8/3/2011 1:52:01 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: