



Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, MS 39150

**Michael A. Krupa**  
Director, Extended Power Uprate  
Grand Gulf Nuclear Station  
Tel. (601) 437-6684

GNRO-2011/00074

August 30, 2011

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**SUBJECT:** Supplemental Information Regarding  
Extended Power Uprate  
Grand Gulf Nuclear Station, Unit 1  
Docket No. 50-416  
License No. NPF-29

**REFERENCES:** 1. License Amendment Request, Extended Power Uprate, dated  
September 8, 2010 (GNRO-2010/00056, NRC ADAMS Accession No.  
ML102660403)  
2. Response to Request for Additional Information Regarding  
Extended Power Uprate – Electrical Branch, dated May 5, 2011 (NRC  
ADAMS Accession No. ML111250552)

Dear Sir or Madam:

By letter Grand Gulf Nuclear Station, Unit 1 (GGNS) submitted an Extended Power Uprate (EPU) License Amendment Request (LAR) (Reference 1). The environmental qualification (EQ) accident temperature profiles for all plant EQ zones and elevations were provided as Figure 2.3-1 of LAR Attachment 5, "Safety Analysis Report for Grand Gulf Nuclear Station." On July 29, 2011, an error was identified associated with the drywell accident temperature profiles reflected in Revision 6 of the design specification "Environmental Parameters for GGNS" (E100.0). The error, which was documented in the GGNS corrective action program, occurred in 2008 when E100.0 Revision 6 was developed; the curve set for the drywell accident temperature profile was inadvertently changed. This profile had been used in the EPU evaluation. A copy of the corrected curve is included in Attachment 1.

As a result of this error, a review of the EQ information contained in EPU LAR Attachment 5 and the responses to the Electrical Branch questions (Reference 2) has been performed. Based on this review, Entergy has determined two aspects of the EQ-related information are affected by this error:

1. The description of the post-LOCA temperature profile provided in EPU LAR Attachment 5, Section 3.2.1, *Environmental Qualification of Electrical Equipment*, in

the subsection titled "Inside Containment" is incorrect. A similar discussion was included in the response to questions 1 and 2 from the Electrical Branch (Reference 2).

2. The revised CLTP drywell EQ accident temperature profile used for qualification of equipment does not bound the EPU drywell enveloping accident temperature profile.


However, based on a review of the 37 EQ data packages associated with the components in the drywell using the revised EPU drywell curve, the evaluation results presented in EPU LAR Attachment 5 (including EPU LAR Tables 2.3-1 and 2.3-2) are not affected. In addition, the conclusions, other than the characteristics of the curves, to the responses to the Electrical Branch EQ related questions (Reference 2) are unaffected by the revised curves.

No change is needed to the no significant hazards consideration included in the initial EPU LAR (Reference 1) as a result of the additional information provided. There are no new commitments included in this letter.

If you have any questions or require additional information, please contact Jerry Burford at 601-368-5755.

I declare under penalty of perjury that the foregoing is true and correct. Executed on August 30, 2011.

Sincerely,

A handwritten signature in black ink that reads "M. A. Krupa". The signature is written in a cursive, slightly slanted style.

MAK/FGB/dm

Attachments:

1. Revised EPU LAR Attachment 5 Figure 2.3-1

cc: Mr. Elmo E. Collins, Jr.  
Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
612 East Lamar Blvd., Suite 400  
Arlington, TX 76011-4005

U. S. Nuclear Regulatory Commission  
ATTN: Mr. A. B. Wang, NRR/DORL (w/2)

**ATTN: ADDRESSEE ONLY**

ATTN: Courier Delivery Only  
Mail Stop OWFN/8 B1  
11555 Rockville Pike  
Rockville, MD 20852-2378

State Health Officer  
Mississippi Department of Health  
P. O. Box 1700  
Jackson, MS 39215-1700

NRC Senior Resident Inspector  
Grand Gulf Nuclear Station  
Port Gibson, MS 39150

**Attachment 1**

**GNRO-2011/00074**

**Grand Gulf Nuclear Station Extended Power Uprate**

**Revised EPU LAR Attachment 5 Figure 2.3-1**

Revised EPU LAR Attachment 5 Figure 2.3-1  
Worst Case EQ Enveloping Accident Temperature Profiles (All Plant EQ Zones and Elevations)

