ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

	0-331 Duane Arnold AME AUTHOR A D.L. Iowa Elec NAME RECIPIEN	Energy Cente AFFILIATION Stric Light of AT AFFILIATION	& Power Co.	Light & Pow 0500	0331
SUBJECT	: Discusses util re position on opera valves.Util will	esponse to Ni ability of sa adopt more o		aining NRC -function ion & enter	I D
DISTRIB	UTION CODE: A001D OR Submittal: Gener	COPIES RECE	IVED:LTR ENCL _ tion	0 size: 2	_ S
NOTES:					
	RECIPIENT ID CODE/NAME PD3-3 LA SHIRAKI,C.	COPIES LTTR ENCL 1 1 2 2	RECIPIENT ID CODE/NAME PD3-3 PD	COPIES LTTR ENCL 1 1	A D D
INTERNAL:	ACRS NRR/DET/ESGB NRR/DST 8E2 NRR/DST/SICB8H7 NUDOCS-ABSTRACT OGC/HDS2 RES/DSIR/EIB	6 6 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	NRR/DET/ECMB 7D NRR/DOEA/OTSB11 NRR/DST/SELB 7E NRR/DST/SRXB 8E OC/LFMB REG=FILE 01	1 1 1 1	S
EXTERNAL:	NRC PDR	1 1	NSIC	1 1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 220

MA

R

I

D

D

Iowa Electric Light and Power Company

December 11, 1991

NG-91-3909

Dr. Thomas E. Murley, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Attn: Document Control Desk M/S P1-137 Washington, D.C. 20555

Subject: Duane Arnold Energy Center

Docket No: 50-331 Op License No: DPR-49

"Response to NRC Position on Operability of

Safety-Related Dual Function Valves"

Reference: Letter Dated October 3, 1991 from C. Shiraki,

Senior Project Manager to L. Liu, Iowa Electric Light and Power "NRC Position on Operability of Safety-Related Dual Function

Valves" (TAC No 180647)

File: A-117

Dear Dr. Murley:

Iowa Electric Light and Power Company (IELP) staff met with the NRC staff on August 16, 1991, and presented its position that valves such as the Emergency Core Cooling System (ECCS) Torus Suction Valves are not containment isolation valves and that the Technical Specifications (TS) closure action statement does not apply to these valves. IELP concluded that because closure of these valves defeats the ECCS, application of the TS action statement would be contrary to safety.

On October 3, 1991, the above-referenced letter was issued stating the NRC staff's position on safety-related dual function valves, i.e., "if any ECCS/Containment Isolation Valve experiences a failure mode that does not allow the valve to fully function as intended, the requirements for primary containment isolation may no longer be met, and, unless relief is granted, the Limiting Condition of Operation (LCO) for primary containment isolation applies." It is the position of the NRC that valves such as the ECCS Torus Suction Valve are Primary Containment Isolation Valves (PCIVs).

9112190002 911211 PDR ADOCK 05000331 P PDR Dr. Thomas E. Murley NG-91-3909 December 11, 1991 Page 2

We have researched the documentation for the valves in question. Although they have never been listed in the table of Primary Containment Isolation Valves contained in the TS, we can find no documentary explanation for that exclusion. We will therefore adopt the more conservative position and enter the LCO action statements for primary containment isolation if an ECCS/Containment Isolation Valve experiences a failure mode which inhibits the valve from performing its containment isolation function. However, it is our understanding that the referenced letter addressed only TS action statements for dual-function valves and was not intended to modify or supercede any exemptions, reliefs or exceptions to other regulatory requirements, such as, Appendix J, Environmental Qualification, Inservice Testing, etc., nor was it intended to modify our present application of these programs. Please advise us promptly if this is not your understanding.

Very truly yours,

Daniel L. Mineck

Manager, Nuclear Division

DLM/GTK:so

cc: G. Kaeqi

L. Liu

L. Root

R. McGaughy

C. Shiraki (NRC-NRR)

A. Bert Davis (Region III)

NRC Resident Office