



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 9, 2011

LICENSEE: FirstEnergy Nuclear Operating Co.

FACILITY: Davis-Besse

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING CO., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE LICENSE RENEWAL APPLICATION (TAC NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on June 7, 2011, to discuss the Davis-Besse May 24, 2011, response to request for additional information (RAI) B.2.7-1 regarding the proposed Davis-Besse License Renewal Buried Piping Program.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a brief description of the discussion related to RAI B.2.7-1 response.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, appearing to read "S. Cuadrado de Jesús".

Samuel Cuadrado de Jesús
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosures:
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL
DAVIS-BESSE
LICENSE RENEWAL APPLICATION
LIST OF PARTICIPANTS
JUNE 7, 2011

PARTICIPANTS:

AFFILIATIONS:

Samuel Cuadrado de Jesús

U.S. Nuclear Regulatory Commission (NRC)

Bill Holston

NRC

Cliff Custer

FirstEnergy Nuclear Operating Company

Steve Dort

FENOC

Allen McAllister

FENOC

Kathy Nesser

FENOC

REQUESTS FOR ADDITIONAL INFORMATION
LICENSE RENEWAL APPLICATION
JUNE 7, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on June 7, 2011, to discuss the response in FENOC Letter L-11-153 dated May 24, 2011, to NRC request for additional information (RAI) B.2.7-1 regarding the proposed Davis-Besse License Renewal Buried Piping Program.

Discussion on Response to RAI B.2.7-1:

- 1) The staff stated that, in response to RAI B.2.7-1 request #3, the applicant stated its intentions regarding the equipment that would be protected with cathodic protection, yet license renewal future commitment #3 on page 137 of the Enclosure to the letter was not updated.

The applicant stated that it will update and revise commitment #3 to state that Service Water System piping and emergency diesel generator fuel oil storage tanks will be cathodically protected prior to the period of extended operation.

The revision will be submitted with the next set of RAI responses, currently scheduled for June 15, 2011.

- 2) The staff stated that, after reviewing response to RAI B.2.7-1 request #10, clarifying information was needed regarding the applicant's intentions should adverse indications be identified during buried piping inspections. The staff stated that a basis is needed for additional buried in-scope piping inspections for continued reasonable assurance of the integrity of buried piping.

The applicant stated that clarifying information on the scope of additional sampling for buried piping should adverse indications be identified during inspections will be submitted with the next batch of RAIs currently scheduled for June 15, 2011.

September 9, 2011

LICENSEE: FirstEnergy Nuclear Operating Co.

FACILITY: Davis-Besse

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING CO., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE LICENSE RENEWAL APPLICATION (TAC NO. ME4640)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of FirstEnergy Nuclear Operating Company (FENOC or the applicant) held a telephone conference call on June 7, 2011, to discuss the Davis-Besse May 24, 2011, response to request for additional information (RAI) B.2.7-1 regarding the proposed Davis-Besse License Renewal Buried Piping Program.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a brief description of the discussion related to RAI B.2.7-1 response.

The applicant had an opportunity to comment on this summary.

/RA/

Samuel Cuadrado de Jesús
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosures:
As stated

cc w/encls: Listserv

DISTRIBUTION:
See next page

ADAMS Accession No.: ML11242A007

*Concurrence via e-mail

OFFICE	LA:DLR/RPB1*	PM:RPB1:DLR	BC: DLR/RPB1	LA: DLR/RPB1	PM: DLR/RPB1
NAME	SFigueroa	SCuadrado	DMorey	SFigueroa	SCuadrado
DATE	09/6/2011	09/6/2011	09/8/2011	09/8/2011	09/9/2011

OFFICIAL RECORD COPY

Letter to FENOC from Samuel Cuadrado de Jesus dated September 9, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 7, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND FIRSTENERGY NUCLEAR OPERATING CO., CONCERNING REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE DAVIS-BESSE LICENSE RENEWAL APPLICATION (TAC NO. ME4640)

DISTRIBUTION:

HARD COPY:

DLR R/F

E-MAIL:

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

PCooper

BHarris

DWrona

EMiller

MMahoney

ICouret, OPA

TReilly, OCA

BHarris, OGC

VMitlyng, RII

JCameron, RIII