

From: Tran, Linh
Sent: Wednesday, August 31, 2011 9:12 AM
To: Lappert, Glenna
Cc: DiMiglio, Francis
Subject: FW: inadvertent omission from TS

Hi Glenna,

Bellow is the 8/26/2011 email from Dr. Wall to Frank for Washington State University. Please place in ADAMS as discussed.

Thanks,
Linh

From: DiMiglio, Francis
Sent: Tuesday, August 30, 2011 8:48 AM
To: Tran, Linh
Subject: FW: inadvertant omission from TS

FYI

Frank

From: Wall, Donald [mailto:donald_wall@wsu.edu]
Sent: Friday, August 26, 2011 5:31 PM
To: DiMiglio, Francis
Subject: RE: inadvertant omission from TS

[I concur with the insertion of this Technical Specification](#)
Don

From: DiMiglio, Francis [<mailto:Francis.DiMiglio@nrc.gov>]
Sent: Friday, August 26, 2011 4:08 AM
To: Wall, Donald
Subject: inadvertant omission from TS

Don,

Please recall our communications about the TS which was inadvertently omitted from the TS to be issued with the license renewal.

The TS is reproduced below.

Please confirm by return e-mail your concurrence in placing the TS into the appropriate location in the TS.

Thank you.

Frank
A. Francis DiMeglio
Project Manager
Research and Test Reactors
U.S. Nuclear Regulatory Commission
Work (301) 415-0894
francis.dimeglio@nrc.gov

6.2.3 Events Requiring the Direction of a Senior Reactor Operator

A licensed senior reactor operator shall be present at the facility for:

- (1) Initial startup and approach to power;
- (2) All fuel movement or relocation;
- (3) All control rod relocations within the core region
- (4) Relocation of any in-core experiments or irradiation facilities with a reactivity worth greater than \$1.00;
- (5) Recovery from unplanned or unscheduled shutdown; or
- (6) Recovery from unplanned or unscheduled significant power reduction.