



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

November 21, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 29, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE  
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 29, 2011, to discuss and clarify the response to the request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan".

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION  
LIST OF PARTICIPANTS  
August 29, 2011

**PARTICIPANTS:**

Arthur Cunanan  
Allen Hiser  
Chris Sydnor  
Abbas Mostala  
Scott Wood  
John Sisk

**AFFILIATIONS:**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
Energy Northwest (EN)  
EN  
EN

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION  
LICENSE RENEWAL APPLICATIONS  
AUGUST 29, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held telephone conference calls on August 29, 2011, to discuss the following response to the request for additional information (RAI) concerning the Columbia Generating Station license renewal application.

**Response to RAI 4.2-6: Related to the upper shelf energy of the N12 nozzle forging**

Discussion

The staff discussed the need for the applicant to provide a technical basis for initial upper shelf energy (USE) values of 62 ft-lb and copper content of 0.27 percent for SA-508 Class 1 forgings material, which can be verified by the staff, in order for the applicant to demonstrate that the USE value for the N12 nozzle forgings will not pass below 50 ft-lbs prior to the period of extended operation.

The applicant understands the staff's concern and requests an RAI.

The staff will send a follow up RAI related to the N12 nozzle forging.

November 21, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 29, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE  
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 29, 2011, to discuss and clarify the response to the request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

*/RA/*

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION:  
See next page

**ADAMS Accession No.:**

\*concurrence via e-mail

<b>OFFICE</b>	LA: DLR/RPB1*	PM: DLR/RPB1	BC: DLR/RPB1	PM: DLR/RPB1
<b>NAME</b>	SFigueroa	ACunanan	DMorey	ACunanan
<b>DATE</b>	11/17/2011	11/17/2011	11/21/2011	11/21/2011

**OFFICIAL RECORD COPY**

Letter to Energy Northwest from Arthur D. Cunanan dated November 21, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 29, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE  
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

DISTRIBUTION:

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRapb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

-----

DDoyle

MThadani

WWalker, RIV

RCohen, RIV

LSubin, OGC