

As of: September 02, 2011
Received: September 02, 2011
Status: Pending_Post
Tracking No. 80f0eedb
Comments Due: October 31, 2011
Submission Type: Web

PUBLIC SUBMISSION

Docket: NRC-2011-0204

Proposed Generic Communication - Draft Generic Letter on Seismic Risk Evaluations for Operating Reactors

Comment On: NRC-2011-0204-0001

Proposed Generic Communication; Draft NRC Generic Letter 2011-XX: Seismic Risk Evaluations for Operating Reactors

Document: NRC-2011-0204-DRAFT-0001

Comment on FR Doc # 2011-22422

9/1/2011
76 FR 54507

Submitter Information

1

General Comment

1. It would seem wise to ask licensees to consider the risk of core damage from multiple (but linked) external events, such as seismic events and tsunamis.
2. Also, it should be noted that an earthquake induced tsunami is significantly different than a flood due to the dynamic effects of the water.

RECEIVED

SEP -2 11 8:27

RULES AND DIRECTIVES
ENFORCEMENT

*SUNSI Review Complete
of template = ADM-013*

*FRIDS = ADM-03
Ced = K. Worsley (K9m)*