PUBLIC SUBMISSION

As of: September 02, 2011 Received: September 02, 2011

Status: Pending_Post Tracking No. 80f0eedb

Comments Due: October 31, 2011

Submission Type: Web

9/1/2011

Docket: NRC-2011-0204

Proposed Generic Communication - Draft Generic Letter on Seismic Risk Evaluations for Operating Reactors

Comment On: NRC-2011-0204-0001

Proposed Generic Communication; Draft NRC Generic Letter 2011-XX: Seismic Risk Evaluations for

Operating Reactors

Document: NRC-2011-0204-DRAFT-0001

Comment on FR Doc # 2011-22422

76FR 54507

Submitter Information

General Comment

- 1. It would seem wise to ask licensees to consider the risk of core damage from multiple (but linked) external events, such as seismic events and tsunamis.
- 2. Also, it should be noted that an earthquake induced tsunami is significantly different then a flood due to the dynamic effects of the water.

77 (SP - 2 M 8: 27

5005I Review Complete Hemplote = ADM-013 ERIDS= ADH-03 Cold = K. worroly (Kam)