

From: STEELMAN, WILLIAM J [wsteelm@entergy.com]
Sent: Thursday, September 08, 2011 8:59 AM
To: STEELMAN, WILLIAM J; Kalyanam, Kaly
Subject: UFSAR Clarification

Kaly

Updated Final Safety Analysis Report (UFSAR) Section 7.2.1.1.1.4 (Low Departure from Nucleate Boiling Ratio) contains information on the Core Protection Calculator (CPC) DNBR setpoint (1.26) and the revised safety limit. The information in this section is consistent with NRC Amendment 224 Safety Evaluation Report (SER) and associated submittal. The information in UFSAR Section 7.2.1.1.1.4 is correct but the CPC setpoint of 1.26 could lead to confusion and will be clarified. LO-LAR-2010-0145 CA45 will track this UFSAR change.

Any questions please let me know.
Billy Steelman
Entergy Waterford 3
Licensing Manager