

Overview of 08/23/11 Earthquake Response and Restart Readiness Demonstration Plan

North Anna Power Station Units 1 and 2



Introduction and Agenda

Gene Grecheck Vice President, Nuclear Development



Agenda

- Overview of Event
 - Station
 - ISFSI
- Seismic Results
- Restart Readiness Demonstration Plan
- Results to Date
- Restart Schedule
- Summary
- Questions



Overview of Event

Fred Mladen Director, Station Nuclear Safety and Licensing



Quake Epicenter (~Eleven miles southwest of North Anna Power Station)





- <u>08/23/11</u> Both units at 100% power; U1 Turbine Driven AFW pump removed from service for scheduled surveillance test
- 13:51:00 Magnitude 5.8 earthquake with epicenter near Mineral, Va.
- 13:51:11 Reactor Trip Breakers open on negative flux rate trip (Both Units Mode 3)
- 13:51:12 Transformers 1-EP-MT-1A, 2-EP-MT-1A,1B, 1C, all RSSTs, 1-EP-SST-1C and Switchyard Transformer #2 tripped due to sudden pressure relay actuations (Loss of offsite power)
- 13:51:20 All four EDGs auto start and energize their respective emergency buses

Dominion North Anna Electrical Distribution System





- 14:03 ALERT declared Tab HA6.1, Shift Manager judgment
- 14:19 1-FW-P-2 available (flowing to "A" S/G)
- 14:40 2H EDG manually tripped on coolant leak 2H Emergency Bus de-energized
- 14:55 ALERT declared Tab SA1.1 U2 AC capability reduced to a single source (2J EDG)
- 15:18 2H Emergency Bus re-energized by the Station Blackout (SBO) Diesel



- 17:23 Energized C RSST and F transfer bus
- 17:40 2J emergency bus transferred to C RSST
- 17:48 1H energized from F transfer bus, securing 1H EDG
- 20:03 B RSST energized
- 20:17 A RSST energized
- 22:58 Offsite power supplying Emergency Busses, 3 EDGs and SBO diesel in 'Auto' and available



<u>8/24/11</u>

- 08:51 Commenced Unit 1 cooldown
- 11:16 Downgrade to NOUE under Tab HU1.1
- 13:15 NOUE terminated
- 13:34 Unit 1 in Mode 4, Hot Shutdown
- 21:26 Unit 1 in Mode 5, Cold Shutdown



<u>8/25/11</u>

- 01:08 NOUE declared under Tab HU1.1(aftershock)
- 11:37 Commenced Unit 2 cooldown
- 16:22 Unit 2 in Mode 4, Hot Shutdown

8/26/11

- 14:05 NRC notification EP criteria seismic activity >OBE met but not declared (EAL HA6.1 versus HA1.1)
- 16:23 NRC notification of potential unanalyzed condition (DBE above 5 Hz)
- 20:38 Unit 2 in Mode 5, Cold Shutdown



8/28/11

15:36 NOUE terminated

<u>9/1/11</u>

- 05:18 NOUE Declared, tab HU1.1 (aftershock)
- 12:23 NOUE terminated



U2 Turbine Building

Powdex Demineralizer Tanks (Non-safety Related)





U2 Turbine Building

Powdex Demineralizer Tanks Base Pedestal (Non-safety Related)





Unit 1 Containment Seal Table Room (Interior Wall)





Unit 1 Containment Seal Table Room – Excavated Section





- 25 of 27 TN-32 casks shifted during earthquake
- Largest shift was 4.5" on TN-32.21
- No alarms were received, alarm panel test sat
- Radiological conditions were normal
- 6 pairs of casks <16' center to center
- Confirmed all cask heat loads <27.1 KW, therefore, minimum 16' spacing requirement not applicable
- Evaluating possible cask movement following aftershocks









Dominion Dry Cask Storage Pad No. 2

- NUHOMS Horizontal Storage Module
 - Gaps noted
 - Limited concrete damage (non-structural)
- HSMs were intact and capable of performing their intended function
- Radiological conditions were normal

Dominion Dry Cask Storage Pad No. 2









NUHOMS HSM





Roof Vents







Seismic Results

Eric Hendrixson Director, Nuclear Engineering



- The station has two separate recording systems, an active system (provided by Kinemetrics Inc.) and a primarily passive system (provided by Engdahl)
- Both systems provide input to the Main Control Room (MCR) via a common instrumentation panel

MCR Seismic Instrumentation Panel





- Kinemetrics
 - Triaxial Seismic Trigger
 - Triaxial Seismic Switch
 - Triaxial Time History Accelerograph
- Engdahl
 - Triaxial Response Spectrum Recorder
 - Triaxial Peak Accelerograph



Plant Seismic Instrumentation (Kinemetrics - Active)

all and the second second	and the second sec	the second se
Sensor Type	Location/Elevation	Equipment Mounting
Triaxial Time History Accelerograph	Unit 1 Containment 216'	U1 Containment Mat
Triaxial Seismic Trigger	Unit 1 Containment 216'	U1 Containment Mat
Triaxial Seismic Switch	Unit 1 Containment 216'	U1 Containment Mat
Triaxial Time History Accelerograph	Unit 1 Containment 291'	U1 Containment Operating Deck



Plant Seismic Instrumentation (Engdahl - Passive)

Sensor Type	Location/Elevation	Equipment Mounting
Triaxial Response Spectrum Recorder	Unit 1 Containment 216'	Unit 1 Containment Mat
Triaxial Response Spectrum Recorder	Unit 1 Containment 231'	Unit 1 Residual Heat Removal (RHR) pump and heat exchanger area
Triaxial Response Spectrum Recorder	Aux Building 244'	In between Unit 1 and Unit 2 Component Cooling (CC) pumps
Triaxial Response Spectrum Recorder	Aux Building 274'	Near Unit 1 "A" CC heat exchanger
Triaxial Peak Accelerograph	Unit 1 Containment 218'	On Unit 1 "C" Safety Injection Accumulator discharge piping
Triaxial Peak Accelerograph	Unit 1 Containment 241'	On Unit 1 "B" RHR heat exchanger
Triaxial Peak Accelerograph	Aux Building 279'	On Unit 1 "A" CC heat exchanger,

Dominion Triaxial Response Spectrum Recorder



Triaxial Response Spectrum Recorder



Recorder Scratch Plates Styluses



Recorder Scratch Plates



North Anna Design Basis Seismic Criteria (Station and ISFSI)

	Horizontal Peak Ground Acceleration (g) Rock	Vertical Peak Ground Acceleration (g) Rock	Horizontal Peak Ground Acceleration (g) Soil	Vertical Peak Ground Acceleration (g) Soil
OBE	0.06	0.04	0.09	0.06
DBE	0.12	0.08	0.18	0.12



Comparison of Kinemetrics Data – Horizontal Direction





Comparison of Kinemetrics Data – Vertical Direction





- Concept used by EPRI to address OBE Exceedance in 1988 (EPRI NP-5930)
- Indicator of damage based on analysis of 263 time-histories from 42 earthquakes
- OBE Exceedance criterion is CAV <0.16 g-sec (EPRI TR-100082 and RG 1.166)
- Criterion is conservative and has a minimum factor of three



	East-West	North-South	Vertical
	(g-sec)	(g-sec)	(g-sec)
Kinemetrics	0.137	0.175	0.118
SGH	0.118	0.169	0.105
Bechtel	0.134	0.181	0.113
Average	0.130	0.175	0.112

(CAV limit = 0.16 g-sec, per NRC RG 1.166)



Husid Function Plot – Representation of Cumulative Energy



Cumulative Energy (HUSID Plot) for the Containment Basemat Records

Effective Strong Motion Duration for Records Labeled "CW026"

Time History	Effective Strong Motion Duration (sec)
CW026_CH1_L_corrected	3.1
CW026_CH2_V_corrected	1.5
CW026_CH3_T_corrected	1.0

36



As part of response to GL 88-20 (IPEEE) and GL 87-02 (USI-A46), the following actions were completed:

- Extensive inspections of 1800 safe shutdown components assuming an earthquake peak acceleration of 0.3g for IPEEE
- With few exceptions, components evaluated could withstand 0.3g or higher
- Worst case capacity of 0.16g, which exceeds 0.12g DBE
- Modifications provided additional seismic ruggedness
- Comprehensive peer review walkdown of 20% sample

Consequently, safe shutdown components are capable of surviving seismic accelerations in excess of the DBE design criteria



Restart Readiness Demonstration Plan

North Anna UFSAR – Section 3.7.4.6

Use of Data from Seismic Instrumentation - In accordance with paragraph V(a) of Appendix A to 10 CFR 100, an orderly and sequential shutdown of the North Anna units will be carried out according to detailed written station procedures if a seismic event with vibratory ground motion equal to or exceeding that of the operational-basis earthquake occurs. Prior to resuming operations, it will be demonstrated to the NRC that no functional damage has occurred to those features necessary for continued operation without undue risk to the health and safety of the public, or that the necessary repairs to those features have been completed. [emphasis added]



Based on exceeding the station OBE and DBE seismic criteria and the CAV limit, the station restart readiness assessment actions were based on the guidance contained in the following documents:

- RG 1.166, Pre-earthquake Planning and Immediate Nuclear Power Plant Operator Post-earthquake Actions, dated March 1997
- RG 1.167, Restart of a Nuclear Power Plant Shut Down by a Seismic Event, dated March 1997
- EPRI NP-6695, Guidelines for Nuclear Plant response to an Earthquake, dated December 1989





Figure 3-1. Flow Diagram of Short-Term Actions

Dominion EPRI NP-6695 Figure 3-2



42





Dominion EPRI NP-6695 Figure 3-2



44

- Seismic Data Collection and Analysis
- Damage Assessment and Evaluation
- Restart Assessment
- Long-Term Actions

Seismic Data Collection and Analysis

- Perform data collection/analysis of earthquake seismic data to quantitatively define earthquake magnitude **Complete**
- Compare results with the station design basis OBE and DBE criteria to determine if they were exceeded **Complete**
- Obtain 3rd party peer reviews of analysis by industry experts

Dominion Restart Readiness Demonstration Plan

Damage Assessment and Evaluation

- Perform post-earthquake walkdowns/inspections of plant structures, systems and components (SSCs) consistent with regulatory and industry guidance (includes North Anna Spillway dam and SG tube inspections)
- Perform comprehensive surveillance testing to validate SSC operability/performance
- Perform comprehensive inspections and evaluations of ISFSI pads and casks
- Perform evaluations of reactor vessel internals and fuel in the core, Spent Fuel Pool and New Fuel Storage Area
- Complete Root Cause Evaluation of reactor trip
- Document assessments/evaluations in appropriate engineering technical evaluations

Restart Assessment

- Complete inspections, evaluations, testing and repair, if necessary, of SSCs to ensure they are capable of performing their intended design functions
- Finalize and obtain FSRC review and approval of Engineering technical documents demonstrating SSC restart readiness
- Review and disposition open Condition Reports, as necessary, to ensure that no outstanding issues exist that would preclude restart

- Installation of free-field seismic instrumentation
- Permanently re-power Seismic Monitoring Panel in MCR from an Uninterruptible Power Supply
- Coordinate update of the station seismic design and licensing bases with ongoing GI-199 resolution effort

Results to Date

Mark Walker Manager, Nuclear Site Engineering

Although evaluations are continuing, to date, SSCs inspections have only identified superficial damage and Surveillance Tests have not identified any safety-related SSC operability issues related to the seismic event

- Inspector Training and Inspection Process
- Inspection results indicate North Anna in the "0" category of the EPRI Damage Intensity Scale
- As of 9/7/11
 - 82% of 134 system inspections completed
 - 97% of 141 structure inspections completed
 - 28% of 448 Surveillance Tests completed (Unit 1)
 - 20% of 50 High Confidence Low Probability of Failure (HCLPF) component SQUG inspections completed

Restart Schedule

N. Larry Lane Site Vice President – North Anna Power Station

- 09/07 Facility Safety Review Committee (FSRC) approval of Safe Shutdown System Operability Determination
- 09/16 Engineering Final Technical Evaluation review by FSRC
- 09/18-20Comprehensive ESF functional testing completeComprehensive post-event testing and inspections
complete

Start-up Assessment by FSRC

09/22 Containment close-out complete and unit ready to enter Mode 4

NAPS U2 Planned Refueling Restart Timeline

- 09/07 FSRC approval of the Safe Shutdown System OD
- 09/12 FSRC approval of the Mode 6 System OD
- 09/12-15 Reactor Disassembly- Inspections
- 09/15-17 Reactor Core Off-load to the SFP
- 09/16 Secondary activities complete
 - Engineering Final Technical Evaluation review by FSRC
- 09/17-30 Defueled Primary Maintenance
- 10/01-02 Reactor Core Reload
- 10/02-06 Reactor Reassembly
- 10/06-13Comprehensive ESF functional testing complete
Comprehensive post-event testing and inspections complete
Containment close-out complete
Start-up Assessment by FSRC
- 10/13 Ready for Mode 4

Summary

Gene Grecheck Vice President, Nuclear Development

- OBE and DBE criteria were exceeded; however, CAV calculations indicate that significant damage would not be expected
- Extensive actions are underway to inspect, evaluate, test and repair, if necessary, SSCs to ensure they are capable of performing their required design basis functions Results are confirming the CAV expectations
- To date, no safety related SSCs have been identified that require repair
- IPEEE and USI-A46 results demonstrate that safe shutdown SSCs are capable of withstanding peak accelerations in excess of DBE
- Unit will be ready for restart when we establish confidence that SSCs will perform as designed
- Long-term actions are planned to improve plant seismic monitoring capability and to re-evaluate plant OBE and DBE criteria in conjunction with resolution of GI-199

Questions?

AC	Alternating Current
AFW	Auxiliary Feedwater
DBE	Design Basis Earthquake
EAL	Emergency Action Level
EDG	Emergency Diesel Generator
EP	Electric Power or Emergency Plan
EPRI	Electric Power Research Institute
ESF	Engineered Safety Features
FSRC	Facility Safety Review Committee
FW	Feedwater
GI	Generic Issue
HSM	Horizontal Storage Module
IPEEE	Individual Plant Examination External Events
KW	Kilowatts
MT	Main Transformer
NRC	Nuclear Regulatory Commission
NOUE	Notification of Unusual Event
NUHOMS	Nuclear Horizontal Modular Storage System
OBE	Operating Basis Earthquake
OD	Operability Determination

Р	Pump
RSST	Reserve Station Service Transformer
SBO	Station Blackout
SGH	Simpson Gumpertz & Heger
SFP	Spent Fuel Pool
SSC	Systems, Structures and Components
SST	Station Service Transformer
TN	Transnuclear
U1	Unit 1
U2	Unit 2
USI	Unresolved Safety Issue

