11.0 Radioactive Waste Management

11.1 Source Terms

The information in this section of the reference ABWR DCD, including all subsections and tables, is incorporated by reference with ~~no departures or supplements~~the following departure.

STD DEP 10.1-3 (Table 11.1-6)

Table 11.1-6 Plant Parameters for Source Term Adjustment

Parameter	Reference Plant	ABWR
Thermal Power, MW	*3400*	*3926*
Reactor Water Mass, kg	*1.73 E+05*	*3.06 E+05*
Cleanup System Flow Rate kg/h	*5.9 E+04*	*1.52 E+05*
Steam Flow Rate kg/h	*6.81 E+06*	~~*7.63 E+06*~~7.65 E+06
Ratio of Condensate Demineralizer Flow Rate to Steam Flow Rate	*1.0*	*
The above values are expressed in the units required by the procedure in ANSI/ANS-18.1.		

** See Table 11.1-7.*