

Dominion Energy Kewaunee, Inc.  
N490 Hwy 42, Kewaunee, WI 54216  
Web Address: www.dom.com



AUG 31 2011

ATTN: Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Serial No. 11-501  
LIC/NW/R0  
Docket No.: 50-305  
License No.: DPR-43

**DOMINION ENERGY KEWAUNEE, INC.**  
**KEWAUNEE POWER STATION**  
**CORE OPERATING LIMITS REPORT CYCLE 31 REVISION 2**

Pursuant to Kewaunee Power Station (KPS) Technical Specification 5.6.3.d, enclosed is a copy of the Kewaunee Power Station Core Operating Limits Report Cycle 31, Revision 2.

If you have questions or require additional information, please feel free to contact Mr. Jack Gadzala at 920-388-8604.

Very truly yours,

Michael J. Wilson  
Director Safety and Licensing  
Kewaunee Power Station

Commitments made by this letter: NONE

Enclosure

1. Kewaunee Power Station Core Operating Limits Report Cycle 31, Revision 2.

A001  
MRR

cc: Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
2443 Warrenville Road  
Suite 210  
Lisle, IL 60532-4352

Mr. K. D. Feintuch  
Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop O8-H4A  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Kewaunee Power Station

CORE OPERATING LIMITS REPORT  
Kewaunee Unit 1 Cycle 31  
Revision 2

August 2011

## 1.0 INTRODUCTION

This Core Operating Limits Report (COLR) for Kewaunee Unit 1 Cycle 31 has been prepared in accordance with the requirements of Kewaunee Technical Specification 5.6.3.

A cross reference between the COLR section and the KPS Technical Specifications affected by this report is given below:

COLR Section	KPS Technical Specification	Description
2.1	2.1.1	Reactor Core Safety Limit
2.2	3.1.1	Shutdown Margin
2.3	3.1.3	Moderator Temperature Coefficient (MTC)
2.4	3.1.5	Shutdown Bank Insertion Limits
2.5	3.1.6	Control Bank Insertion Limits
2.6	3.2.1	Heat Flux Hot Channel Factor ( $F_Q(Z)$ )
2.7	3.2.2	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )
2.8	3.2.3	AXIAL FLUX DIFFERENCE (AFD)
2.9	3.3.1 Function 6	Reactor Protection System Instrumentation: Overtemperature $\Delta T$
2.10	3.3.1 Function 7	Reactor Protection System Instrumentation: Overpower $\Delta T$
2.11	3.4.1	RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits
2.12	3.9.1	Boron Concentration (Refueling Operations)
Figure 1	2.1	Reactor Core Safety Limits Curve (1772 MWt)
Figure 2		DELETED (Required Shutdown Margin)
Figure 3		DELETED (Hot Channel Factor Normalized Operating Envelope ( $K(Z)$ ))
Figure 4	3.1.6	Control Bank Insertion Limits
Figure 5		N(Z) Values (Top and Bottom 9% excluded)
Figure 6		DELETED (Penalty Factor, $F_p$ , for $F_Q(Z)$ )
Figure 7	3.2.3	AXIAL FLUX DIFFERENCE Envelope

## **2.0 OPERATING LIMITS**

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 5.6.3.

### **2.1 Reactor Core Safety Limits** (TS 2.1.1)

The combination of rated power level, coolant pressure, and coolant temperature shall not exceed the limits shown in COLR Figure 1 (1772 MWt). The safety limit is exceeded if the point defined by the combination of Reactor Coolant System average temperature and power level is at any time above the appropriate pressure line.

### **2.2 Shutdown Margin** (TS 3.1.1)

Shutdown Margin shall be  $\geq$  **1554 pcm**.

### **2.3 Moderator Temperature Coefficient (MTC)** (TS 3.1.3)

2.3.1 When the reactor is critical and  $\leq$  60% of RATED THERMAL POWER, the moderator temperature coefficient shall be  $\leq$  5.0 pcm/ $^{\circ}$ F. When the reactor is  $>$  60% RATED THERMAL POWER, the moderator temperature coefficient shall be zero or negative.

- a. The BOC/ARO-MTC shall be  $\leq$  5.0 pcm/ $^{\circ}$ F (upper limit), when  $\leq$  60% RTP, and  $\leq$  0.0 pcm/ $^{\circ}$ F when  $>$  60% RTP.
- b. The EOC/ARO/RTP-MTC shall be less negative than or equal to **-44.7 pcm/ $^{\circ}$ F** (lower limit).

MTC surveillance limits are:

- i) The 300 ppm/ARO/RTP-MTC should be less negative than or equal to **-39.1 pcm/ $^{\circ}$ F**. If MTC is more negative, then repeat measurement once per 14 EFPD during the remainder of the fuel cycle. Note this surveillance does not need to be repeated if criterion ii, listed below, is satisfied.
- ii) The 60 ppm/ARO/RTP-MTC should be less negative than or equal to **-43.6 pcm/ $^{\circ}$ F**.

## 2.4 Shutdown Bank Insertion Limits (TS 3.1.5)

The shutdown rods shall be fully withdrawn (224 steps) when the reactor is critical or approaching criticality.

## 2.5 Control Bank Insertion Limits (TS 3.1.6)

The control rod banks shall be limited in physical insertion as shown in **COLR Figure 4**.

## 2.6 Nuclear Heat Flux Hot Channel Factor ( $F_Q(Z)$ ) (TS 3.2.1)

### 2.6.1 $F_Q^C(Z)$ Limits for Fuel

$$F_Q^N(Z) * 1.03 * 1.05 \leq \frac{CFQ}{P} * K(Z) \quad \text{for } P > 0.5 \quad [422V+]$$

$$F_Q^N(Z) * 1.03 * 1.05 \leq \frac{CFQ}{0.5} * K(Z) \quad \text{for } P \leq 0.5 \quad [422V+]$$

Where:

P is the fraction of full power at which the core is operating

K(Z) is 1.0 for all core heights

Z is the core height location for the FQ of interest

**CFQ equals 2.50**

$F_Q^N(Z)$  is a measured FQ distribution obtained during the target flux determination

### 2.6.2 $F_Q^T(Z)$ Limits for Fuel

$$F_Q^N(Z) * 1.03 * 1.05 * N(Z) * F_p \leq \frac{CFQ}{P} * K(Z) \quad [422V+]$$

Where:

P is the fraction of full power at which the core is operating

K(Z) is 1.0 for all core heights

Z is the core height location for the FQ of interest

**CFQ equals 2.50**

$F_p$  is the penalty factor described in 2.6.3

N(Z) is a cycle-specific non-equilibrium multiplier on  $F_Q^N(Z)$  to account for power distribution transients during normal operation, provided in Figure 5.

$F_Q^N(Z)$  is a measured FQ distribution obtained during the target flux determination

*The N(z) decks are generated for normal operation flux maps that are typically taken at full power, ARO. Additional N(z) decks may be generated, if necessary, consistent with the methodology described in Reference 1.*

2.6.3 A penalty factor of 1.00 shall be used unless the Note criteria of TS SR 3.2.1.2 is met, at which time a penalty of 1.02 shall be used.

**2.7 Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ ) (TS 3.2.2)**

$$F_{\Delta H}^N * 1.04 \leq CFDH * [1 + PFDH * (1 - P)] \quad [422 V+]$$

Where:

- P is the fraction of full power at which the core is operating
- CFDH equals 1.70
- PFDH equals 0.3

**2.8 AXIAL FLUX DIFFERENCE (AFD) (TS 3.2.3)**

The AFD acceptable operation limits are provided in **COLR Figure 7**.

**2.9 Overtemperature  $\Delta T$  Setpoint (TS 3.3.1 Function 6)**

$$\Delta T \leq \Delta T_0 * \left[ K_1 - K_2 * (T - T') * \frac{1 + \tau_1 s}{1 + \tau_2 s} + K_3 * (P - P') - f_1(\Delta I) \right]$$

$\Delta T_0$  = Indicated  $\Delta T$  at RATED THERMAL POWER, %

s = Laplace transform operator,  $\text{sec}^{-1}$ .

T = Average temperature, °F

T'  $\leq$  **573.0 °F**

P = Pressurizer Pressure, psig

P'  $\geq$  **2235 psig**

K<sub>1</sub>  $\leq$  **1.195**

K<sub>2</sub>  $\geq$  **0.015/°F**

K<sub>3</sub>  $\geq$  **0.00072/psig**

$\tau_1$   $\geq$  **30 seconds**

$\tau_2$   $\leq$  **4 seconds**

$f_1(\Delta I)$  = An even function of the indicated difference between top and bottom detectors of the power range nuclear ion chambers. Selected gains are based on measured instrument response during plant startup tests, where qt and qb are the percent power in the top and bottom halves of the core respectively and qt + qb is total core power in percent RATED THERMAL POWER, such that

- (a) For qt - qb within **-13.5, +4.5 %**,  $f(\Delta I) = 0$
- (b) For each percent that the magnitude of qt - qb exceeds **+4.5%**, the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of **1.51%** of RATED THERMAL POWER.
- (c) For each percent that the magnitude of qt - qb exceeds **-13.5%**, the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of **3.78%** of RATED THERMAL POWER.

## 2.10 Overpower $\Delta T$ Setpoint (TS 3.3.1 Function 7)

$$\Delta T \leq \Delta T_0 * \left[ K_4 - K_5 * \frac{\tau_3 s}{\tau_3 s + 1} * T - K_6 * (T - T') - f_2(\Delta I) \right]$$

$\Delta T_0$  = Indicated  $\Delta T$  at RATED THERMAL POWER, %

s = Laplace transform operator,  $\text{sec}^{-1}$ .

T = Average temperature,  $^{\circ}\text{F}$

T'  $\leq$  **573.0  $^{\circ}\text{F}$**

K<sub>4</sub>  $\leq$  **1.095**

K<sub>5</sub>  $\geq$  **0.0275/ $^{\circ}\text{F}$**  for increasing T  
 $\geq$  **0** for decreasing T

K<sub>6</sub>  $\geq$  **0.00103/ $^{\circ}\text{F}$**  for T > T'  
 $\geq$  **0** for T < T'

$\tau_3$   $\geq$  **10 seconds**

$f_2(\Delta I)$  = 0 for all  $\Delta I$

## 2.11 RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits (TS 3.4.1)

2.11.1 During steady state power operation, T<sub>avg</sub> shall be  $\leq$  **576.7  $^{\circ}\text{F}$**  for control board indication or  $\leq$  **576.5  $^{\circ}\text{F}$**  for computer indication.

2.11.2 During steady state power operation, pressurizer pressure shall be  $\geq$  **2217 psig** for control board indication or  $\geq$  **2219 psig** for computer indication.


2.11.3 During steady state power operation, reactor coolant total flow rate shall be  $\geq$  **186,000 gpm**.

## 2.12 Boron Concentration (Refueling Operations) (TS 3.9.1)

When there is fuel in the reactor, a minimum boron concentration of **2500 ppm** and a shutdown margin of  $\geq$  **5%  $\Delta k/k$**  shall be maintained in the Reactor Coolant System during reactor vessel head removal or while loading and unloading fuel from the reactor.



**Figure 1**  
**(TS 2.1.1)**  
**Reactor Core Safety Limits Curve (1772 MWt)**  
**(Cores Containing 422V+ fuel)**




**Figure 2**  
**Required Shutdown Margin vs. Boron Concentration**

**DELETED**

**Figure 3**  
**Hot Channel Factor Normalized Operating Envelope (K(Z))**

**DELETED**

**Figure 4**  
**Control Bank Insertion Limits**  
 (TS 3.1.6)



Note: The Rod Bank Insertion Limits are based on a control bank tip-to-tip distance of 126 steps.

**Figure 5  
N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	0 to 1000	1000 to 3000	3000 to 5000	5000 to 7000	7000 to 9000	9000 to 11000
		MWD/MTU AO = 2.3%	MWD/MTU AO = 0.8%	MWD/MTU AO = -1.0%	MWD/MTU AO = -2.0%	MWD/MTU AO = -2.4%	MWD/MTU AO = -2.6%
Top							
7	10.8	1.100	1.110	1.118	1.146	1.148	1.157
8	10.6	1.099	1.111	1.119	1.144	1.145	1.154
9	10.4	1.100	1.108	1.116	1.141	1.142	1.151
10	10.2	1.099	1.105	1.116	1.138	1.139	1.148
11	10.0	1.096	1.102	1.120	1.135	1.136	1.145
12	9.8	1.092	1.097	1.123	1.130	1.132	1.143
13	9.6	1.089	1.096	1.126	1.127	1.129	1.142
14	9.4	1.084	1.099	1.126	1.126	1.127	1.138
15	9.2	1.083	1.106	1.128	1.132	1.132	1.137
16	9.0	1.084	1.113	1.136	1.144	1.143	1.140
17	8.8	1.089	1.119	1.147	1.157	1.157	1.148
18	8.6	1.095	1.125	1.153	1.166	1.165	1.159
19	8.4	1.102	1.128	1.157	1.171	1.170	1.170
20	8.2	1.108	1.131	1.160	1.175	1.175	1.175
21	8.0	1.112	1.132	1.160	1.177	1.179	1.179
22	7.8	1.117	1.131	1.160	1.178	1.184	1.184
23	7.6	1.120	1.129	1.158	1.178	1.188	1.188
24	7.4	1.122	1.127	1.157	1.178	1.190	1.190
25	7.2	1.124	1.125	1.156	1.176	1.192	1.192
26	7.0	1.124	1.124	1.152	1.173	1.192	1.192
27	6.8	1.123	1.122	1.139	1.168	1.188	1.188
28	6.6	1.120	1.120	1.123	1.161	1.181	1.181
29	6.4	1.118	1.118	1.114	1.157	1.178	1.178
30	6.2	1.115	1.115	1.112	1.154	1.174	1.174
31	6.0	1.113	1.112	1.108	1.149	1.168	1.168
32	5.8	1.109	1.109	1.106	1.141	1.159	1.159
33	5.6	1.102	1.102	1.102	1.130	1.148	1.147
34	5.4	1.099	1.099	1.099	1.121	1.134	1.134
35	5.2	1.102	1.102	1.095	1.114	1.119	1.121
36	5.0	1.107	1.107	1.092	1.111	1.110	1.111
37	4.8	1.111	1.111	1.088	1.110	1.109	1.105
38	4.6	1.120	1.119	1.091	1.107	1.107	1.106
39	4.4	1.131	1.129	1.100	1.101	1.101	1.111
40	4.2	1.136	1.134	1.107	1.100	1.094	1.114
41	4.0	1.136	1.134	1.110	1.105	1.091	1.114
42	3.8	1.137	1.135	1.114	1.108	1.093	1.112
43	3.6	1.143	1.141	1.119	1.110	1.101	1.110
44	3.4	1.153	1.150	1.123	1.111	1.107	1.109
45	3.2	1.167	1.163	1.129	1.113	1.113	1.110
46	3.0	1.181	1.176	1.135	1.117	1.118	1.115
47	2.8	1.195	1.189	1.144	1.122	1.122	1.120
48	2.6	1.208	1.201	1.153	1.123	1.123	1.121

**Figure 5 (continued)**  
**N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	0 to 1000 MWD/MTU	1000 to 3000 MWD/MTU	3000 to 5000 MWD/MTU	5000 to 7000 MWD/MTU	7000 to 9000 MWD/MTU	9000 to 11000 MWD/MTU
49	2.4	1.222	1.214	1.164	1.126	1.126	1.124
50	2.2	1.240	1.230	1.179	1.135	1.135	1.134
51	2.0	1.251	1.241	1.188	1.142	1.142	1.141
52	1.8	1.256	1.245	1.191	1.143	1.143	1.143
53	1.6	1.260	1.249	1.195	1.145	1.145	1.145
54	1.4	1.268	1.257	1.202	1.150	1.150	1.150
55	1.2	1.275	1.263	1.207	1.154	1.154	1.155

Bottom

1) Excludes top and bottom 9%

*These decks were generated for normal operation flux maps that are typically taken at full power ARO. Additional N(z) decks may be generated, if necessary, consistent with the methodology described in Reference 1.*

**Figure 5 (continued)**  
**N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	11000 to 13000	13000 MWD/MTU
		MWD/MTU	to EOR
		AO = -2.7%	AO = -2.7%
Top			
7	10.8	1.157	1.158
8	10.6	1.154	1.155
9	10.4	1.151	1.153
10	10.2	1.148	1.151
11	10.0	1.145	1.150
12	9.8	1.143	1.148
13	9.6	1.142	1.146
14	9.4	1.137	1.140
15	9.2	1.137	1.139
16	9.0	1.144	1.145
17	8.8	1.158	1.158
18	8.6	1.171	1.171
19	8.4	1.181	1.181
20	8.2	1.187	1.187
21	8.0	1.190	1.190
22	7.8	1.193	1.193
23	7.6	1.196	1.195
24	7.4	1.197	1.196
25	7.2	1.198	1.198
26	7.0	1.195	1.197
27	6.8	1.186	1.192
28	6.6	1.173	1.184
29	6.4	1.168	1.181
30	6.2	1.164	1.177
31	6.0	1.157	1.172
32	5.8	1.148	1.162
33	5.6	1.140	1.151
34	5.4	1.131	1.137
35	5.2	1.120	1.121
36	5.0	1.111	1.108
37	4.8	1.106	1.102
38	4.6	1.106	1.097
39	4.4	1.111	1.090
40	4.2	1.114	1.085
41	4.0	1.114	1.084
42	3.8	1.112	1.084
43	3.6	1.110	1.087
44	3.4	1.109	1.091
45	3.2	1.110	1.099
46	3.0	1.114	1.108
47	2.8	1.120	1.117
48	2.6	1.120	1.120

**Figure 5 (continued)**  
**N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	11000 to 13000 MWD/MTU	13000 MWD/MTU to EOR
49	2.4	1.125	1.125
50	2.2	1.138	1.138
51	2.0	1.149	1.149
52	1.8	1.152	1.152
53	1.6	1.155	1.155
54	1.4	1.159	1.159
55	1.2	1.163	1.163

Bottom

1) Excludes top and bottom 9%


*These decks were generated for normal operation flux maps that are typically taken at full power ARO. Additional N(z) decks may be generated, if necessary, consistent with the methodology described in Reference 1.*

**Figure 6**  
**Penalty Factor,  $F_p$ , for  $F_Q(Z)$**

**DELETED**



**Figure 7**  
**AXIAL FLUX DIFFERENCE Target Band**  
(TS 3.2.3)



### 3.0 REFERENCES

1. Topical Report DOM-NAF-5-A, Revision 0.2-A, "Application of Dominion Nuclear Core Design and Safety Analysis Methods to the Kewaunee Power Station (KPS)," January 2011.

Methodology for:

- TS 2.1.1 – Reactor Core Safety Limit;
- TS 3.1.1 – Shutdown Margin;
- TS 3.1.3 – Moderator Temperature Coefficient;
- TS 3.1.5 – Shutdown Bank Insertion Limits;
- TS 3.1.6 – Control Bank Insertion Limits;
- TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ );
- TS 3.2.2 – Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ );
- TS 3.2.3 – AXIAL FLUX DIFFERENCE (AFD);
- TS 3.4.1 – RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits;
- TS 3.9.1 – Boron Concentration (Refueling Operations)

2. Topical Report WPSRSEM-NP, Revision 3, "Kewaunee Nuclear Power Plant – Review for Kewaunee Reload Safety Evaluation Methods," September 10, 2001.

Methodology for:

- TS 3.1.1 – Shutdown Margin

3. WCAP-12945-P-A (Proprietary), "Westinghouse Code Qualification Document for Best-Estimate Loss-of-Coolant Accident Analysis," Volume I, Revision 2, and Volume II-V, Revision 1, March 1998.

Methodology for:

- TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ )
- TS 3.2.2 – Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ );

4. WCAP-10054-P-A, "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," August 1985.

Methodology for:

- TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ )

5. WCAP-10054-P-A, Addendum 2, Revision 1, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code: Safety Injection into the Broken Loop and the COSI Condensation Model," July 1997.

Methodology for:

- TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ )

6. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.

Methodology for:

TS 2.1.1 – Reactor Core Safety Limit;

TS 3.1.3 – Moderator Temperature Coefficient;

7. WCAP-8745-P-A, "Design Bases for the Thermal Overtemperature  $\Delta T$  and Thermal Overpower  $\Delta T$  trip functions," September 1986.

Methodology for:

TS 3.3.1 Function 6 – Overtemperature  $\Delta T$  Setpoint;

TS 3.3.1 Function 7 – Overpower  $\Delta T$  Setpoint

8. WCAP-14449-P-A, Revision 1, "Application of Best Estimate Large-Break LOCA Methodology to Westinghouse PWRs with Upper Plenum Injection," October 1999.

Methodology for:

TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ )

TS 3.2.2 – Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ );

9. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995.

Methodology for:

TS 3.2.1 – Heat Flux Hot Channel Factor ( $F_Q(Z)$ )

10. CENP-397-P-A, Revision 1, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," May 2000.

Methodology for:

TS 3.3.1 Function 6 – Overtemperature  $\Delta T$  Setpoint;

TS 3.3.1 Function 7 – Overpower  $\Delta T$  Setpoint