

NRR-PMDAPEm Resource

From: Harris, Brian
Sent: Monday, September 12, 2011 1:18 PM
To: Mitchel.Mathews@exeloncorp.com
Cc: DiFrancesco, Nicholas; jeff.hansen@exeloncorp.com; James.Peterson@exeloncorp.com
Subject: Acceptance Review Results for Clinton Power Station, Unit No. 1 Re: License Amendment Request to Modify Technical Specifications 3.8.1, "AC Sources - Operating" (TAC ME6876)

September 12, 2011

Mitchel Mathews
Senior Regulatory Engineer
Exelon Generation Company

Mr. Mathews,

By letter dated August 15, 2011 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML112280256), Exelon Generation Company, LLC (EGC, the licensee) submitted a license amendment request (LAR) for the Clinton Power Station, Unit 1 (CPS). The proposed LAR will revise EGC's Technical Specifications (TSs) 3.8.1 "AC Sources – Operating." Specifically, the LAR will revise TS 3.8.1 Surveillance Requirements to reduce the maximum steady voltage limit for 4.16kV safety-related buses from 4580V to 4300V.

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staffs acceptance review of this application. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-2277. A copy of this email will be made publicly available in ADAMS.

Docket No. 50-461

Sincerely,

Brian K. Harris

*Project Manager
Plant Licensing Branch III-2
Division of Operating Reactor Licensing
brian.harris2@nrc.gov*

Tel: (301)-415-2277

Hearing Identifier: NRR_PMDA
Email Number: 144

Mail Envelope Properties (Brian.Harris@nrc.gov20110912131700)

Subject: Acceptance Review Results for Clinton Power Station, Unit No. 1 Re: License Amendment Request to Modify Technical Specifications 3.8.1, "AC Sources - Operating" (TAC ME6876)
Sent Date: 9/12/2011 1:17:41 PM
Received Date: 9/12/2011 1:17:00 PM
From: Harris, Brian

Created By: Brian.Harris@nrc.gov

Recipients:

"DiFrancesco, Nicholas" <Nicholas.DiFrancesco@nrc.gov>

Tracking Status: None

"jeff.hansen@exeloncorp.com" <jeff.hansen@exeloncorp.com>

Tracking Status: None

"James.Peterson@exeloncorp.com" <James.Peterson@exeloncorp.com>

Tracking Status: None

"Mitchel.Mathews@exeloncorp.com" <Mitchel.Mathews@exeloncorp.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2686	9/12/2011 1:17:00 PM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: