

Catts, Michelle

From: Baker, John R
Sent: Tuesday, August 10, 2010 3:17 PM
To: Catts, Michelle
Subject: Unit 2 PAB Items

Michelle,

From the list that we discussed:

1. 22 CCW pump discharge valve leaking grease from 760B – grease wiped up.
2. Tools near 21 CCW pump – all tools removed from area
3. Fire Extinguisher unsecured on 80' PAB over Containment Spray pump area – returned to the MOB locker
4. Ladded storage at 80' PAB – Removed from area
5. Scaffolding stored near the Containment Spray Pumps – Bob Trombetta (8505) is investigating. He expects to have the information on Wednesday.
6. Loose items near scaffolding area – items secured
7. CCW pump area App R fire barrier extension cord – rerouted cord away from this area.

Thanks for bringing these items to my attention. I am using this list as a discussion point with our NPO's on housekeeping standards.

John Baker

AS