



DEPARTMENT OF VETERANS AFFAIRS
Veterans Health Administration
National Health Physics Program
2200 Fort Roots Drive
North Little Rock, AR 72114

In Reply Refer To: 598/115HP/NLR

SEP 19 2011

Kevin G. Null
Division of Nuclear Material Safety
Nuclear Regulatory Commission (NRC), Region III
2443 Warrenville Road, Suite 210
Lisle, Illinois 60532-4352

Re: NRC Master Materials License 03-23853-01VA; VHA Permit Number 04-23242-01

Dear Mr. Null:

I request release, for unrestricted use, of Building 2 at the VA Palo Alto Health Care System, Palo Alto, California. Building 2 is located at 3801 Miranda Avenue, Palo Alto, California. As supporting information, I am enclosing a radiological decommissioning report prepared for the building by a contractor. The documentation provides information consistent with decommissioning survey requirements in 10 CFR 30.36 and demonstrates the building is acceptable for unrestricted use under criteria in 10 CFR 20.1402.

As information, the derived concentration guideline levels (DCGLs) used for the release survey are listed in Table 7 of the report. The DCGLs for H-3 and C-14 are well below screening levels in Table B.1 of NUREG-1757, Vol. 1, Rev. 2, and correspond to a dose level of about 0.5 mrem/year based on building occupancy scenarios used to determine the values in the NUREG. Based on evaluations by my staff using NRC software D&D, Version 2.1.0, for a building occupancy scenario (with default parameter values, a "constant" distribution, and an "unlimited" area of contamination), the DCGL for Ca-41 was determined to be associated also with a release level of about 0.5 mrem/year. Similarly, my staff determined the value stated for U-238 is associated with a dose level of about 25 mrem/year. A higher value was necessary for alpha emitters due to instrument sensitivity. In addition, to these total activity limits, the contractor applied removable activity limits of 1000 dpm/100cm² for beta emitters and 20 dpm/100 cm² for alpha emitters. These levels are consistent with values specified for unrestricted areas in NUREG-1556 series documents.

Minimum detectable concentration (MDC) values for measurement techniques were sufficiently low to provide reasonable assurance that residual radioactivity could be

RECEIVED SEP 20 2011

Page 2

Kevin G. Null


detected below the 25 mrem/year release criterion in 10 CFR 20.1042 as well as the additional removable activity levels specified in Table 7 of the survey report. All beta measurements were well below the most restrictive DCGL level for beta emitters. All alpha measurements were below MDC values.

My staff reviewed the NRC docket files you provided for the facility and identified one additional room (A107) in which radioactive materials were used. Correspondence included in Enclosure 2 between my staff and the Radiation Safety Officer indicated that any residual activity that could be present from sources used in this room would be well below levels of concern and support release for unrestricted use per 10 CFR 20.1402.

The health care system plans to demolish Building 2 and construct a new building to provide medical services for veterans. Construction of the new building is planned for FY 2012.

If you have any questions or comments, please contact Thomas E. Huston, Ph.D., National Health Physics Program, at 501-257-1578.

Sincerely,

A handwritten signature in black ink that reads "G. E. Williams". The signature is written in a cursive style with a large initial "G".

Gary E. Williams
Director, National Health Physics Program

Enclosures (2)

Enclosure 1

Radiological Decommissioning Report for Building 2



Radiological Decommissioning Report

UNITED STATES
DEPARTMENT OF VETERANS AFFAIRS



Prepared for:
**U.S. Department of Veterans Affairs
Palo Alto Health Care System
Building 2
3801 Miranda Ave.
Palo Alto, CA 94304
Radioactive Materials License #0676-43**

**Survey Dates: June 13 – 16, 2011
Report Date: July 6, 2011**

Prepared by:
Philotechnics, Ltd.
7384 Trade St.
San Diego, CA 92121

DECOMMISSIONING REPORT CONTENTS

<i>Section 1.0</i>	<i>Executive Summary</i>
<i>Section 2.0</i>	<i>Project Scope, Findings and Summary</i>
<i>Section 3.0</i>	<i>Assessment, Methodology and Report Limitations</i>
<i>Section 4.0</i>	<i>License Review and Historical Use</i>
<i>Section 5.0</i>	<i>Radiation Surveys</i>
<i>Section 6.0</i>	<i>Data Quality Assessment and Interpretation of Survey Results</i>
<i>Section 7.0</i>	<i>Decontamination/ Decommissioning Review</i>
<i>Appendix A</i>	<i>VA Palo Alto Health Care System Building 2 Site Diagram Identifying Decommissioned Areas</i>
<i>Appendix B</i>	<i>VAPAHCS Area Survey Maps</i>
<i>Appendix C</i>	<i>Certificates of Calibration & Scintillation Check</i>
<i>Appendix D</i>	<i>MARSSIM Analytical Calculation Sheets</i>
<i>Appendix E</i>	<i>Background Documentation</i>
<i>Appendix F</i>	<i>Static Measurement Data Sheets and DPM Calculations</i>
<i>Appendix G</i>	<i>Wipe Survey Data Sheets and DPM Calculations</i>

ACRONYM LIST

<i>ALARA</i>	<i>As Low As Reasonably Achievable</i>
<i>Bldg</i>	<i>Building</i>
<i>CFR</i>	<i>Code of Federal Regulations</i>
<i>CPM</i>	<i>counts per minute</i>
<i>D&D</i>	<i>Decontamination and Decommissioning</i>
<i>DCGL_w</i>	<i>Derived Concentration Guideline Level – Wilcoxon Rank Sum</i>
<i>DPM</i>	<i>disintegrations per minute</i>
<i>HASP</i>	<i>Health and Safety Plan</i>
<i>HSA</i>	<i>Historical Site Assessment</i>
<i>keV</i>	<i>kiloelectron volt</i>
<i>LBGR</i>	<i>Lower Bound of the Gray Region</i>
<i>MARSSIM</i>	<i>Multi-Agency Radiation Survey and Site Investigation Manual</i>
<i>MDC</i>	<i>Minimum Detectable Concentration</i>
<i>NRC</i>	<i>U.S. Nuclear Regulatory Commission</i>
<i>NUREG</i>	<i>Nuclear Regulatory Commission Guidance Document</i>
<i>RAM</i>	<i>radioactive materials</i>
<i>Rm</i>	<i>Room</i>
<i>TEDE</i>	<i>Total effective dose equivalent</i>
<i>RAM</i>	<i>radioactive materials</i>

Section 1.0 – Executive Summary

A radiological survey was completed utilizing the guidance provided in NUREG 1757, “Consolidated Nuclear Materials Safety and Safeguards (NMSS) Decommissioning Guidance” and recommendations from NUREG 1575, “Multi-Agency Radiation Survey and Site Investigation Manual” (MARSSIM) in order to provide pertinent information for the radiological decommissioning of specified impacted areas at the U.S. Department of Veterans Affairs – Palo Alto Health Care System (VAPAHCS) facility located at 3801 Miranda Ave. A review of all data collection and analysis supports our professional opinion the 18 former radiologically impacted areas of VAPAHCS Building 2 meet the release criteria for unrestricted use based upon the following:

- *All scanning measurements were less than the Derived Concentration Guideline Level (DCGL_w) which was established using a dose based criteria of 0.5 mrem/yr.*
- *All static measurements were less than the established DCGL_w.*
- *All wipe survey results were below the established removable DCGL_w.*

Section 2.0 – Project Scope, Findings and Summary

Prior to releasing the previously impacted areas, the Nuclear Regulatory Commission (NRC) requires that an appropriate decommissioning survey and report be submitted for their review. This document provides the licensee with appropriate information to release the 18 former laboratories being surveyed for unrestricted release.

In accordance with our agreement with the VAPAHCS, Philotechnics performed final status surveys of specific rooms in Building 2 (Rooms A04, A05A, A05, A06, A06B, A008, A009, A010, B121-B124, B126-B128, B131A, B131B and B131C). The final status survey, report and analytical data provide pertinent information for the radiological decommissioning and follow the guidance in NUREG 1757, NUREG 1575 and NUREG-1507. Research involving the use of radioactive materials was performed in the rooms listed above located in Building 2.

The following summarizes the independent conclusions representing Philotechnics best professional judgment based on information and data available to us during the course of this project. Factual information regarding operations, conditions and test data provided by the client, owner or their representative has been assumed correct and complete based upon careful and diligent review of the radiation safety program and past inspection records. Additionally, the conclusions presented are based on the conditions that existed at the time of the assessment. Note that on-site observation of the above referenced facilities consisted of readily visible, accessible areas only.

Table 1: Assessment Review

Assessment Component	Acceptable	Unacceptable	Section
License Review & Historical Use	X		4.0
<u>Radiation Surveys</u>			
A) Static Measurements – Hand-held instruments	X		5.0
B) Static Measurements – Scintillation Counter	X		5.0
C) Scanning Measurements – Hand-held instruments	X		5.0

Conclusions and Recommendations

Based upon the results of our survey, it is our professional opinion the 18 former laboratory areas in Building 2 are free of any radioactive contamination and/or radioactive material sources and may be released for unrestricted use in accordance with Code of Federal Regulations, Title 10, Section 30.36 “Expiration and termination of licenses and decommissioning of sites and separate buildings or outdoor areas.”. During the survey, Philotechnics verified that all labels, signs or other similar markings indicating the presence of radioactive materials had been removed or obliterated. Additionally, no concerns requiring further investigation exist at this time.

Project Team


The project team consisted of the following individuals:

Researched by: Robert Trimble and Dave Aguero
Surveyed by: Dave Aguero, Doug Bassett, Steve Beck and Garrett Eastman
Written by: Dave Aguero

Project Manager and Contact: Dave Aguero

Closing

We appreciate the opportunity to provide this radiological decommissioning report and trust that the enclosed information is adequate for decision-making needs. Should you have any questions, please do not hesitate to call the undersigned.



Dave Aguero
Project Manager
Philotechnics, Ltd.

Section 3.0 – Assessment, Methodology and Report Limitations

The decommissioning process evaluates a property's environmental status for release of affected areas to allow unrestricted use by current or future tenants. The assessment involves the review of operations as they pertain to radioactive materials (RAM) use in order to identify potential radioactive contamination.

Assessment activities related to the laboratory decommissioning for the facility included the following tasks:

- A visual survey of historic RAM use and storage areas in order to identify potential contamination and/or presence of radioactive materials
- Interviews with EH&S and client personnel regarding the historical use of RAM at the facility
- Review of existing documentation, as provided, regarding prior inspections, investigations, events or conditions at the facility related to RAM use
- Direct surveys of all laboratory areas with the use of portable hand-held radiation detection equipment to identify the presence of radioactive materials
- Indirect surveys to test for removable contamination with the use of a scintillation counter and wipes taken throughout the impacted areas
- Preparation of a report documenting our findings, recommendations, and professional opinions regarding observed or suspected radiological concerns

Facility Point of Contact

At the facility, Dave Aguero met with Ms. Arefeh Shanjani and Ms. Leanne Amoroso, who are Senior Health Physicists at Stanford University. The EH&S Department at Stanford University provides radiological oversight for the VAPAHCS. Ms. Shanjani and Ms. Amoroso were able to provide specific information regarding radioactive materials use based upon their historical knowledge of the facility and implemented practices.

Report Limitations

This report has been prepared solely for the use and benefit of the VAPAHCS in compliance with requirements and recommendations by the NRC. Our professional services have been performed, our findings obtained and our recommendations prepared in accordance with customary principles and practices in the field of environmental science. This warranty is in lieu of all other warranties either expressed or implied. Philotechnics is not responsible for the independent conclusions, opinions or recommendations made by others based on the field exploration presented in this report.

It must be noted that no investigation, or survey, can absolutely rule out the existence of radioactive materials. However, the survey was performed using acceptable industry practices and utilizing appropriate technology to provide statistical confidence with the data provided. This assessment has been based upon prior history, observable conditions, direct surveys and indirect surveys. There are limitations based upon this approach where contaminants can escape detection using these methods. Minimum detectable concentrations have been specified for the instrumentation used to qualify the detection limits.

Section 4.0 License Review and Historical Use

Radioactive Materials (RAM) License

This decommissioning project for unrestricted release pertains to all radiological impacted areas identified in Building 2 located at 3801 Miranda Ave. operated under VAPAHCS Radioactive Materials Use Permit. A summary of areas where radionuclides were historically used or stored is detailed in the Restricted Area Summary (Table 2). VAPAHCS has a broad scope radioactive materials license and is allowed to possess any radionuclides with atomic numbers 3 through 83 and tritium (H-3). Radioactive material usage consisted of H-3 and C-14 on the first floor, while U-238 and Ca-41 were used in specific rooms in addition to H-3 and C-14 in the basement of the VAPAHCS Building 2.

Restricted Area Summary

The VAPAHCS requires the removal of Building 2 from their permit before they can be released for unrestricted use and ultimate dismantlement. Areas where radioactive materials were historically used or stored are summarized in Table 2 below and are identified on the building diagrams in Appendix A. The survey model was developed and implemented to detect the radionuclides used in each survey unit.

Table 2: Restricted Area Summary

VAPAHCS – Building 2, 3801 Miranda Ave.		
Area	Room	Historical Radionuclide Usage
Building 2 Basement	A008	Ca-41
Building 2 Basement	A009	H-3, C-14, Ca-41
Building 2 Basement	A010	H-3, C-14
Building 2 Basement	A05A	H-3, C-14
Building 2 Basement	A05	H-3, C-14
Building 2 Basement	A04	H-3, C-14
Building 2 Basement	A06	U-238
Building 2 Basement	A06B	U-238
Building 2 1 st Floor	B121	H-3, C-14
Building 2 1 st Floor	B122	H-3, C-14
Building 2 1 st Floor	B123	H-3, C-14
Building 2 1 st Floor	B124	H-3, C-14
Building 2 1 st Floor	B126	H-3, C-14
Building 2 1 st Floor	B127	H-3, C-14
Building 2 1 st Floor	B128	H-3, C-14
Building 2 1 st Floor	B131A	H-3, C-14
Building 2 1 st Floor	B131B	H-3, C-14
Building 2 1 st Floor	B131C	H-3, C-14

Historical Use

Historically, H-3, C-14, P-32, P-33, S-35, Ca-41, U238 and I-125 been the primary radionuclides used in Building 2 located at 3801 Miranda Avenue. P-32, P-33, S-35 and I-125 have not been used at the site for approximately 11 years. Based on its short half-life, it was excluded from the survey design. The survey model was developed and implemented to detect the isotopes used in each specific area.

Over the years tenant improvements have taken place on the first floor of Building 2 including converting previously impacted laboratory space (Rooms B121 – B128, B131A, B131B and B131C) into patient rooms, a day room and a dining room. These modified areas were internally surveyed by Stanford staff around April 2000 before the construction took place; however, a MARSSIM survey was not performed. Philotechnics took a conservative approach to surveying these areas by completing MARSSIM survey of the area as they are currently.

Waste Disposal

No radioactive materials remain at Building 2 of the VAPAHCS site located at 3801 Miranda Avenue. All radioactive waste and materials have been transferred to Stanford's Waste Storage Facility.

Radioactive Materials Spills

By completing a review of pertinent records and an interview with Ms. Shanjani and Ms. Amoroso, we were able to ascertain there have not been any significant radioactive materials spills affecting the specified areas. Significant spills are defined as those spills that were not readily cleaned up by the researcher and/or caused contamination to be found during follow-up or routine contamination surveys in excess of regulatory limits.

Section 5.0 – Radiation Surveys

During the period of June 13 – June 16, 2011, Philotechnics completed a comprehensive wipe and meter survey in the impacted areas listed in Table 3, which included benches, floors, sinks and cabinetry. Survey maps depicting these areas are included as Appendix B.

The following instrumentation was used to quantify radiation levels:

- Ludlum 2350-1, with the following probe
 - ✓ BP19DD (beta probe)
 - Serial # 212233 (Calibrated on 9/7/10)
- Ludlum 2350-1, with the following probe
 - ✓ BP19DD (beta probe)
 - Serial # 203439 (Calibrated on 9/7/10)
- Ludlum 2350-1, with the following probe
 - ✓ 43-68 (alpha probe)
 - Serial # 212233 (Calibrated on 9/7/10)
- Ludlum 2350-1, with the following probe
 - ✓ GP13A (gamma probe)
 - Serial # 203447 (Calibrated on 7/1/10)
- Ludlum 2350-1, with the following probe
 - ✓ GP13A (gamma probe)
 - Serial # 246986 (Calibrated on 7/1/10)
- Ludlum 3030 Planchet Counter, with the following probe
 - ✓ 43-10-1 (alpha/beta probe)
 - Serial # 242683 (Calibrated on 8/6/10)
- Beckman Scintillation Counter, Serial #7065636 (Operational Test 6/17/11)
NIST certificate for H-3 and C-14 standards included

The instrument calibrations were completed using NIST traceable sources and the Certificates of Calibration are included as Appendix C.

Minimum Detectable Concentration (MDC) Calculations

Philotechnics analytical sheets are included as Appendix D, which show calculations for the static MDC for the scintillation counter, static MDC and scanning MDC for hand-held instruments. The MDC's were calculated using the most conservative background values. These calculations follow the guidance in NUREG-1575 and NUREG-1507 and the information is used to verify the effectiveness of the instrumentation used in units of dpm/100 cm².

Area Classifications

Based on the results of the historical site assessment, facility areas were classified as impacted or non-impacted areas. Non-impacted areas are areas with no potential residual radioactivity from licensed activities. These include all property outside the building and non-laboratory areas inside the building. Impacted areas are those areas that may have some level of potential residual radioactivity from licensed activities.

Impacted areas are typically divided into Class 1, 2, or 3 areas. Class 1 areas have the greatest potential for contamination and therefore receive the highest degree of survey effort for the final status survey, followed by Class 2 and then by Class 3. Table 3 lists the recommended maximum survey unit sizes based on floor area. It should be noted that these limits are recommended and are not absolute.

Class 1 Areas – Areas with the highest potential for contamination, and meet the following criteria: (1) impacted; (2) potential for delivering a dose above the release criterion; (3) potential for small areas of elevated activity; and (4) insufficient evidence to support classification as Class 2 or Class 3.

Class 2 Areas – Areas that meet the following criterion: (1) impacted; (2) low potential for delivering a dose above the release criterion; and (3) little or no potential for small areas of elevated activity.

Class 3 Areas – Areas that meet the following criterion: (1) impacted; (2) little or no potential for delivering a dose above the release criterion; and (3) little or no potential for small areas of elevated activity.

Non-impacted: Building exterior, outside grounds, indoor areas other than those identified as restricted areas by the licensee, and surfaces above two meters in height in the areas specified below.

Impacted Class 1 Areas: None

Impacted Class 2 Areas: Rooms A04, A05A, A05, A06, A06B, A008, A009 and A010

Impacted Class 3 Areas: B121-B124, B126-B128, B131A, B131B, B131C and the basement hallway

Table 3: Recommended Maximum Survey Unit Size Limits

Survey Unit	Class 1	Class 2	Class 3
Structures	Up to 100 m ²	100 m ² to 1,000 m ²	No limit
Land	Up to 2,000 m ²	2,000 m ² to 10,000 m ²	No limit

Table 4 lists the survey units and their final classification. During the survey none of the data collected during the scans, static or removable measurements warranted re-classifying any of the survey units. Each previously impacted area was made its own survey unit.

Table 4: Laboratory Classification

3801 Miranda Ave.	Survey Unit	Classification
Building 2 Rooms A008-A010	1	Class 2
Building 2 Room A05A	2	Class 2
Building 2 Room A05	3	Class 2
Building 2 Room A04 Cold Room	4	Class 2
Building 2 Rooms A06, A06B	5	Class 2
Building 2 Room B124	6	Class 3
Building 2 Rooms B121-B123	7	Class 3
Building 2 Rooms B126-B128	8	Class 3
Building 2 Room B131A	9	Class 3
Building 2 Rooms B131B, B131C	10	Class 3
Building 2 Basement Hallway	11	Class 3

Survey Methodology

Determination of Class 1 survey unit sample locations is accomplished by first determining sample spacing and then systematically plotting the sample locations from a randomly generated start location. The random starting point of the grid provides an unbiased method for obtaining measurement locations to be used in the statistical tests. Class 1 survey units have the highest potential for small areas of elevated activity so the areas between measurement locations may be adjusted to ensure that these areas can be detected by scanning techniques. The previously impacted laboratories were not initially classified as Class 1, nor upgraded to Class 1; however, the methodology is described to give a comprehensive overview of our surveying approach.

Similar systematic spacing methods are used for Class 2 survey units because there is an increased probability of small areas of elevated activity. The use of a systematic grid allows the decision-maker to draw conclusions about the size of the potential areas of elevated activity based on the area between measurement locations. All of the impacted rooms in the basement were classified as Class 2 due to the potential for radioactive contamination although it was not expected to exceed the DCGL_w. Beta and gamma scans and static measurements were taken in all of the impacted rooms in the basement due to Ca-41 being used in the area. Alpha and beta scans and static measurements were taken in Rooms A06 and A06B due to the use of U-238 with the electron microscope. Swipes taken in these areas were first counted in the planchet counter prior to being counted in the liquid scintillation counter. We utilized a square grid system for the Class 2 areas and the starting point was determined using a random number generator. Judgmental sample locations were added to the survey as directed by the Project Manager which included all sinks and traps.

The guidance in MARSSIM recommends simple random measurement patterns for Class 3 survey units to ensure that the measurements are independent and support the assumptions of the statistical tests. For Class 2 and Class 3 survey units, the sensitivity for scanning techniques is not tied to the area between measurement locations as they apply only to Class 1 areas. The scanning techniques selected represent the best reasonable effort based on the survey data quality objectives.

In all classifications, permanent counter tops and other horizontal surfaces which block floor surfaces, were included as a replacement to the blocked floor surface. Likewise, fixed cabinetry faces and other permanent equipment replace blocked wall surfaces.

Internal surfaces of permanent furnishings (i.e., drawer or cabinetry interior surfaces) are not included in the systematic measurement location placement. However, these surfaces were included in the scan surveys. Although not necessary, additional surface activity measurements would have been collected at each area of elevated activity identified during the scan surveys.

Background Determination

Ten (10) 1-minute ambient, floor, benchtop and drywall backgrounds were taken with each survey meter. The average of these ten measurement were used to determine the natural background levels. Appendix E provides a summary of background data points, which were collected in a non-impacted area of similar construction to the area being requested for unrestricted release. The background averages were subtracted from the gross CPM data to convert the readings to net CPM.

Ten (10) 1-minute background samples were counted on the Beckman Liquid Scintillation Counter and one 10 minute background sample was counted on the Ludlum 3030E Planchet Counter. The results for each channel of the LSC were then averaged and used in determining an average MDC for each channel.

Surface Scans

The following table compares MARSSIM recommendations and actual area coverage for the scan survey completed at the VAPAHCS.

Table 5: Scan Survey Coverage Comparison

Classification	Percentage of Surface Area Requiring Scan Coverage (MARSSIM)	VA Hospital – Palo Alto's Surface Area Scan Coverage
1	100%	N/A
2	10 – 100% (Judgmental)	100% Floors; 80% Structures
3	Judgmental	50% Floors

The scan survey percentages were chosen in order to provide a comprehensive survey of the impacted areas and provide confidence there was no contamination above the release limit present. The probes were held at a distance of ¼" to ½" above the surface moving at a scan rate of 5 cm/sec. Class 2 survey areas received a 100% scan of all accessible floor areas and an 80% scan of permanent structures. Permanent structures are defined as hoods, benches, casework and walls. Class 3 survey areas received a 50% scan of all accessible floor areas. After tenant improvements on the first floor, no permanent structures remained that required scanning. The scanned areas chosen were those areas with the highest probability of containing residual activity. These included normal foot traffic routes and floor areas in front of lab benches, fume hoods and sinks. Additional areas where scan surveys were completed included lab bench working surfaces, fume hood interior surfaces, sinks, base cabinet interiors and wall surfaces adjacent to work areas. In the event of any elevated activity noted from the survey, the location

would have been marked and additional measurements performed to quantify the activity. ***All scanning measurements collected were less than the established DCGL_w.***

Fixed or Static Measurements

Class 1 survey units generally consist of one or two rooms or laboratories. Class 2 and Class 3 survey units generally consist of many rooms. The MARSSIM sample measurement locations (i.e., random static and wipe measurements) for all survey units was determined by folding down the walls to create a 2-dimensional overhead map. This protocol increased the probability for finding residual contamination. Additional judgmental sample locations were always included by the Project Manager in all sink basins and traps.

The probe head was held as close to the surface as practicable to determine a count rate in counts per minute. The data calculations from this survey are included as Appendix F. ***All static measurements were below the established DCGL_w.***

Removable Measurements

Removable contamination measurements (smears) were collected on building structural surfaces at each sample location. Each smear encompassed an area of approximately 100cm²; if an area of less than 100cm² was wiped, a comment was added to the survey data sheet estimating the surface area wiped to allow for area correction of the results. Swabs were used when system or component access points were not large enough to allow for a wipe of a 100cm² surface area.

Two swipes were taken for each sink in the Class 2 impacted areas; one inside the sink basin and one beyond the trap. All of the smear samples taken in the class 2 impacted areas were first counted for one minute on a Ludlum Model 3030 Planchet Counter for gross alpha and beta contamination and then counted on a Beckman Liquid Scintillation Counter (LSC) for one minute. All smear samples taken from the class 3 survey units were counted for one minute on the LSC because these areas only used H-3 and C-14. A data sheet, included as Appendix G, details the CPM results, the DPM conversions and indicates if the result is below the DCGL_w. The channels for the LSC were set up so H-3 would be detected in Channel A, C-14 in Channel B and all other beta emitters with energies above 156 keV in Channel C. Scintillation standards were used to determine if the LSC was operating between normal parameters. The efficiencies for the LSC were determined from the quench curves. We have included a table in Appendix C that shows the efficiencies for H-3 and C-14 based on the amount of quench. Using the FORECAST function in Excel, we extrapolated the efficiency based on the H number which Beckman uses to document the quench of the sample. The efficiencies were generally around 54% for H-3 and 95% for C-14. The total efficiency of the planchet counter was 39.49% for alpha emitters and 46.56% for beta emitters. ***All final wipe survey results were below the established DCGL_w.***

Section 6.0 - Data Quality Assessment and Interpretation of Survey Results

The statistical guidance contained in Section 8 of MARSSIM was used to determine if areas are acceptable for unrestricted release and whether additional surveys or sample measurements were needed.

The following table summarizes MARSSIM guidance for conclusions based upon data provided by the Final Status Survey.

Table 6: Guidance for Survey Conclusions

Survey Result	Conclusion
All measurements less than DCGL _w	Survey unit meets release criterion
Average greater than DCGL _w	Survey unit does not meet release criterion
Any measurement greater than DCGL _w and the average less than DCGL _w	Conduct Sign test and elevated measurement comparison

The Derived Concentration Guideline Limit (DCGL) is used as a determining factor to the survey unit meeting the criterion for unrestricted release. Due to the current situation in California where there is not an established dose based release criteria, the DCGL_w's have been selected by using a 1.0 mrem/yr release criterion with our actions levels set at 50% of the DCGL_w. Based on the results of the survey where all the measurements were below the DCGL, by definition, each survey unit met the release criterion.

Table 7: Established DCGL_w's for Survey

Isotope	Total Activity DCGL _w 's (DPM/100 cm ²)	Removable Activity Limit (DPM/100 cm ²)
H-3	2.40 x 10 ⁶	1000
C-14	7.00 x 10 ⁴	1000
Ca-41	1.16 x 10 ⁵	1000
U-238	100 ✦	20

✦ U-238 DCGL corresponds to a dose level of approx. 25 mrem/yr per DandD, Version 2.1.0.
 7/24/2011
 8/11/2011

Based on a 1.0 mRem/yr release criterion, the limiting DCGL_w for beta emitters is C-14 at 1.4 x 10⁵ dpm/100 cm². For alpha emitters the limiting DCGL_w is U-238 at 100 dpm/100 cm².

Calculation of Relative Shift – Determining the Number of Samples

A minimum number of samples are needed to obtain sufficient statistical confidence that the conclusions drawn from the samples are correct. The number of samples will depend on the relative shift (the ratio of the concentration to be measured relative to the statistical variability of the contaminant concentration). The minimum number of samples is obtained from MARSSIM tables or calculated using equations in Section 5 of MARSSIM. For the VAPAHCS Building 2 project we estimated that the relative shift would be close to 3. With a relative shift of 3 and decision errors of 0.05 for Type I and Type II, the number of samples for each survey unit was determined to be 14. As a conservative measure, the minimum number of samples for each survey unit was increased to a minimum of 23. In addition to the number of samples recommended by MARSSIM additional samples were judgmentally selected by the project manager as an ALARA measure.

Table 8 compares the actual relative shift to the estimated relative shift in order to determine if the number of systematic measurements for each survey unit satisfies the statistical criteria listed in section 5 of MARSSIM. For each class 2 survey unit the actual number of locations sampled were compared to the number required by MARSSIM Table 5.5 "Values of N for Use with the Sign Test" for both beta and gamma measurements. *As a result of the analysis, no additional sample locations were necessary.*

Table 8: Survey Unit Data Analysis

Survey Unit #	Class	Actual	Type I Error	Type II Error	Beta Relative Shift	Beta Static Locations Required	Gamma Relative Shift	Gamma Static Locations Required	Additional Static Locations Required?
1	2	33	0.05	0.05	129.6	14	80.6	14	No
2	2	47	0.05	0.05	185.1	14	57	14	No
3	2	33	0.05	0.05	54.5	14	72.1	14	No
4	2	29	0.05	0.05	55.5	14	67.1	14	No
5	2	49	0.05	0.05	56.2	14	N/A	N/A	No*
6	3	44	0.05	0.05	117.7	14	N/A	N/A	No
7	3	35	0.05	0.05	117.5	14	N/A	N/A	No
8	3	35	0.05	0.05	76.0	14	N/A	N/A	No
9	3	38	0.05	0.05	149.4	14	N/A	N/A	No
10	3	42	0.05	0.05	142.2	14	1.54	N/A	No
11	3	23	0.05	0.05	123.3	14	62.8	14	No

*Alpha measurements taken in Survey Unit 5 due to the use of U-238 with the electron microscope

Section 7.0 –Decontamination / Decommissioning Review

Decontamination

Decontamination is the physical or chemical process of reducing and preventing the spread or potential exposure from contamination. Decontamination options include the use of commercially available materials and/or equipment that will effectively remove radioactive materials from surface areas so the contamination can be collected and properly disposed.

Decontamination was not required in any of the impacted areas listed in Table 3 as part of the decommissioning survey. The survey results did not indicate the presence of any level of radioactive materials that would require decontamination based upon our established action levels. At the time of our review, the action levels were based upon 50% of the DCGL_w. Based on the results of the survey where all the measurements were below the DCGL, by definition, each survey unit met the release criterion.


Decommissioning Review

Philotechnics has reviewed all of the applicable data pertaining to the history of radioactive material use as well as the static and wipe surveys completed at the VAPAHCS Building 2 facility located at 3801 Miranda Avenue, Palo Alto, CA. It is our professional opinion that the facility is free of any radioactive materials and/or radioactive contamination, would qualify for unrestricted release, and may be removed from VAPAHCS Radioactive Materials Use Permit in accordance with Code of Federal Regulations Title 10 30.36 “Expiration and termination of licenses and decommissioning of sites and separate buildings or outdoor areas.”

APPENDIX A
VA Palo Alto Health Care System
Building 2 Site Diagram Identifying
Decommissioned Areas

VAPAHCS


3801 Miranda Ave, Palo Alto, CA 94304
Building 2, B-Wing, First Floor



 - *Decommissioned Rooms*

VAPAHCS

3801 Miranda Ave, Palo Alto, CA 94304
Building 2, A-Wing, Basement



 - *Decommissioned Rooms*

APPENDIX B
VAPAHCS
Area Survey Maps

VAPAHCS


Final Status Survey Report

Appendix B

Building: Building 2 Area: Room A008, 009, 010 Survey Unit: 1 Date: 6-13-11 Class: 2

Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10
Ludlum 2350-1 (Serial #203447), GP13A Detector, Calibrated on 7-1-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Doug Bassett, Garrett Eastman, Steve Beck



● - Random Start Location
 Sample Spacing = 2.13 m (7')
 Total Area ~ 71.2 m² (767 ft²)

VAPAHCS


Final Status Survey Report

Appendix B

Building: Building 2 Area: Room A05A Survey Unit: 2 Date: 6-14-11 Class: 2

Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10
Ludlum 2350-1 (Serial #203447), GP13A Detector, Calibrated on 7-1-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Garrett Eastman



● - Random Start Location
Sample Spacing = 1.07 m (3'6")
Total Area ~ 16 m² (171 ft²)

VAPAHCS


Final Status Survey Report

Appendix B

Building: Building 2 Area: Room A05 Survey Unit: 3 Date: 6-14-11 Class: 2

Instruments: Ludlum 2350-1 (Serial #203439), BP19DD Detector, Calibrated on 9-7-10
Ludlum 2350-1 (Serial #246986), GP13A Detector, Calibrated on 7-1-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Steve Beck



● - Random Start Location
Sample Spacing = 0.91 m (3')
Total Area ~ 7.3 m² (79 ft²)

VAPAHCS


Final Status Survey Report

Appendix B

Building: Building 2 Area: Room A04 Cold Room Survey Unit: 4 Date: 6-14-11 Class: 2

Instruments: Ludlum 2350-1 (Serial #203439), BP19DD Detector, Calibrated on 9-7-10
Ludlum 2350-1 (Serial #246986), GP13A Detector, Calibrated on 7-1-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Steve Beck



● - Random Start Location
Sample Spacing = 1.12 m (3'8")
Total Area ~ 8.5 m² (91 ft²)

VAPAHCS


Final Status Survey Report

Appendix B

Building: Building 2 Area: Room A06, 06B Survey Unit: 5 Date: 6-15-11 Class: 2

Instruments: Ludlum 2350-1 (Serial #203439), BP19DD Detector, Calibrated on 9-7-10
Ludlum 2350-1 (Serial #212233), 43-68 (Alpha) Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Doug Bassett



● - Random Start Location
 Sample Spacing = 1.22 m (4')
 Total Area ~ 19.5 m² (210 ft²)

VAPAHCS

Final Status Survey Report

Building: Building 2 Area: Room B124* Survey Unit: 6 Date: 6-13-11 Class: 3
Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11
Surveyor: Doug Bassett

**Original Lab was B124, new room numbers and configuration are shown on the map*



● - Random Start Location
Sample Spacing = 2.13 m (7')
Total Area ~ 120.8 m² (1300 ft²)

VAPAHCS

Final Status Survey Report


Appendix B

Building: Building 2 Area: Room B121, 122, 123* Survey Unit: 7 Date: 6-13-11 Class: 3

Instruments: Ludlum 2350-1 (Serial #203439), BP19DD Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Steve Beck, Garrett Eastman

**Original Labs were B121, B122 & B123; new room numbers and configuration are shown on the map*



⊙ - Random Start Location
 Sample Spacing = 1.83 m (6')
 Total Area ~ 71.9 m² (774 ft²)

VAPAHCS


Final Status Survey Report

Building: Building 2 Area: Room B126, B127, B128* Survey Unit: 8 Date: 6-13-11 Class: 3

Instruments: Ludlum 2350-1 (Serial #203439), BP19DD Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Steve Beck, Garrett Eastman

**Original Labs were B126, B127 & B128; new room numbers and configuration are shown on the map*



⊙ - Random Start Location
Sample Spacing = 1.98 m (6'6")
Total Area ~ 83.4 m² (898 ft²)

VAPAHCS

Final Status Survey Report

Appendix B

Building: Building 2 Area: Room B131A* Survey Unit: 9 Date: 6-14-11 Class: 3

Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Doug Bassett, Steve Beck & Garrett Eastman

**Original Lab was B131A; new room numbers and configuration are shown on the map*




● - Random Start Location
Sample Spacing = 1.83 m (6')
Total Area ~ 64.3 m² (692 ft²)

VAPAHCS Final Status Survey Report

Building: Building 2 Area: Room B131B, B131C* Survey Unit: 10 Date: 6-14-11 Class: 3
Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10
Beckman Scintillation Counter, Operational Test 6-17-11
Surveyor: Garrett Eastman, Doug Bassett, Steve Beck

**Original Labs were B131B & B131C; new room numbers and configuration are shown on the map*



⊙ - Random Start Location
Sample Spacing = 1.83 m (6')
Total Area ~ 65 m² (700 ft²)

VAPAHCS

Final Status Survey Report

Appendix B


Building: Building 2 Area: Basement Hallway Survey Unit: 11 Date: 6-15-11 Class: 3

Instruments: Ludlum 2350-1 (Serial #212233), BP19DD Detector, Calibrated on 9-7-10

Ludlum 2350-1 (Serial #203477), GP13A Detector, Calibrated on 7-1-10

Beckman Scintillation Counter, Operational Test 6-17-11

Surveyor: Garrett Eastman, Doug Bassett, Steve Beck



APPENDIX C
*Certificates of Calibration &
Scintillation Check*

**VA Hospital - Palo Alto
Instrument Operational Check
6/17/2011**

Counting Data:

Standard	CPM
H-3	53,721
C-14	42,691
Blank	36

Nuclide Information:

Analytical Sampling Date: 6/17/2011

Nuclide	Initial Activity (DPM)	Calib. Date	Current Activity (DPM)
H-3	98,800	11/26/2008	85,546
C-14	44,100	11/26/2008	44,086

Unquenched Efficiency Calculations:

Nuclide	CPM	Corrected DPM	Efficiency
H-3	53,721	85,546	62.80%
C-14	42,691	44,086	96.83%

Efficiency Used Based on Quench Curve:

H-3 Quench	
H#	Eff.
0.1	61.20%
39.8	55.95%
94.1	42.34%
132.4	33.29%
165.7	25.65%
202.8	18.25%
231.6	13.55%
253.5	10.52%
280.6	7.49%

C-14 Quench	
H#	Eff.
0.1	95.64%
46.9	94.75%
95.2	92.78%
124.4	91.27%
159.7	88.63%
204.2	84.76%
224.2	82.04%
263.1	76.05%
284.5	72.26%

Activity Calibration and Error Analysis

The ^{14}C or ^3H standards have been assayed for activity by comparison with the National Institute of Standards and Technology (NIST) carbon-14 solution standard, Standard Reference Material (SRM) No. 438 tartaric acid in 2M HCl, and tritium solution standard SRM No. 391-B-5, tritiated water in water. The H-Number method of calibration was used with secondary standards prepared from the NIST standard.

The estimated activities for the activity standards and the reference dates for all standards are as follows:

H3 DPMs:	98,800	REF DATE:	26NOV08
C14 DPMs:	44,100	REF DATE:	26NOV08
BKG DPMs:	N/A	REF DATE:	26NOV08

THE PRODUCTION SERIAL NUMBERS
FOR THE 3 STANDARDS ARE
AS FOLLOWS :

H3	-	HPP4811
C14	-	CPP0506
BKG	-	BPP2212

The overall uncertainty associated with the activity values are estimated to be less than $\pm 3.5\%$ for the ^3H and $\pm 3.5\%$ for the ^{14}C . These estimates are determined in accordance with error analysis procedures recommended by the International Commission on Radiation Units and Measurements

(ICRU Report 12). The limits are calculated by arithmetically summing the uncertainty due to random errors at the 99% confidence level with the assessable systematic errors. Random errors arise from production and assay procedures such as dispensing, weighing, and counting. Systematic errors consist of uncertainty in the activity of the NIST-based secondary standards, overall uncertainty of the NIST SRM No. 391-B-5 as a function of time (assuming a half-life of 12.43 years and a half-life uncertainty of 0.5%); uncertainties in the standard weights used for calibrating the balances used in gravimetric determinations, losses of activity by evaporation, and uncertainties in corrections applied for the effects of impurities on the scintillation process.


Recommendations for Use

Unquenched standards can be used to:

- Calibrate the instrument. Only one of these standards, ^{14}C or ^3H , can be used for calibration of your instrument. Refer to your Operator's Manual for proper calibration standard instructions.

IMPORTANT Use of any other standard from this set or another set requires the construction of new quench curves.

- Measure day-to-day ^3H and ^{14}C counting efficiencies for comparison with original factory specifications and for verifying stable system performance.



GRIFFIN INSTRUMENTS



CALIBRATION CERTIFICATE FOR 3030E SERIAL# 242683
Owner: PHILOTECHNICS

DATE: 08/06/10 LOCATION: Griffin Inst
TECH: Joanne Glenn DATE LAST CAL EXPIRES: 06/17/10
Reason For Calibration: Due For Calibration Repair (See Remarks)
CABLE LENGTH: 39" Other (See Remarks) Due and Repair (See Remarks)

NIST TRACEABLE EQUIPMENT USED DURING CALIBRATION

MODEL: M-500 SERIAL #: 114512 CAL. DUE: 07/28/11
MODEL: SERIAL #: CAL. DUE:

Condition: Sat Unsat AF Mechanical Zero: 0
AL Mechanical Zero: 0

Scaler Function Check	As Found	As Left		
Beta Channel Window (4-50 mV):	4-50	A.F.		
Alpha Channel Window (175 mV, 120 for 3030):	120	A.F.		
Alpha Counts w/Pulser @ 10,000 CPM:	9,960	A.F.	% Error:	0.4%
Beta Counts w/Pulser @ 10,000 CPM:	9,959	A.F.	% Error:	0.4%
HIGH VOLTAGE POWER SUPPLY CAL. (2929 only)				
1 KV Reading (R-5 on HV Board):	1	A.F.		
Max HV (1500 V +):	<input checked="" type="radio"/> Sat <input type="radio"/> Unsat			

REMARKS:

Does Instrument Meet Final Acceptance Criteria? Yes No
Calibration Sticker Attached? Yes No
Date Instrument is Due For Next Calibration: 08/06/11

INSTRUMENT MARRIED WITH 43-10-1 # PR255979

Performed/Reviewed by: Joanne Glenn Date: 8/6/2010 Entered by: [Signature] Initials

Ludlum Measurements, Inc.
Model 3030 Parameters

8/6/2010
9:40:56 AM

Header 1: Philotechnics
Header 2: Serial#242683
Header 3: Probe#255979
Header 4:
Header 5: More Comments?
Header 6: More Comments?

Calibration Due Date: 8/6/2011

Model 3030 Date: 8/6/2011
Model 3030 Time: 8:04:00 AM

Count Time Switch (min): 0001.0
User PC Time (min): 1.0

Alpha Alarm: 999999
Beta Alarm: 999999
Alpha + Beta Alarm: 999999

High Voltage (VDC): 625

Loss of Count Time (min): 30.0

Count Mode: SCALER

Alpha Efficiency %: 38.9
Beta Efficiency %: 27.4

Background Subtract: OFF
Alpha Background: 2.0
Beta Background: 48.0

Crosstalk Correction: OFF
Alpha to Beta Crosstalk %: 2.6
Beta to Alpha Crosstalk %: 0.0

Show Parameters during startup: Enabled

Daily QC Check: OFF

Last Alpha Efficiency %: 0
Last Beta Efficiency %: 8

Standard Alpha Efficiency %: 40
Standard Beta Efficiency %: 33

Allowable Alpha QC Efficiency ± %: 15
Allowable Beta QC Efficiency ± %: 15

Alpha Source Size (dpm): 30900
Alpha Source Size (µCi): 0.01391891892

Beta Source Size (dpm): 22900
Beta Source Size (µCi): 0.01031531532

Last Alpha QC Background: 0.0
Last Beta QC Background: 36.0

Alpha Background Upper Limit (cpm): 3
Alpha Background Lower Limit (cpm): 0
Beta Background Upper Limit (cpm): 80
Beta Background Lower Limit (cpm): 0

Next Sample Number: 0014
User-defined Comment: TEST
Logging Mode: Log QC Only
Recycle Mode: OFF
Printer Mode: OFF



GRIFFIN INSTRUMENTS



CALIBRATION CERTIFICATE FOR 43-10-1 PROBE # PR255979

Owner: PHILOTECHNICS

DATE: 08/06/10 LOCATION: Griffin Inst
TECH: Joanne Glenn DATE LAST CAL EXPIRES: 06/17/10

REASON FOR CALIBRATION:

- Due For Calibration Repair (See Remarks) Other (See Remarks) Due and Repair

CABLE LENGTH: 39"

INPUT SENSITIVITY: dual

NIST TRACEABLE EQUIPMENT AND STANDARDS USED DURING CALIBRATION

MODEL: 3030E SERIAL #: 242683 CAL. DUE: 08/06/11

NIST TRACEABLE SOURCES USED

Table with 5 columns: Source Number, Isotope, 4 pi Activity, Assay Date, 2 pi Activity. Rows include sources like 00TC470-0654, 94TH470-1593, 2696-00, 2697-00, and PX 726.

Efficiencies from last cal.:

Condition: Sat Unsat

Pu: 39.49% Th: 31.55% Sr: 46.56%

Tc ss: 22.18% C14: 10.85% Tc Ni:

As Found (AF) Efficiencies:

Table with columns for HV/Vernier, Tc-99 Source Response Nickel (CPM), Pu-239 Source Response (CPM), Background (CPM), and Tc-99 Source Response Stainless Steel (CPM). Includes sub-columns for A ch., B ch., and Net Eff.

Table with 2 columns: Net A to B Xtalk: <10%, B to A Xtalk: <1%. Values: 2.6%, <1%.

Table with columns for Pu239, Tc99 Ni, Tc99 ss, Th-230, Sr90, C-14. Rows for AF CPM, AF 4 pi eff, and AF 2 pi eff.

Is as found efficiency within 20% of the efficiency from the last cal? Yes No (See Remarks)

Note: If the as found data is within 10% of the last calibration and the B-A Xtalk is <1% and the A-B Xtalk is <10%, then the technician may N/A the plateau section and go directly to remarks.

Ludlum Measurements, Inc.
Model 3030 Plateau Data

8/6/2010
9:39:17 AM

Header 1: Philotechnics
Header 2: Serial#242683
Header 3: Probe#255979
Header 4:
Header 5: More Comments?
Header 6: More Comments?

Calibration Due Date: 8/6/2011

Model 3030 Date: 8/6/2011
Model 3030 Time: 8:04:00 AM

User PC Time: 1.0

Alpha Isotope: Pu239, 2696-00, 12/2/09
Alpha Source Size (dpm): 18500
Alpha Source Size (uCi): 0.008333333

Beta Isotope: Tc99, 00TC470-0654, 6/15/09
Beta Source Size (dpm): 17300
Beta Source Size (uCi): 0.007792793

Starting High Voltage: 575
Starting High Voltage: 675
High Voltage Increment: 25

Plateau Count Mode: SCALER
Source Count Time (min): 0001.0
Background Count Time (min): 1.0

HV	Source (Beta)	ALPHA			BETA			
		Background	Eff	CrossTalk	Source (Alpha)	Background	Eff	Crosstalk
575	7045 (208)	0	38.1%	2.4%	3652 (0)	39	20.9%	0.0%
600	7180 (179)	0	38.8%	2.0%	4236 (1)	37	24.3%	0.0%
625	7197 (238)	2	38.9%	2.6%	4790 (0)	48	27.4%	0.0%
650	7331 (231)	2	39.6%	2.5%	5096 (0)	51	29.2%	0.0%
675	7265 (264)	2	39.3%	3.0%	5284 (1)	49	30.3%	0.0%

GRIFFIN INSTRUMENTS

CALIBRATION CERTIFICATE FOR

2350-1

SERIAL#

212233

Owner: PHILOTECHNICS

DATE: 09/07/10

LOCATION: Griffin Inst

TECH: Joanne Glenn

DATE LAST CAL EXPIRES: 09/18/10

Reason For Calibration:

Due For Calibration

Repair (See Remarks)

Other (See Remarks)

Due and Repair (See Remarks)

NIST TRACEABLE EQUIPMENT USED DURING CALIBRATION

MODEL: M-500

SERIAL #: 114512

CAL. DUE: 07/28/11

MODEL:

SERIAL #:

CAL DUE:

Audio Response

CABLE LENGTH 5'

CONDITION: Sat

NEW BATTERIES: Yes No

BATTERY CHECK: 5.6 V

HV (+/-10%)

AS FOUND HV

AS LEFT HV

500 V:

495

A.F.

1250 V:

1250

A.F.

2000 V:

1990

A.F.

AF Threshold: 350

AL Threshold: A.F.

RATE CPM AS FOUND % ERROR AS LEFT % ERROR

RATE CPM	AS FOUND	% ERROR	AS LEFT	% ERROR
250	249	0.4%	A.F.	
2500	2496	0.2%	A.F.	
25K	24.953 K	0.2%	A.F.	
250K	249.491 K	0.2%	A.F.	

Is the As Found Data Within 2% of the Set Point?:

Yes No

	AF	AL
Detector #:	00	A.F.
Detector Serial #:	K109	A.F.
Model #:	BP-19DD	A.F.
U:	7	A.F.
M:	0	A.F.
TB:	1	A.F.

	AF	AL
HV:	950	A.F.
Window:	Off	A.F.
Count Time (sec):	60	A.F.
Threshold:	350	A.F.
Correction Constant:	1	A.F.
Dead Time (uSec):	0.0	A.F.

REMARKS:

Does Instrument Meet Final Acceptance Criteria? Yes No

Calibration Sticker Attached? Yes No

Date Instrument is Due For Next Calibration: 09/07/11

INSTRUMENT MARRIED WITH

IBP19DD

K109

Performed/Reviewed by:

Joanne Glenn

Date: 9/7/2010

Entered by: *JG* Initials

Serial #	212233		
Detector #	00	01	02
Det Ser #	K109	PR142542	PR142542
Model	BP19DD	43-68 Alpha	43-68 Beta
U	7	7	7
M	0	0	0
TB	1	1	1
HV	950	1250	1700
W (Window)	Off	Off	Off
CT (Count Time)	60 sec	60 sec	60 sec
T (Threshold)	350	40	40
CC	1	1	1
DT	0.0 usec	0.0 usec	0.0 usec



GRIFFIN INSTRUMENTS



CALIBRATION CERTIFICATE FOR IBP19DD PROBE # K109

Owner: PHILOTECHNICS

DATE: 09/07/10 LOCATION: Griffin Inst
TECH: Joanne Glenn DATE LAST CAL EXPIRES: 09/18/10

REASON FOR CALIBRATION:

- Due For Calibration (checked)
Repair (See Remarks)
Other (See Remarks)
Due and Repair

CABLE LENGTH: 5' INPUT SENSITIVITY: 35 mV

NIST TRACEABLE EQUIPMENT AND STANDARDS USED DURING CALIBRATION

MODEL: 2350-1 SERIAL #: 212233 CAL. DUE: 09/07/11

NIST TRACEABLE SOURCES USED

Table with 5 columns: Source Number, Isotope, 4 pi Activity, Assay Date, 2 pi Activity. Rows include 00TC470-0654 (Tc99 SS), 2697-00 (Sr90), and PX 726 (C14).

Efficiencies from last cal.:

Condition: Sat (checked) Unsat
Pu: [] Th: [] Sr: 39.47%
Tc ss: 16.43% C14: 7.95% Tc Ni: []

As Found (AF) Efficiencies:

Table with 4 main columns: HV / Vernier, Tc-99 Source Response Nickel (CPM), Pu-239 Source Response (CPM), Background (CPM), Tc-99 Source Response Stainless Steel (CPM). Includes sub-columns for A ch., B ch., Net Eff.

Table with 2 columns: Net A to B Xtalk: <10%, B to A Xtalk: <1%

Table with 6 columns: Pu239, Tc99 Ni, Tc99 ss, Th-230, Sr90, C-14. Rows include AF CPM, AF 4 pi eff, and AF 2 pi eff.

Is as found efficiency within 20% of the efficiency from the last cal? Yes No (See Remarks) (checked)

Note: If the as found data is within 10% of the last calibration and the B-A Xtalk is <1% and the A-B Xtalk is <10%, then the technician may N/A the plateau section and go directly to remarks.



GRIFFIN INSTRUMENTS



PROBE #: K109

Date: 09/07/10

PLATEAU AND SET POINT DATA

HV / Vernier	Tc-99 Source Response SS (CPM):			Pu-239 Source Response (CPM):			Background (CPM):		Net A to B Xtalk: <10%	B to A Xtalk: <1%
	A ch.	B ch.	Net Eff.	A ch.	B ch.	Net Eff.	A ch.	B ch.		
850		2142	11.5%					157		
900		3221	17.1%					261		
950		4106	21.6%					364		
1000								727		

Alpha / Beta Bkg (cpm)	430					
HV / Vernier	Pu-239	Tc-99 Ni	Tc-99 SS	Th-230	C-14	Sr-90
950 / N/A	CPM:		3910		4438	4110
	<i>4 pi AL Efficiencies:</i>		20.12%		8.22%	38.84%
	<i>2 pi AL Efficiencies:</i>		32.22%		21.48%	55.55%

REMARKS: Higher Tc efficiency could be due to thinner mylar sheet.

Does Instrument Meet Final Acceptance Criteria?: Yes No

Calibration Sticker Attached?: Yes No

Date Instrument is Due For Next Calibration: 09/07/11

INSTRUMENT MARRIED WITH 2350-1 # 212233

Performed/Reviewed by: *Jeanne Glenn*

Date: 9/7/2010

Entered by: *[Signature]* Initials

2 pi efficiencies denoted in italics.

Calibrations performed to ANSI N323A-1997 standards.



GRIFFIN INSTRUMENTS



CALIBRATION CERTIFICATE FOR 43-68 PROBE # PR142542

Owner: PHILOTECHNICS

01792

DATE: 09/07/10

LOCATION: Griffin Inst

TECH: Joanne Glenn

DATE LAST CAL EXPIRES: 09/18/10

REASON FOR CALIBRATION:

- Due For Calibration, Repair (See Remarks), Other (See Remarks), Due and Repair

CABLE LENGTH: 5'

INPUT SENSITIVITY: 4 mV

NIST TRACEABLE EQUIPMENT AND STANDARDS USED DURING CALIBRATION

MODEL: 2350-1 SERIAL #: 212233 CAL. DUE: 09/07/11

NIST TRACEABLE SOURCES USED

Table with 5 columns: Source Number, Isotope, 4 pi Activity, Assay Date, 2 pi Activity. Lists sources like 00TC470-0654 (Tc99 SS) and 94TH470-1593 (Th230).

Efficiencies from last cal:

Condition: Sat Unsat

Pu: Th: 23.05% Sr: Tc ss: 27.33% C14: 14.67% Tc Ni:

As Found (AF) Efficiencies:

Table with 4 main columns: HV / Vernier, Tc-99 Source Response Nickel (CPM), Pu-239 Source Response (CPM), Background (CPM), Tc-99 Source Response Stainless Steel (CPM). Includes sub-columns for A ch., B ch., Net Eff.

Table with 2 columns: Net A to B Xtalk: <10%, B to A Xtalk: <1%

Table with 7 columns: Pu239, Tc99 Ni, Tc99 ss, Th-230, Sr90, C-14. Rows include AF CPM, AF 4 pi eff, and AF 2 pi eff.

Is as found efficiency within 20% of the efficiency from the last cal? Yes No (See Remarks)

Note: If the as found data is within 10% of the last calibration and the B-A Xtalk is <1% and the A-B Xtalk is <10%, then the technician may N/A the plateau section and go directly to remarks.



GRIFFIN INSTRUMENTS



PROBE #: PR142542

Date: 09/07/10

PLATEAU AND SET POINT DATA

HV / Vernier:	Tc-99 Source Response SS (CPM):			Pu-239 Source Response (CPM):			Background (CPM):		Net A to B Xtalk: <10%	B to A Xtalk: <1%
	A ch.	B ch.	Net Eff.	A ch.	B ch.	Net Eff.	A ch.	B ch.		
N/A										

Alpha / Beta Bkg (cpm)		308	308			
HV / Vernier	Pu-239	Tc-99 Ni	Tc-99 SS	Th-230	C-14	Sr-90
1250 a / 1700 b	CPM: 4483		5157	3776	7514	4210
	4 pi AL Efficiencies: 24.22%		28.04%	22.59%	14.78%	41.21%
	2 pi AL Efficiencies: 47.71%		44.92%	46.18%	38.63%	58.93%

REMARKS: Clean screen and mylar due to as found high beta background.

Does Instrument Meet Final Acceptance Criteria?: Yes No

Calibration Sticker Attached?: Yes No

Date Instrument is Due For Next Calibration: 09/07/11

INSTRUMENT MARRIED WITH 2350-1 # 212233

Performed/Reviewed by: *Jessica Glavin*

Date: 9/7/2010

Entered by: *[Signature]* Initials

2 pi efficiencies denoted in italics.

Calibrations performed to ANSI N323A-1987 standards.

GRIFFIN INSTRUMENTS

CALIBRATION CERTIFICATE FOR

2350-1

SERIAL# 203439

Owner: PHILOTECHNICS

DATE: 09/07/10

LOCATION: Griffin Inst

TECH: Joanne Glenn

DATE LAST CAL EXPIRES: 09/02/10

Reason For Calibration:

- Due For Calibration Repair (See Remarks)
 Other (See Remarks) Due and Repair (See Remarks)

NIST TRACEABLE EQUIPMENT USED DURING CALIBRATION

MODEL: M-500

SERIAL #: 114512

CAL DUE: 07/28/11

MODEL:

SERIAL #:

CAL DUE:

Audio Response

CABLE LENGTH 5'

CONDITION: Sat

NEW BATTERIES: Yes No

BATTERY CHECK: Sat

HV (+/-10%)

AS FOUND HV

AS LEFT HV

500 V:

495

500

1250 V:

1225

1250

2000 V:

1975

2000

AF Threshold: 350

AL Threshold: A.F.

RATE CPM AS FOUND % ERROR AS LEFT % ERROR

RATE CPM	AS FOUND	% ERROR	AS LEFT	% ERROR
250	249	0.4%	A.F.	
2500	2498	0.1%	A.F.	
25K	24.983 K	0.1%	A.F.	
250K	249.868 K	0.1%	A.F.	

Is the As Found Data Within 2% of the Set Point?:

- Yes No

AF AL
 Detector #: 00 A.F.
 Detector Serial #: 351 A.F.
 Model #: BP19DD A.F.
 U: 7 A.F.
 M: 0 A.F.
 TB: 1 A.F.

AF AL
 HV: 850 975
 Window: Off A.F.
 Count Time (sec): 30 60
 Threshold: 350 A.F.
 Correction Constant: 1 A.F.
 Dead Time (uSec): 0.0 A.F.

REMARKS:

Does Instrument Meet Final Acceptance Criteria? Yes No

Calibration Sticker Attached? Yes No

Date Instrument is Due For Next Calibration: 09/07/11

INSTRUMENT MARRIED WITH BP19DD # 351

Performed/Reviewed by:

Joanne Glenn

Date: 9/7/2010

Entered by: *JG* Initials



GRIFFIN INSTRUMENTS



CALIBRATION CERTIFICATE FOR **BP19DD** PROBE # **351**

Owner: **PHILOTECHNICS**

DATE: **09/07/10**

LOCATION: **Griffin Inst**

Griffin Inst

TECH: **Joanne Glenn**

DATE LAST CAL EXPIRES: **09/02/10**

09/02/10

REASON FOR CALIBRATION:

- Due For Calibration
 Repair (See Remarks)
 Other (See Remarks)
 Due and Repair

CABLE LENGTH: **5'**

INPUT SENSITIVITY: **35 mV**

NIST TRACEABLE EQUIPMENT AND STANDARDS USED DURING CALIBRATION

MODEL: **2350-1** SERIAL #: **203439** CAL. DUE: **09/07/11**

NIST TRACEABLE SOURCES USED

Source Number	Isotope	4 pi Activity	Assay Date	2 pi Activity
00TC470-0654	Tc99 SS	17,300 dpm	06/15/09	10,600 cpm
2697-00	Sr90	12,200 dpm	03/01/00	8,530 cpm
PX 726	C14	48,780 dpm	01/21/08	18,660 cpm

Efficiencies from last cal.:

Condition: Sat Unsat

Pu: Th: Sr: **34.39%**

Tc ss: **16.91%** C14: **5.39%** Tc Ni:

As Found (AF) Efficiencies:

HV / Vernier:	Tc-99 Source Response Nickel (CPM):			Pu-239 Source Response (CPM):			Background (CPM):		Tc-99 Source Response Stainless Steel (CPM):		
	A ch.	B ch.	Net Eff.	A ch.	B ch.	Net Eff.	A ch.	B ch.	A ch.	B ch.	Net Eff.
850 / N/A								264		2908	15.28%

Net A to B Xtalk: <10%	B to A Xtalk: <1%
------------------------	-------------------

	Pu239	Tc99 Ni	Tc99 ss	Th-230	Sr90	C-14
AF CPM:	<input type="text"/>	<input type="text"/>	2908	<input type="text"/>	3510	2070
AF 4 pi eff:	<input type="text"/>	<input type="text"/>	15.28%	<input type="text"/>	34.26%	3.70%
AF 2 pi eff:	<input type="text"/>	<input type="text"/>	24.46%	<input type="text"/>	49.00%	9.68%

Is as found efficiency within 20% of the efficiency from the last cal? Yes No (See Remarks)

Note: If the as found data is within 10% of the last calibration and the B-A Xtalk is <1% and the A-B Xtalk is <10%, then the technician may N/A the plateau section and go directly to remarks.



GRIFFIN INSTRUMENTS



PROBE #: 351

Date: 09/07/10

PLATEAU AND SET POINT DATA

HV / Vernier:	Tc-99 Source Response SS (CPM):			Pu-239 Source Response (CPM):			Background (CPM):		Net A to B Xtalk: <10%	B to A Xtalk: <1%
	A ch.	B ch.	Net Eff.	A ch.	B ch.	Net Eff.	A ch.	B ch.		
850		2814	14.8%					262		
900		3244	17.1%					282		
950		3598	18.3%					433		
975		3890	19.2%					560		
1000								718		

Alpha / Beta Bkg (cpm)	560					
HV / Vernier	Pu-239	Tc-99 NI	Tc-99 SS	Th-230	C-14	Sr-90
975 / N/A	CPM:		3890		3854	4054
	4 pi AL Efficiencies:		19.25%		6.75%	36.88%
	2 pi AL Efficiencies:		30.83%		17.65%	52.74%

REMARKS: Probe fell off plateau. Cleaned film off mylar.

Does Instrument Meet Final Acceptance Criteria? Yes No

Calibration Sticker Attached? Yes No

Date Instrument is Due For Next Calibration: 09/07/11

INSTRUMENT MARRIED WITH 2350-1 # 203439

Performed/Reviewed by: *Jeanne Glass*

Date: 9/7/2010

Entered by: *JP* Initials

2 pi efficiencies denoted in Italics.

Calibrations performed to ANSI N323A-1997 standards.



**CALIBRATION
CERTIFICATE**

Duratek Instrument Services
628 Gallaher Road
Kingston, TN 37763
Phone: (865) 376-8337
Fax: (865) 376-8331

This Certificate will be accompanied by Calibration Charts or Readings where applicable

CUSTOMER INFORMATION		INSTRUMENT INFORMATION			
Customer Name: Philotechnics Ltd.		Manufacturer: Ludlum			
Address: 201 Renovare Blvd. Oak Ridge, TN 37830		Model: 2350-1	Serial Number: 203447		
Contact Name: Justin Button		Probe: N/A	Serial Number: N/A		
Customer Purchase Order Number: Credit Card	Work Order Number: 2010-10806	Calibration Method: Electronic			
INSTRUMENT CALIBRATION INFORMATION					
Instrument Range (CPM)	Calibration Standard Value (CPM)	Instrument Response ($\pm 10\%$)		Comments	
		Before Calibration	After Calibration	Calibrated in accordance with CP-IN-WI-239	
400	400	399	399	Pulser: 120935	Cal Due: 08/30/10
4,000	4,000	3,988	3,988	DVM: 88020324	Cal Due: 11/12/10
40,000	40,000	39,884	39,884	D-812: 2816	Cal Due: 09/02/10
400,000	400,000	398,733	398,733	Humidity: 992290	Cal Due: 02/17/11
HV Cal Values (M2350 HV Entry)	Desired HV Tolerance (Voltmeter) (VDC)	As Found (VDC)	As Left (VDC)	EPPROM Version: 37122N28	
500	(490-510)	502	497	Temp: 21.8°C	
1,500	(1,498-1,502)	1,513	1,500	Pressure: 743 mmHg	
2,000	(1,940-2,060)	2,014	1,997	Humidity: 41%	
Parameter	Tolerance ($\pm 10\%$)	As Found	As Left		
Threshold T = 100	10 \pm (9 to 11) mVDC	9.9	9.9	Geotropism: SAT	ACK/Scroll: SAT
Threshold T = 500	50 \pm (45 to 55) mVDC	46.5	46.5	BAT>4.5: SAT	Volume: SAT
Threshold T = 1000	100 \pm (90 to 110) mVDC	91	91	Count: SAT	Audio Divide: SAT
Window Width W = 100	10 \pm (9 to 11) mVDC	10	10	Alarms: SAT	Lamp: SAT
Display-to-mV ratio:	100 to 10 mV			Overload Test: SAT	Physical Cond: SAT
STATEMENT OF CERTIFICATION					
We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Institute of Standards and Technology. (We are not responsible for damage incurred during shipment or use of this instrument).					
Instrument					
Calibrated By:	<i>M. Pauli</i>	Reviewed By:	<i>Jeff D'Antonio</i>	Date:	7/1/10
Calibration Date: 07/01/2010			Certification Due: 07/01/2011		



**CALIBRATION
CERTIFICATE**

Duratek Instrument Services
628 Gallaher Road
Kingston, TN 37763
Phone: (865) 376-8337
Fax: (865) 376-8331

This Certificate will be accompanied by Calibration Charts or Readings where applicable

CUSTOMER INFORMATION				DETECTOR INFORMATION		
Customer Name: Philotechnics Ltd.				Manufacturer: NE Technology		
Address: 201 Renovare Blvd. Oak Ridge, TN 37830				Model: GP13A	Serial Number: 333	
Contact Name: Justin Button				Calibration Method:		
Contract Purchase Order Number: Credit Card		Work Order Number: 2010-10806		Source		
DETECTOR PARAMETER SETUPS						
Parameter	As Found	As Left	Parameter	As Found	As Left	Comments
Model	N/A	GP13A	CC	1.0	1.0	DVM: 88020324 Cal Due: 11/12/10
S/N	N/A	333	DT	0uSec	4uSec	D-812: 2816 Cal Due: 09/02/10
Units	7=counts	7=counts	Threshold	100=10mv	350=35mv	Humidity: 992290 Cal Due: 02/17/11
multiplier	0=auto	0=auto				
Time base	1=minutes	1=minutes				Temp: 21.8 °C Pressure: 743 mmHg
HV	N/A	820V				Humidity: 41%
Count time	10sec	60sec				**Detector specific parameters must be entered into instrument manually to be used with another 2350-1**
Saved as Detector #1						
INSTRUMENT INFORMATION						
<u>Model</u>		<u>Serial Number</u>		<u>Calibration Due Date</u>		
2350-1		203447		07/01/2011		
USED FOR EFFICIENCY DETERMINATION AND HV PLATEAUIING						
I ¹²⁹ #040202 at 95,682 DPM Certification Date: 04/13/99						
Background (CPM)	Gross Source Counts (CPM)	Net Source Counts (CPM)		Efficiency in % (Determined on contact)		
4,679	17,576	12,897		13.5% for I ¹²⁹		
Gross source counts taken from an average of three one minute counts from the Heel, Middle, and Toe of Detector						
COMMENTS						
Detectors set up with a 2350-1 may be used with any 2350-1 provided that the setup parameters are scanned into the 2350-1 prior to use with that specific detector and the threshold ratio is 100=10mV on the instrument						
STATEMENT OF CERTIFICATION						
We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Institute of Standards and Technology. (We are not responsible for damage incurred during shipment or use of this instrument).						
Instrument		Reviewed By:		Date:		
Calibrated By: <i>M. Pauli</i>		<i>J. D. ...</i>		7/11/10		
Calibration Date: 07/01/2010				Calibration Due: 07/01/2011		

NE Technology GP13A HIGH VOLTAGE PLATEAU DATA SHEET

Serial Number: 333

HIGH VOLTAGE	BACKGROUND (CPM)	SOURCE (CPM)
740	4,639	9,604
760	4,758	15,299
780	4,534	17,655
800	4,417	17,163
820 (SET)	4,621	17,682
840	4,648	17,965
860	4,831	18,341
880	4,833	18,431
900	4,882	18,153
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

Plateau performed with I¹²⁹ Source # 040202 at 95,682 dpm at center of detector

Performed By: M. Pauli

Date: 7-1-10



**CALIBRATION
CERTIFICATE**

Duratek Instrument Services
628 Gallaher Road
Kingston, TN 37763
Phone: (865) 376-8337
Fax: (865) 376-8331

This Certificate will be accompanied by Calibration Charts or Readings where applicable

CUSTOMER INFORMATION		INSTRUMENT INFORMATION			
Customer Name: Philotechnics Ltd.		Manufacturer: Ludlum			
Address: 201 Renovare Blvd. Oak Ridge, TN 37830		Model: 2350-1	Serial Number: 246986		
Contact Name: Justin Button		Probe: N/A	Serial Number: N/A		
Customer Purchase Order Number: Credit Card	Work Order Number: 2010-10806	Calibration Method: Electronic			
INSTRUMENT CALIBRATION INFORMATION					
Instrument Range (CPM)	Calibration Standard Value (CPM)	Instrument Response ($\pm 10\%$)		Comments	
		Before Calibration	After Calibration		
400	400	402	402	Pulser: 120935 Cal Due: 08/30/10	
4,000	4,000	3,994	3,994	DVM: 88020324 Cal Due: 11/12/10	
40,000	40,000	39,929	39,929	D-812: 2816 Cal Due: 09/02/10	
400,000	400,000	399,167	399,167	Humidity: 992290 Cal Due: 02/17/11	
HV Cal Values (M2350 HV Entry)	Desired HV Tolerance (Voltmeter) (VDC)	As Found (VDC)	As Left (VDC)	EPPROM Version: 37122N28	
500	(490-510)	503	500	Temp:	21.8° C
1,500	(1,498-1,502)	1,514	1,500	Pressure:	743 mmHg
2,000	(1,940-2,060)	2,016	1,998	Humidity:	41%
Parameter	Tolerance ($\pm 10\%$)	As Found	As Left		
Threshold T = 100	10 \pm (9 to 11) mVDC	10.2	10.2	Geotropism: SAT	ACK/Scroll: SAT
Threshold T = 500	50 \pm (45 to 55) mVDC	48.7	48.7	BAT>4.5: SAT	Volume: SAT
Threshold T = 1000	100 \pm (90 to 110) mVDC	97	97	Count: SAT	Audio Divide: SAT
Window Width W = 100	10 \pm (9 to 11) mVDC	10	10	Alarms: SAT	Lamp: SAT
Display-to-mV ratio:	100 to 10 mV			Overload Test: SAT	Physical Cond: SAT
STATEMENT OF CERTIFICATION					
We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Institute of Standards and Technology. (We are not responsible for damage incurred during shipment or use of this instrument).					
Instrument		Reviewed By: <i>Jeff DeBarnis</i>		Date: 7/1/10	
Calibrated By: <i>M. Paul</i>					
Calibration Date: 07/01/2010			Certification Due: 07/01/2011		



**CALIBRATION
CERTIFICATE**

Duratek Instrument Services
628 Gallaher Road
Kingston, TN 37763
Phone: (865) 376-8337
Fax: (865) 376-8331

This Certificate will be accompanied by Calibration Charts or Readings where applicable

CUSTOMER INFORMATION				DETECTOR INFORMATION			
Customer Name: Philotechnics Ltd.				Manufacturer: NE Technology			
Address: 201 Renovare Blvd. Oak Ridge, TN 37830				Model: GP13A		Serial Number: 334	
Contact Name: Justin Button				Calibration Method: Source			
Contract Purchase Order Number: Credit Card		Work Order Number: 2010-10806					
DETECTOR PARAMETER SETUPS							
Parameter	As Found	As Left	Parameter	As Found	As Left	Comments	
Model	GP13A	GP13A	CC	1.0	1.0	DVM: 88020324 Cal Due: 11/12/10	
S/N	334	334	DT	0uSec	4uSec	D-812: 2816 Cal Due: 09/02/10	
Units	7=counts	7=counts	Threshold	350=35mv	350=35mv	Humidity: 992290 Cal Due: 02/17/11	
multiplier	0=auto	0=auto					
Time base	1=minutes	1=minutes				Temp: 21.8 °C Pressure: 743 mmHg	
HV	1240V	1140V				Humidity: 41%	
Count time	60sec	60sec				**Detector specific parameters must be entered into instrument manually to be used with another 2350-1**	
Saved as Detector #1							
INSTRUMENT INFORMATION							
<u>Model</u>		<u>Serial Number</u>		<u>Calibration Due Date</u>			
2350-1		246986		07/01/2011			
USED FOR EFFICIENCY DETERMINATION AND HV PLATEAUING							
I ¹²⁹ #040202 at 95,682 DPM Certification Date: 04/13/99							
<u>Background (CPM)</u>	<u>Gross Source Counts (CPM)</u>	<u>Net Source Counts (CPM)</u>	<u>Efficiency in % (Determined on contact)</u>				
5,658	17,784	12,126	12.7% for I ¹²⁹				
Gross source counts taken from an average of three one minute counts from the Heel, Middle, and Toe of Detector							
COMMENTS							
Detectors set up with a 2350-1 may be used with any 2350-1 provided that the setup parameters are scanned into the 2350-1 prior to use with that specific detector and the threshold ratio is 100=10mV on the instrument							
STATEMENT OF CERTIFICATION							
We Certify that the instrument listed above was calibrated and inspected prior to shipment and that it met all the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Institute of Standards and Technology. (We are not responsible for damage incurred during shipment or use of this instrument).							
Instrument							
Calibrated By: <i>M. Paul</i>		Reviewed By: <i>Jeff Robinson</i>		Date: 7/1/10			
Calibration Date: 07/01/2010				Calibration Due: 07/01/2011			

NE Technology GP13A HIGH VOLTAGE PLATEAU DATA SHEET

Serial Number: 334

HIGH VOLTAGE	BACKGROUND (CPM)	SOURCE (CPM)
1020	3,552	12,593
1040	3,643	14,351
1060	3,970	15,646
1080	4,151	16,635
1100	4,211	17,112
1120	4,466	17,942
1140 (SET)	4,712	18,261
1160	5,018	20,514
1180	8,190	22,155
1200	9,424	20,638
1220	6,901	21,361
1240	7,715	24,226
1260	9,992	26,438
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

Plateau performed with I^{129} Source # 040202 at 95,682 dpm at center of detector

Performed By: M. Paul

Date: 7-1-10

APPENDIX D
MARSSIM Analytical Calculation
Sheets

Philotechnics Analytical Worksheet

Appendix D

Minimum Detectable Concentration (MDC) Static Count

Calculations for Liquid Scintillation Counter

(95% confidence level via NUREG 1507 method)

$$MDC (dpm/100cm^2) = \frac{3 + 3.29\sqrt{(R_b)(T_{s+b})(1 + T_{s+b}/T_b)}}{(Eff.)(T_{s+b})} \quad (\text{Eq. 1})$$

Where:

- Eff. = LSC total efficiency, Counter cpm/NIST Standard dpm
- R_b = LSC background rate (cpm)
- T_{s+b} = Sample count time (minutes)
- T_b = Background count time (minutes)

Static Count MDC Calculations					
Nuclide	Eff.	R _b	T _{s+b}	T _b	MDC (Static)
H-3	62.8%	15.5	1	1	33.9 dpm/100 cm ²
C-14	96.8%	9.5	1	1	17.9 dpm/100 cm ²

Minimum Detectable Concentration (MDC) Static Count

Calculations for Planchet Counter

(95% confidence level via NUREG 1507 method)

$$MDC (dpm/100cm^2) = \frac{3 + 3.29\sqrt{(R_b)(T_{s+b})(1 + T_{s+b}/T_b)}}{(Eff.)(T_{s+b})} \quad (\text{Eq. 1})$$

Where:

- Eff. = Planchet total efficiency {4π efficiency}
- R_b = Planchet background rate (cpm)
- T_{s+b} = Sample count time (minutes)
- T_b = Background count time (minutes)

Static Count MDC Calculations						
Ludlum 3030 Meter: 242683 w/43-10-1 Probe						
Meter	Nuclide	Total Eff.	R _b	T _{s+b}	T _b	MDC (Static)
3030	Pu-239	39.49%	0.8	1	1	18.1 dpm/100 cm ²
3030	Sr-90	46.56%	56.4	1	1	81.5 dpm/100 cm ²

Philotechnics Analytical Worksheet

Appendix D

Minimum Detectable Concentration (MDC) Static Count

Calculations for Hand-Held Monitors

(95% confidence level via NUREG 1507 method)

$$MDC (dpm/100cm^2) = \frac{3 + 3.29 \sqrt{(R_b)(T_{s+b})(1 + T_{s+b}/T_b)}}{(Eff.)(T_{s+b})(probeareacm^2/100cm^2)} \quad (Eq. 2)$$

Where:

Total Eff. = Total Efficiency (2pi efficiency * 0.25 per ISO 7503-1)

R_b = Average background rate (cpm)

T_{s+b} = Sample count time (minutes)

T_b = Background count time (minutes)

P = Probe area (cm²)

Static Count MDC Calculations						
<i>Meter: 212233 w/BP19DD Probe (Hand Held Beta)</i>						
Nuclide	Total Eff.	R _b	T _{s+b}	T _b	P	MDC (Static)
C-14	5.37%	337.2	1	1	100	1646.9 dpm/100 cm ²
C-14	5.37%	327.3	1	1	100	1623.4 dpm/100 cm ²
C-14	5.37%	368.1	1	1	100	1718.2 dpm/100 cm ²
C-14	5.37%	322.7	1	1	100	1612.3 dpm/100 cm ²
<i>Meter: 203439 w/BP19DD Probe (Hand Held Beta)</i>						
Nuclide	Total Eff.	R _b	T _{s+b}	T _b	P	MDC (Static)
C-14	4.41%	478.3	1	1	100	2375.4 dpm/100 cm ²
C-14	4.41%	482.9	1	1	100	2386.5 dpm/100 cm ²
C-14	4.41%	579.6	1	1	100	2608.0 dpm/100 cm ²
C-14	4.41%	431.2	1	1	100	2258.9 dpm/100 cm ²
<i>Meter: 212233 w/43-68 Probe (Hand Held Alpha)</i>						
Nuclide	Total Eff.	R _b	T _{s+b}	T _b	P	MDC (Static)
Pu-239	12.43%	0.4	1	1	100	47.8 dpm/100 cm ²
Pu-239	12.43%	0.8	1	1	100	57.6 dpm/100 cm ²
Pu-239	12.43%	1.0	1	1	100	61.6 dpm/100 cm ²
Pu-239	12.43%	0.6	1	1	100	53.1 dpm/100 cm ²
<i>Meter: 203447 w/GP13A Probe (Hand Held Gamma)</i>						
Nuclide	Total Eff.	R _b	T _{s+b}	T _b	P	MDC (Static)
I-125	25.11%	4225.9	1	1	100	1216.5 dpm/100 cm ²
I-125	25.11%	4256.3	1	1	100	1220.8 dpm/100 cm ²
I-125	25.11%	4338.0	1	1	100	1232.4 dpm/100 cm ²
I-125	25.11%	2908.0	1	1	100	1011.2 dpm/100 cm ²
<i>Meter: 246986 w/GP13A Probe (Hand Held Gamma)</i>						
Nuclide	Total Eff.	R _b	T _{s+b}	T _b	P	MDC (Static)
I-125	23.62%	3965.6	1	1	100	1253.2 dpm/100 cm ²
I-125	23.62%	4340.1	1	1	100	1310.4 dpm/100 cm ²
I-125	23.62%	4743.9	1	1	100	1369.4 dpm/100 cm ²
I-125	23.62%	3658.1	1	1	100	1204.1 dpm/100 cm ²

Philotechnics Analytical Worksheet

Appendix D

Scan Minimum Detectable Concentration (MDC) Calculations for Hand-Held Monitors

(Scan MDA per NUREG-1575, NUREG-1507 methodology)

$$\text{Scan MDC} = \frac{\text{MDCR}}{\sqrt{p} (\epsilon_i)(\epsilon_s) \left(\frac{A}{100\text{cm}^2} \right)} \quad (\text{Eq. 3})$$

Where:

- p = surveyor efficiency, per NUREG 1507 (0.5)
 ϵ_i = total efficiency (2π geometry)
 ϵ_s = surface efficiency, 0.5 for gammas and high energy betas >1 MeV E_{max}
 (e.g. P-32, Cl-36, S/Y-90, etc.), 0.25 for low energy betas
 (e.g. C-14, P-33, S-35, Tc-99, Ca-45, etc.)
 A = probe active area (cm^2)

And,

$$\text{MDCR} = S_i (60 \text{ sec / min}) / i \text{ sec} \quad (\text{Eq. 4})$$

Where:

- MDCR = Minimum detectable count rate (cpm)
 S_i = source counts in time interval, i .

And,

$$S_i = d' \sqrt{B_i} \quad (\text{Eq. 5})$$

Where:

- d' = 1.38 for 95% true positive scan detection rate,
 per, NUREG 1507, Table 6.1
 B_i = Background counts in interval, i

And,

$$B_i = (P_b)(i)(1 \text{ min} / 60 \text{ sec}) \quad (\text{Eq. 6})$$

Where:

- P_b = probe background count rate (cpm)
 i = observation interval

Philotechnics Analytical Worksheet

Scan Minimum Detectable Concentration (MDC)

Calculations for Hand-Held Monitors

(Scan MDA per NUREG-1575, NUREG-1507 methodology)

Specific Scan MDC calculation results:

#212233	Ambient	Dywall	Floor	Metal	
$P_b =$	337.2	327.3	368.1	322.7	cpm
$i =$	1.34	1.34	1.34	1.34	sec
$B_i =$	7.53	7.31	8.22	7.21	counts
$d' =$	1.38	1.38	1.38	1.38	
$S_i =$	3.79	3.73	3.96	3.70	counts
MDCR =	169.6	167.1	177.2	165.9	cpm

#203439	Ambient	Drywall	Floor	Metal	
$P_b =$	478.3	482.9	579.6	431.2	cpm
$i =$	1.34	1.34	1.34	1.34	sec
$B_i =$	10.68	10.78	12.94	9.63	counts
$d' =$	1.38	1.38	1.38	1.38	
$S_i =$	4.51	4.53	4.97	4.28	counts
MDCR =	202.0	202.9	222.3	191.8	cpm

#212233	Ambient	Dywall	Floor	Metal	
$P_b =$	0.4	0.8	1.0	0.6	cpm
$i =$	1.34	1.34	1.34	1.34	sec
$B_i =$	0.01	0.02	0.02	0.01	counts
$d' =$	1.38	1.38	1.38	1.38	
$S_i =$	0.13	0.18	0.21	0.16	counts
MDCR =	5.8	8.3	9.2	7.2	cpm

#203447	Ambient	Dywall	Floor	Metal	
$P_b =$	4225.9	4256.3	4338.0	2908.0	cpm
$i =$	1.34	1.34	1.34	1.34	sec
$B_i =$	94.38	95.06	96.88	64.95	counts
$d' =$	1.38	1.38	1.38	1.38	
$S_i =$	13.41	13.45	13.58	11.12	counts
MDCR =	600.3	602.4	608.2	498.0	cpm

#246986	Ambient	Dywall	Floor	Metal	
$P_b =$	3965.6	4340.1	4743.9	3658.1	cpm
$i =$	1.34	1.34	1.34	1.34	sec
$B_i =$	88.57	96.93	105.95	81.70	counts
$d' =$	1.38	1.38	1.38	1.38	
$S_i =$	12.99	13.59	14.20	12.47	counts
MDCR =	581.5	608.3	636.0	558.5	cpm

Philotechnics Analytical Worksheet

Appendix D

Scan MDC Calculations			
<i>Meter: 212233 (Hand Held Beta)</i>			
Nuclide	Total Efficiency	Area	MDC (Scan)
C-14	5.37%	100	4465.7 dpm/100 cm ²
C-14	5.37%	100	4399.6 dpm/100 cm ²
C-14	5.37%	100	4665.8 dpm/100 cm ²
C-14	5.37%	100	4368.6 dpm/100 cm ²
<i>Meter: 203439 (Hand Held Beta)</i>			
Nuclide	Total Efficiency	Area	MDC (Scan)
C-14	4.41%	100	6476.3 dpm/100 cm ²
C-14	4.41%	100	6507.4 dpm/100 cm ²
C-14	4.41%	100	7129.2 dpm/100 cm ²
C-14	4.41%	100	6149.2 dpm/100 cm ²
<i>Meter: 212233 (Hand Held Alpha)</i>			
Nuclide	Total Efficiency	Area	MDC (Scan)
Pu-239	12.43%	100	66.4 dpm/100 cm ²
Pu-239	12.43%	100	94.0 dpm/100 cm ²
Pu-239	12.43%	100	105.1 dpm/100 cm ²
Pu-239	12.43%	100	81.4 dpm/100 cm ²
<i>Meter: 203447 (Hand Held Gamma)</i>			
Nuclide	Total Efficiency	Area	MDC (Scan)
I-125	25.11%	100	3380.9 dpm/100 cm ²
I-125	25.11%	100	3393.0 dpm/100 cm ²
I-125	25.11%	100	3425.4 dpm/100 cm ²
I-125	25.11%	100	2804.6 dpm/100 cm ²
<i>Meter: 246986 (Hand Held Gamma)</i>			
Nuclide	Total Efficiency	Area	MDC (Scan)
I-125	23.62%	100	3481.7 dpm/100 cm ²
I-125	23.62%	100	3642.4 dpm/100 cm ²
I-125	23.62%	100	3808.1 dpm/100 cm ²
I-125	23.62%	100	3344.0 dpm/100 cm ²

APPENDIX E
Background Documentation

Philotechnics Analytical Worksheet

Background Documentation

Fail Levels

Ld, system detection limit is the net count having 95% probability of being detected when a survey sample point contains activity at Ld, which translates to a 5% probability of falsely interpreting sample activity as activity due to background (NUREG-1507 Table 3-8)

$$L_d (cpm) = 3 + 4.65\sqrt{B} \tag{Eq. 7}$$

Fail Level CPM = Bkg cpm + Ld cpm

Fail Level Calculations (Static) #212233 Beta				
Probe	Surface	Bkg	Ld (cpm)	Fail Level (cpm)
BP19DD	Ambient	337.2	88.4	425.6
BP19DD	Drywall	327.3	87.1	414.4
BP19DD	Floor	368.1	92.2	460.3
BP19DD	Metal	322.7	86.5	409.2

Fail Level Calculations (Static) #203439 Beta				
Probe	Surface	Bkg	Ld (cpm)	Fail Level (cpm)
BP19DD	Ambient	478.3	104.7	583.0
BP19DD	Drywall	482.9	105.2	588.1
BP19DD	Floor	579.6	114.9	694.5
BP19DD	Metal	431.2	99.6	530.8

Fail Level Calculations (Static) #212233 Alpha				
Probe	Surface	Bkg	Ld (cpm)	Fail Level (cpm)
43-68	Ambient	0.4	5.9	6.3
43-68	Drywall	0.8	7.2	8.0
43-68	Floor	1.0	7.7	8.7
43-68	Metal	0.6	6.6	7.2

Fail Level Calculations (Static) #203447 Gamma				
Probe	Surface	Bkg	Ld (cpm)	Fail Level (cpm)
GP13A	Ambient	4225.9	305.3	4531.2
GP13A	Drywall	4256.3	306.4	4562.7
GP13A	Floor	4338.0	309.3	4647.3
GP13A	Metal	2908.0	253.8	3161.8

Fail Level Calculations (Static) #246986 Gamma				
Probe	Surface	Bkg	Ld (cpm)	Fail Level (cpm)
GP13A	Ambient	3965.6	295.8	4261.4
GP13A	Drywall	4340.1	309.3	4649.4
GP13A	Floor	4743.9	323.3	5067.2
GP13A	Metal	3658.1	284.2	3942.3

Philotechnics Analytical Worksheet

Background Data

Ludlum 2350-1 with BP19DD probe #212233 (Hand Held Beta Probe)					
Surface	Counts (cpm)				
Ambient	335	346	306	308	356
	346	336	341	343	355

Average: 337.2 cpm

Surface	Counts (cpm)				
Drywall	345	323	335	326	333
	325	314	302	339	331

Average: 327.3 cpm

Surface	Counts (cpm)				
Floor	340	399	368	372	358
	374	380	371	366	353

Average: 368.1 cpm

Surface	Counts (cpm)				
Metal	327	322	353	322	302
	306	316	338	326	315

Average: 322.7 cpm

Ludlum 2350-1 with BP19DD probe #203439 (Hand Held Beta Probe)					
Surface	Counts (cpm)				
Ambient	452	495	498	458	546
	443	450	469	474	498

Average: 478.3 cpm

Surface	Counts (cpm)				
Drywall	480	453	459	487	459
	495	517	495	477	507

Average: 482.9 cpm

Surface	Counts (cpm)				
Floor	592	590	566	581	592
	564	582	573	571	585

Average: 579.6 cpm

Surface	Counts (cpm)				
Metal	402	421	431	428	441
	436	429	448	437	439

Average: 431.2 cpm

Philotechnics Analytical Worksheet

Ludlum 2350-1 with 43-68 probe #PR142542 (Hand Held Alpha Probe)					
Surface	Counts (cpm)				
Ambient	0	1	1	0	0
	1	1	0	0	0

Average: 0.4 cpm

Surface	Counts (cpm)				
Drywall	0	1	1	0	1
	1	0	1	1	2

Average: 0.8 cpm

Surface	Counts (cpm)				
Floor	2	1	1	1	2
	0	2	1	0	0

Average: 1.0 cpm

Surface	Counts (cpm)				
Metal	0	1	1	1	1
	1	0	0	0	1

Average: 0.6 cpm

Ludlum 2350-1 with GP13A probe #203447 (Hand Held Gamma Probe)					
Surface	Counts (cpm)				
Ambient	4226	4123	4215	4123	4198
	4066	4259	4366	4244	4439

Average: 4225.9 cpm

Surface	Counts (cpm)				
Drywall	4108	4370	4141	4336	4207
	4297	4327	4191	4357	4229

Average: 4256.3 cpm

Surface	Counts (cpm)				
Floor	4319	4276	4316	4276	4401
	4302	4259	4484	4398	4349

Average: 4338.0 cpm

Surface	Counts (cpm)				
Metal	2824	2943	2745	2849	3065
	2841	2896	3084	2929	2904

Average: 2908.0 cpm

Philotechnics Analytical Worksheet

Appendix E

Ludlum 2350-1 with GP13A probe #246986 (Hand Held Gamma Probe)					
Surface	Counts (cpm)				
Ambient	4437	4068	4035	3910	3998
	3698	3951	3878	3857	3824

Average: 3965.6 cpm

Surface	Counts (cpm)				
Drywall	4518	4501	4400	4143	4315
	4342	4380	4187	4353	4262

Average: 4340.1 cpm

Surface	Counts (cpm)				
Floor	4725	4722	4754	4693	4812
	4734	4785	4734	4785	4695

Average: 4743.9 cpm

Surface	Counts (cpm)				
Metal	3430	3728	3608	3634	3690
	3685	3632	3807	3614	3753

Average: 3658.1 cpm

Planchet Counter 3030 - Serial #242683		
Surface	Counts (cpm)	
Ambient (Alpha)	One 10 minute count	8
Ambient (Beta)	One 10 minute count	564

Average: Alpha 0.8 cpm Beta 56.4 cpm

		Scintillation Counter Counts (cpm)		
Sample	Time	Chan A (cpm)	Chan B (cpm)	Chan C (cpm)
1	1 min.	17	8	48
2	1 min.	22	11	51
3	1 min.	14	8	37
4	1 min.	15	9	35
5	1 min.	17	6	36
6	1 min.	10	14	39
7	1 min.	20	10	45
8	1 min.	14	13	43
9	1 min.	10	7	31
10	1 min.	16	9	41

Average: 15.5 9.5 40.6

APPENDIX F
*Static Measurement Data Sheets and
DPM Calculations*

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Static Measurements

Survey Unit 1 Rooms A008, A009, A010		Beta 212233		Gamma 203447	
Surface		Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient	A	337.2	1646.9	4225.9	1216.5
Drywall	D	327.3	1623.4	4256.3	1220.8
Floor	F	368.1	1718.2	4338.0	1232.4
Metal	M	322.7	1612.3	2908.0	1011.2
Beta Meter Efficiency		5.37%			
Gamma Meter Efficiency		25.11%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	350	-18	-337	±	36	4159	-179	-713	±	52	<DCGL
2	F	341	-27	-505	±	44	4386	48	191	±	27	<DCGL
3	F	396	28	520	±	45	4634	296	1179	±	67	<DCGL
4	F	360	-8	-151	±	24	4608	270	1075	±	64	<DCGL
5	F	352	-16	-300	±	34	4396	58	231	±	30	<DCGL
6	F	328	-40	-747	±	54	4077	-261	-1039	±	63	<DCGL
7	D	313	-14	-266	±	32	3910	-346	-1379	±	73	<DCGL
8	D	324	-3	-61	±	15	4227	-29	-117	±	21	<DCGL
9	D	313	-14	-266	±	32	4449	193	767	±	54	<DCGL
10	D	339	12	218	±	29	4148	-108	-431	±	41	<DCGL
11	D	327	0	-6	±	5	4576	320	1273	±	70	<DCGL
12	D	345	18	330	±	36	4146	-110	-439	±	41	<DCGL
13	D	331	4	69	±	16	4251	-5	-21	±	9	<DCGL
14	D	315	-12	-229	±	30	4509	253	1006	±	62	<DCGL
15	F	362	-6	-114	±	21	4403	65	259	±	32	<DCGL
16	F	373	5	91	±	19	4209	-129	-514	±	44	<DCGL
17	F	365	-3	-58	±	15	4161	-177	-705	±	52	<DCGL
18	F	364	-4	-76	±	17	3957	-381	-1517	±	76	<DCGL
19	F	338	-30	-561	±	46	4274	-64	-255	±	31	<DCGL
20	F	322	-46	-858	±	57	4286	-52	-207	±	28	<DCGL
21	F	395	27	501	±	44	4367	29	115	±	21	<DCGL
22	F	386	18	333	±	36	4087	-251	-1000	±	62	<DCGL
23	D	306	-21	-397	±	39	4083	-173	-690	±	51	<DCGL
24	D	345	18	330	±	36	3969	-287	-1144	±	66	<DCGL
25	D	306	-21	-397	±	39	4042	-214	-853	±	57	<DCGL
26	D	329	2	32	±	11	4037	-219	-873	±	58	<DCGL
27	D	354	27	497	±	44	4001	-255	-1017	±	62	<DCGL
28	D	343	16	292	±	34	4895	639	2544	±	99	<DCGL
29	D	407	80	1484	±	76	5236	980	3902	±	122	<DCGL
30	D	357	30	553	±	46	5173	917	3651	±	118	<DCGL
31	D	378	51	944	±	60	5148	892	3551	±	117	<DCGL
32	D	312	-15	-285	±	33	4142	-114	-455	±	42	<DCGL
33	A	415	78	1449	±	75	3938	-288	-1147	±	66	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 2 Room A05A		Beta 212233		Gamma 203447	
Surface		Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient	A	337.2	1646.9	4225.9	1216.5
Drywall	D	327.3	1623.4	4256.3	1220.8
Floor	F	368.1	1718.2	4338.0	1232.4
Metal	M	322.7	1612.3	2908.0	1011.2
Beta Meter Efficiency		5.37%			
Gamma Meter Efficiency		25.11%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	M	341	18	341	±	36	3378	470	1872	±	85	<DCGL
2	M	368	45	844	±	57	4141	1233	4910	±	137	<DCGL
3	M	358	35	657	±	50	3325	417	1661	±	80	<DCGL
4	F	388	20	371	±	38	4249	-89	-354	±	37	<DCGL
5	F	362	-6	-114	±	21	4361	23	92	±	19	<DCGL
6	M	313	-10	-181	±	26	3187	279	1111	±	65	<DCGL
7	M	359	36	676	±	51	2542	-366	-1458	±	75	<DCGL
8	F	361	-7	-132	±	23	3974	-364	-1450	±	75	<DCGL
9	F	358	-10	-188	±	27	4029	-309	-1231	±	69	<DCGL
10	F	388	20	371	±	38	4119	-219	-872	±	58	<DCGL
11	F	378	10	184	±	27	4060	-278	-1107	±	65	<DCGL
12	F	351	-17	-318	±	35	4181	-157	-625	±	49	<DCGL
13	M	301	-22	-404	±	39	2941	33	131	±	22	<DCGL
14	M	324	1	24	±	10	2767	-141	-562	±	46	<DCGL
15	F	378	10	184	±	27	3450	-888	-3536	±	117	<DCGL
16	M	312	-11	-199	±	28	3069	161	641	±	50	<DCGL
17	M	304	-19	-348	±	37	2963	55	219	±	29	<DCGL
18	M	298	-25	-460	±	42	2631	-277	-1103	±	65	<DCGL
19	M	319	-4	-69	±	16	3394	486	1935	±	86	<DCGL
20	M	293	-30	-553	±	46	3671	763	3039	±	108	<DCGL
21	M	313	-10	-181	±	26	3114	206	820	±	56	<DCGL
22	M	312	-11	-199	±	28	3340	432	1720	±	81	<DCGL
23	M	325	2	43	±	13	3676	768	3059	±	108	<DCGL
24	M	301	-22	-404	±	39	3272	364	1450	±	75	<DCGL
25	M	305	-18	-330	±	36	2934	26	104	±	20	<DCGL
26	M	304	-19	-348	±	37	2568	-340	-1354	±	72	<DCGL
27	M	314	-9	-162	±	25	2414	-494	-1967	±	87	<DCGL
28	M	350	27	508	±	44	2890	-18	-72	±	17	<DCGL
29	M	332	9	173	±	26	3612	704	2804	±	104	<DCGL
30	M	328	5	99	±	19	3538	630	2509	±	98	<DCGL
31	M	314	-9	-162	±	25	3187	279	1111	±	65	<DCGL
32	M	305	-18	-330	±	36	2725	-183	-729	±	53	<DCGL
33	M	341	18	341	±	36	4152	1244	4954	±	138	<DCGL
34	M	304	-19	-348	±	37	3869	961	3827	±	121	<DCGL
35	M	287	-36	-665	±	51	2903	-5	-20	±	9	<DCGL
36	M	301	-22	-404	±	39	2900	-8	-32	±	11	<DCGL
37	M	324	1	24	±	10	2813	-95	-378	±	38	<DCGL
38	M	315	-8	-143	±	23	2615	-293	-1167	±	67	<DCGL
39	M	319	-4	-69	±	16	2716	-192	-765	±	54	<DCGL
40	M	316	-7	-125	±	22	2463	-445	-1772	±	83	<DCGL
41	M	296	-27	-497	±	44	3556	648	2581	±	100	<DCGL
42	M	325	2	43	±	13	2970	62	247	±	31	<DCGL
43	M	374	51	955	±	61	2643	-265	-1055	±	64	<DCGL
44	M	346	23	434	±	41	2665	-243	-968	±	61	<DCGL
45	M	351	28	527	±	45	2701	-207	-824	±	56	<DCGL
46	A	346	9	164	±	25	3209	-1017	-4050	±	125	<DCGL
47	A	331	-6	-115	±	21	3140	-1086	-4325	±	129	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 3		Beta 203439		Gamma 246986	
Room A05		Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient	A	478.3	2375.4	3965.6	1253.2
Drywall	D	482.9	2386.5	4340.1	1310.4
Floor	F	579.6	2608.0	4743.9	1369.4
Metal	M	431.2	2258.9	3658.1	1204.1
Beta Meter Efficiency		4.41%			
Gamma Meter Efficiency		23.62%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	638	58	1324	±	71	4525	-219	-927	±	60	<DCGL
2	F	664	84	1914	±	86	4305	-439	-1858	±	84	<DCGL
3	F	590	10	236	±	30	3978	-766	-3243	±	112	<DCGL
4	F	503	-77	-1737	±	82	4129	-615	-2603	±	100	<DCGL
5	F	525	-55	-1238	±	69	4380	-364	-1541	±	77	<DCGL
6	F	497	-83	-1873	±	85	4431	-313	-1325	±	71	<DCGL
7	F	513	-67	-1510	±	76	4511	-233	-986	±	62	<DCGL
8	F	516	-64	-1442	±	74	4132	-612	-2591	±	100	<DCGL
9	F	573	-7	-150	±	24	4304	-440	-1862	±	85	<DCGL
10	D	459	-24	-542	±	46	4098	-242	-1025	±	63	<DCGL
11	D	471	-12	-270	±	32	3491	-849	-3595	±	118	<DCGL
12	D	475	-8	-179	±	26	3812	-528	-2236	±	93	<DCGL
13	D	470	-13	-293	±	34	3667	-673	-2850	±	105	<DCGL
14	D	457	-26	-587	±	47	3812	-528	-2236	±	93	<DCGL
15	D	458	-25	-565	±	47	3917	-423	-1791	±	83	<DCGL
16	D	430	-53	-1200	±	68	4584	244	1033	±	63	<DCGL
17	D	462	-21	-474	±	43	4377	37	156	±	24	<DCGL
18	D	451	-32	-723	±	53	4394	54	228	±	30	<DCGL
19	D	462	-21	-474	±	43	4820	480	2032	±	88	<DCGL
20	D	460	-23	-519	±	45	4473	133	563	±	46	<DCGL
21	D	522	39	887	±	58	4387	47	199	±	28	<DCGL
22	D	572	89	2020	±	88	4572	232	982	±	61	<DCGL
23	D	573	90	2043	±	89	4365	25	105	±	20	<DCGL
24	D	557	74	1680	±	80	4423	83	351	±	37	<DCGL
25	D	492	9	206	±	28	4724	384	1625	±	79	<DCGL
26	D	537	54	1227	±	69	4684	344	1456	±	75	<DCGL
27	D	531	48	1091	±	65	4701	361	1528	±	77	<DCGL
28	D	508	25	569	±	47	4661	321	1359	±	72	<DCGL
29	D	522	39	887	±	58	4719	379	1604	±	79	<DCGL
30	D	538	55	1249	±	69	3769	-571	-2418	±	96	<DCGL
31	D	630	147	3336	±	113	4099	-241	-1021	±	63	<DCGL
32	D	553	70	1590	±	78	4184	-156	-661	±	50	<DCGL
33	D	540	57	1295	±	71	3913	-427	-1808	±	83	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 4 Room A04 Cold Room		Beta 203439		Gamma 246986	
Surface		Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient	A	478.3	2375.4	3965.6	1253.2
Drywall	D	482.9	2386.5	4340.1	1310.4
Floor	F	579.6	2608.0	4743.9	1369.4
Metal	M	431.2	2258.9	3658.1	1204.1
Beta Meter Efficiency		4.41%			
Gamma Meter Efficiency		23.62%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	705	125	2844	±	105	4574	-170	-719	±	53	<DCGL
2	F	637	57	1302	±	71	4831	87	369	±	38	<DCGL
3	D	518	35	796	±	55	4057	-283	-1199	±	68	<DCGL
4	D	608	125	2837	±	104	4542	202	855	±	57	<DCGL
5	F	568	-12	-263	±	32	3891	-853	-3611	±	118	<DCGL
6	D	539	56	1272	±	70	3967	-373	-1580	±	78	<DCGL
7	D	529	46	1045	±	63	4125	-215	-911	±	59	<DCGL
8	F	552	-28	-626	±	49	4000	-744	-3149	±	110	<DCGL
9	D	629	146	3313	±	113	4640	300	1270	±	70	<DCGL
10	D	553	70	1590	±	78	4345	5	21	±	9	<DCGL
11	D	544	61	1385	±	73	4497	157	664	±	51	<DCGL
12	D	566	83	1884	±	85	4385	45	190	±	27	<DCGL
13	D	409	-74	-1676	±	80	4289	-51	-216	±	29	<DCGL
14	D	447	-36	-814	±	56	4318	-22	-94	±	19	<DCGL
15	D	503	20	456	±	42	4433	93	393	±	39	<DCGL
16	D	556	73	1658	±	80	4707	367	1553	±	77	<DCGL
17	D	480	-3	-66	±	16	4790	450	1905	±	86	<DCGL
18	D	430	-53	-1200	±	68	4250	-90	-381	±	38	<DCGL
19	D	531	48	1091	±	65	4556	216	914	±	59	<DCGL
20	D	451	-32	-723	±	53	4409	69	292	±	33	<DCGL
21	D	489	6	138	±	23	4606	266	1126	±	66	<DCGL
22	D	470	-13	-293	±	34	4346	6	25	±	10	<DCGL
23	D	459	-24	-542	±	46	3628	-712	-3015	±	108	<DCGL
24	D	524	41	932	±	60	4683	343	1452	±	75	<DCGL
25	D	479	-4	-89	±	18	4490	150	635	±	49	<DCGL
26	D	542	59	1340	±	72	5101	761	3221	±	111	<DCGL
27	D	547	64	1454	±	75	5214	874	3700	±	119	<DCGL
28	A	458	-20	-460	±	42	4501	535	2267	±	93	<DCGL
29	A	537	59	1331	±	72	4536	570	2415	±	96	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 5	Beta 203439		Alpha 212233	
Room A06 & A06B	Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient A	478.3	2375.4	0.4	47.8
Drywall D	482.9	2386.5	0.8	57.6
Floor F	579.6	2608.0	1.0	61.6
Metal M	431.2	2258.9	0.6	53.1
Beta Meter Efficiency	4.41%			
Alpha Meter Efficiency	12.43%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Alpha Gross CPM	Alpha Net CPM	Alpha DPM /100CM2	±	1.96 Sigma	Comment
1	F	584	4	100	±	20	0	-1	-8	±	6	<DCGL
2	F	546	-34	-762	±	54	0	-1	-8	±	6	<DCGL
3	F	539	-41	-921	±	59	1	0	0	±	0	<DCGL
4	F	561	-19	-422	±	40	3	2	16	±	8	<DCGL
5	F	592	12	281	±	33	0	-1	-8	±	6	<DCGL
6	F	598	18	417	±	40	2	1	8	±	6	<DCGL
7	F	591	11	259	±	32	1	0	0	±	0	<DCGL
8	F	553	-27	-603	±	48	1	0	0	±	0	<DCGL
9	A	518	40	900	±	59	1	1	5	±	4	<DCGL
10	A	488	10	220	±	29	0	0	-3	±	4	<DCGL
11	A	520	42	946	±	60	2	2	13	±	7	<DCGL
12	D	463	-20	-451	±	42	2	1	10	±	6	<DCGL
13	D	531	48	1091	±	65	1	0	2	±	2	<DCGL
14	D	491	8	184	±	27	1	0	2	±	2	<DCGL
15	D	495	12	274	±	32	0	-1	-6	±	5	<DCGL
16	D	644	161	3653	±	118	1	0	2	±	2	<DCGL
17	D	550	67	1522	±	76	0	-1	-6	±	5	<DCGL
18	D	516	33	751	±	54	2	1	10	±	6	<DCGL
19	D	509	26	592	±	48	0	-1	-6	±	5	<DCGL
20	D	557	74	1680	±	80	1	0	2	±	2	<DCGL
21	D	507	24	546	±	46	1	0	2	±	2	<DCGL
22	F	587	7	168	±	25	1	0	0	±	0	<DCGL
23	F	549	-31	-694	±	52	0	-1	-8	±	6	<DCGL
24	D	466	-17	-383	±	38	2	1	10	±	6	<DCGL
25	D	456	-27	-610	±	48	3	2	18	±	8	<DCGL
26	A	560	82	1853	±	84	1	1	5	±	4	<DCGL
27	D	525	42	955	±	61	2	1	10	±	6	<DCGL
28	D	534	51	1159	±	67	2	1	10	±	6	<DCGL
29	D	538	55	1249	±	69	1	0	2	±	2	<DCGL
30	M	408	-23	-526	±	45	3	2	19	±	9	<DCGL
31	M	406	-25	-571	±	47	0	-1	-5	±	4	<DCGL
32	A	495	17	379	±	38	0	0	-3	±	4	<DCGL
33	F	445	-135	-3052	±	108	0	-1	-8	±	6	<DCGL
34	M	511	80	1810	±	83	0	-1	-5	±	4	<DCGL
35	F	546	-34	-762	±	54	0	-1	-8	±	6	<DCGL
36	F	561	-19	-422	±	40	1	0	0	±	0	<DCGL
37	M	499	68	1537	±	77	1	0	3	±	4	<DCGL
38	M	577	146	3306	±	113	0	-1	-5	±	4	<DCGL
39	M	557	126	2853	±	105	1	0	3	±	4	<DCGL
40	M	465	34	766	±	54	2	1	11	±	7	<DCGL
41	M	464	33	744	±	53	2	1	11	±	7	<DCGL
42	M	360	-71	-1615	±	79	2	1	11	±	7	<DCGL
43	M	435	4	86	±	18	0	-1	-5	±	4	<DCGL
44	M	403	-28	-639	±	50	0	-1	-5	±	4	<DCGL
45	M	360	-71	-1615	±	79	3	2	19	±	9	<DCGL
46	M	398	-33	-753	±	54	1	0	3	±	4	<DCGL
47	M	454	23	517	±	45	2	1	11	±	7	<DCGL
48	A	447	-31	-710	±	52	1	1	5	±	4	<DCGL
49	A	545	67	1512	±	76	1	1	5	±	4	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 6	Beta		No Gamma Readings
Room B124	212233		Taken; H-3 & C-14 Only
Surface	Bkg (CPM)	MDC (dpm)	
Ambient A	337.2	1646.9	
Drywall D	327.3	1623.4	
Floor F	368.1	1718.2	
Metal M	322.7	1612.3	
Beta Meter Efficiency	5.37%		

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	377	9	166	±	25	N/A	N/A	N/A	±	N/A	<DCGL
2	F	373	5	91	±	19	N/A	N/A	N/A	±	N/A	<DCGL
3	F	304	-64	-1194	±	68	N/A	N/A	N/A	±	N/A	<DCGL
4	F	369	1	17	±	8	N/A	N/A	N/A	±	N/A	<DCGL
5	F	355	-13	-244	±	31	N/A	N/A	N/A	±	N/A	<DCGL
6	F	389	21	389	±	39	N/A	N/A	N/A	±	N/A	<DCGL
7	F	341	-27	-505	±	44	N/A	N/A	N/A	±	N/A	<DCGL
8	F	386	18	333	±	36	N/A	N/A	N/A	±	N/A	<DCGL
9	F	388	20	371	±	38	N/A	N/A	N/A	±	N/A	<DCGL
10	F	378	10	184	±	27	N/A	N/A	N/A	±	N/A	<DCGL
11	F	380	12	222	±	29	N/A	N/A	N/A	±	N/A	<DCGL
12	F	336	-32	-598	±	48	N/A	N/A	N/A	±	N/A	<DCGL
13	F	361	-7	-132	±	23	N/A	N/A	N/A	±	N/A	<DCGL
14	F	342	-26	-486	±	43	N/A	N/A	N/A	±	N/A	<DCGL
15	F	354	-14	-263	±	32	N/A	N/A	N/A	±	N/A	<DCGL
16	F	355	-13	-244	±	31	N/A	N/A	N/A	±	N/A	<DCGL
17	F	342	-26	-486	±	43	N/A	N/A	N/A	±	N/A	<DCGL
18	F	325	-43	-803	±	56	N/A	N/A	N/A	±	N/A	<DCGL
19	F	352	-16	-300	±	34	N/A	N/A	N/A	±	N/A	<DCGL
20	F	371	3	54	±	14	N/A	N/A	N/A	±	N/A	<DCGL
21	F	373	5	91	±	19	N/A	N/A	N/A	±	N/A	<DCGL
22	F	353	-15	-281	±	33	N/A	N/A	N/A	±	N/A	<DCGL
23	F	368	0	-2	±	3	N/A	N/A	N/A	±	N/A	<DCGL
24	F	357	-11	-207	±	28	N/A	N/A	N/A	±	N/A	<DCGL
25	F	373	5	91	±	19	N/A	N/A	N/A	±	N/A	<DCGL
26	D	396	69	1279	±	70	N/A	N/A	N/A	±	N/A	<DCGL
27	D	341	14	255	±	31	N/A	N/A	N/A	±	N/A	<DCGL
28	D	336	9	162	±	25	N/A	N/A	N/A	±	N/A	<DCGL
29	D	381	54	1000	±	62	N/A	N/A	N/A	±	N/A	<DCGL
30	D	382	55	1019	±	63	N/A	N/A	N/A	±	N/A	<DCGL
31	D	424	97	1801	±	83	N/A	N/A	N/A	±	N/A	<DCGL
32	D	347	20	367	±	38	N/A	N/A	N/A	±	N/A	<DCGL
33	D	359	32	590	±	48	N/A	N/A	N/A	±	N/A	<DCGL
34	D	373	46	851	±	57	N/A	N/A	N/A	±	N/A	<DCGL
35	D	388	61	1130	±	66	N/A	N/A	N/A	±	N/A	<DCGL
36	D	368	41	758	±	54	N/A	N/A	N/A	±	N/A	<DCGL
37	D	361	34	628	±	49	N/A	N/A	N/A	±	N/A	<DCGL
38	D	369	42	777	±	55	N/A	N/A	N/A	±	N/A	<DCGL
39	D	366	39	721	±	53	N/A	N/A	N/A	±	N/A	<DCGL
40	D	359	32	590	±	48	N/A	N/A	N/A	±	N/A	<DCGL
41	D	374	47	870	±	58	N/A	N/A	N/A	±	N/A	<DCGL
42	D	331	4	69	±	16	N/A	N/A	N/A	±	N/A	<DCGL
43	D	320	-7	-136	±	23	N/A	N/A	N/A	±	N/A	<DCGL
44	D	315	-12	-229	±	30	N/A	N/A	N/A	±	N/A	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 7 Room B121, B122, B123		Beta 203439		No Gamma Readings Taken; H-3 & C-14 Only	
Surface		Bkg (CPM)	MDC (dpm)		
Ambient	A	478.3	2375.4		
Drywall	D	482.9	2386.5		
Floor	F	579.6	2608.0		
Metal	M	431.2	2258.9		
Beta Meter Efficiency		4.41%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	610	30	689	±	51	N/A	N/A	N/A	±	N/A	<DCGL
2	F	590	10	236	±	30	N/A	N/A	N/A	±	N/A	<DCGL
3	F	578	-2	-36	±	12	N/A	N/A	N/A	±	N/A	<DCGL
4	F	572	-8	-172	±	26	N/A	N/A	N/A	±	N/A	<DCGL
5	F	505	-75	-1692	±	81	N/A	N/A	N/A	±	N/A	<DCGL
6	F	572	-8	-172	±	26	N/A	N/A	N/A	±	N/A	<DCGL
7	F	577	-3	-59	±	15	N/A	N/A	N/A	±	N/A	<DCGL
8	F	559	-21	-467	±	42	N/A	N/A	N/A	±	N/A	<DCGL
9	F	588	8	190	±	27	N/A	N/A	N/A	±	N/A	<DCGL
10	F	582	2	54	±	14	N/A	N/A	N/A	±	N/A	<DCGL
11	F	506	-74	-1669	±	80	N/A	N/A	N/A	±	N/A	<DCGL
12	F	519	-61	-1374	±	73	N/A	N/A	N/A	±	N/A	<DCGL
13	F	581	1	32	±	11	N/A	N/A	N/A	±	N/A	<DCGL
14	F	588	8	190	±	27	N/A	N/A	N/A	±	N/A	<DCGL
15	F	596	16	372	±	38	N/A	N/A	N/A	±	N/A	<DCGL
16	F	533	-47	-1057	±	64	N/A	N/A	N/A	±	N/A	<DCGL
17	F	596	16	372	±	38	N/A	N/A	N/A	±	N/A	<DCGL
18	F	573	-7	-150	±	24	N/A	N/A	N/A	±	N/A	<DCGL
19	F	544	-36	-807	±	56	N/A	N/A	N/A	±	N/A	<DCGL
20	F	545	-35	-785	±	55	N/A	N/A	N/A	±	N/A	<DCGL
21	F	570	-10	-218	±	29	N/A	N/A	N/A	±	N/A	<DCGL
22	F	582	2	54	±	14	N/A	N/A	N/A	±	N/A	<DCGL
23	F	571	-9	-195	±	27	N/A	N/A	N/A	±	N/A	<DCGL
24	F	601	21	485	±	43	N/A	N/A	N/A	±	N/A	<DCGL
25	F	609	29	667	±	51	N/A	N/A	N/A	±	N/A	<DCGL
26	F	594	14	327	±	35	N/A	N/A	N/A	±	N/A	<DCGL
27	D	467	-16	-361	±	37	N/A	N/A	N/A	±	N/A	<DCGL
28	D	447	-36	-814	±	56	N/A	N/A	N/A	±	N/A	<DCGL
29	D	450	-33	-746	±	54	N/A	N/A	N/A	±	N/A	<DCGL
30	D	443	-40	-905	±	59	N/A	N/A	N/A	±	N/A	<DCGL
31	D	461	-22	-497	±	44	N/A	N/A	N/A	±	N/A	<DCGL
32	D	471	-12	-270	±	32	N/A	N/A	N/A	±	N/A	<DCGL
33	D	459	-24	-542	±	46	N/A	N/A	N/A	±	N/A	<DCGL
34	D	479	-4	-88	±	18	N/A	N/A	N/A	±	N/A	<DCGL
35	D	468	-15	-338	±	36	N/A	N/A	N/A	±	N/A	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 8		Beta		No Gamma Readings	
Room B126, B127, B128		203439		Taken; H-3 & C-14 Only	
Surface		Bkg (CPM)	MDC (dpm)		
Ambient	A	478.3	2375.4		
Drywall	D	482.9	2386.5		
Floor	F	579.6	2608.0		
Metal	M	431.2	2258.9		
Beta Meter Efficiency		4.41%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	632	52	1188	±	68	N/A	N/A	N/A	±	N/A	<DCGL
2	F	649	69	1574	±	78	N/A	N/A	N/A	±	N/A	<DCGL
3	F	579	-1	-14	±	7	N/A	N/A	N/A	±	N/A	<DCGL
4	F	577	-3	-59	±	15	N/A	N/A	N/A	±	N/A	<DCGL
5	F	600	20	463	±	42	N/A	N/A	N/A	±	N/A	<DCGL
6	F	566	-14	-308	±	34	N/A	N/A	N/A	±	N/A	<DCGL
7	F	614	34	780	±	55	N/A	N/A	N/A	±	N/A	<DCGL
8	F	548	-32	-717	±	52	N/A	N/A	N/A	±	N/A	<DCGL
9	F	619	39	893	±	59	N/A	N/A	N/A	±	N/A	<DCGL
10	F	555	-25	-558	±	46	N/A	N/A	N/A	±	N/A	<DCGL
11	F	573	-7	-150	±	24	N/A	N/A	N/A	±	N/A	<DCGL
12	F	592	12	281	±	33	N/A	N/A	N/A	±	N/A	<DCGL
13	F	582	2	54	±	14	N/A	N/A	N/A	±	N/A	<DCGL
14	F	600	20	463	±	42	N/A	N/A	N/A	±	N/A	<DCGL
15	F	727	147	3342	±	113	N/A	N/A	N/A	±	N/A	<DCGL
16	F	703	123	2798	±	104	N/A	N/A	N/A	±	N/A	<DCGL
17	F	577	-3	-59	±	15	N/A	N/A	N/A	±	N/A	<DCGL
18	F	586	6	145	±	24	N/A	N/A	N/A	±	N/A	<DCGL
19	F	559	-21	-467	±	42	N/A	N/A	N/A	±	N/A	<DCGL
20	F	551	-29	-649	±	50	N/A	N/A	N/A	±	N/A	<DCGL
21	F	560	-20	-444	±	41	N/A	N/A	N/A	±	N/A	<DCGL
22	F	550	-30	-671	±	51	N/A	N/A	N/A	±	N/A	<DCGL
23	F	619	39	893	±	59	N/A	N/A	N/A	±	N/A	<DCGL
24	F	559	-21	-467	±	42	N/A	N/A	N/A	±	N/A	<DCGL
25	F	595	15	349	±	37	N/A	N/A	N/A	±	N/A	<DCGL
26	D	465	-18	-406	±	39	N/A	N/A	N/A	±	N/A	<DCGL
27	D	462	-21	-474	±	43	N/A	N/A	N/A	±	N/A	<DCGL
28	D	465	-18	-406	±	39	N/A	N/A	N/A	±	N/A	<DCGL
29	D	473	-10	-224	±	29	N/A	N/A	N/A	±	N/A	<DCGL
30	D	446	-37	-837	±	57	N/A	N/A	N/A	±	N/A	<DCGL
31	D	480	-3	-66	±	16	N/A	N/A	N/A	±	N/A	<DCGL
32	D	463	-20	-451	±	42	N/A	N/A	N/A	±	N/A	<DCGL
33	D	491	8	184	±	27	N/A	N/A	N/A	±	N/A	<DCGL
34	D	495	12	274	±	32	N/A	N/A	N/A	±	N/A	<DCGL
35	D	483	0	2	±	3	N/A	N/A	N/A	±	N/A	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 9	Beta		No Gamma Readings	
Room B131A	212233		Taken; H-3 & C-14 Only	
Surface	Bkg (CPM)	MDC (dpm)		
Ambient A	337.2	1646.9		
Drywall D	327.3	1623.4		
Floor F	368.1	1718.2		
Metal M	322.7	1612.3		
Beta Meter Efficiency	5.37%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	356	-12	-225	±	29	N/A	N/A	N/A	±	N/A	<DCGL
2	F	367	-1	-20	±	9	N/A	N/A	N/A	±	N/A	<DCGL
3	F	352	-16	-300	±	34	N/A	N/A	N/A	±	N/A	<DCGL
4	F	391	23	426	±	40	N/A	N/A	N/A	±	N/A	<DCGL
5	F	365	-3	-58	±	15	N/A	N/A	N/A	±	N/A	<DCGL
6	F	347	-21	-393	±	39	N/A	N/A	N/A	±	N/A	<DCGL
7	F	377	9	166	±	25	N/A	N/A	N/A	±	N/A	<DCGL
8	F	373	5	91	±	19	N/A	N/A	N/A	±	N/A	<DCGL
9	F	331	-37	-691	±	52	N/A	N/A	N/A	±	N/A	<DCGL
10	F	369	1	17	±	8	N/A	N/A	N/A	±	N/A	<DCGL
11	F	339	-29	-542	±	46	N/A	N/A	N/A	±	N/A	<DCGL
12	F	352	-16	-300	±	34	N/A	N/A	N/A	±	N/A	<DCGL
13	F	354	-14	-263	±	32	N/A	N/A	N/A	±	N/A	<DCGL
14	F	371	3	54	±	14	N/A	N/A	N/A	±	N/A	<DCGL
15	F	360	-8	-151	±	24	N/A	N/A	N/A	±	N/A	<DCGL
16	F	377	9	166	±	25	N/A	N/A	N/A	±	N/A	<DCGL
17	F	412	44	818	±	56	N/A	N/A	N/A	±	N/A	<DCGL
18	F	393	25	464	±	42	N/A	N/A	N/A	±	N/A	<DCGL
19	F	368	0	-2	±	3	N/A	N/A	N/A	±	N/A	<DCGL
20	F	376	8	147	±	24	N/A	N/A	N/A	±	N/A	<DCGL
21	D	394	67	1242	±	69	N/A	N/A	N/A	±	N/A	<DCGL
22	D	358	31	572	±	47	N/A	N/A	N/A	±	N/A	<DCGL
23	D	367	40	739	±	53	N/A	N/A	N/A	±	N/A	<DCGL
24	D	349	22	404	±	39	N/A	N/A	N/A	±	N/A	<DCGL
25	D	383	56	1037	±	63	N/A	N/A	N/A	±	N/A	<DCGL
26	D	369	42	777	±	55	N/A	N/A	N/A	±	N/A	<DCGL
27	D	359	32	590	±	48	N/A	N/A	N/A	±	N/A	<DCGL
28	D	391	64	1186	±	68	N/A	N/A	N/A	±	N/A	<DCGL
29	D	335	8	143	±	23	N/A	N/A	N/A	±	N/A	<DCGL
30	D	339	12	218	±	29	N/A	N/A	N/A	±	N/A	<DCGL
31	D	346	19	348	±	37	N/A	N/A	N/A	±	N/A	<DCGL
32	D	358	31	572	±	47	N/A	N/A	N/A	±	N/A	<DCGL
33	D	352	25	460	±	42	N/A	N/A	N/A	±	N/A	<DCGL
34	D	349	22	404	±	39	N/A	N/A	N/A	±	N/A	<DCGL
35	D	340	13	236	±	30	N/A	N/A	N/A	±	N/A	<DCGL
36	D	344	17	311	±	35	N/A	N/A	N/A	±	N/A	<DCGL
37	D	332	5	88	±	18	N/A	N/A	N/A	±	N/A	<DCGL
38	D	384	57	1056	±	64	N/A	N/A	N/A	±	N/A	<DCGL

Philotechnics Analytical Worksheet

Appendix F

VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

→ B131B and B131C
 per communication with R.S. Trimble of Philotechnics.com
 7/2/2011
 8/11/2011

Survey Unit 10 Room B101A	Beta 212233		No Gamma Readings Taken; H-3 & C-14 Only	
Surface	Bkg (CPM)	MDC (dpm)		
Ambient A	337.2	1646.9		
Drywall D	327.3	1623.4		
Floor F	368.1	1718.2		
Metal M	322.7	1612.3		
Beta Meter Efficiency	5.37%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	366	-2	-39	±	12	N/A	N/A	N/A	±	N/A	<DCGL
2	F	380	12	222	±	29	N/A	N/A	N/A	±	N/A	<DCGL
3	F	378	10	184	±	27	N/A	N/A	N/A	±	N/A	<DCGL
4	F	383	15	277	±	33	N/A	N/A	N/A	±	N/A	<DCGL
5	F	387	19	352	±	37	N/A	N/A	N/A	±	N/A	<DCGL
6	F	370	2	35	±	12	N/A	N/A	N/A	±	N/A	<DCGL
7	F	369	1	17	±	8	N/A	N/A	N/A	±	N/A	<DCGL
8	F	334	-34	-635	±	49	N/A	N/A	N/A	±	N/A	<DCGL
9	F	348	-20	-374	±	38	N/A	N/A	N/A	±	N/A	<DCGL
10	F	325	-43	-803	±	56	N/A	N/A	N/A	±	N/A	<DCGL
11	F	352	-16	-300	±	34	N/A	N/A	N/A	±	N/A	<DCGL
12	F	399	31	575	±	47	N/A	N/A	N/A	±	N/A	<DCGL
13	F	363	-5	-95	±	19	N/A	N/A	N/A	±	N/A	<DCGL
14	F	386	18	333	±	36	N/A	N/A	N/A	±	N/A	<DCGL
15	F	404	36	669	±	51	N/A	N/A	N/A	±	N/A	<DCGL
16	F	314	-54	-1007	±	62	N/A	N/A	N/A	±	N/A	<DCGL
17	F	340	-28	-523	±	45	N/A	N/A	N/A	±	N/A	<DCGL
18	F	323	-45	-840	±	57	N/A	N/A	N/A	±	N/A	<DCGL
19	F	363	-5	-95	±	19	N/A	N/A	N/A	±	N/A	<DCGL
20	F	368	0	-2	±	3	N/A	N/A	N/A	±	N/A	<DCGL
21	F	357	-11	-207	±	28	N/A	N/A	N/A	±	N/A	<DCGL
22	F	364	-4	-76	±	17	N/A	N/A	N/A	±	N/A	<DCGL
23	D	328	1	13	±	7	N/A	N/A	N/A	±	N/A	<DCGL
24	D	336	9	162	±	25	N/A	N/A	N/A	±	N/A	<DCGL
25	D	337	10	181	±	26	N/A	N/A	N/A	±	N/A	<DCGL
26	D	349	22	404	±	39	N/A	N/A	N/A	±	N/A	<DCGL
27	D	356	29	534	±	45	N/A	N/A	N/A	±	N/A	<DCGL
28	D	332	5	88	±	18	N/A	N/A	N/A	±	N/A	<DCGL
29	D	316	-11	-210	±	28	N/A	N/A	N/A	±	N/A	<DCGL
30	D	308	-19	-359	±	37	N/A	N/A	N/A	±	N/A	<DCGL
31	D	319	-8	-155	±	24	N/A	N/A	N/A	±	N/A	<DCGL
32	D	311	-16	-304	±	34	N/A	N/A	N/A	±	N/A	<DCGL
33	D	340	13	236	±	30	N/A	N/A	N/A	±	N/A	<DCGL
34	D	351	24	441	±	41	N/A	N/A	N/A	±	N/A	<DCGL
35	D	326	-1	-24	±	10	N/A	N/A	N/A	±	N/A	<DCGL
36	D	350	23	423	±	40	N/A	N/A	N/A	±	N/A	<DCGL
37	D	366	39	721	±	53	N/A	N/A	N/A	±	N/A	<DCGL
38	D	346	19	348	±	37	N/A	N/A	N/A	±	N/A	<DCGL
39	D	358	31	572	±	47	N/A	N/A	N/A	±	N/A	<DCGL
40	D	342	15	274	±	32	N/A	N/A	N/A	±	N/A	<DCGL
41	D	401	74	1372	±	73	N/A	N/A	N/A	±	N/A	<DCGL
42	D	394	67	1242	±	69	N/A	N/A	N/A	±	N/A	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix F

Survey Unit 11 Basement Hallway		Beta 212233		Gamma 203447	
Surface		Bkg (CPM)	MDC (dpm)	Bkg (CPM)	MDC (dpm)
Ambient	A	337.2	1646.9	4225.9	1216.5
Drywall	D	327.3	1623.4	4256.3	1220.8
Floor	F	368.1	1718.2	4338.0	1232.4
Metal	M	322.7	1612.3	2908.0	1011.2
Beta Meter Efficiency		5.37%			
Gamma Meter Efficiency		25.11%			

Sample	Surface	Beta Gross CPM	Beta Net CPM	Beta DPM /100CM2	±	1.96 Sigma	Gamma Gross CPM	Gamma Net CPM	Gamma DPM /100CM2	±	1.96 Sigma	Comment
1	F	400	32	594	±	48	5005	667	2656	±	101	<DCGL
2	F	354	-14	-263	±	32	4094	-244	-972	±	61	<DCGL
3	F	423	55	1022	±	63	5505	1167	4648	±	134	<DCGL
4	F	358	-10	-188	±	27	4314	-24	-96	±	19	<DCGL
5	F	365	-3	-58	±	15	4058	-280	-1115	±	65	<DCGL
6	F	335	-33	-616	±	49	3956	-382	-1521	±	76	<DCGL
7	F	340	-28	-523	±	45	3731	-607	-2417	±	96	<DCGL
8	F	408	40	743	±	53	4818	480	1912	±	86	<DCGL
9	F	431	63	1171	±	67	4337	-1	-4	±	4	<DCGL
10	F	369	1	17	±	8	4582	244	972	±	61	<DCGL
11	F	334	-34	-635	±	49	3805	-533	-2123	±	90	<DCGL
12	F	394	26	482	±	43	4026	-312	-1243	±	69	<DCGL
13	F	371	3	54	±	14	4204	-134	-534	±	45	<DCGL
14	F	404	36	669	±	51	4616	278	1107	±	65	<DCGL
15	F	338	-30	-561	±	46	3991	-347	-1382	±	73	<DCGL
16	F	357	-11	-207	±	28	3822	-516	-2055	±	89	<DCGL
17	F	405	37	687	±	51	4011	-327	-1302	±	71	<DCGL
18	F	388	20	371	±	38	4549	211	840	±	57	<DCGL
19	F	422	54	1004	±	62	4926	588	2342	±	95	<DCGL
20	F	367	-1	-20	±	9	4765	427	1701	±	81	<DCGL
21	F	373	5	91	±	19	4483	145	577	±	47	<DCGL
22	F	339	-29	-542	±	46	3711	-627	-2497	±	98	<DCGL
23	F	394	26	482	±	43	4609	271	1079	±	64	<DCGL

APPENDIX G
*Wipe Survey Data Sheets and DPM
Calculations*

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Scintillation Counter
 Laboratory Results

Survey Unit 1	Instrument			
Bldg. 2	3030 - 242683		LSC	
A008, A009, A010	Alpha	Beta	Chan A	Chan B
Background (CPM)	0.8	56.4	15.5	9.5
MDC Value	18.1	81.5	33.9	17.9
Meter Efficiency	39.49%	46.56%	See Quench Eff.	

Survey Unit 1 - Rooms A008, A009, A010												
Sample	Gross CPM/100 cm ²				Quench and Efficiency			DPM/100 cm ²				Comments
	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	H#	H-3 Eff.	C-14 Eff.	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	
1	0	59	16	9	47	54.00%	95.04%	-2.0	5.6	0.9	-0.5	<DCGL
2	0	57	19	9	49	53.52%	94.93%	-2.0	1.3	6.5	-0.5	<DCGL
3	0	63	23	11	43	54.96%	95.25%	-2.0	14.2	13.6	1.6	<DCGL
4	1	81	17	11	42	55.20%	95.31%	0.5	52.8	2.7	1.6	<DCGL
5	0	59	10	7	43	54.96%	95.25%	-2.0	5.6	-10.0	-2.6	<DCGL
6	0	62	17	8	44	54.72%	95.20%	-2.0	12.0	2.7	-1.6	<DCGL
7	0	58	21	10	44	54.72%	95.20%	-2.0	3.4	10.1	0.5	<DCGL
8	0	61	19	8	43	54.96%	95.25%	-2.0	9.9	6.4	-1.6	<DCGL
9	0	87	15	7	44	54.72%	95.20%	-2.0	65.7	-0.9	-2.6	<DCGL
10	0	60	22	6	44	54.72%	95.20%	-2.0	7.7	11.9	-3.7	<DCGL
11	0	71	14	15	42	55.20%	95.31%	-2.0	31.4	-2.7	5.8	<DCGL
12	0	63	18	5	46	54.24%	95.09%	-2.0	14.2	4.6	-4.7	<DCGL
13	1	56	17	15	46	54.24%	95.09%	0.5	-0.9	2.8	5.8	<DCGL
14	0	72	14	15	44	54.72%	95.20%	-2.0	33.5	-2.7	5.8	<DCGL
15	0	70	18	14	46	54.24%	95.09%	-2.0	29.2	4.6	4.7	<DCGL
16	0	75	21	12	50	53.28%	94.88%	-2.0	39.9	10.3	2.6	<DCGL
17	0	62	13	8	52	52.80%	94.77%	-2.0	12.0	-4.7	-1.6	<DCGL
18	1	68	18	10	46	54.24%	95.09%	0.5	24.9	4.6	0.5	<DCGL
19	0	77	21	8	56	51.83%	94.56%	-2.0	44.2	10.6	-1.6	<DCGL
20	0	74	17	10	44	54.72%	95.20%	-2.0	37.8	2.7	0.5	<DCGL
21	1	59	27	11	54	52.31%	94.67%	0.5	5.6	22.0	1.6	<DCGL
22	1	69	21	11	45	54.48%	95.15%	0.5	27.1	10.1	1.6	<DCGL
23	0	64	19	6	43	54.96%	95.25%	-2.0	16.3	6.4	-3.7	<DCGL
24	0	60	25	6	43	54.96%	95.25%	-2.0	7.7	17.3	-3.7	<DCGL
25	2	77	21	3	43	54.96%	95.25%	3.0	44.2	10.0	-6.8	<DCGL
26	0	67	24	15	45	54.48%	95.15%	-2.0	22.8	15.6	5.8	<DCGL
27	0	67	13	7	43	54.96%	95.25%	-2.0	22.8	-4.5	-2.6	<DCGL
28	2	73	14	14	43	54.96%	95.25%	3.0	35.7	-2.7	4.7	<DCGL
29	0	91	18	9	45	54.48%	95.15%	-2.0	74.3	4.6	-0.5	<DCGL
30	0	71	19	16	44	54.72%	95.20%	-2.0	31.4	6.4	6.8	<DCGL
31	1	76	15	7	44	54.72%	95.20%	0.5	42.1	-0.9	-2.6	<DCGL
32	0	64	20	16	47	54.00%	95.04%	-2.0	16.3	8.3	6.8	<DCGL
33	0	73	15	12	81	45.81%	93.22%	-2.0	35.7	-1.1	2.7	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Survey Unit 2	Instrument			
Bldg. 2	3030 - 242683		LSC	
A05A	Alpha	Beta	Chan A	Chan B
Background (CPM)	0.8	56.4	15.5	9.5
MDC Value	18.1	81.5	33.9	17.9
Meter Efficiency	39.49%	46.56%	See Quench Eff.	

Survey Unit 2 - Room A05A												
Sample	Gross CPM/100 cm ²				Quench and Efficiency			DPM/100 cm ²				Comments
	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	H#	H-3 Eff.	C-14 Eff.	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	
1	0	62	16	3	57	51.59%	94.51%	-2.0	12.0	1.0	-6.9	<DCGL
2	0	76	14	12	48	53.76%	94.99%	-2.0	42.1	-2.8	2.6	<DCGL
3	0	70	20	10	48	53.76%	94.99%	-2.0	29.2	8.4	0.5	<DCGL
4	1	77	14	6	50	53.28%	94.88%	0.5	44.2	-2.8	-3.7	<DCGL
5	0	86	14	11	55	52.07%	94.61%	-2.0	63.6	-2.9	1.6	<DCGL
6	1	73	16	11	64	49.90%	94.13%	0.5	35.7	1.0	1.6	<DCGL
7	0	73	14	11	54	52.31%	94.67%	-2.0	35.7	-2.9	1.6	<DCGL
8	1	61	18	6	49	53.52%	94.93%	0.5	9.9	4.7	-3.7	<DCGL
9	0	84	17	12	47	54.00%	95.04%	-2.0	59.3	2.8	2.6	<DCGL
10	0	62	25	7	48	53.76%	94.99%	-2.0	12.0	17.7	-2.6	<DCGL
11	0	69	25	11	50	53.28%	94.88%	-2.0	27.1	17.8	1.6	<DCGL
12	0	63	16	6	52	52.80%	94.77%	-2.0	14.2	0.9	-3.7	<DCGL
13	0	61	16	9	52	52.80%	94.77%	-2.0	9.9	0.9	-0.5	<DCGL
14	0	59	10	11	51	53.04%	94.83%	-2.0	5.6	-10.4	1.6	<DCGL
15	0	68	15	7	49	53.52%	94.93%	-2.0	24.9	-0.9	-2.6	<DCGL
16	0	82	14	8	49	53.52%	94.93%	-2.0	55.0	-2.8	-1.6	<DCGL
17	0	62	10	5	51	53.04%	94.83%	-2.0	12.0	-10.4	-4.7	<DCGL
18	0	70	17	8	45	54.48%	95.15%	-2.0	29.2	2.8	-1.6	<DCGL
19	0	78	18	9	49	53.52%	94.93%	-2.0	46.4	4.7	-0.5	<DCGL
20	0	65	24	15	46	54.24%	95.09%	-2.0	18.5	15.7	5.8	<DCGL
21	0	60	15	18	58	51.35%	94.45%	-2.0	7.7	-1.0	9.0	<DCGL
22	0	81	16	9	46	54.24%	95.09%	-2.0	52.8	0.9	-0.5	<DCGL
23	0	69	15	9	60	50.87%	94.35%	-2.0	27.1	-1.0	-0.5	<DCGL
24	0	80	14	11	58	51.35%	94.45%	-2.0	50.7	-2.9	1.6	<DCGL
25	1	82	21	14	52	52.80%	94.77%	0.5	55.0	10.4	4.7	<DCGL
26	0	75	12	8	58	51.35%	94.45%	-2.0	39.9	-6.8	-1.6	<DCGL
27	0	67	19	7	52	52.80%	94.77%	-2.0	22.8	6.6	-2.6	<DCGL
28	0	67	22	7	52	52.80%	94.77%	-2.0	22.8	12.3	-2.6	<DCGL
29	0	77	13	10	48	53.76%	94.99%	-2.0	44.2	-4.7	0.5	<DCGL
30	0	74	12	5	45	54.48%	95.15%	-2.0	37.8	-6.4	-4.7	<DCGL
31	0	94	23	8	52	52.80%	94.77%	-2.0	80.8	14.2	-1.6	<DCGL
32	0	76	11	11	44	54.72%	95.20%	-2.0	42.1	-8.2	1.6	<DCGL
33	0	74	15	12	59	51.11%	94.40%	-2.0	37.8	-1.0	2.6	<DCGL
34	0	68	19	8	52	52.80%	94.77%	-2.0	24.9	6.6	-1.6	<DCGL
35	0	79	17	14	45	54.48%	95.15%	-2.0	48.5	2.8	4.7	<DCGL
36	0	70	19	11	42	55.20%	95.31%	-2.0	29.2	6.3	1.6	<DCGL
37	2	75	15	14	43	54.96%	95.25%	3.0	39.9	-0.9	4.7	<DCGL
38	0	96	22	9	41	55.44%	95.36%	-2.0	85.1	11.7	-0.5	<DCGL
39	1	55	14	10	42	55.20%	95.31%	0.5	-3.0	-2.7	0.5	<DCGL
40	0	72	18	5	43	54.96%	95.25%	-2.0	33.5	4.5	-4.7	<DCGL
41	0	54	23	9	47	54.00%	95.04%	-2.0	-5.2	13.9	-0.5	<DCGL
42	0	65	23	14	47	54.00%	95.04%	-2.0	18.5	13.9	4.7	<DCGL
43	1	49	15	11	51	53.04%	94.83%	0.5	-15.9	-0.9	1.6	<DCGL
44	1	67	16	8	54	52.31%	94.67%	0.5	22.8	1.0	-1.6	<DCGL
45	0	83	14	6	46	54.24%	95.09%	-2.0	57.1	-2.8	-3.7	<DCGL
46	0	60	16	6	50	53.28%	94.88%	-2.0	7.7	0.9	-3.7	<DCGL
47	0	80	11	9	78	46.53%	93.38%	-2.0	50.7	-9.7	-0.5	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Survey Unit 3	Instrument			
Bldg. 2	3030 - 242683		LSC	
A05	Alpha	Beta	Chan A	Chan B
Background (CPM)	0.8	56.4	15.5	9.5
MDC Value	18.1	81.5	33.9	17.9
Meter Efficiency	39.49%	46.56%	<i>See Quench Eff.</i>	

Survey Unit 3 - Room A05													
Sample	Gross CPM/100 cm ²				Quench and Efficiency			DPM/100 cm ²				Comments	
	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	H#	H-3 Eff.	C-14 Eff.	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint		
1	0	74	12	12	49	53.52%	94.93%	-2.0	37.8	-6.5	2.6	<DCGL	
2	0	75	13	6	48	53.76%	94.99%	-2.0	39.9	-4.7	-3.7	<DCGL	
3	0	79	17	10	61	50.63%	94.29%	-2.0	48.5	3.0	0.5	<DCGL	
4	0	80	15	5	57	51.59%	94.51%	-2.0	50.7	-1.0	-4.8	<DCGL	
5	0	67	7	9	50	53.28%	94.88%	-2.0	22.8	-16.0	-0.5	<DCGL	
6	0	85	18	10	82	45.57%	93.17%	-2.0	61.4	5.5	0.5	<DCGL	
7	1	65	15	16	57	51.59%	94.51%	0.5	18.5	-1.0	6.9	<DCGL	
8	1	69	18	7	57	51.59%	94.51%	0.5	27.1	4.8	-2.6	<DCGL	
9	1	96	13	9	64	49.90%	94.13%	0.5	85.1	-5.0	-0.5	<DCGL	
10	0	71	16	3	42	55.20%	95.31%	-2.0	31.4	0.9	-6.8	<DCGL	
11	0	75	14	7	45	54.48%	95.15%	-2.0	39.9	-2.8	-2.6	<DCGL	
12	1	71	19	14	48	53.76%	94.99%	0.5	31.4	6.5	4.7	<DCGL	
13	0	62	13	7	45	54.48%	95.15%	-2.0	12.0	-4.6	-2.6	<DCGL	
14	0	83	18	12	47	54.00%	95.04%	-2.0	57.1	4.6	2.6	<DCGL	
15	0	67	15	6	56	51.83%	94.56%	-2.0	22.8	-1.0	-3.7	<DCGL	
16	0	77	16	15	46	54.24%	95.09%	-2.0	44.2	0.9	5.8	<DCGL	
17	0	84	18	10	42	55.20%	95.31%	-2.0	59.3	4.5	0.5	<DCGL	
18	0	61	18	11	42	55.20%	95.31%	-2.0	9.9	4.5	1.6	<DCGL	
19	0	76	17	12	46	54.24%	95.09%	-2.0	42.1	2.8	2.6	<DCGL	
20	0	73	11	13	45	54.48%	95.15%	-2.0	35.7	-8.3	3.7	<DCGL	
21	0	66	23	4	42	55.20%	95.31%	-2.0	20.6	13.6	-5.8	<DCGL	
22	1	68	18	7	54	52.31%	94.67%	0.5	24.9	4.8	-2.6	<DCGL	
23	1	81	12	11	53	52.55%	94.72%	0.5	52.8	-6.7	1.6	<DCGL	
24	0	76	17	14	66	49.42%	94.02%	-2.0	42.1	3.0	4.8	<DCGL	
25	0	72	11	7	49	53.52%	94.93%	-2.0	33.5	-8.4	-2.6	<DCGL	
26	0	77	21	12	46	54.24%	95.09%	-2.0	44.2	10.1	2.6	<DCGL	
27	0	55	11	10	59	51.11%	94.40%	-2.0	-3.0	-8.8	0.5	<DCGL	
28	0	79	23	9	45	54.48%	95.15%	-2.0	48.5	13.8	-0.5	<DCGL	
29	0	71	19	8	51	53.04%	94.83%	-2.0	31.4	6.6	-1.6	<DCGL	
30	0	79	16	10	48	53.76%	94.99%	-2.0	48.5	0.9	0.5	<DCGL	
31	0	82	15	9	44	54.72%	95.20%	-2.0	55.0	-0.9	-0.5	<DCGL	
32	0	86	10	5	45	54.48%	95.15%	-2.0	63.6	-10.1	-4.7	<DCGL	
33	0	62	14	8	45	54.48%	95.15%	-2.0	12.0	-2.8	-1.6	<DCGL	

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Survey Unit 4	Instrument			
Bldg. 2	3030 - 242683		LSC	
A04	Alpha	Beta	Chan A	Chan B
Background (CPM)	0.8	56.4	15.5	9.5
MDC Value	18.1	81.5	33.9	17.9
Meter Efficiency	39.49%	46.56%	See Quench Eff.	

Survey Unit 3 - Room A04													
Sample	Gross CPM/100 cm ²				Quench and Efficiency			DPM/100 cm ²				Comments	
	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	H#	H-3 Eff.	C-14 Eff.	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint		
1	0	72	11	6	56	51.83%	94.56%	-2.0	33.5	-8.7	-3.7	<DCGL	
2	0	65	16	6	51	53.04%	94.83%	-2.0	18.5	0.9	-3.7	<DCGL	
3	1	78	15	13	65	49.66%	94.08%	0.5	46.4	-1.0	3.7	<DCGL	
4	0	70	16	7	52	52.80%	94.77%	-2.0	29.2	0.9	-2.6	<DCGL	
5	1	71	20	8	53	52.55%	94.72%	0.5	31.4	8.6	-1.6	<DCGL	
6	0	66	18	17	59	51.11%	94.40%	-2.0	20.6	4.9	7.9	<DCGL	
7	0	91	21	13	65	49.66%	94.08%	-2.0	74.3	11.1	3.7	<DCGL	
8	1	71	11	10	51	53.04%	94.83%	0.5	31.4	-8.5	0.5	<DCGL	
9	0	64	18	11	61	50.63%	94.29%	-2.0	16.3	4.9	1.6	<DCGL	
10	0	96	21	9	41	55.44%	95.36%	-2.0	85.1	9.9	-0.5	<DCGL	
11	0	64	15	11	47	54.00%	95.04%	-2.0	16.3	-0.9	1.6	<DCGL	
12	0	75	14	10	44	54.72%	95.20%	-2.0	39.9	-2.7	0.5	<DCGL	
13	0	72	24	9	42	55.20%	95.31%	-2.0	33.5	15.4	-0.5	<DCGL	
14	0	76	19	10	40	55.69%	95.41%	-2.0	42.1	6.3	0.5	<DCGL	
15	0	77	15	12	46	54.24%	95.09%	-2.0	44.2	-0.9	2.6	<DCGL	
16	0	63	12	7	40	55.69%	95.41%	-2.0	14.2	-6.3	-2.6	<DCGL	
17	0	71	12	9	40	55.69%	95.41%	-2.0	31.4	-6.3	-0.5	<DCGL	
18	0	69	5	12	40	55.69%	95.41%	-2.0	27.1	-18.9	2.6	<DCGL	
19	0	69	13	6	40	55.69%	95.41%	-2.0	27.1	-4.5	-3.7	<DCGL	
20	0	46	17	11	40	55.69%	95.41%	-2.0	-22.3	2.7	1.6	<DCGL	
21	0	67	28	9	40	55.69%	95.41%	-2.0	22.8	22.4	-0.5	<DCGL	
22	0	73	14	8	41	55.44%	95.36%	-2.0	35.7	-2.7	-1.6	<DCGL	
23	2	67	12	9	41	55.44%	95.36%	3.0	22.8	-6.3	-0.5	<DCGL	
24	0	77	13	8	42	55.20%	95.31%	-2.0	44.2	-4.5	-1.6	<DCGL	
25	0	79	17	6	41	55.44%	95.36%	-2.0	48.5	2.7	-3.7	<DCGL	
26	0	69	13	12	42	55.20%	95.31%	-2.0	27.1	-4.5	2.6	<DCGL	
27	0	63	16	12	46	54.24%	95.09%	-2.0	14.2	0.9	2.6	<DCGL	
28	0	67	23	7	60	50.87%	94.35%	-2.0	22.8	14.7	-2.6	<DCGL	
29	0	73	12	10	49	53.52%	94.93%	-2.0	35.7	-6.5	0.5	<DCGL	

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Survey Unit 5	Instrument			
Bldg. 2	3030 - 242683		LSC	
A06, A06B	Alpha	Beta	Chan A	Chan B
Background (CPM)	0.8	56.4	15.5	9.5
MDC Value	18.1	81.5	33.9	17.9
Meter Efficiency	39.49%	46.56%	<i>See Quench Eff.</i>	

Survey Unit 5 - Room A06, A06B													
Sample	Gross CPM/100 cm ²				Quench and Efficiency			DPM/100 cm ²				Comments	
	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint	H#	H-3 Eff.	C-14 Eff.	Alpha Planchet	Beta Planchet	Chan A Scint	Chan B Scint		
1	1	75	16	5	45	54.48%	95.15%	0.5	39.9	0.9	-4.7	<DCGL	
2	0	73	15	12	41	55.44%	95.36%	-2.0	35.7	-0.9	2.6	<DCGL	
3	0	82	14	6	42	55.20%	95.31%	-2.0	55.0	-2.7	-3.7	<DCGL	
4	0	73	20	5	41	55.44%	95.36%	-2.0	35.7	8.1	-4.7	<DCGL	
5	0	67	21	18	45	54.48%	95.15%	-2.0	22.8	10.1	8.9	<DCGL	
6	0	73	17	9	45	54.48%	95.15%	-2.0	35.7	2.8	-0.5	<DCGL	
7	0	73	10	7	44	54.72%	95.20%	-2.0	35.7	-10.1	-2.6	<DCGL	
8	0	91	19	8	45	54.48%	95.15%	-2.0	74.3	6.4	-1.6	<DCGL	
9	0	69	14	9	40	55.69%	95.41%	-2.0	27.1	-2.7	-0.5	<DCGL	
10	0	80	23	6	41	55.44%	95.36%	-2.0	50.7	13.5	-3.7	<DCGL	
11	0	77	18	13	44	54.72%	95.20%	-2.0	44.2	4.6	3.7	<DCGL	
12	0	83	17	9	45	54.48%	95.15%	-2.0	57.1	2.8	-0.5	<DCGL	
13	0	66	16	6	49	53.52%	94.93%	-2.0	20.6	0.9	-3.7	<DCGL	
14	1	67	22	12	48	53.76%	94.99%	0.5	22.8	12.1	2.6	<DCGL	
15	0	70	15	6	43	54.96%	95.25%	-2.0	29.2	-0.9	-3.7	<DCGL	
16	2	62	14	8	43	54.96%	95.25%	3.0	12.0	-2.7	-1.6	<DCGL	
17	0	72	18	13	44	54.72%	95.20%	-2.0	33.5	4.6	3.7	<DCGL	
18	0	88	21	12	42	55.20%	95.31%	-2.0	67.9	10.0	2.6	<DCGL	
19	0	75	10	5	45	54.48%	95.15%	-2.0	39.9	-10.1	-4.7	<DCGL	
20	0	69	18	14	42	55.20%	95.31%	-2.0	27.1	4.5	4.7	<DCGL	
21	1	91	17	15	40	55.69%	95.41%	0.5	74.3	2.7	5.8	<DCGL	
22	1	64	13	5	40	55.69%	95.41%	0.5	16.3	-4.5	-4.7	<DCGL	
23	1	64	19	11	40	55.69%	95.41%	0.5	16.3	6.3	1.6	<DCGL	
24	0	61	23	13	41	55.44%	95.36%	-2.0	9.9	13.5	3.7	<DCGL	
25	0	79	21	8	40	55.69%	95.41%	-2.0	48.5	9.9	-1.6	<DCGL	
26	1	64	9	12	41	55.44%	95.36%	0.5	16.3	-11.7	2.6	<DCGL	
27	0	61	14	6	41	55.44%	95.36%	-2.0	9.9	-2.7	-3.7	<DCGL	
28	0	65	19	9	41	55.44%	95.36%	-2.0	18.5	6.3	-0.5	<DCGL	
29	0	64	14	5	42	55.20%	95.31%	-2.0	16.3	-2.7	-4.7	<DCGL	
30	0	78	15	8	42	55.20%	95.31%	-2.0	46.4	-0.9	-1.6	<DCGL	
31	0	66	15	16	41	55.44%	95.36%	-2.0	20.6	-0.9	6.8	<DCGL	
32	0	74	26	7	42	55.20%	95.31%	-2.0	37.8	19.0	-2.6	<DCGL	
33	0	68	21	7	46	54.24%	95.09%	-2.0	24.9	10.1	-2.6	<DCGL	
34	0	83	23	13	45	54.48%	95.15%	-2.0	57.1	13.8	3.7	<DCGL	
35	0	71	19	9	47	54.00%	95.04%	-2.0	31.4	6.5	-0.5	<DCGL	
36	0	62	20	6	46	54.24%	95.09%	-2.0	12.0	8.3	-3.7	<DCGL	
37	3	74	19	7	42	55.20%	95.31%	5.6	37.8	6.3	-2.6	<DCGL	
38	0	75	19	6	40	55.69%	95.41%	-2.0	39.9	6.3	-3.7	<DCGL	
39	0	79	16	5	39	55.93%	95.47%	-2.0	48.5	0.9	-4.7	<DCGL	
40	0	75	25	7	44	54.72%	95.20%	-2.0	39.9	17.4	-2.6	<DCGL	
41	0	57	11	10	43	54.96%	95.25%	-2.0	1.3	-8.2	0.5	<DCGL	
42	0	67	17	11	42	55.20%	95.31%	-2.0	22.8	2.7	1.6	<DCGL	
43	2	68	16	10	45	54.48%	95.15%	3.0	24.9	0.9	0.5	<DCGL	
44	0	59	10	3	43	54.96%	95.25%	-2.0	5.6	-10.0	-6.8	<DCGL	
45	0	58	15	11	42	55.20%	95.31%	-2.0	3.4	-0.9	1.6	<DCGL	
46	0	64	29	16	40	55.69%	95.41%	-2.0	16.3	24.2	6.8	<DCGL	
47	1	71	20	11	42	55.20%	95.31%	0.5	31.4	8.2	1.6	<DCGL	
48	0	72	16	12	41	55.44%	95.36%	-2.0	33.5	0.9	2.6	<DCGL	
49	0	68	21	13	49	53.52%	94.93%	-2.0	24.9	10.3	3.7	<DCGL	

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Scintillation Counter
 Laboratory Areas

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 6 - Room B124								
Sample	CPM		Quench and Efficiency			MDC Values		Comments
	Chan A (H-3)	Chan B (C-14)	H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	
1	13	13	41	55.44%	95.36%	-4.5	3.7	<DCGL
2	11	16	42	55.20%	95.31%	-8.2	6.8	<DCGL
3	19	10	41	55.44%	95.36%	6.3	0.5	<DCGL
4	18	14	40	55.69%	95.41%	4.5	4.7	<DCGL
5	13	7	41	55.44%	95.36%	-4.5	-2.6	<DCGL
6	14	10	42	55.20%	95.31%	-2.7	0.5	<DCGL
7	15	7	39	55.93%	95.47%	-0.9	-2.6	<DCGL
8	20	8	41	55.44%	95.36%	8.1	-1.6	<DCGL
9	14	4	43	54.96%	95.25%	-2.7	-5.8	<DCGL
10	14	9	44	54.72%	95.20%	-2.7	-0.5	<DCGL
11	23	9	42	55.20%	95.31%	13.6	-0.5	<DCGL
12	16	7	40	55.69%	95.41%	0.9	-2.6	<DCGL
13	17	9	41	55.44%	95.36%	2.7	-0.5	<DCGL
14	15	13	41	55.44%	95.36%	-0.9	3.7	<DCGL
15	17	13	41	55.44%	95.36%	2.7	3.7	<DCGL
16	13	5	40	55.69%	95.41%	-4.5	-4.7	<DCGL
17	15	9	43	54.96%	95.25%	-0.9	-0.5	<DCGL
18	19	11	42	55.20%	95.31%	6.3	1.6	<DCGL
19	23	6	43	54.96%	95.25%	13.6	-3.7	<DCGL
20	10	9	43	54.96%	95.25%	-10.0	-0.5	<DCGL
21	21	11	44	54.72%	95.20%	10.1	1.6	<DCGL
22	15	3	44	54.72%	95.20%	-0.9	-6.8	<DCGL
23	20	8	40	55.69%	95.41%	8.1	-1.6	<DCGL
24	17	7	41	55.44%	95.36%	2.7	-2.6	<DCGL
25	15	10	42	55.20%	95.31%	-0.9	0.5	<DCGL
26	10	10	41	55.44%	95.36%	-9.9	0.5	<DCGL
27	13	10	42	55.20%	95.31%	-4.5	0.5	<DCGL
28	13	9	42	55.20%	95.31%	-4.5	-0.5	<DCGL
29	14	11	45	54.48%	95.15%	-2.8	1.6	<DCGL
30	15	11	44	54.72%	95.20%	-0.9	1.6	<DCGL
31	14	6	42	55.20%	95.31%	-2.7	-3.7	<DCGL
32	15	11	42	55.20%	95.31%	-0.9	1.6	<DCGL
33	16	9	43	54.96%	95.25%	0.9	-0.5	<DCGL
34	8	11	41	55.44%	95.36%	-13.5	1.6	<DCGL
35	12	11	42	55.20%	95.31%	-6.3	1.6	<DCGL
36	12	11	43	54.96%	95.25%	-6.4	1.6	<DCGL
37	17	11	41	55.44%	95.36%	2.7	1.6	<DCGL
38	14	11	40	55.69%	95.41%	-2.7	1.6	<DCGL
39	14	15	43	54.96%	95.25%	-2.7	5.8	<DCGL
40	22	10	40	55.69%	95.41%	11.7	0.5	<DCGL
41	18	7	40	55.69%	95.41%	4.5	-2.6	<DCGL
42	16	7	39	55.93%	95.47%	0.9	-2.6	<DCGL
43	17	9	38	56.17%	95.52%	2.7	-0.5	<DCGL
44	20	12	39	55.93%	95.47%	8.0	2.6	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 7 - Rooms B121, B122, B123								
Sample	CPM		Quench and Efficiency			Net DPM / 100 cm ²		Comments
	Chan A (H-3)	Chan B (C-14)	H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	
1	7	2	40	55.69%	95.41%	-15.3	-7.9	<DCGL
2	23	13	40	55.69%	95.41%	13.5	3.7	<DCGL
3	13	9	41	55.44%	95.36%	-4.5	-0.5	<DCGL
4	16	7	44	54.72%	95.20%	0.9	-2.6	<DCGL
5	11	6	45	54.48%	95.15%	-8.3	-3.7	<DCGL
6	17	10	47	54.00%	95.04%	2.8	0.5	<DCGL
7	13	11	43	54.96%	95.25%	-4.5	1.6	<DCGL
8	17	4	44	54.72%	95.20%	2.7	-5.8	<DCGL
9	14	10	42	55.20%	95.31%	-2.7	0.5	<DCGL
10	10	7	43	54.96%	95.25%	-10.0	-2.6	<DCGL
11	14	9	44	54.72%	95.20%	-2.7	-0.5	<DCGL
12	19	16	40	55.69%	95.41%	6.3	6.8	<DCGL
13	15	9	40	55.69%	95.41%	-0.9	-0.5	<DCGL
14	14	10	39	55.93%	95.47%	-2.7	0.5	<DCGL
15	17	11	42	55.20%	95.31%	2.7	1.6	<DCGL
16	17	2	40	55.69%	95.41%	2.7	-7.9	<DCGL
17	15	7	40	55.69%	95.41%	-0.9	-2.6	<DCGL
18	21	11	40	55.69%	95.41%	9.9	1.6	<DCGL
19	21	6	39	55.93%	95.47%	9.8	-3.7	<DCGL
20	23	6	38	56.17%	95.52%	13.4	-3.7	<DCGL
21	14	14	38	56.17%	95.52%	-2.7	4.7	<DCGL
22	10	9	39	55.93%	95.47%	-9.8	-0.5	<DCGL
23	11	15	39	55.93%	95.47%	-8.0	5.8	<DCGL
24	18	10	39	55.93%	95.47%	4.5	0.5	<DCGL
25	18	6	39	55.93%	95.47%	4.5	-3.7	<DCGL
26	22	13	39	55.93%	95.47%	11.6	3.7	<DCGL
27	12	8	38	56.17%	95.52%	-6.2	-1.6	<DCGL
28	18	5	39	55.93%	95.47%	4.5	-4.7	<DCGL
29	28	8	40	55.69%	95.41%	22.4	-1.6	<DCGL
30	26	8	40	55.69%	95.41%	18.9	-1.6	<DCGL
31	20	10	40	55.69%	95.41%	8.1	0.5	<DCGL
32	15	10	42	55.20%	95.31%	-0.9	0.5	<DCGL
33	19	12	41	55.44%	95.36%	6.3	2.6	<DCGL
34	14	8	40	55.69%	95.41%	-2.7	-1.6	<DCGL
35	16	13	41	55.44%	95.36%	0.9	3.7	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 8 - Rooms B126, B127, B128								
Sample	Quench and Efficiency		H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	Comments
	Chan A (H-3)	Chan B (C-14)						
1	23	5	39	55.93%	95.47%	13.4	-4.7	<DCGL
2	12	8	42	55.20%	95.31%	-6.3	-1.6	<DCGL
3	14	8	41	55.44%	95.36%	-2.7	-1.6	<DCGL
4	24	7	40	55.69%	95.41%	15.3	-2.6	<DCGL
5	17	8	39	55.93%	95.47%	2.7	-1.6	<DCGL
6	18	7	40	55.69%	95.41%	4.5	-2.6	<DCGL
7	14	6	42	55.20%	95.31%	-2.7	-3.7	<DCGL
8	14	5	39	55.93%	95.47%	-2.7	-4.7	<DCGL
9	15	8	41	55.44%	95.36%	-0.9	-1.6	<DCGL
10	15	9	42	55.20%	95.31%	-0.9	-0.5	<DCGL
11	17	6	42	55.20%	95.31%	2.7	-3.7	<DCGL
12	20	16	40	55.69%	95.41%	8.1	6.8	<DCGL
13	15	10	40	55.69%	95.41%	-0.9	0.5	<DCGL
14	20	10	40	55.69%	95.41%	8.1	0.5	<DCGL
15	21	7	39	55.93%	95.47%	9.8	-2.6	<DCGL
16	15	6	40	55.69%	95.41%	-0.9	-3.7	<DCGL
17	11	6	40	55.69%	95.41%	-8.1	-3.7	<DCGL
18	21	10	45	54.48%	95.15%	10.1	0.5	<DCGL
19	18	10	47	54.00%	95.04%	4.6	0.5	<DCGL
20	17	8	45	54.48%	95.15%	2.8	-1.6	<DCGL
21	13	8	47	54.00%	95.04%	-4.6	-1.6	<DCGL
22	19	10	44	54.72%	95.20%	6.4	0.5	<DCGL
23	10	8	44	54.72%	95.20%	-10.1	-1.6	<DCGL
24	16	12	42	55.20%	95.31%	0.9	2.6	<DCGL
25	14	9	44	54.72%	95.20%	-2.7	-0.5	<DCGL
26	20	7	43	54.96%	95.25%	8.2	-2.6	<DCGL
27	23	4	42	55.20%	95.31%	13.6	-5.8	<DCGL
28	17	10	44	54.72%	95.20%	2.7	0.5	<DCGL
29	8	12	42	55.20%	95.31%	-13.6	2.6	<DCGL
30	17	5	42	55.20%	95.31%	2.7	-4.7	<DCGL
31	17	4	41	55.44%	95.36%	2.7	-5.8	<DCGL
32	12	5	41	55.44%	95.36%	-6.3	-4.7	<DCGL
33	21	8	41	55.44%	95.36%	9.9	-1.6	<DCGL
34	14	10	41	55.44%	95.36%	-2.7	0.5	<DCGL
35	9	13	42	55.20%	95.31%	-11.8	3.7	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 9 - Room B131A								
Sample	CPM		Quench and Efficiency			Net DPM / 100 cm ²		Comments
	Chan A (H-3)	Chan B (C-14)	H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	
1	15	6	44	54.72%	95.20%	-0.9	-3.7	<DCGL
2	20	9	52	52.80%	94.77%	8.5	-0.5	<DCGL
3	13	10	45	54.48%	95.15%	-4.6	0.5	<DCGL
4	18	7	46	54.24%	95.09%	4.6	-2.6	<DCGL
5	6	13	42	55.20%	95.31%	-17.2	3.7	<DCGL
6	22	8	43	54.96%	95.25%	11.8	-1.6	<DCGL
7	22	11	44	54.72%	95.20%	11.9	1.6	<DCGL
8	23	9	49	53.52%	94.93%	14.0	-0.5	<DCGL
9	17	5	43	54.96%	95.25%	2.7	-4.7	<DCGL
10	20	5	44	54.72%	95.20%	8.2	-4.7	<DCGL
11	11	9	47	54.00%	95.04%	-8.3	-0.5	<DCGL
12	10	12	42	55.20%	95.31%	-10.0	2.6	<DCGL
13	15	6	48	53.76%	94.99%	-0.9	-3.7	<DCGL
14	20	6	44	54.72%	95.20%	8.2	-3.7	<DCGL
15	19	9	47	54.00%	95.04%	6.5	-0.5	<DCGL
16	18	9	49	53.52%	94.93%	4.7	-0.5	<DCGL
17	11	14	44	54.72%	95.20%	-8.2	4.7	<DCGL
18	20	13	47	54.00%	95.04%	8.3	3.7	<DCGL
19	14	5	42	55.20%	95.31%	-2.7	-4.7	<DCGL
20	5	8	41	55.44%	95.36%	-18.9	-1.6	<DCGL
21	13	5	41	55.44%	95.36%	-4.5	-4.7	<DCGL
22	21	5	42	55.20%	95.31%	10.0	-4.7	<DCGL
23	20	11	41	55.44%	95.36%	8.1	1.6	<DCGL
24	18	10	41	55.44%	95.36%	4.5	0.5	<DCGL
25	14	15	41	55.44%	95.36%	-2.7	5.8	<DCGL
26	16	12	40	55.69%	95.41%	0.9	2.6	<DCGL
27	9	14	40	55.69%	95.41%	-11.7	4.7	<DCGL
28	18	6	40	55.69%	95.41%	4.5	-3.7	<DCGL
29	22	10	43	54.96%	95.25%	11.8	0.5	<DCGL
30	15	12	44	54.72%	95.20%	-0.9	2.6	<DCGL
31	9	10	42	55.20%	95.31%	-11.8	0.5	<DCGL
32	13	10	40	55.69%	95.41%	-4.5	0.5	<DCGL
33	18	9	42	55.20%	95.31%	4.5	-0.5	<DCGL
34	9	10	42	55.20%	95.31%	-11.8	0.5	<DCGL
35	17	5	41	55.44%	95.36%	2.7	-4.7	<DCGL
36	20	12	41	55.44%	95.36%	8.1	2.6	<DCGL
37	19	11	41	55.44%	95.36%	6.3	1.6	<DCGL
38	18	9	41	55.44%	95.36%	4.5	-0.5	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 10 - Room B131B, B131C								
Sample	Background Values		Quench and Efficiency			Net DPM / 100 cm ²		Comments
	Chan A (H-3)	Chan B (C-14)	H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	
1	13	13	41	55.44%	95.36%	-4.5	3.7	<DCGL
2	15	6	44	54.72%	95.20%	-0.9	-3.7	<DCGL
3	15	5	44	54.72%	95.20%	-0.9	-4.7	<DCGL
4	11	5	41	55.44%	95.36%	-8.1	-4.7	<DCGL
5	16	4	42	55.20%	95.31%	0.9	-5.8	<DCGL
6	18	5	44	54.72%	95.20%	4.6	-4.7	<DCGL
7	23	9	44	54.72%	95.20%	13.7	-0.5	<DCGL
8	23	9	45	54.48%	95.15%	13.8	-0.5	<DCGL
9	18	2	42	55.20%	95.31%	4.5	-7.9	<DCGL
10	21	15	43	54.96%	95.25%	10.0	5.8	<DCGL
11	15	9	44	54.72%	95.20%	-0.9	-0.5	<DCGL
12	15	7	43	54.96%	95.25%	-0.9	-2.6	<DCGL
13	13	5	46	54.24%	95.09%	-4.6	-4.7	<DCGL
14	14	8	42	55.20%	95.31%	-2.7	-1.6	<DCGL
15	23	3	44	54.72%	95.20%	13.7	-6.8	<DCGL
16	18	11	43	54.96%	95.25%	4.5	1.6	<DCGL
17	15	14	45	54.48%	95.15%	-0.9	4.7	<DCGL
18	16	8	44	54.72%	95.20%	0.9	-1.6	<DCGL
19	18	7	42	55.20%	95.31%	4.5	-2.6	<DCGL
20	17	7	44	54.72%	95.20%	2.7	-2.6	<DCGL
21	13	11	44	54.72%	95.20%	-4.6	1.6	<DCGL
22	16	8	41	55.44%	95.36%	0.9	-1.6	<DCGL
23	10	8	43	54.96%	95.25%	-10.0	-1.6	<DCGL
24	8	7	41	55.44%	95.36%	-13.5	-2.6	<DCGL
25	20	11	41	55.44%	95.36%	8.1	1.6	<DCGL
26	19	11	41	55.44%	95.36%	6.3	1.6	<DCGL
27	11	11	42	55.20%	95.31%	-8.2	1.6	<DCGL
28	13	9	42	55.20%	95.31%	-4.5	-0.5	<DCGL
29	12	10	41	55.44%	95.36%	-6.3	0.5	<DCGL
30	12	8	42	55.20%	95.31%	-6.3	-1.6	<DCGL
31	17	9	42	55.20%	95.31%	2.7	-0.5	<DCGL
32	29	15	41	55.44%	95.36%	24.3	5.8	<DCGL
33	11	6	40	55.69%	95.41%	-8.1	-3.7	<DCGL
34	21	9	40	55.69%	95.41%	9.9	-0.5	<DCGL
35	19	8	41	55.44%	95.36%	6.3	-1.6	<DCGL
36	19	9	40	55.69%	95.41%	6.3	-0.5	<DCGL
37	19	8	40	55.69%	95.41%	6.3	-1.6	<DCGL
38	20	9	41	55.44%	95.36%	8.1	-0.5	<DCGL
39	19	10	40	55.69%	95.41%	6.3	0.5	<DCGL
40	14	6	40	55.69%	95.41%	-2.7	-3.7	<DCGL
41	18	8	42	55.20%	95.31%	4.5	-1.6	<DCGL
42	10	6	42	55.20%	95.31%	-10.0	-3.7	<DCGL

Philotechnics Analytical Worksheet
VAPAHCS - Building 2
3801 Miranda Ave. Palo Alto, CA

Appendix G

Background Values		MDC Values	
CPM		Net DPM / 100 cm ²	
Chan A	Chan B	H-3	C-14/S-35
15.5	9.5	33.9	17.9

Survey Unit 11 - Basement Hallway								
Sample	CPM		Quench and Efficiency			Net DPM / 100 cm ²		Comments
	Chan A (H-3)	Chan B (C-14)	H#	H-3 Eff.	C-14 Eff.	Chan A (H-3)	Chan B (C-14)	
1	17	7	52	52.80%	94.77%	2.8	-2.6	<DCGL
2	12	12	61	50.63%	94.29%	-6.9	2.7	<DCGL
3	8	10	58	51.35%	94.45%	-14.6	0.5	<DCGL
4	12	10	57	51.59%	94.51%	-6.8	0.5	<DCGL
5	14	10	59	51.11%	94.40%	-2.9	0.5	<DCGL
6	14	5	61	50.63%	94.29%	-3.0	-4.8	<DCGL
7	20	12	61	50.63%	94.29%	8.9	2.7	<DCGL
8	18	8	66	49.42%	94.02%	5.1	-1.6	<DCGL
9	13	11	60	50.87%	94.35%	-4.9	1.6	<DCGL
10	16	14	58	51.35%	94.45%	1.0	4.8	<DCGL
11	20	5	60	50.87%	94.35%	8.8	-4.8	<DCGL
12	15	7	67	49.18%	93.97%	-1.0	-2.7	<DCGL
13	16	6	60	50.87%	94.35%	1.0	-3.7	<DCGL
14	17	8	60	50.87%	94.35%	2.9	-1.6	<DCGL
15	19	6	61	50.63%	94.29%	6.9	-3.7	<DCGL
16	11	15	74	47.50%	93.60%	-9.5	5.9	<DCGL
17	17	15	70	48.46%	93.81%	3.1	5.9	<DCGL
18	14	10	74	47.50%	93.60%	-3.2	0.5	<DCGL
19	23	11	54	52.31%	94.67%	14.3	1.6	<DCGL
20	19	14	55	52.07%	94.61%	6.7	4.8	<DCGL
21	16	16	60	50.87%	94.35%	1.0	6.9	<DCGL
22	16	6	63	50.15%	94.18%	1.0	-3.7	<DCGL
23	15	9	69	48.70%	93.86%	-1.0	-0.5	<DCGL

Enclosure 2

Correspondence between NHPP and Permittee Radiation Safety Officer

From: Huston, Thomas E. [mailto:Thomas.Huston2@va.gov]
Sent: Thursday, September 08, 2011 2:58 PM
To: ljpchp@stanford.edu
Subject: Followup Question for Bldg. 2 Decommissioning Based on NHPP Review of NRC Docket Files

Lance,

NHPP received the NRC docket files on 8/31/2011. They amounted to about a 2-foot stack of papers. I have reviewed the information and identified one item for follow-up.

Back in 1989, during an inspection, NRC identified an issue involving a radioactive source in Room A107 of Bldg. 2. According to the files, the room housed a Bone Mineral Analyzer device with a radioactive source inside. I was unable to determine what radionuclide or activity was involved or what happened to the source. And this room is not included in the Decommissioning Report for Building 2. I suspect that the source has been removed from the area and that it is unlikely that the source ever leaked. However, I will need some supplemental information from you.

1. Can you please confirm that the source was transferred to another authorized area in a different building or to another authorized recipient?
2. Can you verify from past records whether there was any indication of the source leaking in the room? One option to providing information about source leakage is to simply perform a survey in the room (take a few wipes and do a scan with a GM pancake) and confirm no residual radioactivity. If you choose the survey route, please provide ample detail about area wiped, count results, scan survey technique (distance and speed of probe), as well as some calibration information.

My plan is to include this supplemental information as a second enclosure to our letter to NRC—where the main report by Philotechnics would be the first enclosure.

Please provide the information as soon as possible so I can send everything on to NRC for their approval.

Thanks,
Tom

Thomas E. Huston, PhD, CHP
National Health Physics Program (115/HP)
Veterans Health Administration
Wk: 501-257-1578; Cell: 501-454-7264; Fax: 501-257-1570

From: Lance J. Phillips [mailto:ljpchp@stanford.edu]
Sent: Wednesday, September 14, 2011 12:56 PM
To: Huston, Thomas E.
Subject: RE: Followup Question for Bldg. 2 Decommissioning Based on NHPP Review of NRC Docket Files

Tom

After some diligent research we have found the whole story.

There were two separate machines in Bldg2 Room A107. Each housed sealed sources. One housed a I125 source and the other Gd153.

First the I125 unit.

The unit was transferred to another VA bldg. on April 4, 1989. At that time the I125 source was down to 9.13 microCi. A quick decay calculation shows that if for some reason the source was not removed the current activity would be 9.44 E ^{-41} microCi.

Now the Gd153 unit.

The unit was transferred to Stanford HP on October 9, 1992. At that time the Gd153 source was down to 115.3 milliCi. A quick decay calculation shows that if for some reason the source was not removed the current activity would be 2.84 E ^{-4} microCi.

Both sources were repeatedly leak checked and no leakage was ever found.

Hope this helps.

Lance

UPS CampusShip: View/Print Label

1. **Print the label(s):** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.
3. **GETTING YOUR SHIPMENT TO UPS Customers without a Daily Pickup**
 Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages.
 Hand the package to any UPS driver in your area.
 Take your package to any location of The UPS Store®, UPS Drop Box, UPS Customer Center, UPS Alliances (Office Depot® or Staples®) or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Customers with a Daily Pickup
 Your driver will pickup your shipment(s) as usual.

FOLD HERE

LISA OFFUTT 5012571574 VHA NATIONAL HEALTH PHYSICS PR 2200 FT ROOTS DR B101 R208D NORTH LITTLE ROCK AR 72114	1.0 LBS LTR	1 OF 1
SHIP TO: KEVIN NULL 6308299887 US NRC REGION III SUITE 210 2443 WARRENVILLE RD LISLE IL 60532-4352		
	IL 603 9-03 	
UPS NEXT DAY AIR		
TRACKING #: 1Z A47 7F5 01 9360 2918		1
		
BILLING: P/P		
Reference # 1: LMO Reference # 2: kelly.mayo@va.gov		
CS 13.6.08. WXP1E70 18.0A 07/2011 LMO 		