



Nuclear Regulatory Commission  
Exhibit # - SNCR20001-MA-CM01  
Docket # - 05200025 | 05200026  
Identified: 09/27/2011

Admitted: 09/27/2011  
Rejected:

Withdrawn:  
Stricken:

SNCR20001



# Vogtle 3 & 4 COL

---

Southern Nuclear Operating Company  
VEGP Units 3 & 4  
Combined Licenses and  
Limited Work Authorization  
Mandatory Hearing

Introduction and Overview  
September 27, 2011

Joseph A. Miller  
Executive Vice President – Nuclear Development

Charles R. Pierce  
Licensing Manager Vogtle 3 and 4

---

# Vogtle 3&4 Overview


---





# Vogtle Construction Program

---



# Vogtle 3&4 Overview



# Construction Status (September 18)

---


- ◆ Unit 3
  - ◆ Backfill 83% complete
  - ◆ Mud mats & waterproof membrane installed; **ready for base mat rebar start**
  - ◆ MSE Wall 90% Complete
  - ◆ MSE Wall Waterproofing 65% Complete
  - ◆ CWS 100% complete in backfill
- ◆ Unit 4
  - ◆ Backfill 53% complete
  - ◆ Lower mud mat placed
  - ◆ MSE Wall 78% Complete
  - ◆ CWS 100% complete in backfill











## COL/LWA Issuance

---

- ◆ SNC has requested by letter that COL/LWA-B be issued based on affirmation of AP1000 Design Certification Rule
  - ◆ Affirmation would constitute final Commission approval of design –necessary findings could be made
  - ◆ No impact on safety review
  
- ◆ LWA-B at earliest allowable date would benefit quality of construction in a number of ways
  - ◆ Avoids disruption of construction processes important to quality
  - ◆ Maintenance of construction completed to date enhanced



# Application Concepts

---

- ◆ Combined License Application ("COLA") for 2 Units
  - ◆ Meets Part 52, Subpart C "Combined Licenses"
  - ◆ Is the Reference COLA for utilities' standard contents
  - ◆ IBRs AP1000 DCD Rev 19
  - ◆ IBRs Vogtle 3 and 4 Early Site Permit information
  
- ◆ NRC Guidance Utilized
  - ◆ Regulatory Guide 1.206
  - ◆ NUREG-0800 (generally updated for Part 52)
  
- ◆ Other COLA IBRs
  - ◆ Nuclear Energy Institute (NEI) templates



# Introduction: Design Centered Review Approach

---

- ◆ NRC use of "One issue, one review, one position"
- ◆ Maximum benefit achieved through standardization
- ◆ Reference (R)-COLA – Southern Nuclear, Vogtle (GA)
- ◆ The AP1000 DCWG is also comprised of these additional Members (Subsequent (S)-COLAs):
  - ◆ South Carolina Electric & Gas, Summer (SC)
  - ◆ Duke Energy, Lee Nuclear (SC)
  - ◆ Progress Energy, Levy County (FL)
  - ◆ Progress Energy, Shearon Harris (NC)
  - ◆ Florida Power and Light, Turkey Point (FL)
  - ◆ Tennessee Valley Authority, Bellefonte (AL)
- ◆ NuStart Coordination
  - ◆ DCWG, WEC, NEI, NRC Staff
  - ◆ Extensive public interactions



## Vogtle 3&4 Overview

---

- ◆ Vogtle COL Application submitted Mar 2008
- ◆ Submitted initially as S-COLA following TVA BLN as the R-COLA
- ◆ Began Vogtle transition to RCOLA in Apr 2009
- ◆ Vogtle includes applicable Bellefonte 3 & 4 standard material
- ◆ Vogtle FSER contains NRC Staff's complete evaluation

# Reference (and S-)COL Application

---

- ◆ Part 1 – General & Administrative Information
- ◆ Part 2 – Final Safety Analysis Report
- ◆ Part 3 – Environmental Report
- ◆ Part 4 – Technical Specifications
- ◆ Part 5 – Emergency Plan
- ◆ Part 6 – Limited Work Authorization
- ◆ Part 7 – Departures, Exemptions & Variances
- ◆ Part 8 – Safeguards/Security Plans
- ◆ Part 9 – Withheld Information
- ◆ Part 10 – License Conditions (including ITAAC)
- ◆ Part 11 – Enclosures

# COL Application Highlights

---

- ◆ Departures from AP1000 DCD Rev 19
- ◆ Variances
- ◆ Exemptions from the Regulations
- ◆ DCD COL Information and Holder Items
- ◆ Early Site Permit COL Items
- ◆ ESP Permit Conditions

# COL Application Highlights

---

- ◆ ITAAC comprised of:
  - ◆ VEGP ESP
  - ◆ DCD
  - ◆ Few additional “Plant-specific” ITAAC in COLA



# COL Application Highlights

---

- ◆ Comparison of Site Characteristics to Certified Design Site Parameters
  - ◆ COL comparison confirms:
    - ◆ DCD Site Parameters are bounding for the site specific Site Characteristics, OR
    - ◆ Justification is provided (10 CFR 52.79(d)(1))
  - ◆ All Vogtle Site Characteristics within bounding DCD Site Parameters (FSAR Section 2.0)



## COL Application Highlights - NEPA

---

- ◆ ESP FEIS resolved all environmental issues associated with construction and operation
- ◆ New & significant review performed throughout COL process
- ◆ No new **AND** significant information identified
- ◆ COL FSEIS issued (March 24, 2011)
  - ◆ ESP FEIS findings still applicable
  - ◆ FSEIS recommends that the COL and LWA-B be issued
- ◆ NEPA § 102(2) (A), (C), & (E) requirements are met
- ◆ Environmental, economic and technical benefits of the project outweigh the environmental impacts and other costs



# Summary of Vogtle COL Application

---

- ◆ Serves as the AP1000 R-COLA
- ◆ Incorporates the AP1000 DCD Amendment by reference
- ◆ Incorporates an approved ESP by reference
- ◆ Provides reasonable assurance two AP1000 units can be safely constructed and operated on the VEGP site
- ◆ All required findings can be made by the NRC to allow issuance of the LWA-B and COLs

**UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION**

**BEFORE THE COMMISSION**

<b>In the Matter of</b>	)	
	)	
<b>Southern Nuclear Operating Company</b>	)	<b>Docket Nos. 52-025-COL and 52-026-COL</b>
	)	
<b>(Vogtle Electric Generating Plant,</b>	)	<b>September 26, 2011</b>
<b>Units 3 and 4)</b>	)	

**CERTIFICATE OF SERVICE**

I hereby certify that copies of EXHIBIT SNCR20001 for the Vogtle Units 3 & 4 COL Mandatory Hearing in the above-captioned proceeding have been served by electronic mail as shown below, this 26th day of September, 2011, and/or by e-submittal.

M. Stanford Blanton  
C. Grady Moore  
Peter D. LeJeune  
Leslie Garrett Allen  
Millicent Ronnlund  
Balch & Bingham LLP  
P. O. Box 306  
Birmingham, AL 35201  
(E-mail: [sblanton@balch.com](mailto:sblanton@balch.com);  
[plejeune@balch.com](mailto:plejeune@balch.com);  
[mronnlund@balch.com](mailto:mronnlund@balch.com))

Marcia Carpentier  
Karen Francis  
Joseph Gilman  
Ann P. Hodgdon  
Sara Kirkwood  
Patrick A. Moulding  
Marian Zabler  
Office of the General Counsel  
Mail Stop O-15D-21  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001  
(E-mail: [marcia.carpentier@nrc.gov](mailto:marcia.carpentier@nrc.gov);  
[karin.francis@nrc.gov](mailto:karin.francis@nrc.gov);  
[joseph.gilman@nrc.gov](mailto:joseph.gilman@nrc.gov);  
[ann.hodgdon@nrc.gov](mailto:ann.hodgdon@nrc.gov);  
[sara.kirkwood@nrc.gov](mailto:sara.kirkwood@nrc.gov);  
[patrick.moulding@nrc.gov](mailto:patrick.moulding@nrc.gov);  
[marian.zabler@nrc.gov](mailto:marian.zabler@nrc.gov))

Kristy Remsburg  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001  
(E-mail: [ogcmailcenter@nrc.gov](mailto:ogcmailcenter@nrc.gov))

Office of Commission Appellate  
Adjudication  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001  
(E-mail: [ocaamail@nrc.gov](mailto:ocaamail@nrc.gov))

Charles Pierce  
Southern Nuclear Operating Company  
42 Inverness Center Parkway  
Birmingham, AL 35242  
(E-mail: [CRPIERCE@southernco.com](mailto:CRPIERCE@southernco.com))

Kathryn M. Sutton  
Mary Freeze  
Morgan, Lewis & Bockius, LLP  
1111 Pennsylvania Ave., N.W.  
Washington, DC 20004  
(E-mail: [ksutton@morganlewis.com](mailto:ksutton@morganlewis.com);  
[mfreeze@morganlewis.com](mailto:mfreeze@morganlewis.com))

Office of the Secretary  
Mail Stop O-16C1  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001  
(E-mail: [HEARINGDOCKET@nrc.gov](mailto:HEARINGDOCKET@nrc.gov))

Anita Ghosh  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001  
(E-mail: [anita.ghosh@nrc.gov](mailto:anita.ghosh@nrc.gov))

Rebecca Giitter  
U.S. Nuclear Regulatory Commission  
Rulemakings and Adjudications Staff  
Office of the Secretary  
Washington, D.C. 20555-0001  
(E-mail: [rebecca.giitter@nrc.gov](mailto:rebecca.giitter@nrc.gov))

Respectfully submitted,

(Original signed by M. Stanford Blanton)

---

M. Stanford Blanton, Esq.  
BALCH & BINGHAM LLP  
1710 Sixth Avenue North  
Birmingham, AL 35203-2015  
Telephone: (205) 251-8100  
Facsimile: (205) 226-8798

COUNSEL FOR SOUTHERN NUCLEAR  
OPERATING COMPANY

Kathryn M. Sutton, Esq.  
MORGAN, LEWIS & BOCKIUS LLP  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004  
Telephone: (202) 739-5738  
Facsimile: (202) 739-3001  
CO-COUNSEL FOR SOUTHERN NUCLEAR  
OPERATING COMPANY