

PMSTPCOL PEmails

From: Tai, Tom
Sent: Thursday, August 25, 2011 3:27 PM
To: Price, John E
Cc: STPCOL
Subject: STP - Question on Response to 03.09.02-49 S1

John,

In the response to RAI 03.09.02-49 S1, item a, STP stated that all of the welds in the dryer are not full penetration welds, and the high stress locations have full penetration welds. The staff requests STP to confirm that the highest stresses at non full penetration welds do not exceed the fatigue limit, and revise the RAI response. The weld factor for non full penetration welds (4 vs. 2) may cause these weld location stresses to exceed the fatigue limit.

Let's plan to discuss this during the Wednesday (8/31) call.

I'll be sending you the complete EMB2 and SEB2 agenda no later than Monday (8/29). I want to make sure I have a chance to go over the agenda with Samir and Manas Monday when they both return.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3043

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED142B617EDAC)

Subject: STP - Question on Response to 03.09.02-49 S1
Sent Date: 8/25/2011 3:26:42 PM
Received Date: 8/25/2011 3:26:45 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Price, John E" <jeprice@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	836	8/25/2011 3:26:45 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: