

CCNPP3eRAIPEm Resource

From: Arora, Surinder
Sent: Thursday, September 29, 2011 7:17 AM
To: Infanger, Paul
Cc: CCNPP3eRAIPEm Resource; Colaccino, Joseph; Hearn, Peter; Wilson, Anthony; Vrahoretis, Susan; McCann, Edward; Dreisbach, Jason; Segala, John
Subject: Final RAI 321 SBPA 5954
Attachments: FINAL RAI 321 SBPA 5954.doc

Paul,

Attached please find the subject request for additional information (RAI). The draft of this RAI was sent to you on September 19, 2011. A clarification phone call to discuss the draft question was held on September 27, 2011; however, no changes were required to the draft question. The RAI is, therefore, being issued as "Final".

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a schedule date for submitting your technically correct and complete response will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the review schedule of the applicable FSAR Chapter.

Your response letter should also include a statement confirming that the response does or does not contain any sensitive or proprietary information.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Col_RAI
Email Number: 151

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED85B8458B15)

Subject: Final RAI 321 SBPA 5954
Sent Date: 9/29/2011 7:16:56 AM
Received Date: 9/29/2011 7:16:59 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3eRAIPEm Resource" <CCNPP3eRAIPEm.Resource@nrc.gov>

Tracking Status: None

"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>

Tracking Status: None

"Hearn, Peter" <Peter.Hearn@nrc.gov>

Tracking Status: None

"Wilson, Anthony" <Anthony.Wilson@nrc.gov>

Tracking Status: None

"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>

Tracking Status: None

"McCann, Edward" <Edward.McCann@nrc.gov>

Tracking Status: None

"Dreisbach, Jason" <Jason.Dreisbach@nrc.gov>

Tracking Status: None

"Segala, John" <John.Segala@nrc.gov>

Tracking Status: None

"Infanger, Paul" <paul.infanger@unistarnuclear.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1185	9/29/2011 7:16:59 AM
FINAL RAI 321 SBPA 5954.doc		30202

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information No. 321 (eRAI 5954)

9/29/2011

Calvert Cliffs Unit 3

UniStar

Docket No. 52-016

SRP Section: 09.05.01 - Fire Protection Program

Application Section: 9.5.1

QUESTIONS for Balance of Plant Branch 1 (SBPA)

09.05.01-18

Section 9.5.1.2.1 addresses COL Information Item 9.5-19 which relates to providing site-specific Fire Protection System piping and instrumentation diagrams. The applicant in this section described providing Figures 9.5-2 and 9.5-3 to address this issue. CCNPP Unit 3 FSAR Revision 6 had these figures as per Section 9.5.1.2.1. CCNPP Unit 3 FSAR Revision 7 revised Figures 9.5-1, 9.5-2, and 9.5-3 such that the write-up in Section 9.5.1.2.1 no longer applies to the revised figures. Update Section 9.5.1.2.1 to agree with CCNPP Unit 3 FSAR Revision 7 revised Figures 9.5-1, 9.5-2, and 9.5-3.