NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M N M N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 6 3 (7) | 1 0 2 1 7 8 (8) | 1 1 2 2 7 8 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | DURING LOCAL LEAK TEST, RCIC-9, RCIC TURBINE EXHAUST LINE CHECK VALVE WAS FOUND
03 | LEAKING IN EXCESS OF TECHNICAL SPECIFICATION ACCEPTANCE CRITERIA (T.S. 4.7.A.2.F).
04 | THE AS FOUND LEAKAGE WAS 25.0 scfh. ONE PREVIOUS EVENT (M-RO-78-024).
05 |
06 |
07 |
08 |

09 | SYSTEM CODE S D (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE V A L V E X (14) | COMP. SUBCODE C (15) | VALVE SUBCODE A (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 2 5 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN B (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER A 3 9 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | ANCHOR VALVE COMPANY, 8"-150 LB. SWING CHECK VALVE, 2373-5, ASTM 216 WCB.
11 | FAILED TEST DUE TO ACCUMULATED DIRT ON SEATING SURFACES. SEATS CLEANED. RETESTED
12 | SATISFACTORILY. PLAN TO INSTALL A DIFFERENT TYPE PRIMARY CONTAINMENT ISOLATION
13 | VALVE IN EXHAUST LINE.
14 |

15 | FACILITY STATUS H (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) LOCAL LEAK RATE TEST

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

7811280253

NAME OF PREPARER S. J. HAMMER PHONE: 612/295-5151

GPO 917-926