MEMO ROUTE SL(P Form ERDA=93 (1-75) ERDAM 0240			No.	See me about this. Note and return.	J	For concurrence.		For information:
TO (Name and unl	1)	INITIALS	RI	REMARKS				
IE Chief, FC&EB IE:HQ(4) Licensing(4) DR Central Files. J. Rizzo, OMIPC			Northern States Power Company					
		DATE		Monticello	Plar	nt.		
				Docket No.	. 50-2	263		
TO (Name and unit)		INITIALS	R	EMARKS				
A/D for Info. Processi		ng		· · · · · · · · · · · · · · · · · · ·				
Region I								
Region II		DATE	_					
PDR								* * * * * * * * * * * * * * * * * * *
Local PDR								
TO (Name and unit)		INITIALS	R	EMARKS .				
NSIC			-					
OGC, Beth, P-506A		DATE						
ogo, Beth, 1-50011		DATE						
] .						<u> </u>
FROM (Name and unit) G. Fiorelli IE:III		REMARKS Attached is a copy of licensee's reply dated November 24,						
		1975, to IE Bulletin 75-04A.						
PHONE NO.	DATE							
	11/28/75	11,5			5		<u>ki saji was</u>	
				ISE OTHER SIDE FOR ADDITIO	ONAL REMA	RKS.		GPO : 1975 O-577-369

.



NORTHERN

November 24, 1975

Mr. J. G. Keppler Director - Region III Office of Inspection and Enforcement United States Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

This monthly summary report is submitted as requested in IE Bulletin 75-04A. (As discussed with Mr. E. Jordan of your office, this report is being submitted on November 24, 1975, rather than November 23, 1975.) As a result of the review of fire detection sensor and fire hose station locations, the following changes to the facility are scheduled to be completed by May 23, 1976:

- Installation of fire detection sensors in the Standby Gas Treatment Room, the 4.16 KV Switchgear Area, and the Intake Structure Pump Room.
- 2. Installation of a fire hose station in the Intake Structure Pump

Also, four fire hose stations located in the Administration Building have been fitted with nozzles designed for use on electrical fires.

Yours very truly,

L. J. Wachter

Vice President - Power Production

and System Operation

cc: Mr. R. S. Boyd

Mr. G. Charnoff

Minnesota Pollution Control Agency

Attention: Mr. J. W. Ferman

RECEIVED DIVISION OF ACCOUNTING

U.S. NUCLEAR REGULATORY COMMISSION