Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title:	Advisory Committee on Reactor Safeguards Reliability and Probabilistic Risk Assessment
Docket Number:	(n/a)
Location:	Rockville, Maryland
Date:	Wednesday, September 21, 2011

Work Order No.: NRC-1154

Pages 1-139

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + +
7	SUBCOMMITTEE ON RELIABILITY AND
8	PROBABILISTIC RISK ASSESSMENT
9	+ + + + +
10	WEDNESDAY
11	SEPTEMBER 21, 2011
12	+ + + +
13	ROCKVILLE, MARYLAND
14	+ + + +
15	The Subcommittee met at the Nuclear
16	Regulatory Commission, Two White Flint North, Room
17	T2B3, 11545 Rockville Pike, at 1:00 P.m., John
18	Stetkar, Chairman, presiding.
19	SUBCOMMITTEE MEMBERS PRESENT:
20	JOHN W. STETKAR, Chair
21	SAID ABDEL-KHALIK
22	DENNIS C. BLEY *
23	JOY REMPE
24	WILLIAM J. SHACK
25	GORDON R. SKILLMAN
I	

		2
1	NRC STAFF PRESENT:	
2	JOHN LAI, Designated Federal Official	
3	RICH CORREIA	
4	SUSAN COOPER	
5	MARK SALLEY	
6	STEPHEN DINSMORE	
7	THERON BROWN	
8		
9		
10	ALSO PRESENT:	
11	ERIN COLLINS	
12	STACEY HENDRICKSON	
13	JEFF JULIUS *	
14	JOHN FORESTER *	
15		
16	* Present via telephone	
17		
18		
19		
20		
21		
22		
23		
24		
25		
ļ	1	

	3
1	C-O-N-T-E-N-T-S
2	Page
3	Opening Remarks 4
4	J. Stetkar, ACRS
5	EPRI/NRC-RES Fire HRA Guidelines
6	(NUREG-1921) :
7	RES Management Remarks 6
8	Rich Correia, RES
9	Fire HRA Guidelines: Updates
10	Susan Cooper, RES
11	Erin Collins, SAIC
12	Stacey Hendrickson, SNL
13	Fire HRA Guidelines Project Status and
14	Path Forward
15	Stacey Hendrickson, SNL
16	Member Discussion
17	Adjournment
18	
19	
20	
21	
22	
23	
24	
25	
ļ	

	4
1	P-R-O-C-E-E-D-I-N-G-S
2	1:00 p.m.
3	CHAIR STETKAR: The meeting will now
4	come to order. This is a meeting of the Reliability
5	and PRA Subcommittee. I'm John Stetkar, chairman of
6	the Subcommittee meeting.
7	The ACRS members in attendance are Said
8	Abdel-Khalik, Dick Skillman, Dennis Bly, Bill Shack,
9	and Joy Rupee. John Lai of the ACRS staff is the
10	designated federal official for this meeting.
11	The subcommittee will hear the latest
12	developments with fire HRA guidelines in NUREG
13	1921. We'll hear presentations from the NRC staff
14	and NRC contractors. There will be a phone bridge
15	line. To preclude interruption of the meeting, the
16	phone will be place in the listen-in mod during the
17	presentations and committee discussions. We have
18	received no written comments or requests for time to
19	make oral statements from members of the public
20	regarding today's meeting. The entire meeting will
21	be open to public attendance.
22	Simply, we will gather information,
23	analyze relevant issues and facts, and formulate
24	proposed positions and actions as appropriate for
25	deliberation by the full committee.
	I

(202) 234-4433

	5
1	The rules for participation in today's
2	meeting have been announced as a part of the notice
3	of this meeting previously, published in the Federal
4	Register. A transcript of the meeting is being kept
5	and will be made available as stated in the Federal
6	Register notice.
7	We request that participants in this
8	meeting use the microphones located throughout the
9	meeting room when addressing the subcommittee. The
10	participants should first identify themselves and
11	speak with sufficient clarity and volume so that
12	they may be readily heard.
13	I'd like to, for the record and also for
14	the subcommittee members, give you some information
15	on recently breaking news.
16	For a variety of reasons, we've made the
17	decision not to present this topic at the October
18	full committee meeting. It was originally slated on
19	our schedule for the October meeting, and as I said,
20	for a variety of reasons, we've decided to pull that
21	back. So it will not be presented to the full
22	committee in October. I don't yet know whether it
23	will be scheduled for our November or December
24	subcommittee meeting. But those of you who are
25	interested, as I said, now we have it on public
	I

(202) 234-4433

	6
1	record.
2	With that, we'll now proceed with the
3	meeting, and I guess Rich Correia would like to say
4	a few things.
5	Rich.
6	RICH CORREIA: Yes, thank you.
7	I'm Rich Correia, Division Director of
8	Risk Analysis and Research. Thank you to the
9	subcommittee today for yet another opportunity to
10	present to you the fire HRA guidelines, We already
11	went over that. We've been here three times, I
12	believe. Hopefully, this is going to be one of the
13	last.
14	The project started in 2007 as a joint
15	NRC-EPRI effort. We've had the benefit of a peer
16	review and a pilot at two sites. We went though a
17	public comment period. We actually utilized the
18	guidelines in a fire-protection training course. We
19	feel it's important that we complete the work on
20	this effort as soon as possible to give licensees
21	following the NFPA 805 licensing process some final
22	guidelines.
23	With any comments we receive today, and
24	I understand there are some other issues we need to
25	address, we'll get the final report to you as soon
	1

(202) 234-4433

	7
1	as possible.
2	With that, I'd like to turn it over to
3	Mark. Any comments?
4	MR. SALLEY: No.
5	CHAIR STETKAR: Susan?
6	MS. COOPER: Okay.
7	First of all, I'd just like to recognize
8	the other speakers here in addition to myself
9	Susan Cooper from the Office of Research and Stacey
10	Hendrickson from Sandia National Laboratories, a
11	contractor to the NRC. We also have Erin Collins
12	from SAIC, who is one of EPRI's contractors in this
13	joint effort.
14	It's also my understanding that there
15	should be a few of our team members on the phone,
16	although on mute. If we need to use that lifeline,
17	we'll
18	CHAIR STETKAR: We can open it up.
19	MS. COOPER: Anyway, I believe that Jeff
20	Julius and Katie Kohlhepp from Scientech will be on
21	the line, and also John Forester from Sandia
22	National Laboratories should be on the bridge line.
23	I guess before I get started, I see that
24	John Peters, my branch chief, has arrived.
25	Did you want to add anything before we
	1

(202) 234-4433

	8
1	get started?
2	(No response.)
3	MS. COOPER: All right. So I guess it's
4	up to us.
5	As Rich mentioned, this is the third or
6	maybe even the fourth time that you've heard about
7	this, but certainly is it four? Okay we
8	weren't here that long ago, just in April. But I
9	will try refresh your memory on a few things,
10	starting off with our first set of presentations,
11	which is introduction and summary on the joint
12	guidelines.
13	I'm very briefly going to go over the
14	background because you have seen it before yes?
15	CHAIR STETKAR: Susan, let me interrupt
16	you quickly, one more thing. I mentioned it in
17	April, and that's, the document in Section 1 still
18	suffers from a big misperception. Indeed, you've
19	been before the subcommittee; this is your third
20	time.
21	MS. COOPER: Yes.
22	CHAIR STETKAR: You've not yet been
23	before the ACRS. Chapter 1 still says that you've
24	been before the ACRS four times, so
25	MS. COOPER: I apologize. I thought
I	I

	9
1	that was one of the things that we had that
2	CHAIR STETKAR: Just of note. We've
3	pretty sensitive to this and the subcommittee does
4	not speak for the committee.
5	MS. COOPER: Okay.
6	CHAIR STETKAR: And indeed, whenever we
7	have that full committee presentation, it will be
8	the first time that the full committee has seen this
9	topic.
10	MS. COOPER: Right.
11	CHAIR STETKAR: So, if you could,
12	please, please make that change.
13	MS. COOPER: Yes, we will
14	CHAIR STETKAR: And with that, I'm
15	sorry for the interruption, but since we've talking
16	about how many times we've been here, it sort of
17	reminded me to bring that up.
18	MS. COOPER: Okay, thank you.
19	All right, I'm going to briefly go over
20	the background because we have gone over this
21	before, as well as the project summary. It is our
22	intention today, because we have spoken to you about
23	details of the document, that we won't be going into
24	all the details in the document. So, in this
25	introductory presentation, I just remind you what
I	

(202) 234-4433

the content consists of insofar as topics and sections and stuff like that. So that's the 2 And then I'll talk about the agenda for summary. 4 today.

5 So, just in brief, the reason why we're here really is because there is such a thing as an 6 7 NFP 805 that roughly half the plants are transitioning to using for fire protection 8 9 That requires a fire PRA, NUREG/CR regulation. 6850, which is a joint NRC/EPRI document that 10 addresses fire PRA but did not fully treat HRA in 11 It did talk about identifying, 12 that document. advance screening, at some level, and the kinds of 13 14 performance-shaping factors that might be relevant. What it does not do, 6850 does not 15 provide a methodology for developing BEHFP -- that's 16

the best estimate human failure probabilities -- and 17 it doesn't s specifically address the HRA 18 19 requirements that are in the PRA standard. So it was recognized that we needed to do something beyond 20

what was in 6850, and I think, even before 6850 was 21 published, that was recognized. 22

So, a number of things happened, then 23 24 with that recognition, and this may not necessarily be in order, but in any case, the Office of Research 25

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

3

	11
1	has, with the ongoing fire search, a user need from
2	NRR and a task added to that user need asking the
3	Office of Research to develop guidance for HRA using
4	existing methods in order to address fire.
5	We had an existing relationship with
6	EPRI and we developed, under the existing memorandum
7	of understanding, we developed another initiative,
8	teamed together, and got started on work with the
9	objective of trying to put together another joint
10	document like the NUREG/CR 6850.
11	The intent was, in addition to what's
12	stated in the User Need from NRR, to use existing
13	methods, also to move forward with state of the art
14	and fire HRA.
15	So, a little bit about the history. We
16	started, as Rich Correia mentioned, back in 2007.
17	That's when we started identifying people to work on
18	the project. We had our first integrated draft
19	about a year later, followed very quickly afterward
20	by a peer review and some testing at two different
21	plants.
22	We got a lot of good feedback from those
23	reviews, the peer review and testing, so we actually
24	made quite a few changes and came out with another
25	draft in April 2009 and made sure that NRR and NRO
Į	1

(202) 234-4433

Í	12
1	had a chance to look at that. We've always had
2	interactions with NRR.
3	We had a number of other activities
4	then, including coming here, the PWR Owners Group,
5	tested, piloted the guidelines. We issued it for
6	public comment at the same time.
7	We got our comments in March of 2010,
8	resolved most of them by this last summer, came back
9	and saw you guys again and then I started doing our
10	first run of training and the joint EPRI-NRC fire
11	training course. The first full track on fire HRA
12	was a year ago. We wrapped up our final public
13	comment resolution over this past summer, and also
14	comments from you and the subcommittee in April.
15	We're in the middle of the two fire PRA
16	training courses right now. We did one in August.
17	There will be another one in November. We're here
18	today, and we're hoping to try to get this published
19	as final. It says Fall 2011, but anyway, that's our
20	aim.
21	So that's the overall history. I just
22	want to remind those of you who have already seen
23	and maybe who haven't been here that the basis of
24	this guidance, first of all, was to build on what
25	existed already in HRA.

(202) 234-4433

13 1 So we have a standard process or it's 2 built on the standard process for HRA; in other 3 words, there were basic steps that are recognized as 4 being important in HRA, and that includes the 5 ASME-ANS standard, the good practices NUREG 1792. Also, input from NUREG 1852 on fire manual actions. 6 7 EPRI's SHARP1 document -- and NRC's ATHEANA, which 8 has a process of its own. 9 However, it was recognized, in order to address the specifics of fire, we needed to do some 10 additional things and write additional quidance to 11 address those needs, especially in an the area of 12 information collection, evaluating the feasibility 13 of actions, and so on and so forth. 14 15 So here are the process steps, which 16 also comprise some of the major sections in the 17 document NUREG 1921. One section specifically addresses the identification, definition of human 18 19 failure events that are put into the model. One thing that's different for fire HRA 20 that we have very explicitly included in this 21 section is the notion of a feasibility test; in 22 other words, before you're going to put it into your 23 24 PRA model, you need to make sure that the actions associated with that human failure event actually 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	14
1	can be performed. So there is go/no-go, very
2	explicit feasibility test included in that
3	particular section.
4	We then have an
5	ever-increasing-in-length chapter on qualitative
6	analysis
7	CHAIR STETKAR: Which is actually a good
8	thing.
9	MS. COOPER: Some of us are getting
10	attached to it.
11	But in any case, the qualitative
12	analysis chapter is trying to recognize, first of
13	all, something that's well known to anyone who does
14	HRA, and that is that it's important to collect and
15	evaluate good information. Otherwise, your results
16	are to be exactly what you put into it. So we've
17	chosen among the team to make an explicit chapter on
18	qualitative analysis process, whereas that's not
19	often done.
20	So it's a collection of general guidance
21	on how to do qualitative analysis and also some
22	specifics that are related to fire. And then, when
23	we get into some is the details or the changes that
24	we've made since the last time we were here, there
25	are some discussion sections on special topics

(202) 234-4433

	15
1	related to fire, such as main control abandonment
2	and so on and so forth. So it's become kind of
3	collection point for discussion topics that might
4	be, what we think are important for analysts to
5	think about when they're going through their
6	analysis.
7	CHAIR STETKAR: Just out of curiosity,
8	Susan, one of the special topics is the self-induced
9	station blackout or fault-clearing process however
10	it's characterized. Are you going to discuss a
11	little bit more about that in the detailed
12	discussion of the changes?
13	MS. COOPER: Well, Well, it is one of
14	the topics. There's not a lot discussed of the
15	technical issues on any of those.
16	CHAIR STETKAR: Okay.
17	MS. COOPER: But we did do something
18	with it, especially with respect to your suggestion.
19	CHAIR STETKAR: Yes, I don't and I
20	don't speak for the subcommittee
21	MS. COOPER: Right.
22	CHAIR STETKAR: and certainly not for
23	the committee. I kind of like what you did, but
24	that's me.
25	My only question is I actually had
I	

(202) 234-4433

	16
1	someone from industry, who shall obviously be
2	unnamed, express surprise that indeed there were
3	operating plants out there that indeed had in their
4	current existing fire procedures self-induced
5	station blackout.
6	As far as you know, is that still the
7	case?
8	MS. COLLINS: There are as far as I
9	know, there still are some.
10	MS. COLLINS: as we know
11	CHAIR STETKAR: Okay, well, that was my
12	understanding.
13	MS. COLLINS: So one could say that are
14	still procedures that include the concept of what we
15	might call preemptive action.
16	CHAIR STETKAR: Yes.
17	MS. COOPER: So it's similar enough in
18	
19	CHAIR STETKAR: It may not be a total
20	blackout, but stripping a large fraction of okay.
21	As I said, somebody, you know, in
22	passing over the last month or so, from industry
23	expressed honest surprise that there were plants out
24	there doing that.
25	MS. COLLINS: Right.
I	

(202) 234-4433

	17
1	CHAIR STETKAR: And I just wanted to
2	make sure that we weren't addressing something that
3	was, you know, not at all relevant anymore.
4	MS. COOPER: No, it still lingers. Now
5	I think, as we go through and do fire PRA, there's a
6	recognition that that is not a preferred state of
7	being and that the fire PRA can assist and HRA can
8	assist in identifying which of these actions you
9	want to retain and which ones you want to remove, or
10	perhaps an entire revision of your procedures
11	accordingly.
12	CHAIR STETKAR: Yes, okay. Thanks. I
13	just wanted to make sure of that.
14	MS. COOPER: Okay.
15	CHAIR STETKAR: Because I personally
16	like what you've done with that, but it's just a
17	question of whether it was at all relevant to
18	(Simultaneous speaking.)
19	MS. COOPER: and Erin would be one of
20	those that would know that because I know that she
21	has had projects with them, and I think SAIC in the
22	past, because in a previous life, I did some work
23	with those kinds of plants.
24	CHAIR STETKAR: Sure.
25	MS. COOPER: But I'm not
Į	

(202) 234-4433

	18
1	CHAIR STETKAR: No, there's enough
2	positive feedback from your group that
3	MR. SALLEY: Yes. That's not going to
4	be something that any plant's going to want to
5	advertise.
6	CHAIR STETKAR: No, I understand that.
7	MR. SALLEY: I mean, the poster child
8	for this years ago was Trojan, and I think Trojan
9	was one of the first plants where this was really
10	identified as being risk-significant. Of course, we
11	all know the Trojan is no more.
12	I believe Brown's Ferry also had this,
13	and that was part of their findings that they dealt
14	with last summer. So there still are a few plants
15	there if for no other reason than if somebody, the
16	next generation thought, hey, this may be a good
17	idea if we capture this information. They can read
18	it and say, maybe this is not such a good idea. So
19	if nothing else, for historical reasons, I think
20	that's valuable.
21	CHAIR STETKAR: The only reason I bring
22	it up is, as I said, it was somebody from the
23	industry who expressed because I said, gee, you
24	know, we were talking about the procedures that,
25	part of the guidance addresses this and they sort
I	

(202) 234-4433

	19
1	of raised the question of, why is that an issue? I
2	said, gee, it's my understanding there are some
3	plants that still have that in their fire procedures
4	and said, gee, I don't think that's the case.
5	Apparently, they were wrong.
6	Thanks.
7	MS. COOPER: Okay. And now we'll move
8	on. After the qualitative analysis, at least in the
9	serial approach well, the way it has to be
10	presented in the report has to be serial.
11	The next thing is the quantification
12	methods. We have three different types of
13	quantification methods that are included in our
14	report. We have retained and borrowed from NUREG/CR
15	6850, the screening quantification approach that we
16	had introduced in that document; a slight change
17	there, but not much. And we've talked to you about
18	that in the past.
19	Then there's a new method that's been
20	introduced in the document called the scoping fire
21	HRA method. It's a decision-tree format and it was
22	developed principally to try to provide less
23	conservative values than the screening values, but
24	with some savings on the effort and resources
25	required to do detailed analysis.

(202) 234-4433

	20
1	Also, another motivation was to try to
2	have an approach that was easy to review and easy to
3	reproduce results. And that request came not only
4	from the industry side but also from our NRR
5	reviewers.
6	Finally, we have detailed fire HRA
7	methods. In this case, we built on or used expanded
8	existing methods to fire context. Those two methods
9	or two approaches that we used, first on the EPRI
10	side, we have the cause-based decision tree
11	supplemented by the ACR/ORE and FERC methods, and
12	then from the NRC side, we've got ATHEANA.
13	The final technical chapter addresses
14	three topics, dependency, recovery, and uncertainty
15	analysis. The focus in this particular section or
16	chapter is to highlight any differences that an
17	analyst would need to be aware of that are new for
18	the fire context.
19	For the most part, everything that you
20	would do in an HRA from an internal events PRA is
21	the same. There are two things that are a little
22	bit different in the fire context and that's what
23	we've try to highlight in this particular section,
24	and then also just indicate what the latest
25	resources are for the those particular tasks in HRA.
ļ	I

(202) 234-4433

	21
1	So that's the guts, if you will, of the document.
2	There are appendices, I think it's now
3	appendices A and B, that present the details on the
4	two detailed HRA methods are or is it D and C, or
5	
6	CHAIR STETKAR: B and C.
7	MS. COOPER: We've reorganized so often
8	that I kind of lose track.
9	CHAIR STETKAR: In the version I have,
10	it's B and C.
11	(Simultaneous speaking.)
12	MS. COOPER: Yes.
13	Then there's one that goes into the
14	scoping. In any case, there are other things that
15	are supporting it.
16	One of the appendices also summarizes
17	the results from our various peer reviews and public
18	comments and so on and so forth.
19	So the focus for today is just so look
20	at how we've changed the guidelines since we were
21	here back in April, and we had provided the
22	subcommittee a draft report in March of this year.
23	So we're just going to focus on how things have
24	changed at a high level; not every edit. But in any
25	case, that's what we're going to talk about today.
Į	

(202) 234-4433

	22
1	We have tried to categorize how we've
2	responded to various comments. There are some
3	things that were carryovers, also changes that came
4	from public comments that we tried to address. But
5	principally, this is coming from the suggestions or
6	comments and questions that came out of the meeting
7	last April.
8	So that's it for introduction and
9	summary, and we'll move on to the next presentation
10	unless there are any questions or comments.
11	MEMBER ABDEL-KHALIK: I've got a
12	question raised by John about some plants having a
13	self-induced station blackout in their fire
14	procedures. Do we have any idea about how many
15	plants have that?
16	MR. SALLEY: I would think it would be a
17	very small minority that the inspectors in the
18	regions will eventually pick on.
19	You've got to remember, though, where
20	that came about. That's some old technology,
21	because when Appendix R was first introduced in
22	1980, the electrical engineers were trying to
23	understand it. The idea of associated circuits gave
24	them a problem because there'd be so many.
25	The second thing is a lot of people
ļ	I

(202) 234-4433

	23
1	interpreted Appendix R to say that you need to take
2	a loss of off-site power with your fire. They
3	didn't want to read exactly what the regs were
4	MS. COOPER: It just happened.
5	MR. SALLEY: what the regs were
6	saying. So they thought they were doing a
7	conservative worst-case scenario, was what they were
8	thinking about back in the 1980s. And we can see
9	that it isn't really a worst-case scenario. It's
10	kind of a, not a good scenario, because you're now
11	as good as those diesel generators, basically, to
12	shut the plant down. It becomes a very risky.
13	So that goes back to the early 1980s, is
14	where that was first conceived. And again, because
15	of the loss of off-site power, they thought they
16	were doing a good thing.
17	CHAIR STETKAR: And I suspect and I
18	don't know. I mean, I've not looked at the fire
19	procedures, and I suspect they're different from
20	plant to plant.
21	Generally, people speak about this as
22	self-induced station blackout. And I know some
23	plans actually did that. I suspect that there's
24	probably and Erin, you may know better than I do
25	a gradation that some plants strip selected buses
ļ	I

(202) 234-4433

24 1 because the notion is they've identified those buses as their preferred power supplies, or that faults on 2 3 those buses may give them spurious indications that 4 they don't want to deal with or things like that. 5 So I suspect there's probably a mix out there in terms of degree of severity, in terms of 6 7 shedding loads and selectively reenergizing things 8 that you might find --9 MS. COOPER: Exactly. No, you're 10 absolutely right. CHAIR STETKAR: -- where the 11 self-induced station blackout is at one end of the 12 But apparently, there are plants that do 13 spectrum. 14 that, surprisingly enough. MS. COOPER: And to echo what Mark had 15 said, I think it is primarily confined in, let's 16 17 say, older plants based on a previous philosophy. But, as you say, there are different iterations of 18 that depending on wholesale SISBO or whether there 19 are different facets of it. 20 So each of the plants is --21 22 CHAIR STETKAR: It's actually, though, true, anybody who is not transitioning to the NFPA 23 24 805, if they have self-induced station blackout in their procedures, will indeed retain self-induced 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	25
1	station blackout in their procedures. Right? I
2	mean, as long as they aren't challenged to look at
3	those activities in the context of a, you know, fire
4	PRA if you will.
5	MR. SALLEY: There are other things
6	happening. For example, the enforcement discretion
7	on the multiple spuriouses is being lifted, so the
8	inspectors are going to be going back out and
9	looking for it. I think if you do see something as
10	egregious as like Trojan was, that they'll be on
11	that and the inspectors will pick that up.
12	CHAIR STETKAR: If they have that
13	inspection vehicle to
14	MR. SALLEY: Yes. The inspectors are
15	pretty good. They'll pick that up.
16	CHAIR STETKAR: Thanks, Mark.
17	MS. COOPER: Okay. Well, I think we'll
18	go ahead unless there's another question or
19	comment, we'll move to the next presentation, which
20	is pretty much the meat for today, and that is to
21	discuss the updates that we've made to the
22	guidelines. And the three of us that are here at
23	the table will be taking turns at this. I'm going
24	to start off.
25	So, as I mentioned at the end of the
ļ	I

(202) 234-4433

last presentation, the starting point for 1 2 modifications was our March draft of this year that we provided to the ACRS. Revisions were agreed to 3 4 by the team and were motivated by individual reviews 5 by team members if needed. Team discussions leading to consensus were held. 6 7 The two principal inputs to revisions or motivations for revisions were either comments and 8 9 discussions and so forth from the April 20th meeting 10 with the subcommittee and also any outstanding issues or concerns that came out of the public 11 comments or actually from the team. 12 I mean, we have constant feedback from 13 14 our team members, well, principally through our EPRI 15 counterparts as they're applying this method, and we also get feedback through the training as well. 16 So 17 we're getting a pretty steady diet of feedback on how things are going on and what's important out 18 19 there. In order to facilitate the report 20 revision, we needed to develop some categories of 21 changes, which can be organized by the report 22 section or by topic. Today's discussion uses a bit 23 24 of both, and I'm going to try to streamline our discussions and minimize the overlap. 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

26

27 1 The categories of updates that we'll be 2 talking about are Section 1, 2, 4, 5, and 6 edits, and there are some associated edits to the 3 4 appendices. Section 3 is not mentioned here because 5 most of those were editing edits, and otherwise, any 6 7 sort technical changes are going to be addressed by 8 another issue or two that are coming up, 9 specifically clarifying treatment of spurious cable fires and multiple spurious operations and how 10 that's treated in HRA. 11 And then we also have some discussion on 12 exploring uncertainties in timing information, some 13 14 more discussion on main control room abandonment, and then there's also some editing that's been done 15 with respect to an appendix that we had in the March 16 version on self-induced station blackout. 17 So changes to Section 3, as noted on 18 19 this particular slide, have been captured under these other topics. 20 So, just to organize things with respect 21 to presentation, I'm going talk about the changes to 22 the guidelines for the first two sections. Erin's 23 24 going to talk about changes to Section 4, which is the qualitative analysis as well as treatment of 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	28
1	multiple spurious operations, main control room
2	abandonment, and SISBO. And then Stacey will talk
3	about Sections 5, 6, associated appendices, and then
4	certainties and timing information.
5	As you've already pointed out, I guess
6	we didn't get this first one right. But we did try
7	to edit it.
8	CHAIR STETKAR: Some of it was okay.
9	You got more than one out; not all. So the first
10	bullet is actually correct. The implication that
11	they're completely expurged is not correct.
12	MS. COOPER: Okay. All right.
13	CHAIR STETKAR: Expunged, I guess, is
14	the right term.
15	MS. COOPER: Otherwise, Section 1
16	principally had some text edits made and additions.
17	There already was a paragraph in Section 1, which is
18	the introductory chapter, talking about the
19	likelihood that there will be future improvements to
20	the methodology for fire HRA just because this is
21	one of the first times something's been put into
22	print. But what we've done is we've added some
23	additional text to say some things explicitly about
24	maybe that a maybe need for guidance to address main
25	control and abandonment in a little bit more detail
	I

(202) 234-4433

	29
1	than we've done.
2	Another topic that I know that was of
3	interest in our April 20th meeting was the treatment
4	of a fire-induced cable failures, specifically those
5	that lead to spurious indications that are currently
6	out of the scope of fire PRA as defined by the
7	standard requirements for, say, Capability Category
8	2.
9	We also included, added a reference to
10	other work going on in the Office of Research with
11	regard to response to SRM on HRA model differences
12	and how that might play a role in any future
13	improvements and also, just recognizing that, as
14	people do perform and submit their studies for NFPA
15	805 transition, that that kind of feedback may also
16	indicate the need for places where improvements can
17	be made.
18	Moving to Section 2, there is quite a
19	bit more that was added to this particular section,
20	and there is a little bit of overlap here with some
21	of the other topics that will be discussing. But
22	since there's quite a lot added to Section 2, I'll
23	just discuss it here.
24	Those of you who were here may recall,
25	we had a fairly extended discussion on April 20th of
I	I

(202) 234-4433

1 this year about multiple spurious failures and their impacts on operators in the control room. 2 So the 3 team took that as an initiative and actually did a 4 lot of work and had quite a lot of discussion, 5 conference calls and so forth, on this topic and, as 6 a result, has added a new section to chapter 2, a 7 new section 2.5, called fire-induced spurious failures and electrical faults. 8 9 The purpose of this is to help the HRA 10 analysts understand what the rest of the PRA is doing so far is addressing cable failures, 11 fire-induced spurious cable failures, the inputs 12 that they might be getting from those other PRA 13 14 tasks, fire PRA tasks, and what you might do with 15 them or what you might need them for. 16 Along with that, there is a table 2.3 17 that's been added that's tried to help the analysts understand these interfaces and their actions and so 18 19 forth, and just clarify who's doing what so far as who's handling this part of that problem. And if it 20 has an HRA impact, how is that represented in NRA. 21 So I guess one question I have -- in a 22 sidebar,, we talked about, I guess, the report that 23 24 we sent over had a little trouble with table 3. Ιf there's an interest, we might be able to bring that 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

30

	31
1	that up if we have the ability to hook up another
2	computer and look at it.
3	CHAIR STETKAR: You can read it. The
4	sentences. Just look a little strange, so
5	MS. COOPER: Okay. All right
6	(Simultaneous speaking.)
7	CHAIR STETKAR: assuming that the
8	vertical letters accurately represent the horizontal
9	thoughts, we're okay.
10	(Laughter.)
11	MS. COOPER: We spent a lot of time on
12	that, so we're anxious for you to be able to
13	understand that.
14	But in any case, that was the principal
15	change to Section 2, was to add that discussion and
16	a supporting table for that discussion.
17	So now we move to Erin's portion of the
18	presentation where she's going to about Section 4
19	changes generally, but also which will include
20	treatment of multiple spurious, main control
21	abandonment, and so on and so forth.
22	So, Erin, your turn, and I assume you
23	have a microphone nearby.
24	MS. COLLINS: I assume that's
25	functioning.
I	I

(202) 234-4433

	32
1	CHAIR STETKAR: That is. It's fairly
2	sensitive, so you should be okay.
3	MS. COLLINS: Okay. That's great.
4	As Susan mentioned, I'm going to go
5	through some of our, an overview of what we did in
6	Section 4 on qualitative analysis to address some of
7	the concerns that have been raised by this
8	subcommittee as well as some of the internal issues
9	in our team that we wanted to take a better look at
10	and reflect in our document and some of that
11	particular topics that were addressed.
12	CHAIR STETKAR: Just because the
13	woodpecker's in the attic, just move the mic, just
14	pull it a little bit closer to you.
15	MS. COLLINS: No, I don't want to drag
16	this across the table.
17	CHAIR STETKAR: It's really sensitive
18	but it helps pick you up a little bit because of the
19	background noise.
20	MS. COLLINS: Okay. Good enough. I
21	hope that works.
22	Again, three of the main topics that had
23	come up for discussion the previous meeting with you
24	folks were MSOs and MCR abandonment and the whole
25	self-imposed station blackout consideration.
I	I

(202) 234-4433

Í	33
1	So, in general, to go through an
2	overview to some of the changes that we made to
3	qualitative analysis, there was some discussion on
4	part of the team as to whether or not we should make
5	this section Chapter 0 is qualitative analysis
6	that substantial, that important, the basis for
7	everything that we should put it up front and
8	say, start with this and go through the rest of
9	that? However, amongst our team, there was some
10	discussion as to, but, you know, first you need to
11	identify, then you need to define.
12	I think, hopefully, the consensus of the
13	group was that we really felt that it, to keep it
14	where it was, is Chapter 4 because you have a
15	certain progression in the study and to set the
16	stage for what one needed for quantitative analysis,
17	but to provide further discussion of qualitative
18	issues in that context of identifying, defining, and
19	then quantitative.
20	I think this is a topic that one can
21	discuss until the cows come home as to where's the
22	proper place for this. But for the time being,
23	we're keeping it as it is.
24	CHAIR STETKAR: The important thing is
25	that it's in the documents and its coherent
	I

(202) 234-4433

	34
1	technically.
2	MS. COLLINS: Right.
3	CHAIR STETKAR: There are certainly
4	preferences. I think we've learned a lot since
5	perhaps several of the traditionalists regarding how
6	one might approach doing a modern human reliability
7	analysis, and as you said, we could discuss it
8	forever and it's probably not worth it.
9	It's more important, the context of
10	that. It's just a concern that the impression of
11	putting it in the middle of the document leaves with
12	people who are perhaps not as familiar with the
13	modern HRA methods practitioners, the people out
14	field actually doing this.
15	MS. COLLINS: Yes, I understand there is
16	a risk.
17	CHAIR STETKAR: Presuming you know,
18	I'm presuming that not necessarily as applicants
19	will use, you know, contracted HRA experts, if I can
20	call it that, to do the work and that, you know, we
21	need to write this guidance for people at the
22	nuclear power plant, PRA groups who might be doing
23	this.
24	So it's an impression, the technical
25	content is the most important part, so
I	1

(202) 234-4433

	35
1	MS. COLLINS: Well, I
2	CHAIR STETKAR: if you've decided
3	that that's where it belongs
4	MS. COLLINS: We did. However, I would
5	say I believe that what we decided to the other
6	sections. An indication of you recognize that many
7	of these tasks are iterative, particularly
8	qualitative analysis.
9	CHAIR STETKAR: Right, but the
10	follow-on sections do that. It's not as clear that
11	the lead-in sections do that. But that's okay.
12	MS. COLLINS: Yes, at some point, when
13	we went back and reviewed, it seemed like every
14	paragraph, we were hammering on them, you need to
15	iterate, you need to iterate. Okay, we get it
16	already, you now.
17	Well, there was the other issue of, once
18	you have it there as Chapter 4 and then you move it
19	to Chapter
20	CHAIR STETKAR: No, I understand the
21	editing part of the process. That's obviously a
22	nontrivial exercise.
23	MS. COLLINS: Yes. I was concerned
24	about that as well.
25	CHAIR STETKAR: Yes.
Į	I

(202) 234-4433

	36
1	MS. COLLINS: All right. The second
2	issue, that again, to clarify, we have an ACRS
3	comment but that's more ACRS PRA subcommittee
4	comment; let's make that clear. The comment was, it
5	might be worth emphasizing that we had a section on
6	special cases where little to no credit is given.
7	And we essentially took that almost directly from
8	6850. And so we have clarified that in there. It
9	specifically says, as mentioned in the Section
10	umpty-squat of 6850, here are particular cases
11	where, if you're asking for heroic actions in SCBA,
12	don't do that. Don't give them credit for that.
13	You know, things like this.
14	Another comment was made regarding the
15	impact of security issues. As security is
16	increased, might there be an impact on
17	accessibility? Are keys going to be available? Is
18	Mr. Security Guard going to prevent you from going
19	through this particular door when you need to? So
20	we have added to some of our feasibility assessment
21	sections, when you're considering travel paths and
22	the likelihood of being able to perform an action
23	what are the security issues that might impact that
24	feasibility assessment.
25	And finally, in some of these summaries
ļ	I

	37
1	of changes, do we address the possibility of being
2	in multiple procedures the same time because, as we
3	discussed, there are your standard set of EOPs and
4	then there are fire- specific procedures. So there
5	is a significant likelihood that, at least for the
6	time being, you're going to be looking at both sets
7	of procedures. So we have reviewed our particular
8	sections and the appendices, where we discuss
9	detailed HRA.
10	There are points in the EPRI HRA
11	calculator method where you can actually select; are
12	there multiple procedures? Yes or no. Things like
13	this. And it's used as, let's say,
14	performance-shaping factor on your ATP.
15	CHAIR STETKAR: By the way, Erin, we
16	did have some discussion regarding, the term I've
17	coined is, the procedure-centric notion of this
18	entire NUREG.
19	The methodology is very strongly
20	oriented toward the traditional notion of, the
21	operators will follow a procedure. At a particular
22	step in the procedures, the operator will either
23	successfully implement that step or they will
24	unsuccessfully implement that step. And then we go
25	to the next step in the procedure. And if you have
ļ	I

(202) 234-4433

	38
1	three procedures, you need to understand how they
2	will use those procedures.
3	One of my concerns, quite honestly, is
4	it was mentioned earlier that there will be
5	links perhaps between this effort and the larger SRM
6	on, if I can call it a holistic approach to human
7	reliability analysis.
8	A lot of what we've learned about modern
9	HRA is that this notion of step-by-step following of
10	procedures is not the way to think about the way
11	people respond to a real event.
12	MS. COLLINS: Yes.
13	CHAIR STETKAR: In practice, there's
14	nothing that can be done to undo the
15	procedure-centric notion of this document. You'd
16	pretty much have to change it substantially. I
17	think a lot of the qualitative information in
18	Section 4 should increase the awareness of someone
19	who wants their awareness increased to the fact that
20	perhaps you shouldn't just focus on procedures.
21	MS. COLLINS: Yes.
22	CHAIR STETKAR: But I tell you, when
23	you get back in Chapter 5, it's procedure,
24	procedure, procedure, procedure.
25	MS. COLLINS: Yes, it's
	I

	39
1	CHAIR STETKAR: So, as I said, we had
2	some discussion about this in April, and in fact,
3	some of the material that's been added to the
4	document in the last few months, you know,
5	constantly reinforces the notion of procedures.
6	MS. COOPER: I guess I would like to
7	respond a little bit to that, specifically with
8	respect to the focus of Section 5. The majority of
9	the text in Section 5 is related to the scoping
10	method.
11	CHAIR STETKAR: Right.
12	MS. COOPER: There are entry conditions
13	for the scoping method that are intended to help
14	analysts only consider a certain number of
15	performance-shaping factors. And then, if they
16	don't meet that criteria, they need to consider a
17	broader set and use one of the detailed methods.
18	We use procedures and how well they
19	match the scenario as an important criteria to
20	indicate, how difficult is this going to be? Are
21	they going to have to think outside the box? Are
22	the procedures not going to work? And if they
23	don't, then you can't use the scoping approach; you
24	need to use detail. So that's why, if you look at
25	Section 5, which is predominately discussion of
ļ	I

(202) 234-4433

	40
1	scoping, there is going to be that emphasis.
2	The detailed methods ought to be able to
3	think a little bit more broadly. Well, the two
4	approaches are different and will have different
5	ways that the analysts might arrive at that or they
6	might be driven to that because the method, in some
7	ways, does drive the qualitative analysis.
8	CHAIR STETKAR: I know you want to be
9	done. On the other hand, at least some recognition
10	in the exceedingly short section on uncertainty or
11	somewhere in the qualitative analysis, you could
12	talk about consideration of situations in which the
13	operators might be driven through alternative paths
14	through the procedures to identify cases to consider
15	to approach the uncertainty analysis. That might
16	be a possibility.
17	MS. COOPER: Yes, okay. We'll consider
18	that.
19	I guess one thing I'd like to add is
20	that my impression, which I'm getting feedback
21	second hand from the EPRI site because I'm not doing
22	this work anymore it's my impression that on the
23	fire procedures and the viewpoint of the operators
24	of the fire procedures has been evolving as part of
25	this overall transition effort in the sense that
I	1

(202) 234-4433

	41
1	they're more likely to be using them, they're making
2	changes to them, format of procedures are being
3	contemplated or made. So there's definitely an
4	evolution, I think, in the way procedures may be
5	playing a role in fire events.
6	I don't think that evolution is done
7	yet, and I suspect that there's going to be
8	something on the order of how we move from the
9	procedures we had before TMI to the EOPs we have
10	now, maybe not but in that direction but I think
11	they're going to be, eventually.
12	Now some changes that are actually going
13	to change the way not only the operators' use of the
14	procedures but the way we might want to model them.
15	So, at this point in time, my impression
16	is that many of them haven't experienced fire
17	events, so they are to feel more comfortable within
18	a procedure environment
19	D. They have lost confidence that they won't have
20	trouble. If they've thought carefully about the
21	Robinson event, maybe they'd change their minds.
22	Under different modes of how many people were
23	available in the control room and what their
24	capabilities are I mean, they're all licensed,
25	but they have different capabilities
l	I

(202) 234-4433

	42
1	MS. COOPER: Yes.
2	D. You know, even just the fact that one of them
3	may be dragged off of everything else might just be
4	the one who could best diagnose other things.
5	You know, there are things there that at
6	least affect the uncertainty and I think
7	MS. COOPER: Sure.
8	D although this is changing, giving some
9	recognition to that and raising that as an issue
10	seems to me really appropriate.
11	MS. COOPER: Yes.
12	CHAIR STETKAR: I was going to bring up
13	Robinson in a different context, but we might as
14	well bring it up.
15	There, there was clear evidence that,
16	for whatever reason, they focused on what they
17	thought was born and him and him wanting some sort
18	of, several fundamental indications that, if you
19	just took a procedure centric viewpoint, you'd say,
20	well, of course, your emergency operating procedures
21	would keep you away from an overcooling event, at
22	least force you to look for it; of course your
23	emergency operating procedures would point you in
24	the direction of verifying cooling for your reactor
25	cooling pump seals both of which were completely

(202) 234-4433

	43
1	ignored in a real fire because, for whatever reason,
2	the crew know what they needed to respond to.
3	That's a bit of the problem of an
4	abstract analyst within the context of a narrowly
5	defined, precisely square, black-and-white PRA model
6	saying I, in the context of the PRA, am only
7	interested in the operator successfully performing
8	this particular action. And what information do I
9	have available regarding that particular action and
10	focusing only on the procedural guidance that may or
11	may not lead me to that particular action?
12	It's not the way we drive an automobile
13	down the street. It's not the way pilots fly an
14	airplane, and it's not the way nuclear power plant
15	operators operate in the heat of battle. So that's
16	the whole notion of, be really, really careful about
17	sort of this procedure view.
18	And as I said as an introduction, as a
19	pragmatic sense, I think you'd have to do a
20	substantial amount of rewriting of the current
21	document to remove that sort of pervasive notion
22	because there are a lot of explanatory examples, you
23	know, a sentence here and a sentence there that come
24	back to EOPs and fire procedures, and the operators
25	will be doing this, and of course they'll be
ļ	I

(202) 234-4433

	44
1	following the EOPs, or of course they'll be
2	following the fire procedures. Well, of course they
3	may not be following either one of them.
4	MS. COLLINS: Well, some of this
5	procedure-centric focus may come from discussions
6	within the fire PRA standard of, if you don't have
7	procedures, you'd better have a pretty good
8	justification for why you're crediting a particular
9	action in terms of training, et cetera, so that's
10	part of it.
11	The other part of it may be that,
12	frequently, when you get to into the heat of battle
13	of looking at your CDF on your fire PRA, you begin
14	to investigate all sorts of different sorts of
15	recovery strategies for reducing the risk.
16	CHAIR STETKAR: Sure.
17	MS. COLLINS: And in that sense, you may
18	be requested as an HRA person to well, gee,
19	aren't they going to go down and do this and take
20	this action and blah blah, where it gets into, no,
21	we don't have any procedures for that and we really
22	need to have strong operators entries and
23	walk-throughs and talk-throughs to see if we can
24	give any credit to that.
25	So there's a concern, I think, that we
	I

(202) 234-4433

	45
1	do you're right; maybe we're too procedure
2	centric but we don't want to open the door to,
3	hey, if Operator X says he can do it, then, yes,
4	sure, he's going to be able to go down and take this
5	heroic action.
6	CHAIR STETKAR: I fully agree with that.
7	Nobody's ever thought about it to the extent of at
8	least writing it down on a piece paper or telling
9	operators they might need to think about a
10	particular type of scenario. You need to be very
11	careful about kind of creative solutions to
12	problems. That's the lack of procedures.
13	My concern is the opposite of the
14	spectrum
15	MS. COLLINS: Right.
16	CHAIR STETKAR: where people point to
17	precise procedures and make the presumption that
18	they will be following those precise in that precise
19	procedure because that's what I need to know for
20	this particular action.
21	MS. COLLINS: Yes.
22	CHAIR STETKAR: And again, I don't read
23	this from the perspective of, let me call it the
24	human reliability analysis professional. I read it
25	from the perspective of a PRA analyst out at a
	I

(202) 234-4433

ĺ	46
1	nuclear power plant doing a fire analysis, and
2	they've been given the task to do the HRA. For
3	whatever reason, they're not going to go out and
4	hire a PRA expert or HRA expert. And how will they
5	then think about the problem. That's really the
6	(Simultaneous speaking.)
7	MS. COLLINS: So if it
8	CHAIR STETKAR: path that I find
9	MS. COLLINS: they may have the
10	tendency to just go through and say, look at the
11	procedures.
12	CHAIR STETKAR: Absolutely, we have that
13	sense. They know their procedures. They know what
14	they have. They know their goal is to demonstrate
15	the human error probability for failing to pick up
16	this cup is 10 ⁻⁶ .
17	MS. COLLINS: Right. No, I
18	MS. COOPER: Yes, I think this i8s a good
19	point. I guess we may well also have been
20	influenced by a substantial amount of feedback from
21	some of our students in training courses where
22	they've been asking us for guidance on format for
23	fire procedures.
24	We did some presentations as part of the
25	training this year on different types of procedure
I	I

(202) 234-4433

1 formats that our various contractors that are 2 involved in the project have run across, and in the 3 worst-case scenario, but not infrequently, it's been 4 the fire protection engineer that has written the 5 procedure -- actually, they've written the procedure -- and it's absolutely clear to them that everything 6 7 that anyone would need to know in order to respond to a fire in this particular location is there. 8 But it doesn't look like any procedure any operator is 9 10 familiar with, and it seems to be missing things from that perspective. 11 MS. COLLINS: 12 Yes. MS. COOPER: So we've had a lot of 13 14 feedback about, gee-wiz, these things look really different. 15 How are they going to use them? Can they use them? And do they know how to use them if 16 17 it's even possible. Have they tried to work with them and understand what the paths are, where to 18 19 find things and so on and so forth. So in a certain sense, we're sort of 20 back in '70s days, if you will, with some of these 21 procedure formats. So we're kind of in different 22 spaces if you will. 23 24 CHAIR STETKAR: That may be very true. Ι just hope we're not back in the '70s days where you 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

47

	48
1	look at each step in the procedure and draw a little
2	THERP tree that says "success" or "fail" and you go
3	to the next step in the procedure and it's success
4	or fail. That's
5	MS. COOPER: No, no. We're not doing
6	CHAIR STETKAR: That's the fear that I
7	have.
8	MS. COOPER: It's certainly not our
9	intent to do that. It is just simply recognition
10	that the procedures are different and we can't think
11	about them in the same way
12	CHAIR STETKAR: Yes.
13	MS. COOPER: that the EOPs have been
14	structured and modified, in order to really support
15	the operators in their response.
16	CHAIR STETKAR: And as I said, I think
17	there are some things in Chapter 4 that sort of say
18	things like that, which is good. You know, reading
19	it as a I don't want to characterize myself as an
20	HRA professional because that's a brand reading
21	it as someone who's sort of familiar with the
22	methods, I can see the message that's trying to get
23	across.
24	But then, putting the other hat on, when
25	I go to the actual implementation and some of the

(202) 234-4433

	49
1	explanatory text, some of that, I think, would
2	quickly get lost.
3	MS. COOPER: Okay.
4	CHAIR STETKAR: So I think that's enough
5	on procedures.
6	MS. COLLINS: No, I know that it comes
7	from all over the map. We've had people who have
8	talked to us and said, please, if the 805 and the
9	PRA process give us a way to change our current fire
10	procedures, we would like that because we'd like to
11	be able to do it within the context of
12	CHAIR STETKAR: Okay, but then, sure
13	MS. COLLINS: mitigate risk.
14	CHAIR STETKAR: which was great. But
15	the fact of matter is they're the licensee. They
16	should know best how to
17	MS. COLLINS: Yes.
18	CHAIR STETKAR: And if, indeed, there's
19	some, you know, industry efforts in the same way as
20	structuring format and content of EOPs, you know,
21	that's fine, but that's not the purpose of this
22	NUREG, certainly.
23	MS. COLLINS: No. It's just nice that
24	we're being asked to help fix the problem
25	CHAIR STETKAR: Sure.
I	I

```
(202) 234-4433
```

	50
1	MS. COLLINS: Which has not always
2	been a capability of HRA.
3	MS. COLLINS: And I hope that we've
4	tried to emphasize in our document the need to do
5	these walk-throughs and talk-throughs with
6	Operations when you get down to the meat of what you
7	are really crediting in these PRAs so that we do
8	understand the realities versus what the
9	CHAIR STETKAR: It does except, if I go
10	to an operator and say, show me the procedure that
11	leads me to picking up this cup of coffee, the
12	operator will show me that procedure. If I say,
13	what happens if this room is full of smoke and, you
14	know, that thing is there and this alarm is going
15	off there, how might you come to the decision that
16	you're going to pick up the cup of coffee? I might
17	get a different answer.
18	MS. COLLINS: Different answer, yes. I
19	agree; it all depends on how you ask the question.
20	CHAIR STETKAR: Indeed.
21	MS. COLLINS: All right, moving on to
22	another fun topic, multiple spurious operations
23	there were discussions in our previous meetings with
24	you folks, and then we had discussions amongst
25	ourselves, as Susan mentioned, and then subsequent
I	1

(202) 234-4433

	51
1	discussions, sidebars. And so we have attempted to
2	address the issue.
3	I'll start by saying one of the first
4	issues that was brought to our attention were
5	various references that discussed multiple spurious
6	operations, such as the Reg guide and NEI documents
7	and whether we should add references to these. And
8	we have added references to these.
9	However, ever when you look at these
10	particular documents, the focus is primarily circuit
11	analysis, component selection, fire modeling. So
12	the intent of these regulations and guidance
13	documents are that the multiple spurious operation
14	issue is primarily addressed by other fire PRA
15	tasks, and provides input for the fire HRA.
16	With the component selection task, I'm
17	finding more and more, and rightfully so, that one
18	needs to speak very closely with component selection
19	because part of their tasking if you read 6850, is
20	to identify instruments that, if they have spurious
21	impacts, can impact the HRA. So I need to obviously
22	make sure. What are they saying in their notebooks
23	and in their analysis that impacts me as the HRA
24	person?
25	However, again, it is an issue that
	I

(202) 234-4433

1 impacts HRA, but it is not, from the document standpoint, stated as an HRA subtask. But we do 2 3 need to be mindful of it, and it is an important 4 issue. So it's with that perspective in mind that 5 we have added a new section and the table hopefully will be clarified to identify, here are particular 6 7 ways in which spurious operations are modeled in the 8 fire PRA, and here are the interactions with the 9 fire HRA, accordingly, that be a fire HRA person needs to be aware of, such that the MSO issues are 10 addressed and incorporated. 11 And I think also, in the quantification 12 standpoint, we do have ways we get into detailed 13 14 analysis of saying, if we have a case of multiple indications that can potentially provide a situation 15 of lack of clarity or confusion to the operator, we 16 17 know that there are certain procedures and quidance that are provided at certain plants to indicate 18 19 which indications are trustworthy, and which are not potentially, so that gets fed into our human 20 reliability analysis. 21 I know, myself, I factor it into the 22 calculation of the human error probability by 23 24 looking at, is there additional delay time I need to be adding to my diagnosis time to account for that? 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

52

	53
1	Are there additional performance-shaping factor
2	tweaks I need to be doing to make that HEP less
3	optimistic by virtue of this.
4	So I think we have reviewed the issue.
5	We have discussed it amongst ourselves. And I think
6	we are providing good guidance to our users at this
7	point in terms of a table. There's never going to
8	be something that's going to cover every situation,
9	but I think we're raising awareness of the need to
10	interface with other pieces of the PRA where this
11	issue comes up.
12	CHAIR STETKAR: Thanks. I love quoting
13	from things because, regardless of what's said
14	orally, what's written is important.
15	MS. COLLINS: I understand.
16	CHAIR STETKAR: In Table 2-3, the fourth
17	row in that table does address multiple spurious
18	actuations, multiple spurious cable failures and
19	electrical faults. It says, "Quantification of the
20	HEP focus is on reliability of the operator, given
21	at least one good train of instrumentation,
22	regardless of whether there are one, two or 20
23	spurious indications on non-credited components.
24	"In scoping in the equity approach, the
25	additional spurious instrumentation impacts on a
	I

(202) 234-4433

	54
1	scenario are currently outside the scope for HEP
2	development but may impact on certainty.
3	"There's a potential source of modeling
4	uncertainty issue. For example, if one area has
5	action HFE 1 and those spurious indications in
6	another area as the same HFE but somewhat
7	distracting spurious indications, then the HEP for
8	each area may appear to be the same HEP using
9	today's methods, but the uncertainty associated with
10	each development should be assessed as being
11	different."
12	This says to me, there's no real effect
13	on operator performance. Yes, we've got to do this
14	and some uncertainty, sensitivity stuff, but if you
15	read the uncertainty guidance, that's an
16	afterthought. We don't really need to do that
17	because point estimates are okay anyway. So,
18	essentially, the decision of the team is w3e don't
19	need to treat multiple spurious actuations. And
20	indeed, the guidance, as you get back in Chapter 5,
21	reinforces the notion of all I need to do is
22	consider whether or not I have one train of
23	instrumentation available that, according to my
24	procedures, says I shell pick up this cup of coffee
25	because that is precisely the action that I want to
	1

(202) 234-4433

(202) 234-4433

	55
1	evaluate.
2	H.B. Robinson completely ignored an
3	over-cooling transient, completely ignored loss of
4	all cooling for the reactor coolant pump seals,
5	because they were distracted by things over in the
6	secondary side of the plant, non-safety electrical
7	things, and what was going on had no bearing on
8	either of the safety functions that they missed. I
9	can't understand how this rationale in this guidance
10	can give me any reasonable approach to modeling
11	human performance.
12	MS. COOPER: Yes.
13	CHAIR STETKAR: You've obviously put some
14	thought into this, so if that's sort of the position
15	that the NUREG is taking, I want to make sure that I
16	understand that because, from my perspective, it is
17	woefully deficient this area and it's kind of
18	reinforced that notion that as long as I have one
19	train of instrumentation. And I can assume I have
20	it because my deterministic fire protection says
21	that I'm protecting that train.
22	As long as I have that, I don't need to
23	worry about the fact that the ceiling fell down over
24	there or that, you know, Joe's screaming for help in
25	the other part of the control room because he's
	1

(202) 234-4433

	56
1	losing feedwater and of that non-safety stuff that I
2	don't care about for this particular action in my
3	PRA.
4	MS. COOPER: If you don't mind, Erin,
5	I'll respond first.
6	I don't think that exactly matches the
7	way everyone on the train team thinks, and we
8	probably should look at the exact wording of that
9	table because when you get to table summaries,
10	sometimes the summary and the table doesn't
11	necessarily represent all the details of the
12	description.
13	CHAIR STETKAR: I couldn't find anything
14	else is the problem. The problem is if I look at
15	the the table is meant to define the scope of
16	what analysts will look at, and indeed, that
17	narrowly focused scope is reinforced again when I
18	get back to the more detailed guidance in subsequent
19	chapters, regardless of what the middle Chapter 4
20	may say in a more general perspective about, be
21	careful of things.
22	MS. COOPER: I wouldn't be surprised if
23	the appendix on the EPRI approach is consistent with
24	that, but I don't know that for a fact. I'll let
25	Erin answer that. The ATHEANA appendix doesn't have
I	I

(202) 234-4433

	57
1	very long content because it already was trying to
2	address areas, errors of commission as its intent.
3	However, if memory serves me and it
4	may not one of the examples in there, or maybe
5	the only example, which was taken from the 2010
6	training, I actually developed with the Robinson
7	event in mind.
8	CHAIR STETKAR: Okay. There's two
9	MS. COOPER: There's things that
10	there were problems with how the procedures were
11	used and potential distractions on the part of the
12	operators, the shift supervisors, and so forth.
13	It's not the same event; there are other things that
14	are going on.
15	The problem, I guess, is, and this is
16	what we tried to say in Chapter 1 and what we were
17	trying to sum up in Section 2 is that, given the way
18	fire PRA is done right now (specifically the circuit
19	analysis), we don't have inputs that would help us
20	understand what other things are going on to then
21	evaluate if it's important.
22	We also don't have the ability to say,
23	if these indications were doing something funny and
24	I was trying to do this, that would be important. I
25	mean, there are just too many different things to
I	I

(202) 234-4433

58 1 pick from. We can't come up with a set, and certainly not generically, can we figure out a set 2 3 of rules to do that. So we do not have that 4 capability right now. 5 So we are trying to represent in the table the way the interfaces and interaction and the 6 7 input development and what's done with it now --8 what are we doing it now? 9 Your point is well taken. I think that 10 text probably needs to be looked at, because I don't necessarily agree with it the way you've discussed 11 it, but --12 CHAIR STETKAR: Well, I quoted it and --13 14 MS. COOPER: -- well, I mean, when --15 CHAIR STETKAR: -- editorialized my own impressions. 16 17 MS. COOPER: Right. CHAIR STETKAR: My biggest concern is, 18 19 and I recognize certainly, first of all, that one of the reasons why I think we requested the references 20 to the documents that are in the first bullet on 21 screen there is that those documents explicitly 22 state that there is no limit to the number of 23 24 spurious actuations that should come from circuit So the circuit analysis is not limited 25 analysis.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	59
1	for a particular fire area to examine the only a
2	single spurious signal.
3	Fire analysis for this area may identify
4	a thousand spurious signals. In a deterministic
5	sense, as long as I've protected another train, I
6	don't care. From a probabilistic sense, I need to
7	deal with it. So, saying, well, we don't get the
8	information from the circuit analysis isn't quite
9	correct. It, in principle, should be there if
10	they're doing the analysis according to that
11	guidance in terms of a potentially large number of
12	spurious actuation.
13	Whether they look a spurious actuations
14	in non-safety secondary systems is admittedly a
15	question.
16	MS. TOOPER: Yes.
17	CHAIR STETKAR: Should they? Perhaps
18	they should, from HRA. Perhaps the HRA analysts
19	should say, gee, are there any secondary systems in
20	this particular fire area that might cause
21	additional problems for the operator if, for
22	example, you know, they're losing all feedwater and
23	blowing down the secondary side of the plant and
24	could get distracted by that. So it's not clear
25	division as you might want to make it.
ļ	I

(202) 234-4433

The bigger concern is if we have actual operating experience evidence of people either doing the wrong thing or not doing something that we would hope that they would do in the context of our PRA model. For example, we store cooling to the reactor coolant pump seals.

7 Simply saying the current methods don't address this and we can use the current methods to 8 develop a 10⁻⁴ probability for the human error for 9 failure to do that, because we don't need to worry 10 about distractions, will lead to optimistic 11 assessments of operator performance for the NFPA 805 12 submittals. And that's a bit of concern, that 13 14 guidance in the sense of saying we don't quite know 15 how to treat multiple spurious operations, but if you have a fire scenario that gives you a lot of 16 17 spurious actuations in the control room, you may want to be pretty doggone conservative about your 18 19 operator performance.

MS. COLLINS: Yes, and I think there is -- personally, I think there is more of a tendency to go that direction. We usually get more flak from the HRA in going more conservative and then things pop up more frequently in cutsets and then we have to scrutinize them, and I'm --

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

	61
1	CHAIR STETKAR: Following this guidance
2	is as, again, that PRA practitioner on the plant,
3	not an HRA professional
4	MS. COLLINS: Yes.
5	CHAIR STETKAR: Following the
6	guidance, this guidance, both in terms of things
7	that might prompt an undesired action or error of
8	commission or what I need to consider in terms of
9	errors of omission (There is those two line items in
10	that table 2-3 that addressed those issues a bit
11	differently, separately), I'm looking for things
12	that I don't need to do.
13	I'm looking for guidance that says I can
14	point to a line item in a table, I can point to a
15	subsection in report that says this NUREG guidance
16	told me that I didn't need to think about this. And
17	there's a lot of that here in the sense of multiple
18	spurious. can point to many things as a PRA analyst
19	that says, well, they said I didn't need to look at
20	this because we don't know how to do that, so I had
21	10 [^] -6 for the operator, you know, opening that,
22	picking up the coffee cup or opening up that valve.
23	MS. COLLINS: You're right. I
24	CHAIR STETKAR: I'm honestly looking for
25	that
I	1

(202) 234-4433

	62
1	MS. COLLINS: I think that may be
2	(Simultaneous speaking.)
3	CHAIR STETKAR: as guidance from
4	those
5	MS. COLLINS: the sections where we
6	talk about evaluating things in detail, but
7	CHAIR STETKAR: Yes, but if I
8	MS. COLLINS: you're right, it's has
9	not been brought up here.
10	CHAIR STETKAR: never get to the
11	detail because I haven't flagged that action, it's
12	never shown up in the cutsets
13	MS. COLLINS: Yes.
14	CHAIR STETKAR: so I've never had to
15	re-examine it in the scoping
16	MS. COLLINS: Yes.
17	CHAIR STETKAR: and certainly, I
18	never examined it in the detail; it's just never
19	risen to the surface.
20	So, if we don't have know how to treat
21	it, we ought to at least have some backstop, if you
22	want to call it that, that makes sure it gets
23	flagged, other than just saying it's an issue of
24	modeling uncertainty and, you know, we'll deal with
25	that somehow differently.
ļ	I

(202) 234-4433

	63
1	MS. COLLINS: No, I mean, at this point
2	in time, I don't think we have a strategy for how we
3	would treat it if we had the information. It would
4	take more work to develop that strategy is my is my
5	sense.
6	CHAIR STETKAR: Yes.
7	MS. COOPER: I think we've got some
8	tools out there that can help address that. The
9	ATHEANA deviation search process may help try to
10	focus certain areas. I don't know. You know,
11	which things, if they went wrong, would it matter?
12	Maybe. I don't know.
13	MS. COLLINS: And as I say, within the
14	context of the calculator, for example, when I'm
15	looking at things, and there have been instances on
16	very recent prior PRAs that I've worked on where a
17	separate HEP has been developed for a case of
18	degraded instrumentation as a catchall type of
19	concept to address this.
20	I am uncertain as to how many things I
21	have going on at the same time and I don't know
22	exactly what type of effect that's going to have,
23	but I can presume that, again, if there's confusion
24	there, it may take longer for the person to
25	diagnosis what's going on and to allow myself to use
I	

(202) 234-4433

	64
1	different performance-shaping factors within that
2	calculational tool to reflect that multiple things
3	are going on at the same time.
4	So, again, it's not perfect, but it is a
5	way of discriminating between perhaps a best case
6	and a, you know, funky things are going to be going
7	on and they're going to have more difficulty
8	diagnosing it. It's not
9	MS. COOPER: I mean, other than that, I
10	would say, other than a blanket multiplier, I mean,
11	I don't really know how you would address saying,
12	well, there's a possibility that we don't know, but
13	because we don't have the information, there might
14	be some things going on that could be distracting
15	and that could have a negative impact on the
16	operator performance, and it would raise the
17	probability by X factor.
18	I don't know what other strategy we
19	would have. In the scoping approach, which I
20	mean it would depend on the analyst as to whether or
21	not they decide whether or not that kind of
22	situation would be within the scope of the scoping
23	approach, but if they did, we've already been asked
24	to remove certain conservatisms because of
25	double-counting of factors and stuff like that. But
ļ	I

(202) 234-4433

	65
1	I
2	CHAIR STETKAR: I understand you've been
3	asked, if I'm out in the plant, I will ask you to
4	make sure that I have the guidance in a written
5	document that is endorsed by the Nuclear Regulatory
6	Commission of the United States of America that I
7	can point to so that I can calculate a 10 [^] -6 number
8	for this. Remember, this is an NRC document. It is
9	not an EPRI technical report.
10	MS. COOPER: I know. It wasn't
11	CHAIR STETKAR: It's an NRC NUREG.
12	MS. COOPER: Yes, it was more of a
13	technical review in that you guys really counted
14	this here and now you're counting this here, and
15	you're really double-counting, that sort of ting.
16	So, but anyway, I think Dennis was going
17	to set something.
18	MEMBER BLEY: Yes, I mean there's some
19	minimal things, I think, at least, you could do.
20	You know, flagging these kind of things is one.
21	Another is suggesting to look at the
22	scenarios and what might be going on. What might
23	the initiating event be beyond the fire? And under
24	things that throw you into the emergency procedures,
25	acknowledging that there's multiple paths of
I	

(202) 234-4433

activities, and they can certainly cause problems, and referring to a few of the events in which those problems have occurred.

4 You know, we're seeing already that 5 pressure on the plants' training programs to begin to run drills that aren't plain-vanilla drills that 6 7 are giving people lots of other things going on, trying to replicate that situation at Robinson, and 8 9 there are other events; we keep flagging that 10 because that's the most recent and most interesting. Also, other folks who look over plants and come in 11 and do exams are doing the same kind of things. 12

And we need not to just run drills that 13 14 are not just this one thing at this point but have multiple things going on, like happened in these 15 kinds of events, especially fire events. You know, 16 some years ago, the San Onofre event created a lot 17 They didn't end up in the same of difficulties. 18 19 kind of tough spot but they could have. They were operating under the same kind of problems. 20 So, acknowledging that unless it's a 21 very localized fire and it's not affecting 22

operations at all, it really is going to be the kind
of event that can create overloads, burdens, wrong
focus, pull the crew apart, that kind of stuff, and

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

	67
1	put some emphasis on that and at least flag it in
2	the uncertainty analysis.
3	It seems to me, says there are some
4	things you can do to look at every possible
5	combination of
6	CHAIR STETKAR: You can't do that.
7	MEMBER BLEY: You can't do that, and
8	MS. COLLINS: You can't do that.
9	MEMBER BLEY: what you can
10	acknowledge that it's out there in real flyers and
11	happens, and not extremely rarely, when you get bad
12	fires that those kind of things are going on. So I
13	think you could do that to make some emphasis.
14	CHAIR STETKAR: And in practice, a large
15	fraction of the cables and equipment in a nuclear
16	power plant have nothing to do with safety systems
17	that we primarily deal with in a PRA on the
18	secondary side of the plant. On the other hand, a
19	large fraction of a typical operator's life also
20	deals with keeping that equipment running. They
21	don't ignore that stuff simply because the PRA isn't
22	interested in whether or not I wiped the bearings on
23	the main turbine. They're probably pretty
24	interested in that. And just blanket saying that we
25	don't care about the stuff that's outside of the PRA
	I

(202) 234-4433

	68
1	because we happen to be doing the PRA lends the
2	wrong impression.
3	So, so this notion, of you can't do a
4	deterministic analysis of all signals might be
5	occurring, I mean, it's just impractical, certainly,
6	perhaps impossible, for any given fire scenario.
7	But I think that you can ask the people
8	who are doing those fire analyses, who are doing
9	those circuit analysis not to do a circuit analysis
10	for every wire, for every valve out there in the
11	turbine building, but to at least be aware of the
12	fact that, oh, yes, all of the controls for the
13	turbine systems go through here, so, even though I
14	haven't looked at those circuits, yes, the turbine
15	could be doing funny things in here.
16	So, yes, maybe you ought to think about
17	that in the context of your HRA, whereas another
18	fire location maybe doesn't have anything to do with
19	any of that stuff, and you may have a better
20	foundation for focusing on more of the y-related
21	things.
22	MS. COLLINS: Yes.
23	CHAIR STETKAR: You know, how do you
24	treat that? Yes, simple multipliers might work.
25	Anything, to at least acknowledge that that
I	

(202) 234-4433

	69
1	environmental situation, if you will, exists in
2	terms of the operating team response.
3	MS. COLLINS: From the standpoint of PRA
4	quantification, it comes down to multipliers on the
5	HEP, but that also raises the question of
6	qualitative insights that one gains from that,
7	because as these things surface and as you go
8	through your successive modifications, if this thing
9	is dominating because we've given it a relatively
10	conservative value, we as HRA people have to
11	justify, why are we doing this?
12	CHAIR STETKAR: Sure. Sure.
13	MS. AOLLINS: So part of the
14	assumptions, then, is for us to go back and
15	scrutinize again and talk through again to make sure
16	that we understand a better, and then perhaps going
17	back to fire modeling or circuit analysis and
18	getting further information
19	CHAIR STETKAR: Yes.
20	MS. COLLINS: I think your point in
21	terms of, have we clarified well enough that perhaps
22	some of the initial estimates should be enough to
23	allow that not to get down into the 10 [^] -6 range so
24	it does continually get scrutiny. Maybe that could
25	be
ļ	

(202) 234-4433

70 1 CHAIR STETKAR: You know, obviously, I'm 2 pretty interested in this topic. 3 But at a current snapshot in time, 4 recognizing that you prefaced the whole 5 presentation, we all recognize that this is important input to the NFPA 805 submittals, there 6 7 may be nothing wrong in the context of those submittals to say, look, we've identified the 8 9 following situations in our plant. There may be some scenarios that indeed we can't do much with 10 because they may be driven by multiple spurious 11 operations affecting human performance within the 12 limits of our ability to identify details of those 13 14 and our ability to qualify human performance in 15 whatever the context might be. 16 MS. COLLINS: Yes. CHAIR STETKAR: This is an area for 17 additional research, kind of like what Chapter 1 18 19 says, you know, we need to do more work on this. 20 But at least for this point in time, for the snapshot in time, let the transition process 21 identify that as a particular issue, that if a 22 particular --23 24 Don't touch anything. Theron gets really upset if you will try to fix this. 25 It will

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	71
1	come back.
2	MS. COLLINS: Oh, it does.
3	CHAIR STETKAR: At least identify that
4	as something. You know, maybe for a particular
5	plant, it's not an issue; maybe for a larger plant,
6	it might be a larger issue.
7	MS. BOLLINS: Yes, depending on how
8	well things are traced.
9	CHAIR STETKAR: I think you get the
10	notion.
11	MS. COLLINS: Yes.
12	CHAIR STETKAR: Because, as I said, it's
13	not good enough for that PRA practitioner out in the
14	plant looking for things in NRC-endorsed guidance
15	that I can point to, to say I didn't have to do this
16	because I was told I didn't need to do this. I can
17	I can point to a lot of pointers here in that in MSO
18	issue.
19	MS. COLLINS: Yes.
20	CHAIR STETKAR: So you may want to
21	relook at that not only in Table 2-3, which probably
22	could be cleaned up pretty easily, but back in
23	Chapter 5, there are several examples that sort of
24	reinforce this notion of, well, I need to consider,
25	as long as I have a single train of instrumentation
I	I

(202) 234-4433

	72
1	available that points me towards this, that's all I
2	need to consider.
3	MS. COLLINS: Yes.
4	CHAIR STETKAR: You know, or even
5	editorial comments that says is, as long as I have a
6	procedure and one train of instrumentation, it's
7	very likely that the operators will be successful.
8	You know, that sort of biases my selection of
9	performance-shaping factors, for example, in the
10	scoping stuff.
11	MS. COLLINS: That's funny. I need to
12	look back through the document. When I was looking
13	through
14	(Simultaneous speaking.)
15	CHAIR STETKAR: I could point you to
16	sections, but it's sort not the problem is, if I
17	point you to specific sections, I'll probably miss a
18	few.
19	MS. COLLINS: Oh, I understand. No,
20	that's good. That's just as well, I
21	MS. COOPER: We may be getting to the
22	point that when we read, we can't read anymore.
23	CHAIR STETKAR: The problem is, this
24	office as I said, I read the document as someone
25	who is looking for help or something I can point to,
I	

(202) 234-4433

1 to tell me that I don't need to do something that 2 might be difficult, quite honestly. You know, that's a very cynical attitude, but we all know 3 4 that, indeed, some people may be looking for that. 5 And indeed, some of these problems are really, really difficult and probably not soluble at our 6 7 current state of knowledge. I would agree with that 8 MS. COOPER: 9 completely. I mean, I'm just trying to think ahead. There may be some instances, and we've had quite a 10 lot of discussion on this topic, where perhaps you 11 might be able to say that, for a particular fire 12 location, you know that there aren't going to be any 13 14 other extraneous or additional spurious indications 15 just because there aren't cables going through 16 there. But on the other hand, it seems that 17 there are going to be a lot of events, potentially, 18 19 that you're just not going to know, and to have to put, minimally, a factor 2 on every HEP where you 20 don't have that information, or you know -- I'm 21 struggling a little bit with what that kind of 22 impact will be. It's not going to necessarily 23 24 highlight anything because it's going to be everywhere. It's can bring to the top --25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

73

	74
1	CHAIR STETKAR: It's not, it's
2	MS. COOPER: anything in particular.
3	CHAIR STETKAR: You know, at one level,
4	I don't particularly care, the numerics of product.
5	I don't care if it's a factor f two or five or 100
6	or 300 or 1,000 or 1.0 for the HEP. It's instilling
7	a notion in the guidance that people will follow if
8	the circuit analysts have not provided information
9	about multiple spurious operations, which they
10	should at least for the safety-relevant equipment
11	that they've been instructed to do the analysis for.
12	If they don't provide it, at least the
13	HRA folks should have enough sensitivity to go back
14	and say, hey, in this particular area that you're
15	now giving me this fire scenario, is there anything
16	else in there that might affect what the operators
17	are seeing in the control room?
18	Don't do a detailed analysis of the old
19	circuits, but they should know what cables are
20	routed through there. If they don't know that, they
21	don't know their power plant and they shouldn't be
22	doing a fire PRA of that power plant anyway. They
23	should know what types of cables are run through
24	there without necessarily tracing every single
25	circuit on the secondary side of the plant, and
I	I

(202) 234-4433

	75
1	ought to able say, well, yes, there are rad waste
2	signals here. Fine; you know, I don't particularly,
3	necessarily care about rad waste signals.
4	Oh, all the feedwater control signals
5	are run through this room. Okay, that might be
6	interested even thought I haven't modeled feedwater
7	in my PRA. I don't necessarily need to know. You
8	know, as an HRA analyst, I don't necessarily want
9	you to go out and do a detailed analysis of every
10	one of those circuits because that's not something.
11	But when I do the HRA of this particular focused
12	action to pick up the coffee cup, I need to know
13	that I'm doing that in the context of, feedwater
14	might be going, to use a technical term, "nuts".
15	MS. COOPER: Right.
16	CHAIR STETKAR: It just might. And, you
17	know, my priorities, for whatever reason, might be
18	focused more on feedwater because that's something I
19	deal with all of the time.
20	MS. COOPER: Okay. We'll try to come up
21	with some kind of crude rules on that perhaps.
22	CHAIR STETKAR: You'll probably get
23	pushback. So it's
24	MS. COOPER: Well, it could be. I think
25	there are
	I

(202) 234-4433

	76
1	CHAIR STETKAR: It's probably enough on
2	that topic, I think.
3	MS. COOPER: Yes, I think there are
4	other cases where we have tried to sprinkle it
5	throughout, but just seeing that particular
6	statement in table
7	CHAIR STETKAR: As you do, I mean, read
8	that statement, take kind of my ranting sort of
9	approach to life, and then try to read through the
10	rest of the document and see where there might be
11	examples where either very specific guidance or
12	explanatory comments in the guidance tends to focus
13	you in a particular direction. It might help.
14	MS. COOPER: Yes, just giving some of
15	the other one is, I see where we had talked about
16	cue parameters and how there is a need to consider
17	
18	(Simultaneous speaking.)
19	CHAIR STETKAR: As I said, I have a list
20	of subsection numbers here but I don't want to read
21	them on the road
22	MS. COOPER: Oh, sure.
23	CHAIR STETKAR: because there tends
24	to be I did not read the document line by line in
25	its entirety, and I probably would have missed
Į	I

(202) 234-4433

	77
1	several places.
2	MS. COOPER: Right.
3	MR. SALLEY: Yes, I'd like to interrupt
4	saying I'm little confused following successes here
5	in this document, and I'll tell you why.
6	I listened to your rant. There's a lot
7	of good stuff in your rant, but I have some
8	counterparts on it. One of them is, if you have a
9	bad circuit analysis, that they don't give you the
10	correct information, I don't care how good the HRA
11	is, it can't make up for the circuit analysis; it
12	can only give you the correct pieces.
13	Now, when you talk about the MSOs, we
14	just don't throw the MSOs. First of all, we have
15	one train of equipment free of fire damage for safe
16	shutdown. Now, typically, if I was doing the
17	analysis, I would say this is the train you're going
18	to watch and these are the gauges; this is the
19	instrumentation. And for a fire in this area, this
20	is the stuff you want to focus on. The other stuff
21	is going to be going crazy.
22	And I could take you into the circuit
23	stuff now, where if it's thermoplastic or thermo
24	instrument cable, how it can possibly give you bad
25	indications, which is a whole other section of
Į	1

(202) 234-4433

	78
1	research. So I have that train of equipment ice
2	should procedurally know to use.
3	If I have MSOs. If I identify them
4	electrically, I just can't walk away from them. I
5	mean, one of the things is, if, for example, there's
6	valve positions that are going to change. I have to
7	protect them or I have to do something to eliminate
8	that. So I'm controlling that from an Appendix R or
9	a post fire-safe shutdown analysis. They're not
10	just letting all these signals come in.
11	On the second part, for the secondary
12	side, you know, just like at San Onofre, if they can
13	get the turbine on the turning gear, you want to
14	turn it, which they did. And I understand that some
15	AUO is probably going to be over there putting it on
16	the turning gear and making sure the, the lift pumps
17	are running or whatever. But still, the function of
18	the operators in post fire-safe shutdown event is
19	the reactor.
20	CHAIR STETKAR: You would hope that the
21	function of the operator ought not to be ignoring
22	the fact they've lost all cooling for the reactor
23	coolant pumps seals and doing nothing
24	MR. SALLEY: Yes.
25	CHAIR STETKAR: except for the fact
I	I

(202) 234-4433

1 that in the year 2011, we have evidence that 2 well-trained operators with fire procedures let that happen under a fire the wasn't something like a 3 4 massive fire of the cable spreading room. It was an 5 electrical fire and they had things going on. You can't ignore actual operating experience, regardless 6 7 of what you say about deterministic fire analysis saying I'm protecting that train. 8 9 MR. SALLEY: And I agree with you, and 10 that's why --(Simultaneous speaking.) 11 CHAIR STETKAR: -- be that 12 deterministic. 13 14 MR. SALLEY: But, you know, for example, just like you said though, for other 15 systems that may be of interest to you, are 16 affected, let's go to the cable spreading room. 17 The answer: all. 18 So, for that fire in the cable spreading 19 room, if you're not abandoning and you're going to 20 try to stay in the main control room, which systems 21 are affected? All. So what does it buy you? 22 I 23 mean --24 CHAIR STETKAR: Perhaps nothing for the cable spreading room because the cable spreading 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

79

	80
1	room is a fairly unique, difficult, interesting
2	beast.
3	I'm thinking about plants that have
4	other fire susceptibilities in instrumentation
5	control areas where you where you might have
6	separation between train A and train B. But you
7	lose a lot of secondary things in one train. These
8	things exist.
9	MR. SALLEY: Yes, I mean
10	CHAIR STETKAR: I'm not going to
11	analyze every plant in the United States, but you
12	can't the presuppose, just because we think about
13	cable spreading areas, that that's the only area
14	that might be confusing or important to the
15	operators.
16	MR. SALLEY: And I agree with you. And
17	some areas for example, if someone used 20 foot
18	[sic] of separation and you have the same fire area,
19	you have 20 separation between train A and train B
20	and they have a fire in that area. Which instrument
21	do you believe if your strategy was separation and
22	they're in the same fire area? I don't know. So
23	that's one that would require some more prompting.
24	But, you know, that being said, you
25	mentioned cable locations. Now, I need Dana Power
I	I

(202) 234-4433

	81
1	is here because he'd be doing cartwheels across the
2	stage, because this is something Dana has been
3	saying for years. The fact of the matter is that if
4	you talk to the plants, they're going to tell you
5	that the biggest expense of a lot of this is the
6	electrical engineers trying to find these circuits,
7	and that's for the required, main, post fire-safe
8	shutdown circuits. Now we're asking for ancillary
9	circuits.
10	I just don't see us getting all bunch of
11	traction.
12	CHAIR STETKAR: Let me just say, I've a
13	hell of a lot of people tracing in my life, and it's
14	very, very difficult to determine that the control
15	cable for this particular valve is located in that
16	specific cable tray at that specific location in the
17	specific room. That's really difficult.
18	MR. SALLEY: Yes, it is.
19	CHAIR STETKAR: Understanding that this
20	valve goes somewhere through this room is pretty
21	easy to do because I can trace cable trays even if I
22	have to do it hand over hand. Seeing that the cable
23	comes from the valve and goes into this room isn't
24	that difficult to do. Knowing also that a bunch of
25	feedwater stuff that I haven't model in the PRA also
ļ	I

(202) 234-4433

82 1 comes into this room somewhere isn't all that 2 difficult to do. 3 Knowing precisely which cable is in 4 which microscopically identified geographic location 5 in this room is really difficult to not, and I'm certainly not proposing that that needs to be done 6 7 for out every cable in the entire plant, but the 8 people who have done enough of the cable trays seem 9 to get to the point where they can actually implement the guidance for those other multiple 10 spurious operations, and do know a heck of a lot 11 about the general routing cables in that power plant 12 by the time they get done with that exercise. 13 14 They've not been tasked to think about all of those other cables. 15 16 MR. SALLEY: But they've --17 (Simultaneous speaking.) They were told to MR. SALLEY: -- John. 18 19 qo after certain cables. They normally have crossed a lot of golden nuggets that they throw away and 20 it's not documented, which means they need to 21 re-walk it down. 22 CHAIR STETKAR: Mark, no, they don't 23 24 necessarily the re-walk it down because -- I'm trying to pull back from this notion of very 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

detailed circuit analysis, which needs to be done for some critical set of equipment according to the guidance; I'm not arguing with that. It will be done. People are struggling with that. It's a huge amount of effort even for that critical set of equipment.

7 What I am struggling with is guidance from Human Reliability Analysis that sort of is a 8 9 catch-22 that says, well, because the circuit 10 analysts have not looked at anything else and they haven't fed me information about everything else, I 11 could ignore everything else in the plant and simply 12 focus on those particular actions that the PRA, for 13 14 whatever reason, have identified that the operators 15 must perform.

I don't care that I'm burning up my main 16 17 turbine. I don't care that I'm spilling feedwater I don't care that steam relief all over the plant. 18 19 valves are open all over the place. I don't care about that stuff because the circuit analysts 20 haven't told me that I should care about it and the 21 quidance says I don't need to care about it. 22 So I don't care about it. 23

24 Operators in the real plant will care 25 about that. They will care. In fact they may care

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

	84
1	more about that than this particular valve that the
2	PRA has identified in a specific sequence that they
3	must open. They might eventually get to that valve
4	given enough time and given enough guidance and
5	given enough indications and alarms. But the
6	reliability of on opening that valve may be much
7	different than the fact that the only thing that I
8	need to do in life is worry about that valve.
9	That's a concern.
10	MR. SALLEY: So, with that, again, with
11	this document and where it's at, if you could help
12	me, please define success because that's what I
13	need.
14	CHAIR STETKAR: The ultimate success
15	for the document?
16	MR. SALLEY: For the document.
17	CHAIR STETKAR: The document, in my
18	opinion and again, this is my own opinion; it's
19	not the subcommittee's opinion. I'm hoping that
20	other subcommittee members may chime in if there are
21	different opinions. Certainly the ACRS as a
22	committee would weigh in but my own opinion is
23	that the document should at least provide guidance
24	to the HRA analyst that says, it's incumbent on you,
25	if you're evaluating human performance, to at least
ļ	I

(202) 234-4433

	85
1	go out and make sure that each fire that the
2	circuits in each fire area are limited to only the
3	circuits that the circuit analysis feeding you. Or,
4	are there other things in that area that I need to
5	think about?
6	At least raise the question that the HRA
7	analyst needs to ask that.
8	MR. SALLEY: So, if we put a piece in
9	that suggested that they would consider this, that
10	would be success in this document?
11	CHAIR STETKAR: Well, the document goes
12	on further to you know, that gets into, if there
13	are areas, how do you treat that? You know, that's
14	some Susan's concerns about, well, if there are, do
15	I tell them to increase the HEP by a factor of two
16	or five or 10? Do I told them to fail the HEP? Is
17	it something that only affects the time?
18	You know, that's
19	MS. COOPER: Definitely, that is the
20	question. That could be any of those things.
21	MR. SHACK: And in principle, that could
22	be all of them.
23	MS. COOPER: And in practice.
24	CHAIR STETKAR: But, I mean, at least
25	you would kick them into the detailed analysis
	I

(202) 234-4433

86 1 rather than the scoping analysis. MS. COOPER: Yes. 2 In principle, it 3 shouldn't be there anyway, but yes, I think you 4 would --CHAIR STETKAR: I that's probably as 5 much as John could expect. 6 MR. SHACK: That's as much -- you know I 7 8 9 (Simultaneous speaking.) 10 CHAIR STETKAR: -- some sort of guidance that would --11 MR. SHACK: You know, I have to have 12 faith that --13 14 CHAIR STETKAR: -- yes. MR. SHACK: -- at least kick him into 15 16 the --17 CHAIR STETKAR: Let me give you an Under SISBO, self-induced station blackout example. 18 19 from the record, there's explicit guidance that says, look, if you get into this situation, you need 20 to do a detailed analysis. You know, it says don't 21 use scoping analysis for these particular -- you 22 know, if you get into that part of the procedures, 23 24 you can't do that. MS. COOPER: And, if they do the more 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

87 1 detailed analysis and --2 CHAIR STETKAR: You have to have faith 3 4 MS. COOPER: -- too many signals to 5 figure out --CHAIR STETKAR: It's a limitation on the 6 detailed analysis right now. 7 8 MS. COLLINS: Yes, there's not any way that we would --9 10 MS. COOPER: But see, part of the problem is we can't -- John has given some very good 11 examples of things that operators might care about 12 it, and there may be more plant-specific things that 13 14 we weren't going to be able to dream up, but there may be some specific things like feedwater systems 15 and so forth that could be distractions if there was 16 17 something funny going on. But specifically for a particular fire 18 19 location or for a particular scenario with a particular initiating event, we don't know what 20 questions to ask, what would be distracted? 21 We can't turn that question that way and say, circuit 22 analysis guys, these things would be important to us 23 24 it was also going on. Go tell us if this is a We can't develop that list is the problem. 25 factor.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	88
1	We can't generate the question to ask.
2	Now, if we knew that certain things were
3	going on, we could factor it into the context of
4	everything else, but that's the problem. It's not
5	
6	CHAIR STETKAR: That's impractical. If
7	you had the ultimate, perfect, complete circuit
8	analysis of every wire in a nuclear power plant, you
9	would, in principle, have that information
10	available. You will never have that nor is it
11	reasonable to even suggest that somebody try to do
12	that.
13	MS. COOPER: Right.
14	CHAIR STETKAR: I mean I don't know what
15	else to say. I mean, I think Bill said it correctly
16	that there needs to be an awareness on the part of
17	the HRA analyst that simply what they're given by
18	the circuit analysts is the minimal amount of things
19	that the operators will have to deal with, because
20	that's been defined by the scope of the circuit
21	analysis. That's the minimal complexity of what
22	they'll need to deal with.
23	In some cases, it might be the only
24	complexity because the other circuits that are
25	routed through here might indeed not have anything
Į	1

(202) 234-4433

1 to do with any systems that might distract the operators. On the other hand, the amount of 2 complexity that they may have to deal with, with 3 4 fires in this particular location could be 5 substantially larger if the HRA analyst at least knew, for example, that a fire in this location 6 7 might also be affecting the main turbine and main 8 feed water or something like that. The circuit analysts have no incentive 9 to feed that information forward because they've not 10 been instructed to do that, and right at the moment, 11 the HRA analysts have no instructions to go back and 12 check to see if that's the case, so both sides are 13 14 now happy that they've completely define the problem and can move forward so that the human error 15 probability is 10⁻⁶. 16 (Off-mic comment.) 17 CHAIR STETKAR: 10⁻³ then. I don't 18 19 care -- 99.9% success is good enough for me. 20 MEMBER SHACK: Well, the expert panel that's supposed to generate a generic set of 21 multiples, would they be identifying things like 22 23 that? 24 CHAIR STETKAR: No, because they're only focused -- it's a, indeed, in the guidance, it's 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

89

	90
1	gone through a couple of evolutions, but there are
2	tables of the types of multiple spurious operations.
3	But they're focused on PRA-type scenarios. You
4	know, can you get a LOCA? Can you get a loss of all
5	feedwater.
6	MEMBER SHACK: Okay, so they're
7	CHAIR STETKAR: They're still focused on
8	
9	MEMBER SHACK: Okay, but they would tell
10	you at least that much.
11	CHAIR STETKAR: They tell you that much.
12	They tell you the type, but they tell you the
13	guidance of multiple spurious operations that you
14	need to think about. Are you susceptible to those
15	types of things in this location? They don't really
16	help you in the HRA.
17	MS. COOPER: They should be focusing on
18	the equipment that the PRA's modeling and on the
19	instruments that are on the safe shutdown, what
20	equipment and instrumentation the operators need to
21	know about in order to, in principle, do a safe
22	shutdown. But, as John has pointed out, all kinds
23	of other things could be happening if those tables
24	happen to be in the same location.
25	MEMBER SHACK: Right.
ļ	I

(202) 234-4433

	91
1	MS. COOPER: And it could be a
2	distraction. It could be a minor distraction; it
3	could be a big distraction.
4	CHAIR STETKAR: It could be minor; it
5	could be I mean, you know.
6	MS. COOPER: There's no, unless you know
7	the specifics, you don't have any hope of guessing.
8	CHAIR STETKAR: That's right.
9	MS. COOPER: You don't have any hope of
10	guessing.
11	CHAIR STETKAR: That's right. And to
12	presume in a generic sense, you can't do that, nor
13	should you, in a generic sense. It's more the sense
14	of the biggest concern I have in this area is
15	that in the NFPA 805 transition process, that we
16	optimistically characterize human performance for
17	fires in certain locations at specific power plants
18	because, if you will, both sides of the problem, the
19	circuit analysis and the HRA, have been given
20	guidance that they don't need to think about such
21	that, if we have a fire later perish the thought
22	at one of plants that have transitioned and the
23	operators don't perform correctly, what kind of
24	confidence do we have then in all that risk-informed
25	evaluations that were done as a basis for
I	I

(202) 234-4433

	92
1	transitioning into this entire licensing framework?
2	Because, gee, we missed that one. That's the
3	biggest concern.
4	In the limit, you say, gee, I have
5	multiple spurious operations, you fail the human
6	error probability. I don't know; maybe all the fire
7	analysis and things to all of the gymnastics and you
8	say, well, the likelihood of having multiple
9	spurious operations in this area is 10 [^] -7 and I
10	don't care that the human error probability is 1.
11	MS. COOPER: that's pretty - I kind of
12	broke down in the transition, "optimistically
13	characterize the human performance." Again, maybe
14	it's the disconnect between having someone come in
15	from the outside who has a perspective on this
16	versus someone picking up the guidance document who
17	may not have that.
18	But it's pretty rare that I'm usually
19	getting beat on the other way in terms of, look at
20	all these things that are surfacing. How can that
21	really be that critical? How can that be that
22	pessimistic?
23	CHAIR STETKAR: How can the operators at
24	H.B. Robinson ignore the loss of cooling to the
25	reactor cooling pumps?
I	I

(202) 234-4433

	93
1	MS. COOPER: I agree. Well, again,,
2	then, that part of a give and take that I have with
3	them saying, all right, I will look at it again;
4	however, based on what I've already evaluated, I
5	don't think we have a strong case to make for
6	lowering this probability any further.
7	So my standpoint is I'm usually in the
8	game of defending my potentially pessimistic result
9	against those who would like me very much to reduce
10	that.
11	CHAIR STETKAR: Well, and I think that
12	all say you're the you outside HRA experts have
13	faced that pressure.
14	MS. COOPER: Right. Oh, no I
15	CHAIR STETKAR: Again, I don't read this
16	from the perspective of you doing the analysis or
17	Susan doing the analysis or Stacey doing the
18	analysis or me or Dennis doing the analysis. I read
19	it from this perspective of the person who is
20	putting pressure on you to make those human error
21	probabilities 10 [^] -6 because that's the easiest way
22	out of that scenario.
23	MS. COOPER: Yes, yes. This is
24	obviously something that's pretty important and
25	we'll talk with the team. I'm still very much
l	I

(202) 234-4433

	94
1	concerned about how we would
2	CHAIR STETKAR: However you decide
3	you know, I recognize that this
4	(Simultaneous speaking.)
5	MS. COOPER: every other
6	performance-shaping factor or contextual element
7	that we went to look at it because, otherwise, it's
8	like, why do you do the rest of the qualitative
9	analysis if, in the end, the uncertainty of whether
10	or not there's spurious stuff going on that can take
11	people off the reservation, you know, that's going
12	to swamp any result that we have. That's where I
13	don't know where to go right now, and I have
14	concerns about it.
15	CHAIR STETKAR: You know, we raised it
16	in April. I'm raising it again. I'm an individual.
17	MS. COOPER: Right.
18	CHAIR STETKAR: You know, you need to go
19	back and talk about it; you may decide not to make
20	any changes at all. When you come before the
21	committee, you know, maybe the committee I'm not
22	going to try to presuppose anything, so it's not
23	I think we said enough about it certainly for this
24	afternoon, but
25	MS. COOPER: Okay, well I think we've
ļ	1

(202) 234-4433

	95
1	CHAIR STETKAR: there are only a
2	couple of
3	MS. COOPER: we've had some useful
4	discussions that I think went beyond what we had
5	last time, certainly. I mean, last time I didn't
6	think we were necessarily always talking on the same
7	page and I feel like we are talking on the same
8	page.
9	But I do think this is very clearly not
10	just pushing the state of the art, if sleeping.
11	CHAIR STETKAR: It is.
12	MS. COOPER: I'm really leaping the
13	state of the art.
14	CHAIR STETKAR: It honestly is, and it
15	may be an issue that, there may be other ways to
16	deal with that issue in the context of the NFPA 805
17	transition. I don't think that we can solve the
18	ultimate treatment of this in the context of fire
19	analysis during the NFPA 805 transition process.
20	I think it is an area of continuing
21	research, both in the HRA and in the fire
22	characterization part, if you will, of the problem.
23	I'll go back to notion that that I don't want a
24	situation to occur where a plant has submitted an
25	analysis that's been reviewed and accepted by the
I	

(202) 234-4433

	96
1	staff to support transition to NFPA 805 and then
2	that plant have a fire where the operators don't
3	perform an action that's modeled in the PRA because
4	they've been distracted by something else going on,
5	and then people saying, well, nobody said we needed
6	to think about that. That's the biggest concern.
7	MS. COOPER: Hi, Steve.
8	CHAIR STETKAR: Hi, Steve.
9	MR. DINSMORE: I've been trying to avoid
10	this, but I guess I'd better is this thing
11	working today?
12	My name is Steve Dinsmore from the NRR
13	PRA staff.
14	I guess I'm trying to figure out what
15	you're talking about interacts with the fact that
16	when they do transition, what we're worried about is
17	VFDRs. So if there's no VFDR in other words, if
18	the plant satisfies the deterministic requirements
19	for a fire but the operators make a mistake
20	because of spurious actions, that's not within our
21	review. We wouldn't look at that. It's only if
22	there are some variances from the deterministic
23	requirements in an area. Then we look at how the
24	operators are credited
25	CHAIR STETKAR: Yes.
I	I

(202) 234-4433

	97
1	MR. DINSMORE: to resolve that.
2	CHAIR STETKAR: But in practice, I
3	think, in many practical nuclear power plants,
4	you're more likely to have those variances in
5	locations where the operators may face a fairly
6	difficult and challenging situation not only because
7	of the things that are in the PRA. You're talking
8	about cable spreading rooms; you're talking about
9	locations in the plant that have, you know, multiple
10	divisions of cables and things like that.
11	So my concern is that precisely the
12	areas where there might be more focus on the HRA is
13	where you may be more vulnerable to these types of
14	issues, not in those areas were you doing indeed
15	have very good separation and you can meet
16	deterministic criteria and check off the box that
17	I'm oaky in this area.
18	MR. DINSMORE: Yes, but we do have the
19	opportunity to actually focus in on specific
20	scenarios. So I'm not quite sure how much that
21	helps define the problem. Again, all the general
22	actions that they're taking following a fire are not
23	part of the NFPA 805 transition review. It's only
24	those associated with specifics scenarios.
25	CHAIR STETKAR: Yes?
	I

(202) 234-4433

	98
1	MR. DINSMORE: That probably doesn't
2	help that much.
3	CHAIR STETKAR: That doesn't help
4	I'm not sure that we can talk about some of that
5	other stuff later, but my sense is that some of
6	that it seems to me likely that those scenarios may
7	arise out of locations where the potential for other
8	distractions may exist just because of the nature of
9	how you get into those types of scenarios.
10	MR. DINSMORE: Sometimes, we also could
11	accept a variance by assuming there's no well,
12	let's assume it goes to core damage.
13	CHAIR STETKAR: That's fine. I mean,
14	how they try to work their way around an approval
15	from the transition is sort of case-by-case
16	MR. DINSMORE: Right.
17	CHAIR STETKAR:
18	submittal-by-submittal basis.
19	The subject of this particular meeting
20	is kind of generic guidance that will be applied
21	across the board for doing the HRA to support
22	whatever they need to support. You know, if they
23	decide to take credit for a particular operator
24	action and provide a risk-based, risk-informed
25	analysis to support that action and the human error
l	I

(202) 234-4433

	99
1	probability is 10 [^] -6 I keep using that number
2	because it's because I will use that number
3	10 [^] -6, you want to have good confidence that that's
4	reasonably well founded.
5	MS. COOPER: Okay.
6	Erin, do you want to I think you have
7	another few slides.
8	MS. COLLINS: Yes. Let's see.
9	I don't know if you want to continue on
10	this topic at all because just pointing out
11	particular sections in which we had text changes, I
12	don't think so. No.
13	MS. COOPER: I'd like to just stop. I
14	mean, the procedure focus here is that the procedure
15	can help reduce some confusion with respect to
16	what's going on in the sense that some players have
17	gone so far as not only to identify protected
18	equipment by to identify the other instrumentation
19	in that room that could be impacted, and they've
20	listed that.
21	CHAIR STETKAR: Yes.
22	MS. COOPER: So, in essence, they're
23	saying, okay, they're doing the job you're talking
24	about. They've done that job. They haven't said
25	specifically, yes, it will impacted, but they're

(202) 234-4433

	100
1	saying it's in that location and the operator can
2	say okay. Maybe this stuff is wrong and
3	CHAIR STETKAR: And I'll ignore that
4	whole chunk of the plant.
5	MS. COOPER: Exactly.
6	CHAIR STETKAR: And that's fine. But
7	there are probably plants that haven't done that as
8	well.
9	MS. COOPER: That haven't done that.
10	MS. COLLINS: They may not have done
11	that. That's correct.
12	CHAIR STETKAR: And again, the guidances
13	is going to be picked up by people perhaps at those
14	plants that say, well, I don't need to worry about
15	it because I don't need to worry about it.
16	MS. COLLINS: Well, the next major topic
17	that came up oh, boy, let's start again, was main
18	control room abandonment. So, an attempt to address
19	the subcommittee's concerns, we've added a new
20	section culled from various points in the document
21	issues that we may have mentioned about qualitative
22	analysis related to the abandonment issue and put
23	them in one particular section.
24	Some of the issues that we discuss are
25	habitability, which has to do with specific guidance
I	I

(202) 234-4433

	101
1	from 6850 on smoke levels and heat flux, at et
2	cetera, and the ability to control the plant from
3	the control room. We're finding that, not
4	surprisingly, there may be a preference on the part
5	of the operator to stay in the control room because
6	they had the full range of things available and not
7	go out to a dedicated shutdown panel, which has much
8	less control capability. So where do you make that
9	decision? And the need to evaluate that
10	decision-making process of when they stay and when
11	they go, and how the timing of the decision-making
12	process may impact your detailed analysis of this
13	scenario.
14	Admittedly, however, we recognize that
15	this is an area that would benefit from further
16	research, but there are still some brick people in
17	their fire PRAs who are using the screening value
18	and finding that that is not a dominant contributor,
19	and therefore, not going pretty detail. So I think
20	that each fire PRA tends to look at this slightly
21	differently and say what meets our needs? What's a
22	risk significant issue, and how greater detail. Do
23	we need to go into it?
24	But hopefully, for those who do need the
25	greater detail, we have now provided a specific

(202) 234-4433

(202) 234-4433

	102
1	section that gives the user guidance on
2	performance-shaping factors and other issues that
3	need to be considered.
4	Is there anything in particular that the
5	subcommittee had a question on in this new section
6	if you've had a chance to look at it?
7	CHAIR STETKAR: If you hear silence from
8	me and silence for about 15 seconds, move on.
9	MS. COLLINS: Okay. I've got my sweep
10	second hand. So we'll put a gavel down.
11	CHAIR STETKAR: actually, in truth, I
12	think that you did in this section is good. It does
13	in the sense of raising consciousness, it does
14	it. It solves the issue.
15	MS. TOLLINS: that was the intent
16	because we knew previously we had a section that
17	essentially said, well, you know, a lot of people
18	use the screening value. And other people don't and
19	that's about it. But here, we tried to do it.
20	CHAIR STETKAR: In terms of staff
21	reviews, it also puts into writing the intent of
22	this guidance so that when I look at staff reviews,
23	if indeed people are doing an analysis of control
24	room abandonment, you know, there are issues written
25	here that can be questioned; you know, did you
l	

(202) 234-4433

	103
1	consider these things? And that's it's all we can
2	ask for at this stage of the guidance.
3	MS. TOLLINS: Okay.
4	CHAIR STETKAR: Again, in my personal
5	opinion I don't speak for anyone else.
6	MS. COLLINS: Well, hearing no other
7	inputs, I will forge ahead to the next slide.
8	And our friend, self-induced station
9	blackout, which was previously discussed in probably
10	more detail than necessary in Appendix D, but
11	recognizing that, again, this issue may still exist
12	in the certain procedures either full scope, SISBO,
13	or the concept of having to deal with preemptive
14	operator actions as we usually call them, that there
15	needs to be some discussion of this because it
16	lingers and it continues to be something that needs
17	to be evaluated.
18	So the old Appendix D was deleted.
19	However, certain text that we felt was still
20	relevant was moved into sections on identification
21	and definition of response actions and also into a
22	qualitative analysis associated with these
23	procedures that may contain these preemptive
24	actions.
25	CHAIR STETKAR: And here's a good idea
I	I

(202) 234-4433

	104
1	you know, the discussion is very informative. It
2	sort of raises the issue. It says things to be
3	concerned about. It doesn't try to solve the
4	problem. It also explicitly says, look these are
5	probably complicated enough and potentially
6	risk-beneficial or perhaps not risk-beneficial
7	enough that you ought not to do you know an
8	immediate scoping analysis. You really ought to do
9	a detailed analysis for this.
10	Again, that's all you expect from the
11	type of guidance and it solves that issue and it
12	puts it into the appropriate context on the
13	qualitative stuff.
14	I, personally, again, I really like what
15	you did with this stuff.
16	MS. COLLINS: Okay. Since you seem
17	pleased with the way the abandonment in the SISBO
18	were addressed, is it fair to say that, if a similar
19	type of treatment were given to facets of the MSO
20	issue, that that might address concerns in the sense
21	that here are issues one needs to evaluate and we
22	have a limited understanding, we specifically had to
23	do it, however, the user needs to be aware of that,
24	et cetera?
25	CHAIR STETKAR: Erin, you have to

(202) 234-4433

	105
1	realize I'm not going to give you answer to that
2	because first of all
3	MS. COLLINS: Just trying.
4	CHAIR STETKAR: I speak for me, and
5	whatever I say is not
6	MEMBER SHACK: She' be happy to know
7	what you'd do.
8	CHAIR STETKAR: well, but I'm not going
9	to try I think what I said before. Okay, in my
10	personal opinion, something along those lines
11	raising the consciousness of things that the HRA
12	analyst should be thinking about, why it may be a
13	complicated issue, why the information that you
14	received from the circuit analysts may not
15	completely define the problem in the context that
16	you as an HRA analyst think about the problem would
17	go a long way toward helping to solve the problem.
18	Now, a part of Susan's concerns is where
19	do I go from there? Do I tell them increase the HEP
20	by a factor two, five, 10? Do I set it to 1.0? I
21	don't have an answer for that, and even if I did,
22	it's not my position to sort of suggest one. That's
23	something that I think you as a team need to grapple
24	with. You know, you've grappled with it for SISBO
25	and said, ignore the scope and go directly to the
ļ	1

(202) 234-4433

	106
1	detailed analysis.
2	MS. COLLINS: Okay. I just thought it
3	was worth a try.
4	CHAIR STETKAR: It was.
5	MS. COOPER: Thanks, Erin.
6	At this point, then, Stacy was going to
7	end the discussion.
8	CHAIR STETKAR: Can Stacy how long is
9	yours going to be?
10	MS. HENDRICKSON: Two slides. It's two
11	slides, but that's not counting discussion.
12	MS. COLLINS: Coffee break time?
13	MS. HENDRICKSON: This might be a fine
14	time.
15	CHAIR STETKAR: Let's take a break now
16	because you're talking about uncertainties and I'm
17	going to rant a while. So let's take a break and
18	it will be a different ranting, but it's ranting
19	nonetheless.
20	Let's take a break and reconvene at
21	3:25.
22	(Whereupon, the above-entitled matter
23	went off the record at 3:05 p.m. and resumed at 3:26
24	p.m.)
25	CHAIR STETKAR: We're back in session.
	I

(202) 234-4433

	107
1	Let's hear about the next topic.
2	MS. HENDRICKSON: Thank you.
3	MR. BROWN: Dennis?
4	CHAIR STETKAR: You're in here.
5	MR. BROWN: He's not on the line yet.
6	CHAIR STETKAR: Theron, if you can just
7	let John know when he comes on so we know he's there
8	because we're going to try to index him to where we
9	are in the slides once he's on.
10	MR. BROWN: Okay.
11	CHAIR STETKAR: Thank you.
12	MS. HENDRICKSON: The changes that are
13	noted here to Section 5 have already been commented
14	on elsewhere, so I'll just briefly review what those
15	were. One was in reference to SISBO situations, and
16	we have explicitly stated that caveat that, for
17	SISBO situations, that's really outside the scope of
18	the scoping method.
19	Then also, for our discussion on the
20	MSOs for that second sub-bullet there, for the use
21	of the scoping method, really, what's being referred
22	to here would be spurious instruments, spurious
23	instrumentation. That quote that is pulled out
24	there, "Response may be to a single or to multiple
25	spurious indicators but the assumption is still the
	I

(202) 234-4433

1 same," what that is referring to is the use of the spurious implementation tree, which, in the instance 2 of that tree, it assumes that an error has already 3 4 occurred, so, if there's one spurious instrument or if there's multiple spurious instruments, it assumes 5 that an error of commission or an error of omission 6 has already occurred. 7 If there are multiple spurious 8 9 indicators, what the tree is directing is the 10 recovery of that error. So, if there are multiple spurious indicators, recovery is going to be more 11 difficult and the tree would be used the same way. 12 Now changes to Section 6 primarily were 13 14 noted here. The changes to the guidance on 15 dependencies added in some extra references and then also stated that a lower bound should be 16 17 established, although we did remove that the lower bound of 1E-5 is required. 18 19 We removed that requirement but still added some reference and discussion of why a lower 20 bound would be needed and what it's really referring 21 to, the combination of dependent HEPs. 22 Once you're going into doing that combination, you get into an 23 unrealistic HEP level. 24 We can go on to the next slide, slide 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

108

1	19.
2	Looking at uncertainties in timing
3	information and realizing there can be significant
4	variability in timing information, we've added in a
5	couple of different discussions of it. It's gone
6	into Section 4, the qualitative analysis, Section 5
7	with the quantification and then also in the
8	appendix that supports the scoping method to address
9	what would be good practices, how to then establish
10	a range of time that actually establish a range.
11	It's probably a good practice, as opposed to trying
12	to come up with a single-point estimate for timing
13	information.
14	So those are the issues that have been
15	made throughout the document.
16	CHAIR STETKAR: Let me this is
17	another area, and I'm eventually going to go back to
18	Section 4 again, but let's go through the
19	uncertainty stuff first.
20	In Section 4.6.2, I mean, you've
21	excerpted parts of the paragraph but that says,
22	"Given the range of sources for timing estimates and
23	that expert judgment will often be a contributor to
24	the estimates obtained from the various sources,
25	there could be significant uncertainty associated
	I

(202) 234-4433

	110
1	with point estimates obtained for HRA purposes.
2	"When possible, it would be good
3	practice for HRA analysts to try to get a sense of
4	the range of times possible for a particular
5	parameter for example, timing for an operator to
6	want a particular valve locally for consideration
7	during sensitivity studies analyses that might be
8	performed for potentially significant sequences."
9	Again, the only reason I care about
10	uncertainties is I might somehow do a sensitivity
11	analysis later on. There's other guidance, and I
12	want to pull you back to the time line that's been
13	added in 4.6.2 it's pulled up from Section 5.1,
14	with, it's the time line from the EPRI HCR
15	methodology in particularly, with the definitions
16	from EPRI HCR methodology.
17	So it's another case where the Nuclear
18	Regulatory Commission says this is the way to think
19	about the way the world works some of the times, and
20	they weren't so important back in Section 5.1
21	because it was pretty clear to me what I was
22	conceptually getting at. It's more important in
23	Section 4 because it tells me to think about how the
24	world works and how I should think about timing.
25	For example, there's a mystical
I	I

(202) 234-4433

111 1 something called T(subscript 1/2), which is actually 2 the upper rate of cognitive response is a footnote 3 that says, "In every TR-100259, T(subscript 1/2) is 4 described as a medium response time. Depending on 5 the level of detail required for quantification, T(subscript 1/2) can either be a median time or a 6 7 point estimate." 8 Okay, in the context of a median 9 response time, that means half the operators successfully perform the diagnosis within that time 10 and half of them don't. Half of them don't. 11 How long might those other half who don't take to 12 perform that diagnosis? I don't know. All I have 13 14 to do is put a number in there. A point estimate is 15 I don't care about uncertainty; a point fine. 16 estimate is fine. The only thing I care about on 17 uncertainty is for some later sensitivity analysis. Suppose that I actually go and do the 18 19 infinite number of simulator experiments that EPRI would like me to go, and I determine that it's a 20 very skewed distribution such that the 50th 21 percentile is 15 minutes and the 75th percentile is 22

30 minutes and the 95th percentile -- oh, hell, the
guys never do it; you had to wait for the next crew
to come in four hours later, or whenever your

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	112
1	emergency responders might be. That might give you
2	a different indication about the feasibility
3	analysis than just saying that my 50th percentile is
4	15 minutes and my available time window is, you
5	know, 30 minutes.
6	So there's a case where, in fact, doing
7	the uncertainty analysis requiring, if I can use
8	that term, the human reliability analyst to quantify
9	what that range might be can indeed have an effect
10	on the human reliability analysts' judgment
11	regarding the feasibility of an action, regardless
12	of propagating uncertainties you know, turning a
13	crank, pushing a button, and getting an uncertainty
14	distribution at the back end of some qualification
15	model, it can actually affect decisions about the
16	feasibility of an action.
17	MS. HENDRICKSON: Yes.
18	CHAIR STETKAR: And that's one of the
19	reasons why I think, in the April meeting, we were
20	trying to emphasize the importance of identifying,
21	documenting, and quantifying the uncertainties. At
22	least recognize the fact that there might be a
23	25-percent probability given what we understand from
24	either our analysis or the operator interviews, a
25	25-percent probability that I might not meet the
I	

(202) 234-4433

	113
1	feasibility criteria.
2	What do I do with that? Well, do I
3	thought it's feasible? Well, it's not infeasible
4	but it's not absolutely feasible, and the same
5	decision that I might make just using whatever the
6	point estimate or median value might give me.
7	MS. HENDRICKSON: Yes.
8	CHAIR STETKAR: The same is true
9	obviously for the implementation
10	MS. HENDRICKSON: That's a very good
11	point, and I think, in retrospect, as I think you've
12	pointed out, the EPRI approach time line in
13	particular makes it difficult because I think most
14	of us, when we think about feasibility assessment,
15	we're thinking about a demonstration that's then
16	supposed to be representative of a number of people,
17	not necessarily considering that that represents a
18	median value.
19	CHAIR STETKAR: I sort liked the idea of
20	bringing the the time line was brought up into
21	the qualitative stuff, and I like time lines. But I
22	think it's a good idea because it ties back into the
23	scoping analysis where they define the time margin
24	and people pictorially can see the reason.
25	There are, in my opinion again, a few

(202) 234-4433

	114
1	problems with that not the form of that time
2	line, because I think it's a really good form the
3	particular discussion of the individual elements of
4	that time line are derived specifically from the
5	EPRI HCR methodology, which, you know, I just
6	MS. HENDRICKSON: Right.
7	CHAIR STETKAR: I just highlighted
8	that median, and some of the discussions anecdotally
9	going down, as they discuss those times, may
10	prejudice the way, you know, the way my PRA
11	practitioner out in the plant may think about these
12	things.
13	The other thing that I suggest as you're
14	thinking about that time line, it's very, very
15	import that certainly within Section 4 where you're
16	talking the qualitative analysis, that you clearly
17	identify what bits and pieces of that time line are
18	the "time available" and the "time required." That
19	link is never made.
20	I'll tell you, I can read the words. I
21	mean, I think I know what they are, but I can read
22	the words and interpret things a bit differently
23	such that there's a primer called TSW, which is
24	characterized as the system time window or something
25	like that, and it's a big long time. Okay, well, if
ļ	I

(202) 234-4433

115 I would like that to be my time available, I can probably infer that that might be what I would use and there's something smaller that I could infer might be the time required such that, when I go back and do my feasibility analysis, I might be optimistic about assessing what the time margin might be. So I think it's really important, especially in that qualitative area, that you make sure it's really clear because the notions of time required and time available are used in the Here, they're using qualitative analysis section. NUREG 1852 and many other places. And this is the first place where anybody has seen actual bits and pieces of a response time line. And you're not going back to those concepts, just so somebody knows that this, in the context of what this picture means, is what we mean by time available and what we mean by time required.

20 And if you can be sensitive to some of 21 these other issues, again, in my opinion, I think 22 the guidance should be stronger to tell the analysts 23 to go out and explicitly identify document and 24 quantify those uncertainties not in the sense of 25 turning the crank and quantifying uncertainties in

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

	116
1	the PRA model, in the sense of documenting them such
2	that when I look at the uncertainty in the cognitive
3	response time I look at the uncertainty in the
4	implementation time, and I want to assess an
5	uncertainty on the available time window, I at least
6	have a sense of how big is that overlap.
7	MS. HENDRICKSON: Yes.
8	CHAIR STETKAR: You know, if it's clear
9	that I have a lot of margin, I can feel quite
10	confident that indeed it's a feasible action.
11	MS. HENDRICKSON: Yes, right.
12	CHAIR STETKAR: If I have a substantial
13	overlap, I'd feel much less confident about that and
14	I might want to treat it differently.
15	MS. HENDRICKSON: Right.
16	CHAIR STETKAR: I might not necessarily
17	say that it's infeasible but I might say that I need
18	to do a detailed analysis, for example, in that
19	condition rather than just saying it's feasible or
20	infeasible.
21	MS. HENDRICKSON: Yes.
22	CHAIR STETKAR: So
23	MEMBER SHACK: I mean, 1852 has sort of
24	a much more extended discussion
25	CHAIR STETKAR: They do indeed.
I	

117 1 MEMBER SHACK: -- yes, that sort of takes into account that there's a variability in 2 this and you really ought to think about which value 3 4 you want to use. 5 CHAIR STETKAR: I think part of the problem, Bill, is that some of the text in Section 4 6 sort of paraphrases that, you know, in a more 7 8 limited sense, but the time line has now been added, 9 and the description of that time line, you know, 10 reinforces, again, the notion of median response time or point estimate --11 12 (Simultaneous speaking.) MEMBER SHACK: No, I mean, we didn't in 13 14 that particular response time. 15 CHAIR STETKAR: Yes. MEMBER SHACK: I mean, the discussion 16 17 here in 1852 is really much more CHAIR STETKAR: Right, robust. 18 19 MEMBER SHACK: Right. CHAIR STETKAR: 20 Yes. MR. LAI: Mr. Chairman, Dennis is on the 21 line. 22 CHAIR STETKAR: Good. Welcome, Dennis. 23 24 We are on slide 19 right now. MEMBER BLEY: I haven't got up yet, but 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	118
1	I enjoyed your chat.
2	CHAIR STETKAR: Thanks, Dennis.
3	(Laughter.)
4	CHAIR STETKAR: Don't laugh too much.
5	Remember, you're on the record.
6	MEMBER BLEY: Nineteen.
7	CHAIR STETKAR: We're on 19, and unless
8	Stacey has something more to add, I think we're
9	finishing 19.
10	MEMBER BLEY: Okay. I' going to stay on
11	mute. You know, if I have something
12	CHAIR STETKAR: Yes, just chime in. You
13	know, you're a member. Just chime in whenever you
14	want, Dennis.
15	MS. HENDRICKSON: So now we can move on
16	to the overall summary. So I guess, unless we want
17	to go back to talk about something else, we're at
18	the end of the discussion summarizing changes we've
19	made to the report. We have addressed a number of
20	things that were raised by the subcommittee and
21	other issues raised by team members in public
22	comments.
23	We recognize that there's room for
24	improvement. This is, as far as I know, the first
25	document that the NRC certainly is going to publish,
I	I

(202) 234-4433

119 1 and probably other people too, that explicitly 2 addresses fire HRA. We have had a focus that has been 3 4 related to mail NFPA 805, a different scope and 5 focus. We've tried to address the issues that we 6 think are the most important to this particular 7 process, and definitely recognize that there's room 8 for improvement. As things are identified as being 9 important to research, and regulatory applications, 10 so on and so forth. Yes, thanks. 11 CHAIR STETKAR: I think, you know, sort of again, in the sense of the summary 12 of at least my own personal ranting, in some cases, 13 14 there may be benefit, for the purposes of this 15 document, to take the attitude of what specificity 16 is more productive than trying to get too specific, 17 regardless of what pressure you might be feeling from stakeholders or from people you've interacted 18 19 with in training sessions or the pilot applications, who absolutely want to be told precisely how to do 20 it, and if you do it that way, it's absolutely 21 perfectly acceptable. 22 In some of these areas where you've 23 identified and our discussions have identified a 24 need for advancing the state of the art, if you 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	120
1	will, in HRA and, in some cases, prior modeling
2	trying to, in some sense, be less responsive to the
3	demands for very specific guidance might better
4	serve the greater purpose.
5	MS. COLLINS: Well, I think we're very
6	mindful of the fact that there really is a need for
7	this document out thee in the street. Things are
8	ongoing. There continues to be significant interest
9	in this. So we don't want to spend too much more
10	time. We really recognize this needs to get out
11	there now.
12	CHAIR STETKAR: Yes.
13	MS. COLLINS: And so we're going to be
14	trying to blend the best of responding to some of
15	the issues you brought up with the need to get it
16	out there.
17	CHAIR STETKAR: No, I think we're
18	certainly aware of that as a subcommittee, and as a
19	committee also. I think the only concerns are, as
20	Susan mentioned, it's an important document because
21	it's being published in pick a number, 2011, 2012
22	but it's being published now as guidance for
23	human liability analysis under very challenging
24	circumstances. It will be used widely by people
25	certainly during the NFPA 805 transition efforts.
ļ	

(202) 234-4433

	121
1	And in some sense, it's a very, very
2	important snapshot of how we understand, at least
3	within this context but a challenging context, how
4	to do human reliability analysis. And the concern
5	is to not inadvertently limit the context for the
6	focus of that NRC-endorsed methodology in ways that
7	might be suddenly contrary or not necessarily
8	contrary at least deviating from guidance in, for
9	example, in NUREG 1852 or in some of the other work
10	that's being done in the broader research project on
11	HRA in general.
12	You know, I think that's one of the
13	things that certainly I'm trying to be a little bit
14	sensitive to, recognizing the real need to get some
15	guidance out there and also the demands for
16	something that's very specific that the people can
17	pick and read and say, okay, I've off all these
18	boxes, I've followed all of these guides, I came up
19	with a 10^{-6} , and the staff can look at the 10^{-6}
20	and say they've checked off all the boxes, they
21	followed all the guides, and yea, verily, the 10 [^] -6
22	is okay.
23	I used 10 [^] -6 because I knew you took the
24	10 ⁻⁵ out of there.
25	(Laughter.)

(202) 234-4433

	122
1	MS. COLLINS: That's what I said to
2	Stacy during the break. I said, no, no, I had the
3	number in there; it was for you.
4	(Laughter.)
5	CHAIR STETKAR: Okay, any quick comments
6	from any of the members on this part of the
7	presentation?
8	MEMBER BLEY: Dennis, do you have
9	anything?
10	MEMBER BLEY: Nothing to add. That's a
11	turning point for the discussion.
12	MS. COOPER: All right, so we have one
13	set of two or three slides just to wrap things up.
14	CHAIR STETKAR: Yes, no, I said on this
15	part of the discussion. I know you had one more
16	set.
17	MR. LAI: Control L.
18	MS. COOPER: Okay, so we're going to
19	wrap up with just a few slides here talking about
20	where we are and where we hope to be going in the
21	future.
22	Just to remind you, not of all the
23	twists and turns of this project but a few of them,
24	which will hopefully get us to the bottom of this
25	page, which is publication, but just to remind you,

(202) 234-4433

	123
1	we have done peer review, testing, piloting, public
2	comments and feedback from a variety of sources,
3	including this subcommittee, and we've had a number
4	of traps including the draft for public comment.
5	And actually, I believe the draft was out public and
6	given to the ACRS subcommittee in March was used
7	even as stuff for the last bit of training.
8	We have been working hard and long at
9	this. And in mentioning the training, last year was
10	our first year in 2010, and we're back doing another
11	round of training two, four weeks. The next one
12	comes up in the middle of November.
13	Also, as I understand, other members of
14	the Fire Research Branch have been working on
15	documenting the 2010 training into a NUREG/CP that
16	will include the training slides and a CD that
17	follows along with it, with videotapes of the
18	training that was done in 2010.
19	And we are planning for another round of
20	training for 2012, which will be hosted by NRC this
21	time, so it will be somewhere in this area. I
22	notice that John was out in San Diego last month,
23	although he wasn't taking out
24	MR. LAI: It was in the fire modeling
25	session.
I	I

(202) 234-4433

	124
1	MS. COOPER: Yes.
2	So we're hoping to get this published
3	soon. One or two months was the idea that we had in
4	mind when I put this presentation together. As we
5	mentioned at the beginning, we do anticipate that
6	this will be used by those who are transitioning to
7	NFP 805, then possibly other issues.
8	This report, we believe, that addresses
9	fire PRA goes beyond well, it does go beyond the
10	screening level from 6850, and we think there are
11	number of things that could help us identify
12	potential future improvements, especially as
13	additional plants complete analyses and submit their
14	studies to the NRC and so on and so forth.
15	So, anyway, that's it, and there's
16	everybody on the team. Everyone's logo. So that's
17	all that we had planned to present today. Are there
18	any other questions or comments that you want to add
19	at this time?
20	CHAIR STETKAR: I don't have do any
21	of the members have any questions or comments at the
22	moment?
23	Dennis, anything?
24	MEMBER BLEY: Well, just a little
25	reiteration. The area of bounding for possible
ļ	I

(202) 234-4433

1 complexity for uncertainty or anything else, I think back in the appendix on AHTEANA, there's at least a 2 3 few words about that, that are important. And I 4 certainly hope you can get some kind of caveats up 5 in front that talk about that and tie it to the significant events we've had that, if one's doing 6 risk analysis, one has to account for the unlikely 7 8 but data code situations and, you know, at the very 9 least, raise that and get it clearly stated in a 10 place where it will be observed rather than just in an appendix. 11 You know, the other things we've talked 12 about, I think, are all important, but that's one, 13 14 to me, that's overriding. If you pull out events 15 from the real world and you're not clear that the methodology would somehow --16 (Telephonic interference.) 17 CHAIR STETKAR: Dennis, You cut out 18 19 right at the end, so if you could, repeat the last I don't know where you cut out. 20 sentence or two. That would imply I 21 MEMBER BLEY: remembered what I said. 22 CHAIR STETKAR: Yes, well, you could 23 24 make up something different. MEMBER BLEY: I was just saying that I 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

125

	126
1	think it's important we at least get something
2	there, such that two things one, if somebody
3	looking at this and looking at real-world events
4	says how would these somehow be accounted for, and
5	they can't see it, that's troublesome.
6	More troublesome is the fact that
7	analysts won't be looking for that sort of thing.
8	And I don't think just having a couple sentences in
9	Appendix D is enough to cover that.
10	CHAIR STETKAR: Thank you.
11	Let me ask we'll go back around the
12	table here and get any final comments from the
13	members, but first, I don't think we have any public
14	comments from the multitudes in the room here, since
15	it's empty.
16	Do you have any comments? I mean,
17	anybody else in the room want to make any?
18	Mark, you're
19	MR SALLEY: Do you want to go first, or
20	us, or how do you
21	(Simultaneous speaking.)
22	CHAIR STETKAR: Let me ask first
23	there may be somebody on the bridge line, so I just
24	want to make sure that somebody other than
25	Dennis, if anyone's listening in, could you say

(202) 234-4433

	127
1	something to make sure that we know the bridge line
2	is open first.
3	MR. JULIUS: Hi. This is Jeff Julius.
4	CHAIR STETKAR: Hi, Jeff. Thanks.
5	Now, given the fact that we know you're
6	online, is there anybody out there who wants to make
7	any additional comments?
8	MR. JULIUS: I would. This is Jeff
9	Julius. I would like to say that I thought the
10	discussion on the procedure-centric view of the
11	document and the MSO was a good one.
12	I could see where, like, especially, if
13	you're starting at the beginning where you might not
14	pick up on some of the links or if we needed to
15	better provide guidance on some of those aspects,
16	that some of those in the detailed analyses,
17	especially regarding the procedure-centric view of
18	things some of these are the, you know, the
19	interaction between failure modes or
20	performance-shaping factors where the you're
21	right, I mean, we certainly have to ask questions.
22	Like in the EPRI HRA approach appendix,
23	we have questions about what's the likelihood of not
24	following the procedures or getting the procedure
25	wrong. But there are also additional questions
I	1

(202) 234-4433

	128
1	about the man-machine interface and the timing. We
2	got to lengths in terms of, when we're developing
3	these time lines, of understanding and try to make
4	some estimate of the delays and distraction and the,
5	not only getting information and lining up people
6	and the command-and-control aspects.
7	I know we need to learn more and put
8	more in, maybe explicitly, but also calling out.
9	Some of those factors are there in the methods.
10	They're just not very well called out.
11	CHAIR STETKAR: Yes, and I think
12	Jeff, this is John Stetkar I tend to agree with
13	you. You'll notice, in my ranting, I didn't really
14	say much about the detailed fire analyses back in
15	the appendices because the detailed analyses, if you
16	ever get them, tend to have all of those thoughts in
17	them.
18	The bigger concern is that the people
19	doing the screening analyses, or more in particular,
20	setting up scoping analyses, are equally sensitive
21	to those issues so that they don't inadvertently not
22	think about something that they ought to, or
23	inadvertently make optimistic decisions about
24	something without even the realization that they
25	might be optimistic.
I	I

(202) 234-4433

	129
1	MR. JULIUS: Right.
2	CHAIR STETKAR: And I think that kind of
3	echoes your sentiment that perhaps highlighting a
4	bit more of that thought process up front without
5	repeating everything that's back in the detailed
6	analyses of might be enough to sort of prompt that
7	practitioner in the plant to know that there's
8	something else that they need to think about. So
9	appreciate that.
10	Any other comments from out there?
11	MR. JULIUS: Thanks for the opportunity
12	to discuss this with you again.
13	CHAIR STETKAR: Thanks, Jeff.
14	Anybody else?
15	JOHN FORRESTER: John Forrester's on the
16	line, and I don't think I have any other comments.
17	I think the major issues are in a little bit clearer
18	focus this time, so I appreciate that.
19	CHAIR STETKAR: Thanks, John.
20	Hearing nothing else, let me give the
21	staff if Mark, you, and
22	MR. SALLEY: Yes, but I also have a
23	couple comments I think Rich also too.
24	CHAIR STETKAR: Good.
25	MR. SALLEY: I guess, two things I
I	I

(202) 234-4433

130 1 really want to just have clear, John, is, first, 2 where specifically would you think, really, we need 3 to tweak up here to get the guality of this document 4 to where it's ready for primetime? 5 CHAIR STETKAR: I have to be careful because I am an individual, but the two areas -- I 6 7 think we had discussions about the two areas -- one 8 is the general notion of how should an HRA analyst, 9 that practitioner, approach the issue of multiple 10 spurious operations. And I'll extend that out; Dennis used the term 'complex scenarios' where the 11 operators may be distracted or may have conflicting 12 priorities, for example, depending on what else is 13 14 happening in the plant, that may not necessarily be explicitly identified by the circuit analyses that 15 were performed specifically for the functions that 16 were identified in NPRA and other safety functions. 17 So that's one area. 18 19 The other area is this treatment of uncertainties in those time lines because I think 20 that is also an important issue, again, in the 21 purest sense, quantification of the overall 22

24 importantly, as part of the tools that an HRA 25 analyst ought to have available to make those

uncertainties in the fire analysis, but more

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

23

determinations of feasibility, for example, because it may affect decisions, depending on what those overlaps in the uncertainty distributions look like if there are any.

5 And if there aren't any, again, that's 6 confidence builder. But if you've not thought about 7 those and you've only taken something that's either 8 characterized as a median value or some other point 9 estimate number, I think you're very vulnerable to 10 at least being challenged if not making, you know, 11 inappropriate decisions.

So there's the two areas, from my perspective, I think that given the document as it is, might need some thought. And again, it's up to the team in terms of how you deal with them.

I'm an individual. I'm not the ACRS.
And occasionally, you know, pragmatically, people
make decisions.

MR. SALLEY: Thank you. That helps meunderstand. I appreciate that.

The second thing -- we had planned, you know we still would like a letter from the ACRS to go forward and publish this. That's kind of a last step we have in this document. When do you see the path forward for us on this now, given that you want

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	132
1	me to go back and do some work on this.
2	CHAIR STETKAR: I think that's something
3	that you folks need to go back and kind of caucus
4	and decide what needs to be done.
5	I will tell you that whatever document
6	is sent to the full committee for the meeting ought
7	to be a final, polished document. But whatever
8	changes you may decided to make or not make to the
9	current document to address, you know, the technical
10	issues that we've sort of discussed today, that's up
11	to you, quite honestly.
12	The document that we've received for the
13	subcommittee meeting obviously needs technical
14	editing and things like that to put it in polished
15	form. So you need to go back and think among
16	yourselves about what changes need to be made to
17	produce a document that the full committee would
18	then review.
19	The full committee needs that document
20	30 days in advance of a full committee meeting, so
21	we need to expeditiously schedule a full committee
22	meeting. But, you know, I can't say whether it
23	would be a November full committee meeting or a
24	December full committee meeting. The problem is, we
25	don't have one in January. So, if we don't hit a
I	I

(202) 234-4433

	133
1	full committee meeting by December, then we're
2	looking at February as the first full committee
3	meeting opportunity.
4	And I'll also tell you that our agendas
5	for November and December are right now pretty full.
6	So dovetailing you in, in that time frame, may
7	require a bit of manipulation on our part. There's
8	a bit more uncertainty, quite honestly, in December.
9	November could be a challenge.
10	MR. SALLEY: You don't see a need for
11	another subcommittee meeting?
12	CHAIR STETKAR: I don't, quite honestly,
13	Mark. I think that as a subcommittee, we've
14	discussed these issues. I think we mutually
15	understand what the issues are. I think whatever
16	decisions you make about addressing those issues,
17	certainly in a full committee meeting because the
18	full committee hasn't been briefed on this document
19	at all. You need to be cognizant of that fact. So
20	the full committee needs to both understand the
21	basic concepts of the document; the screening,
22	scoping, and the detailed analysis, the qualitative
23	guidance, and the quantitative guidance.
24	I think the for the full committee's
25	benefit, however you decide to resolve kind of these
I	I

(202) 234-4433

	134
1	two big-picture issues that you've discussed today,
2	the full committee ought to have the benefit of that
3	for people who haven't had the luxury of following
4	all of the detailed ranting.
5	But I don't see a need for another
6	subcommittee meeting. I think it would not be
7	productive at all. So I think the path forward is
8	make whatever decisions you need to make on the
9	document as it is today, finish it up based on those
10	decisions, get a polished, edited document in place,
11	and get it to us within the 30-day time period.
12	Keep in contact with John Lai in the
13	near future so that we can start to anticipate when
14	that full committee meeting may be.
15	And I am planning to be as responsive as
16	we can. I recognize the time pressures. We'd
17	really like to accommodate you according to the
18	schedule, as efficiently as possible. So if we can
19	get it in, in November, that would be great; if we
20	can't get it in, in November, if we can get it in
21	December, that's great. Just recognize that if we
22	don't get it by December, it's going to be February.
23	You know, we can fit you in, in
24	February.
25	MR. CORRIEA: We prefer the sooner the
	I

(202) 234-4433

	135
1	better.
2	CHAIR STETKAR: Sure.
3	MR. CORRIEA: I plan to make this a high
4	priority for the staff.
5	CHAIR STETKAR: Yes.
6	MR. CORRIEA: We'll go back and consider
7	everything that we've heard today and before. We
8	very much appreciate that, and out goal is to get
9	that to you in November.
10	CHAIR STETKAR: That could be tight, but
11	as I said, communicate with John because the full
12	committee meeting schedule for November looks pretty
13	tight already. I don't know what options we have.
14	We have some flexibility of moving particular topics
15	around them meetings.
16	December, there's always a little bit
17	more uncertainty as you go out 60 days, 90 days in
18	the future. But keep that in mind.
19	Thank you, and as usual, I'll go around
20	the table and just see if there are any final
21	thoughts that any of the members have, and I'll
22	start with Joy.
23	MEMBER REMPE: Well, I'm an uninformed
24	member in the area of human reliability, and yes,
25	there are some issues that need to be address, but I
	I

(202) 234-4433

	136
1	did want to say that I thought the document had a
2	lot of good attributes and we informative. And
3	hopefully, the main issues will get addressed.
4	CHAIR STETKAR: Bill?
5	MEMBER SHACK: No comments.
6	CHAIR STETKAR: Dick?
7	MEMBER SKILLMAN: No comments.
8	CHAIR STETKAR: Said?
9	MEMBER ABDEL-KHALIK: No comments.
10	CHAIR STETKAR: And I certainly don't
11	have anything more to say that
12	MEMBER BLEY: Dennis is still here.
13	CHAIR STETKAR: I'm sorry, Dennis. I
14	thought I got your last shot in. Dennis.
15	MEMBER BLEY: No, I didn't see that as a
16	last sot.
17	(Laughter.)
18	CHAIR STETKAR: Oh, I'm sorry. Then
19	Dennis?
20	(Telephonic interference.)
21	CHAIR STETKAR: Dennis, start over
22	again, and you were breaking up.
23	MEMBER BLEY: Is this any better?
24	CHAIR STETKAR: Not clear. Try to keep
25	talking and we'll see.
	1

	137
1	MEMBER BLEY: Let me I'm sorry. Let
2	me switch over to
3	CHAIR STETKAR: You're real good there
4	if you can continue that.
5	MEMBER BLEY: Oh, okay. Then I will sit
6	right here.
7	Jeff Julius raised a few things that
8	kind of triggered some thoughts from me. And I
9	agree, there are a lot of good things in the
10	appendices and detailed analyses.
11	I did something that I would recommend
12	to the staff to try. I just searched the document
13	for the word "appendix". As you work through, you
14	do see each appendix called out, but generally, in a
15	one-liner, there are some details in Appendix B or
16	in Appendix G.
17	I think if you had a few caveats about
18	these important issues and had a more thorough
19	reference to the applicable appendices and said what
20	they would find there and why they need to consult
21	it, it could go a long way to help on some of the
22	issues, especially the one dealing with realistic
23	and complex scenario kind of things, but probably
24	with everything.
25	The appendices are not linked strongly
I	

(202) 234-4433

	138
1	to the main document, and I think that could help
2	you a lot.
3	CHAIR STETKAR: In particular, Dennis,
4	you're talking about Appendices B and C that have
5	the detailed methods; right?
6	MEMBER BLEY: Oh, especially those, but
7	not definitions of terms, but even back to the
8	ATHEANA one and but mainly the two you mentioned,
9	yes.
10	If I pick this up to do an analysis and
11	read that this is how to do it, there's nothing that
12	really pushes me to consider the information in the
13	appendices, and I think that's a shame. And I think
14	people who aren't pushed, some of them won't do it.
15	And that's it.
16	CHAIR STETKAR: Good. Thank you. And
17	I'm sorry for ignoring you if it makes you feel any
18	better.
19	MEMBER BLEY: I'm sure you are.
20	(Laughter.)
21	CHAIR STETKAR: Yes, I am.
22	I don't have anything more to say.
23	Again, I think you. I think we had a really good
24	discussion this time. I really appreciate all the
25	stuff that you've done to get the document.
I	1

(202) 234-4433

	139
1	Honestly, I think it's a really useful
2	document, and I think it will be used, and I think
3	that with what might sound in this environment like
4	a lot of work, looking at the responses may not be
5	that much effort when you stand back and think about
6	it. I think it can be a pretty good document.
7	So I really appreciate the effort you've
8	put into the discussion, and with that, we are
9	adjourned.
10	(Whereupon, the above-entitled matter
11	concluded at 4:11 p.m.)
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
ļ	I






Sandia National Laboratories





STITUTE

ELECTRIC POWER



EPRI/NRC-RES FIRE HRA GUIDELINES

Introduction and Summary

Susan E. Cooper (NRC/RES)

ACRS PRA Subcommittee Meeting September 21, 2011 Rockville, MD

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

Presentation Outline

- Background
- Project history
- Summary of guidelines content
- Agenda for today



Background on the Issue of Fire HRA

- Almost 50% of USA plants transitioning to NFPA-805
- NUREG/CR-6850 [EPRI 1011989] addresses:
 - Identifying human failure events (HFEs)
 - Assigning conservative screening human error probabilities (HEPs)
 - Fire-relevant performance shaping factor (PSF) information
- NUREG/CR-6850 [EPRI 1011989] does not:
 - Describe a methodology for developing best-estimate HEPs (given fire related effects)
 - Address the HRA requirements of:
 - ASME/ANS RA-Sa-2009, "Addenda to ASME/ANS RA-S-2008, Standard for Level 1 / Large Early Release Frequency Probabilistic Risk Assessment for Nuclear Power Plant Applications," Chapter 4 for fires
- Consequently, there was a need for fire-specific methods & guidance for best-estimate HRA quantification in fire PRA

EPRI/NRC Fire HRA Guidelines *High Level Objectives*

- NRR User Need 2008-003, Rev. 1, Task 13, RES asked to "...expand existing HRA methods, typically used in regulatory applications, to incorporate the effect of fires in full-power PRA models.
- Through joint NRC and industry efforts, address the need for HRA methods & guidance, especially for best-estimate quantification, for use in fire PRAs
 - Expand or modify existing HRA methods
 - Develop guidance for implementing the methodology
- Develop a joint EPRI/NRC report under MOU (similar to NUREG/CR-6850 [EPRI 1011989])
- Consider ASME/ANS PRA Standard requirements and other relevant guidance

Move the state-of-the-art for fire HRA a step forward



Fire HRA Project History

- Project initiated: March 5, 2007
- First integrated draft: May 2008
- Peer review: June 2008
- Testing at 2 plants: Summer/Fall 2008
- Revised draft: April 2009
- Quick review by NRR & NRO: April 2009
- ACRS sub-committee information presentation: June 2009
- Piloting by PWR Owner's Group: Summer 2009
- Issued for public comment: December 2009
- Public comment period ended: March 2010
- Resolution of key public comments: June 2010



Fire HRA Project History (continued)

- ACRS sub- & full-committee presentations: Fall 2010
- 1st Joint EPRI/NRC-RES Fire HRA Training Course
 - September & October 2010
- Final public comment resolution: Summer 2011
- 2nd Joint EPRI/NRC-RES Fire HRA Training Course
 - August & November 2011
- Presentation to ACRS PRA Sub-Committee: April 2011
- Presentation to ACRS PRA Sub-Committee & Full Committee: September & October 2011
- Publication of final report: Fall 2011



Fire HRA Guideline Summary

- Standard HRA process used
 - Fire HRA process is based on existing processes and guidance:
 - ASME/ANS PRA Standard
 - NUREG-1792 ("Good Practices")
 - NUREG-1852 (Fire Manual Actions)
 - SHARP1
 - ATHEANA
 - However, additional analyst tasks & emphasis in some existing tasks are needed to address specific needs of fire HRA/PRA, such as
 - information collection and analysis
 - feasibility
 - ability to support Fire PRA successive screening



Fire HRA Guideline Summary

Fire HRA process steps:

- 1. Identification & definition of human failure events:
 - Substantial guidance provided, including "go/no go" feasibility test

2. Qualitative analysis

- Iterative process step that continues throughout quantification steps
- Also addresses evaluation of HFE feasibility under fire conditions
- As fire PRA develops, fire HRA must consider additional fire scenario-specific details that become available



Fire HRA Guideline Summary

3. Quantification Methods – three levels

- Screening Quantification
- Scoping Fire HRA method
 - Decision tree format
 - Guidance developed to provide less conservative values than screening without detailed analysis, & to aid reproducibility & reviewability

Detailed Fire HRA

- Uses existing methods with guidance for application to fire
- Performance shaping factors modified for the fire context:
 - EPRI Cause-Based Decision Tree & HCR/ORE; & THERP
 - ATHEANA

4. Dependency, Recovery, and Uncertainty Analysis

 As for internal events HRA/PRA, with some modifications for fire event-specific issues

Focus for today....

- Discuss updates to Fire HRA Guidelines, i.e.,
 - Modifications made since the March 2011 draft provided to ACRS Sub-Committee for April 20, 2011meeting
- Includes:
 - High-level summary and categorization of updates
 - Principally based on comments and questions from ACRS Sub-Committee
 - Summary of report revisions (organized by update categories)



Agenda Overview

1. Introduction and Summary

2. Updates to the EPRI/NRC Fire HRA Guidelines

- High-level categories of updates
- Summary of changes to guidelines
- 3. Project Status and Path Forward













ACRS PRA Sub-Committee September 21, 2011 EPRI-NRC Fire HRA Guidelines

Slide 12

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)












ELECTRIC POWER



Updates to EPRI/NRC-RES Fire HRA Guidelines

Susan Cooper (USNRC), Erin Collins (SAIC), and Stacey Hendrickson (SNL)

ACRS Meeting – PRA Subcommittee September 21, 2011 Rockville, MD

Agenda Overview

1. Introduction

2. Updates to the EPRI/NRC Fire HRA Guidelines:

- Categories of updates
- Summary of changes to guidelines
- 3. Project Status and Path Forward



Updates to the EPRI/NRC Fire HRA Guidelines

- Starting point for report modifications was the March 2011 draft provided to ACRS Sub-Committee for April 20, 2011meeting
- Revisions to the report were agreed to:
 - Project team members provided individual reviews
 - If necessary, team discussions were held, leading to consensus
- Revisions were motivated by:
 - Comments and questions from ACRS Sub-Committee (e.g., April 20, 2011 meeting)
 - A few outstanding issues or concerns (e.g., improvements considered useful by project team, further support in responding to a public comment)



Updates to the EPRI/NRC Fire HRA Guidelines (continued)

- To facilitate report revision, categories of needed changes were developed:
 - By report section
 - By issue or topic
- This presentation summarizes the changes by both categorization schemes but is organized to minimize repetitions of overlapping issues (to extent possible)



Categories of updates

Report updates by section:

- 1. Section 1 Introduction edits
- 2. Section 2 Identification and Definition edits
- 3. Section 4 Qualitative Analysis edits
- 4. Section 5 Quantification edits
- 5. Section 6 Recovery, Dependency and Uncertainty edits
- 6. Edits to appendices



Categories of updates (continued)

Report updates by issue:

- 7. Clarification of treatment of spurious cable failures and multiple spurious operations (MSOs)
- 8. Add discussion about exploring uncertainties in timing information
- 9. Add more discussion on main control room (MCR) abandonment
- 10. Moved old appendix on self-induced station blackout (SISBO); added to Sections 3 & 4



Presentations summarizing changes to guidelines

- Sections 1 & 2 (Susan Cooper)
- Section 4, treatment of MSOs, MCR abandonment, & SISBO (Erin Collins)
- Sections 5 & 6, associated appendices, uncertainties in timing information (Stacey Hendrickson)



Summary of changes to Section 1

- Edited out: Several references to ACRS reviews
- New text added to paragraph on future improvements:
 - That might be identified via following:
 - Feedback from future NFPA-805 submittals
 - Results of RES' SRM project on HRA model differences
 - Topic areas that might benefit from improvement:
 - Guidance on how to address MCR abandonment in fire HRA/PRA
 - Broadened scope in identifying fire-induced cable failures (leading to spurious indications not currently in the scope of fire PRA but potentially important to HRA)*

* Related to MSO treatment discussed in Sections 2 & 4

Summary of changes to Section 2

Added*:

- New Section 2.5 Fire-Induced Spurious Cable Failure(s) and Electrical Fault(s)
 - Summarizes the various ways spurious cable failures are typically modeled in fire PRA task and their treatment in fire HRA
- Table 2-3 added (supports Section 2.5 discussion)
 - Describes various ways spurious cable failure(s) can impact the plant
 - How the plant impact is typically addressed in fire PRA
 - How the plant impact can be treated in fire HRA (essentially a categorization, e.g., undesired response to spurious failure, potential need for a recovery action, nuisance alarms & indications)
 - Summarizes the treatment of the different categories of spurious failures in NUREG-1921
- * In response to ACRS questions and concerns about treatment of MSOs (addressed in more detail in Section 4)

ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines

Slide 9

Presentation summarizing changes to Section 4....

- Changes to Section 4
- Clarify treatment of multiple spurious operations (MSOs)
- Add more discussion on main control room (MCR) abandonment MCR abandonment
- Deleted old appendix on self-induced station blackout (SISBO); moved majority of text to Sections 3 & 4

 Changes also made to address uncertainties in developing time information – discussed with Sections 5 & 6

Summary of changes to Section 4 - General

- Make Section 4 "chapter zero" No changes to report structure (based on team vote)
- ACRS comment "Might be worth emphasizing that we're copying NUREG/CR-6850 re special cases where little or no credit is given":
 - Response Verified call out to NUREG/CR-6850 in Section 4.3.3
- ACRS comment "Suggest adding a comment about impact of security issues on accessibility (e.g., availability of keys)." Text changed as follows.
 - Section 4.3.4 Feasibility Assessment Factors
 - 4.3.4.5 Accessible Location Bullet on locked doors & the need for keys
 - 4.3.4.6 Equipment/ Tools Available/ and Accessible Added parenthetical phrase regarding keys for locked doors
- ACRS comment "Do we address possibility of being in multiple procedures?
 - Verified Section 4.6.3 & appendices for detailed HRA address this comment.



Summary of changes to regarding MSO treatment

- Add references to Regulatory Guide 1.205, NEI 04-02, & NEI-00-01
 - NEI 04-02 has been added to list of references in Sections 2 & 4
 - Both NEI documents are referenced in Chapter 3, Section 3.4 under "Cue Parameters"
- Clarify treatment of multiple spurious operations
 - Already discussed adding new Section 2.5 & Table 2-3
 - Also added text to existing paragraph about potential benefit to HRA if scope in identifying fire-induced cable failures (leading to spurious indications not currently in the scope of fire PRA) were broadened
 - Additional changes:
 - Renamed Section 3.4 to "Identification and Definition of HFEs Corresponding to Undesired Operator Responses to Spurious Instruments and Alarms" (previously "Examples of Operator Actions that Result in Undesired Response")
 - Changes to Section 4 (next slide)

Summary of changes to Section 4 regarding MSO treatment

- A variety of text changes have been made in Section 4, such as:
 - Section 4.3.4.3, Primary Cues Available/Sufficient, two paragraphs added, including mention of how some plants include tables in their fire procedures that identify the instruments most likely to have been impacted by fire.
 - Under development of HFE Narrative, Section 4.5.5 Availability of Cues and Other Indications for Detection and Evaluation Errors, added text on how other fire PRA tasks provide fire impacts on instrumentation that can be a potential distraction to the operator.

Summary of changes to Section 4 regarding MSO treatment (continued)

- A variety of text changes have been made in Section 4: (continued)
 - Under Performance Shaping Factors, Section 4.6.1, Cues and Indications, added discussion such as how:
 - the safe shutdown list of protected equipment will need to be compared to instruments credited in the fire HRA
 - any instruments not included in the safe shutdown list will need to be added to the component selection list for cable tracing



Changes to Section 4 – MCR Abandonment

- New Section 4.8, Qualitative Analysis associated with MCR Abandonment Actions, has been added:
 - Briefly provides guidance specific to MCR abandonment that was scattered across other PSFs
 - Briefly discusses the decision to leave the control room, including:
 - Habitability
 - Ability to control the plant
 - This is an area that would benefit from future research



Treatment of "old Appendix D" on SISBO

- Deleted Appendix D
- Merged relevant text from old Appendix D into:
 - Section 3.3.2, Fire Response Action Identification and Definition:
 - New heading titled "Unique issues for the identification and definition of SISBO HFEs"
 - Section 4.9 (new section), "Qualitative Analysis Associated with SISBO Procedures"



Summary of changes to Sections 5 & 6

- Changes to Section 5:
 - ACRS Comment "There should be a caveat that scoping shouldn't be used to address SISBO situations".
 - Section 5.2, list of minimum criteria, last paragraph under #1 Procedures
 - Scoping approach clarification on MSO, under Section 5.2.9
 Guidance for ...EOC or EOO due to Spurious Instrumentation:
 - "Response may be to a single or to multiple spurious indicators, but the assumption is still the same."
- Changes to Section 6:
 - Added guidance on dependencies from existing sources
 - Removed statement that lower bound of 1E-5 is required. Section 6.2 now refers to discussions from both NUREG-1792 & EPRI TR-1021081 about the need to establish a lower bound & its associated difficulties.

Slide 18

Added text discussing exploration of uncertainties in timing information

- Depending on location (& associated appropriateness),1-2 sentences have been added in several places to address this issue, e.g.
 - Would be a good practice for HRA analysts to get a good sense of the <u>range of times possible for a particular parameter</u>
- Additions have been made to:
 - Section 4, under Performance Shaping Factors, 4.6.2 Timing,
 - Section 5, under Scoping Fire HRA Quantification, 5.2.2
 Calculation of Time Margin
 - Appendix F, Justification for Scoping Approach, F.1 Time Margin



Overall Summary

- Revisions to various sections of report have been made to specifically address:
 - Comments and questions raised by ACRS PRA Sub-Committee
 - A few outstanding issues raised by team members or public comments
- While there is room for additional advances in treatment of fire HRA, the joint team believes that the current report is useful & represents a substantial step forward in the state-of-the-art in fire HRA




Backup Slides

ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines



A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)



ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines

Slide 22

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

Summary of changes to Section 4 - General

- Make Section 4 "chapter zero" No changes to report structure (based on team vote)
- ACRS comment "Might be worth emphasizing that we're copying NUREG/CR-6850 re special cases where little or no credit is given":
 - Response Verified call out to NUREG/CR-6850 in Section 4.3.3
- ACRS comment "Suggest adding a comment about impact of security issues on accessibility (e.g., availability of keys)": Text changed as follows.
 - Section 4.3.4 Feasibility Assessment Factors
 - 4.3.4.5 Accessible Location Bullet on locked doors & the need for keys
 - 4.3.4.6 Equipment/ Tools Available/ and Accessible Added parenthetical phrase regarding keys for locked doors:

"(especially in light of tighter key controls that some plants may have implemented in response to security needs)"

- ACRS comment "Do we address possibility of being in multiple procedures?
 - Verified Section 4.6.3 & appendices for detailed HRA address this comment.
 "Implementing unfamiliar or multiple procedures simultaneously could lead to confusion."

Summary of changes to Section 4 regarding MSO treatment

- A variety of text changes have been made in Section 4, such as:
 - Section 4.3.4.3, Primary Cues Available/Sufficient, two paragraphs added, including:
 - "Many plants include tables in their fire procedures that identify the instruments most likely to have been impacted by fire and provide alternate instruments for the operators' use in parameter verification and scenario diagnosis. These tables provide valuable information to the fire HRA for instrument vulnerability evaluations."
 - Under development of HFE Narrative, Section 4.5.5 Availability of Cues and Other Indications for Detection and Evaluation Errors, e.g.,
 - "In addition to ensuring a minimal set of cues is available to conduct the operator action, the fire PRA can also provide information regarding the additional fire impacts on instrumentation that can be a potential distraction to the operator. This additional information can be used during the quantification of HEPs and/or identified as a potential source of modeling error."

Slide 24

Summary of changes to Section 4 regarding MSO treatment (continued)

- A variety of text changes have been made in Section 4: (continued)
 - Under Performance Shaping Factors, Section 4.6.1, Cues and Indications, e.g.,
 - "The safe shutdown list of protected equipment will need to be compared to instruments credited in the fire HRA and any instruments not included in the safe shutdown list will need to be added to the component selection list for cable tracing. For example, an Appendix R safe shutdown analysis typically does not consider mitigations of a fire causing a LOCA and may not require RWST level indication as part of its analysis. For fire PRA, RWST level indication would be needed to credit operator actions for switch over to recirculation."

Added text discussing exploration of uncertainties in timing information

- Depending on location (& associated appropriateness),1-2 sentences have been added in several places to address this issue:
 - Section 4, under Performance Shaping Factors, 4.6.2 Timing, i.e.,
 - "Given the range of sources for timing estimates and that expert judgment will often be a contributor to the estimates obtained from the various sources, there could be significant uncertainty associated with point estimates obtained for HRA purposes. When possible, it would be good practice for HRA analysts should try to get a sense of the range of times possible for a particular parameter (e.g., time for an operator to align a particular valve locally) for consideration during sensitivity studies/analyses that might be performed for potentially significant events."
 - Section 5, under Scoping Fire HRA Quantification, 5.2.2 Calculation of Time Margin
 - Appendix F, Justification for Scoping Approach, F.1 Time Margin











ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines

Slide 27

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)






Sandia National Laboratories





ISTITUTE

ELECTRIC POWER



EPRI/NRC-RES FIRE HRA GUIDELINES

Project Status and Path Forward

Susan E. Cooper (NRC/RES)

ACRS PRA Sub-Committee Meeting September 21, 2011 Rockville, MD

Fire HRA Project Status

- Review, testing, and comments:
 - Peer review: June 2008
 - Testing at 2 plants: Summer/Fall 2008
 - Review by NRR & NRO
 - Piloting by PWR Owner's Group: Summer 2009
 - Public comments on December 2009 draft report (March 2010)
 - Feedback on trial use by authors
 - Feedback from ACRS: April 2011
- Various revisions to report:
 - First integrated draft: May 2008
 - Revised draft: April 2009 (based on peer review & testing)
 - Issued for public comment: December 2009
 - March 2011 draft for ACRS briefing
- Publication of final report: Fall 2011

ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines NUREG

Fire HRA Project Status (continued)

- Joint EPRI/NRC-RES Fire PRA Training
 - ½ day, "for information only" presentation on fire HRA (June/October 2009)
 - Developed a new "track" for fire HRA in EPRI/NRC Fire PRA Course (Summer 2010)
 - Full-track, Fire HRA Training presented (September and October 2010)
 - Full-track, Fire HRA Training repeated in 2011 (August and November 2011)
 - NUREG/CP documenting 2010 training (with presentation slides and follow-along CD of videotapes) is in progress
 - Full-track, Fire HRA Training for 2012 is being planned

Fire HRA Guidelines Path Forward

- We now expect the final Fire HRA Guidelines report to be issued in 1-2 months (i.e., Fall 2011).
- It is anticipated that this guidance will be used by the industry as part of transition to NFPA-805 and possibly in response to other regulatory issues.
- This is the first report addressing fire-related HRA for fire PRA that goes beyond the screening level.
- As the methodology is applied at a wide variety of plants, the document may benefit from future improvements to better support industry-wide issues being addressed by fire PRA.













ACRS PRA Sub-Committee, September 21, 2011 EPRI-NRC Fire HRA Guidelines NUREG

Slide 5

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)