



# BWROG Pressure-Temperature Curve Licensing Topical Report Revision

Daniel Sommerville (SI)  
Lucas Martins (GE-H)

NRC Pre-submittal Meeting  
September 29, 2011  
Washington DC



September 29, 2011

# Meeting Agenda

---

- Introductions
- Meeting Objectives
- P-T Curve Methods LTR (SIR-05-044, Rev. 1)
  - Purpose of LTR
  - Summary of Changes
  - Basis information
- Water Level Instrument Nozzle Evaluation LTR (0900876-401, Rev. 0)
  - Purpose of LTR
  - Basis information
  - Overview of Methodology
  - Summary of Results
- Open Dialogue

# Meeting Objectives

---

The BWROG objectives for this meeting are:

- Introduce purpose of each Licensing Topical Report.
- Discuss general methodology and results.
- Provide an early opportunity to identify NRC questions on the LTRs to improve quality of BWROG submittal to NRC and efficiency of NRC review.



# P-T Curve Methods LTR (SIR-05-044, Rev. 1)

## LTR Purpose


- Provide BWROG participants with a NRC approved methodology for preparing BWR P-T limit curves and test temperatures with solutions suitable for water level instrument (WLI) nozzles included in the LTR.
- Eliminate need for plant specific instrument nozzle submittal requiring review.

## Summary of Changes

- Include water level instrument nozzle LEFM solutions consistent with those used in plant specific instrument nozzle evaluations previously submitted to the NRC and subsequently approved.

QUARTER-CIRCULAR CRACK IN INFINITE QUARTER-SPACE

$$K_I = \sqrt{\pi a} \left[ 0.723 A_0 + 0.551 A_1 \left( \frac{2a}{\pi} \right) + 0.462 A_2 \left( \frac{a^2}{2} \right) + 0.408 A_3 \left( \frac{4a^3}{3\pi} \right) \right]$$





# P-T Curve Methods LTR (SIR-05-044, Rev. 1)

---

## Basis Information

- Adequacy of the nozzle solutions are thoroughly documented in the references identified below:
  - PVP2011-57015
  - PVP2011-57742
  - PVP2011-57014
  - ORNL/TM-2010/246
  - ASME Paper 78-PVP-91
  - EPRI Report NP-339
- NRC has previously seen these solutions applied for plant specific submittals and has approved use for treatment of the WLI nozzles for these plant specific cases.

# Discussion

---



# WLI Nozzle Evaluation (0900876-401, Rev. 0)

---

## LTR Purpose

- Provide BWROG participants with a NRC approved, simplified, methodology for obtaining a conservative  $K_{IT}$  and  $K_{IP}$  for the WLI Nozzle
- Eliminate the need for a plant specific instrument nozzle FEA thereby reducing cost to utility.



## Basis Information

- 3 Plant specific calculations:
  - 251" RPV Evaluation, 0900876-301, Rev. 0.
  - 218" RPV Evaluation, 0900876-302, Rev. 0.
  - 238" RPV Evaluation, 0900876-303, Rev. 0.
- 1 Parametric Evaluation:
  - WLI Nozzle fracture mechanics solution, 0900876-304, Rev. 0.
- Adequacy of LEFM solution given by basis documents identified for SIR-05-044, Rev. 1.

# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Methodology

- Performed 3 plant specific calculations for RPV diameters, nozzle materials and sizes which are considered to span the population of plants with partial penetration style WLI Nozzles.
  - 3-D FEM of RPV, nozzle insert, attachment weld, vessel cladding.
  - Considered both internal pressure and cool-down transient.
  - Linear elastic FEA, ANSYS.







# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Methodology



- Performed 1 parametric study in which 38 FEMs built to separately evaluate (using same modeling approach as plant specific evaluations).
  - Geometry considered:
    - 4 RPV diameters (205", 218", 238", 251")
    - 2 WLI diameters (2", 3")
    - 3 WLI insert thicknesses (0.23-0.28", 0.53-0.54", 0.70")
    - 3 WLI materials (Alloy 600, 304 SS, CS)
    - 2 J-groove weld configurations (Short, Long)
  - Load Cases considered:
    - Internal pressure
    - 100 °F/hr thermal ramp
    - Thermal shock



# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Methodology, cont.

- Mesh Density studies performed to ensure mesh independent results obtained from FEA
- Benchmark of FE LEFM mesh and fracture parameter calculation algorithms against Raju and Newman results for corner cracked hole
  - Common method of meshing crack front using quadratic elements with mid-side node on crack face moved to  $\frac{1}{4}$  point location






# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Methodology, cont.

- Boundary Integral Equation / Influence Function (BIE/IF) LEFM solution selected from those being considered by ASME Code for inclusion in ASME XI, Appendix G:

QUARTER-CIRCULAR CRACK IN INFINITE QUARTER-SPACE

$$K_I = \sqrt{\pi a} \left[ 0.723 A_0 + 0.551 A_1 \left( \frac{2a}{\pi} \right) + 0.462 A_2 \left( \frac{a^2}{2} \right) + 0.408 A_3 \left( \frac{4a^3}{3\pi} \right) \right]$$





- Adequacy of BIE/IF solution assessed by comparing:
  - LEFM results for  $K_{IT}$  and  $K_{IP}$  obtained from a polynomial curve fit to a nozzle corner path stress distribution obtained from a linear elastic FEA for each load case.
  - Root Mean Square (RMS)  $K_I$  obtained from a FE LEFM evaluation of equivalent geometry and load case.
- General WLI nozzle  $K_{IP}$  and  $K_{IT}$  solutions obtained from a least squares linear curve fit to parametric results obtained using BIE/IF solution.
- Adequacy of general WLI nozzle solution assessed by benchmark against 3 plant specific evaluations, performed separately, using BIE/IF solution.

# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Results Summary

- Pressure Load Case - BIE/IF LEFM solution is shown to be conservative compared to FE LEFM results of comparable case:
  - **BIE/IF solution** provides  $K_{IP}$  which **bounds  $K_I$  calculated along crack front.**
  - **BIE/IF solution** provides  $K_{IP}$  which is **~40% conservative** for the case considered




Note:  $K_I$  not calculated for WLI insert since this component is either non-ferritic or always is less than 2" thick and is thus exempt from the fracture toughness requirements



# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Results Summary

- Thermal Ramp Load Case – BIE/IF LEFM solution is shown to be conservative compared to FE LEFM results of comparable case:
  - BIE/IF solution** provides  $K_{IT}$  which bounds **RMS  $K_I$**  calculated along crack front at time of max  $K_{IT}$ .
  - BIE/IF solution** provides  $K_{IT}$  which is **~45% conservative** for the case considered



# WLI Nozzle Evaluation (0900876-401, Rev. 0)


## Results Summary

- General WLI nozzle equations for  $K_{IT}$  and  $K_{IP}$  are provided which eliminate need for additional expense for plant specific analysis:


| Pressure Load   | Thermal Ramp Load   |
|---|---|
| $K_{I\_Pressure} = 2.9045 \cdot [R/t_v \sqrt{(t_v/4 + t_n)}] - 4.434$ | $K_{I\_ramp} = 874844 \cdot [\alpha(t_v + t_n)] - 20.715$ |

- Equations taken from 0900876-401, Rev. 0, Table 19.
- Where  $R$  is the vessel radius (in),  $t_v$  is the vessel thickness (in),  $t_n$  is the nozzle thickness (in), and  $\alpha$  is nozzle material thermal expansion coefficient (in/in/°F).

Internal Pressure Load Case (1000 psig)



Thermal Ramp Load Case (100 °F/hr)





# WLI Nozzle Evaluation (0900876-401, Rev. 0)

## Results Summary

- General WLI nozzle equations benchmark well against plant specific data:

|              |   |           |           |         |
|--------------|---|-----------|-----------|---------|
| Dimensions   | Vessel Nominal Diameter (in)                    | 251       | 218       | 238     |
|              | Vessel Thickness (in.)                          | 6.102     | 5.375     | 6.000   |
|              | Nozzle Thickness (in.)                          | 0.532     | 0.277     | 0.715   |
| Material     | Nozzle Material                                 | Alloy 600 | Alloy 600 | 304 SS  |
|              | Nozzle Thermal Expansion Coefficient (in/in/°F) | 7.70e-6   | 7.70e-6   | 9.75e-6 |
|              |   |           |           |         |
| Pressure     | K <sub>I</sub> per General Solution (ksi-√in)   | 81.24     | 70.53     | 81.29   |
|              | K <sub>I</sub> per Reference (ksi-√in)          | 72.88     | 71.26     | 69.40   |
|              | Relative Error (%)                              | 11.47%    | -1.02%    | 17.13%  |
| Thermal Ramp | K <sub>I</sub> per General Solution (ksi-√in)   | 23.97     | 17.35     | 36.56   |
|              | K <sub>I</sub> per Reference (ksi-√in)          | 24.5      | 17.87     | 38.6    |
|              | Relative Error (%)                              | -2.16%    | -2.89%    | -5.29%  |

Taken from 0900876-401, Rev. 0, Table 18.

- Upper bound solutions not developed since **BIE/IF LEFM solution** used to obtain parametric data points is shown to be **~40-50% conservative** when compared to more accurate FE LEFM analysis of identical cases; thus, **best estimate fit to parametric results considered appropriate**.
- Plant specific evaluation for K<sub>IP</sub>, using FE LEFM, may be performed to reduce conservatism, as necessary



# Discussion

---

# Summary

---

- BWROG to submit two (2) P-T curve LTRs for NRC review in Fall 2011

| <u>Submittal</u>                   | <u>Supporting Documentation</u>   |
|------------------------------------|---|
| P-T Curve LTR - SIR-05-044, Rev. 1 | PVP2011-57015<br>PVP2011-57742<br>PVP2011-57014<br>ORNL/TM-2010/246<br>ASME Paper 78-PVP-91<br>EPRI Report NP-339 |
| 0900876-401, Rev. 0                | 0900876-301, Rev. 0<br>0900876-302, Rev. 0<br>0900876-303, Rev. 0<br>0900876-304, Rev. 0                          |

- Objective of current meeting is to introduce intent, scope, and summarize significant conclusions of each LTR to the NRC.



# Summary

---

- SIR-05-044, Rev. 1
  - Incorporates instrument nozzle fracture mechanics methods, previously applied for plant specific submittals, into the existing P-T curve LTR
- 0900876-401, Rev. 0
  - Provides a general LEFM solution for water level instrument nozzles based on parametric evaluation of the WLI nozzle design. Intended to eliminate need for plant specific WLI nozzle FEA.