



UNIVERSITY OF MARYLAND

GLENN L. MARTIN INSTITUTE OF TECHNOLOGY
A. JAMES CLARK SCHOOL OF ENGINEERING

Department of Materials Science and Engineering

Building 090
College Park, Maryland 20742-2115
301.405.5207 TEL 301.314.2029 FAX
www.mse.umd.edu

October 12, 2011

Document Control Desk
United States Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Reference: UNIVERSITY OF MARYLAND, REQUEST FOR ADDITIONAL INFORMATION REGARDING THE LICENSE RENEWAL FOR THE MARYLAND UNIVERSITY TRAINING REACTOR ("MUTR") (TAC NO. ME1592), Docket No. 50-166, License No. R-70

The University of Maryland (UMD) hereby submits its responses to the NRC's Requests for Additional Information issued by letter dated September 8, 2011.

The September 8, 2011 RAIs concerned dose calculations submitted as Enclosure 2 to the University of Maryland letter of July 5, 2011. The dose calculations in Enclosure 2 addressed the occupational dose to workers, the dose to a member of the public in the Nuclear and Chemical Engineering Building next to the Maryland University Training Reactor (MUTR), and the dose at the nearest residence during a maximum hypothetical accident (MHA) and normal operations. In the calculations, UMD considered two operational modes of the ventilation system, namely ventilation "on" and ventilation "off". The purpose of these calculations was to demonstrate that the occupational doses to workers and doses to the members of the public would not exceed the limits of Title 10 of the *Code of Federal Regulations* (10 CFR) Part 20, "Standards for Protection Against Radiation." Request for Additional Information 1 raised four questions regarding the analysis of the consequences of the Maximum Hypothetical Accident.

As requested in Item 2 of your email of September 20, 2011, I am submitting our most up to date tentative schedule for the re-installation of the fission chamber and subsequent reactor operations to re-evaluate Ar-41 measurements and dose calculations initially in our July 5, 2011 submission in response to Request for Additional Information 2 issued by letter dated September 8, 2011. As you are aware, we have had a number of setbacks which impacted our original schedule which we provided to you in the 5 July letter.

Hopefully, all of the issues (mainly circuitry) have been resolved. At the present time, the final welding of the aluminum can that houses the fission chamber will be completed at the beginning of next week (the week of October 17, 2011). After the weld is leak tested, we will be able to begin installation back into the core by late next week. Assuming all proceeds well, installation and initial testing should be completed by 14 October. Per our original schedule, we anticipate three weeks of reactor operation (various power levels and run times), sample collection and analyses, followed by two weeks for final dose calculations and assessment and preparation of the final report which we anticipate can be submitted by November 18, 2011.

A020
MRC

The documents submitted today supplement the University's clarifications and responses to RAIs submitted by letter on the following dates: June 7, 2004; August 4, 2004; September 17, 2004; and October 7, 2004; April 18, 2005, April 25, 2006 (two letters); August 28, 2006 (two letters); November 9, 2006 and December 18, 2006; May 27, 2010; August 27, 2010; September 22, 2010 and December 14, 2010; January 31, February 2, March 17, May 2, July 5, July 29, September 27 and September 28, 2011.

If there are questions about the information submitted, please write to me at the address set forth above or email me at mohamad@umd.edu. Please copy Prof. Robert Briber on any such correspondence (same address; rbriber@umd.edu).

I declare under penalty of perjury that the foregoing is true and correct.

Sincerely,



Mohamad Al-Sheikhly
Professor and Director, Maryland University
Training Reactor

cc: Robert Briber
Enclosure

Calculations of Doses to Occupational Personnel and Members of the Public due to MHA and Normal Operations at the Maryland University Training Reactor

Note:

Internal and external components of doses are denoted for each category as applies.

Dose conversion factors are taken from the RADAR website and are consistent with ICRP and IAEA values
<http://www.doseinfo-radar.com/RADAR-INT-Occ.html>

In the August 10, 2011 teleconference with the NRC and consultant it was determined that the most likely exposed member of the public would be an individual residing at the fence line to the reactor facility and not an individual outside the door since there should be no force pushing anything, like a cloud out through the cracks in such cases as a leak with the ventilation off.

Normal Operations doses will be determined based on Ar-41 concentrations measured following the restart and operation of the reactor.

Table of Contents

I	Dose to Workers in the case of an MHA	2-4
II	Dose to the Nearest Residence in the case of an MHA	5-9
III	Dose to the nearest member of the public in the case of an MHA	10-14
IV	Dose to Workers in the case of Normal Operations	15
V	Dose to Nearest Residence in the case of Normal Operations	16-17
VI	Dose to nearest member of the public in the case of Normal Operations	18

External Submersion Gamma MHA Occupational Worker

External Occupational Dose to Worker [submersion gamma MHA Occupational Worker]									
Gamma Dose rate from the Cloud (DDE = Dy)								ON DDE rem	OFF DDE rem
			χ_0		Avg $\chi_{t w/V}$	Avg $\chi_{t w/L}$	Dose χ_0	Dose χ_v	Dose χ_L
Isotope	$E_{\gamma, avg}$ (MeV)	Release mCi	χ [Ci/m ³]	Dy [rads/s]	Vent factor	Leak factor	300s [rads]	300s [rads]	300s [rads]
Kr-83m	0.00939	0.465	2.748E-07	1.308E-09	7.870E-01	9.960E-01	3.925E-07	3.089E-07	3.909E-07
Kr-85m	0.15118	1.076	6.359E-07	4.874E-08	7.870E-01	9.960E-01	1.462E-05	1.151E-05	1.456E-05
Kr-85	0.51400	0.018	1.064E-08	2.772E-09	7.870E-01	9.960E-01	8.317E-07	6.545E-07	8.284E-07
Kr-87	0.40256	2.070	1.223E-06	2.497E-07	7.870E-01	9.960E-01	7.491E-05	5.895E-05	7.461E-05
Kr-88	2.39210	2.959	1.749E-06	2.121E-06	7.870E-01	9.960E-01	6.363E-04	5.008E-04	6.337E-04
Kr-89	0.22090	3.638	2.150E-06	2.408E-07	7.870E-01	9.960E-01	7.224E-05	5.685E-05	7.195E-05
Kr-90	1.11870	4.133	2.443E-06	1.385E-06	7.870E-01	9.960E-01	4.156E-04	3.271E-04	4.140E-04
Xe-133m	0.03304	0.146	8.629E-08	1.446E-09	7.870E-01	9.960E-01	4.337E-07	3.413E-07	4.319E-07
Xe-133	0.02330	8.516	5.033E-06	5.946E-08	7.870E-01	9.960E-01	1.784E-05	1.404E-05	1.777E-05
Xe-135m	0.42128	2.243	1.326E-06	2.831E-07	7.870E-01	9.960E-01	8.494E-05	6.685E-05	8.460E-05
Xe-135	0.25466	3.844	2.272E-06	2.933E-07	7.870E-01	9.960E-01	8.800E-05	6.925E-05	8.765E-05
Sr-89	0.00010	0.2500	1.478E-07	7.491E-12	7.870E-01	9.960E-01	2.247E-09	1.769E-09	2.238E-09
Sr-91	0.62900	323.00	1.909E-04	6.088E-05	7.870E-01	9.960E-01	1.826E-02	1.437E-02	1.819E-02
Sr-92	1.29200	365.50	2.160E-04	1.415E-04	7.870E-01	9.960E-01	4.245E-02	3.341E-02	4.228E-02
Sr-93	1.66000	414.50	2.450E-04	2.062E-04	7.870E-01	9.960E-01	6.185E-02	4.868E-02	6.161E-02
Cs-134m	0.01792	0.5000	2.955E-07	2.685E-09	7.870E-01	9.960E-01	8.054E-07	6.339E-07	8.022E-07
Cs-134	1.39800	0.8000	4.728E-07	3.351E-07	7.870E-01	9.960E-01	1.005E-04	7.912E-05	1.001E-04
Cs-136	1.79500	6.5000	3.842E-06	3.496E-06	7.870E-01	9.960E-01	1.049E-03	8.254E-04	1.045E-03
Cs-137	0.59510	124.00	7.329E-05	2.211E-05	7.870E-01	9.960E-01	6.633E-03	5.221E-03	6.607E-03
Cs-138	1.04100	515.00	3.044E-04	1.606E-04	7.870E-01	9.960E-01	4.819E-02	3.793E-02	4.800E-02
				DDE =			1.799E-01	1.416E-01	1.792E-01

Internal MHA Occupational Worker

Internal MHA Occupational Worker										
Ventilation ON and OFF: MHA Occupational Internal Dose to Worker									ON CEDE [rem]	OFF CEDE [rem]
Isotope	Release [Ci]	C ₀ [Ci/m ³]	C _v [Ci/m ³]	C _i [Ci/m ³]	B _r [m ³ /s]	t _{evac} [s]	DCF [rem/Ci]	D _w [rem]	D _{w_v300s} [rem]	D _{w_L300s} [rem]
I-131	0.00405	2.3936E-06	1.8821E-06	2.3886E-06	3.33E-04	300	740	5.3085E-06	4.1741E-06	5.2974E-06
I-132	0.00623	3.6820E-06	2.8952E-06	3.6743E-06	3.33E-04	300	407	4.4913E-06	3.5315E-06	4.4818E-06
I-133	0.07250	4.2849E-05	3.3692E-05	4.2759E-05	3.33E-04	300	7770	9.9780E-04	7.8457E-04	9.9571E-04
I-134	0.00954	5.6383E-06	4.4334E-06	5.6265E-06	3.33E-04	300	292.3	4.9393E-06	3.8837E-06	4.9289E-06
I-135	0.00830	4.9054E-06	3.8571E-06	4.8952E-06	3.33E-04	300	1702	2.5022E-05	1.9675E-05	2.4970E-05
Kr-83m	0.000465	2.7482E-07	2.1609E-07	2.7425E-07	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-85m	0.001076	6.3593E-07	5.0003E-07	6.3460E-07	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-85	0.000018	1.0638E-08	8.3649E-09	1.0616E-08	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-87	0.00207	1.2234E-06	9.6196E-07	1.2208E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-88	0.002959	1.7488E-06	1.3751E-06	1.7452E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-89	0.003638	2.1501E-06	1.6906E-06	2.1456E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Kr-90	0.004133	2.4427E-06	1.9207E-06	2.4375E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Xe-133m	0.000146	8.6288E-08	6.7848E-08	8.6107E-08	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Xe-133	0.008516	5.0331E-06	3.9575E-06	5.0225E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Xe-135m	0.002243	1.3257E-06	1.0424E-06	1.3229E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Xe-135	0.003844	2.2719E-06	1.7864E-06	2.2671E-06	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Sr-89	0.00025	1.4775E-07	1.1618E-07	1.4744E-07	3.33E-04	300	5180	2.2938E-06	1.8036E-06	2.2890E-06
Sr-91	0.323	1.9090E-04	1.5010E-04	1.9050E-04	3.33E-04	300	1073	6.1389E-04	4.8270E-04	6.1260E-04
Sr-92	0.3655	2.1602E-04	1.6985E-04	2.1556E-04	3.33E-04	300	666	4.3117E-04	3.3903E-04	4.3027E-04
Sr-93	0.4145	2.4498E-04	1.9262E-04	2.4446E-04	3.33E-04	300	0	0.0000E+00	0.0000E+00	0.0000E+00
Cs-134m	0.0005	2.9551E-07	2.3236E-07	2.9489E-07	3.33E-04	300	96.2	8.5198E-08	6.6991E-08	8.5020E-08
Cs-134	0.0008	4.7281E-07	3.7177E-07	4.7182E-07	3.33E-04	300	35520	5.0333E-05	3.9576E-05	5.0227E-05
Cs-136	0.0065	3.8416E-06	3.0206E-06	3.8336E-06	3.33E-04	300	7030	8.0938E-05	6.3642E-05	8.0769E-05
Cs-137	0.124	7.3286E-05	5.7625E-05	7.3132E-05	3.33E-04	300	24790	5.4448E-03	4.2813E-03	5.4334E-03
Cs-138	0.515	3.0437E-04	2.3933E-04	3.0374E-04	3.33E-04	300	170.2	1.5526E-04	1.2208E-04	1.5493E-04
							Total	7.8164E-03	6.1460E-03	7.8000E-03

External Submersion Beta MHA Occupational Worker

External Occupational Dose to Worker [submersion beta MHA Occupational Worker]											
Beta Dose rate from the Cloud (SDE = D _β)				Shallow Dose Equivalent SDE at 7 mg/cm ²						ON	OFF
				$D_{\beta} = 2.45 \times E^{-7} C E_{avg} e^{-\mu \times 0.007} \text{ mGy/hr}$						SDE rem	SDE rem
		release	χ_0				Avg $\chi_{t w/v}$	Avg $\chi_{t w/l}$	Dose χ_0	Dose χ_v	Dose χ_l
Isotope	$E_{\beta, avg}$ (keV)	mCi	χ [Ci/m ³]	$\mu_{\beta, t}$	$e^{-\mu_{\beta, t} \times 0.007}$	D _β [mGy/hr]	Vent factor	Leak factor	300s [rads]	300s [rads]	300s [rads]
Kr-85m	230	1.0760	6.3593E-07	3.3279E+01	7.9219E-01	1.0504E-03	7.870E-01	9.960E-01	8.7530E-06	6.889E-06	8.718E-06
Kr-85	228	0.0180	1.0638E-08	3.3702E+01	7.8985E-01	1.7367E-05	7.870E-01	9.960E-01	1.4472E-07	1.139E-07	1.441E-07
Kr-87	1329	2.0700	1.2234E-06	2.8316E+00	9.8037E-01	1.4450E-02	7.870E-01	9.960E-01	1.2041E-04	9.477E-05	1.199E-04
Kr-88	366	2.9590	1.7488E-06	1.7129E+01	8.8701E-01	5.1466E-03	7.870E-01	9.960E-01	4.2888E-05	3.375E-05	4.272E-05
Kr-89	1650	3.6380	2.1501E-06	2.1001E+00	9.8541E-01	3.1691E-02	7.870E-01	9.960E-01	2.6409E-04	2.078E-04	2.630E-04
Kr-90	800	4.1330	2.4427E-06	5.7229E+00	9.6073E-01	1.7019E-02	7.870E-01	9.960E-01	1.4182E-04	1.116E-04	1.413E-04
Xe-133	416	8.5160	5.0331E-06	1.4293E+01	9.0479E-01	1.7173E-02	7.870E-01	9.960E-01	1.4311E-04	1.126E-04	1.425E-04
Xe-135m	100	2.2430	1.3257E-06	1.1532E+02	4.4608E-01	5.3605E-04	7.870E-01	9.960E-01	4.4671E-06	3.516E-06	4.449E-06
Xe-135	302	3.8440	2.2719E-06	2.2510E+01	8.5422E-01	5.3128E-03	7.870E-01	9.960E-01	4.4274E-05	3.484E-05	4.410E-05
Sr-89	584	0.2500	1.4775E-07	8.8761E+00	9.3976E-01	7.3508E-04	7.870E-01	9.960E-01	6.1257E-06	4.821E-06	6.101E-06
Sr-91	1354	323.0000	1.9090E-04	2.7595E+00	9.8087E-01	2.2983E+00	7.870E-01	9.960E-01	1.9152E-02	1.507E-02	1.908E-02
Sr-92	1521	365.5000	2.1602E-04	2.3499E+00	9.8369E-01	2.9298E+00	7.870E-01	9.960E-01	2.4415E-02	1.921E-02	2.432E-02
Sr-93	1000	414.5000	2.4498E-04	4.1980E+00	9.7104E-01	2.1564E+00	7.870E-01	9.960E-01	1.7970E-02	1.414E-02	1.790E-02
Cs-134	156	0.8000	4.7281E-07	5.8735E+01	6.6289E-01	4.4322E-04	7.870E-01	9.960E-01	3.6935E-06	2.907E-06	3.679E-06
Cs-136	116	6.5000	3.8416E-06	9.1732E+01	5.2617E-01	2.1255E-03	7.870E-01	9.960E-01	1.7713E-05	1.394E-05	1.764E-05
Cs-137	170	124.0000	7.3286E-05	5.1725E+01	6.9623E-01	7.8631E-02	7.870E-01	9.960E-01	6.5526E-04	5.157E-04	6.526E-04
Cs-138	1239	515.0000	3.0437E-04	3.1199E+00	9.7840E-01	3.3447E+00	7.870E-01	9.960E-01	2.7873E-02	2.194E-02	2.776E-02
I-131	190.00	0.0041	2.3936E-09	4.3932E+01	7.3526E-01	3.0312E-06	7.870E-01	9.960E-01	2.5260E-08	1.988E-08	2.516E-08
I-132	270.00	0.0062	3.6820E-09	2.6420E+01	8.3115E-01	7.4903E-06	7.870E-01	9.960E-01	6.2419E-08	4.912E-08	6.217E-08
I-133	440.00	0.0725	4.2849E-08	1.3206E+01	9.1170E-01	1.5582E-04	7.870E-01	9.960E-01	1.2985E-06	1.022E-06	1.293E-06
I-134	460.00	0.0095	5.6383E-09	1.2405E+01	9.1683E-01	2.1556E-05	7.870E-01	9.960E-01	1.7963E-07	1.414E-07	1.789E-07
I-135	530.00	0.0083	4.9054E-09	1.0168E+01	9.3130E-01	2.1949E-05	7.870E-01	9.960E-01	1.8291E-07	1.439E-07	1.822E-07
Total SDE									7.151E-02	9.050E-02	

Plume Model Calculations for MHA Occupational Worker

Stability Class factors for 175, 200, and 300 meters downwind on the center line													
$\chi(x,0)$ [m]	σ_y [m]					σ_z [m]					pi	wind speed	eff height
	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	π	μ [m/s]	H [m]
175	40	27.5	20	10	7	28	18	4	5	2.5	3.14	2	7.3255
200	45	30	22.5	12.5	8	30	20	15	5.5	3	3.14	2	7.3255
300	70	46.5	35	18	13	55	30	22.5	8.5	4.7	3.14	2	7.3255

$\chi(x,0)$ [m]	$[1/\mu \mu \sigma_y \sigma_z \pi]$					$e^{-[1/2 (H/\sigma)^2]}$				
	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>
175	1.4217E-04	3.2169E-04	1.9904E-03	6.3694E-03	9.0992E-03	9.6636E-01	9.2052E-01	1.8694E-01	3.4189E-01	1.3663E-02
200	1.1795E-04	2.6539E-04	4.7181E-04	4.2463E-03	6.6348E-03	9.7063E-01	9.3512E-01	8.8758E-01	4.1189E-01	5.0728E-02
300	4.1360E-05	1.1415E-04	2.0220E-04	1.8822E-03	2.6061E-03	9.9117E-01	9.7063E-01	9.4838E-01	6.8979E-01	2.9682E-01

$\chi(x,0)$ [m]	$\chi/Q [s/m^3] = [1/\mu \sigma_y \sigma_z \pi] \times e^{-[1/2 (H/\sigma)^2]}$				
	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>
175	1.3739E-04	2.9612E-04	3.7209E-04	2.1777E-03	1.2433E-04
200	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04
300	4.0995E-05	1.1079E-04	1.9177E-04	1.2983E-03	7.7355E-04

Plume Model Calculations for MHA Occupational Worker Ventilation OFF (continued)

MHA Plume Model 200 m Nearest Residence Ground Release Ventilation OFF (leakage)									
MHA data Plume Model 200 m Nearest Residence					A 200	B 200	C 200	E 200	F 200
Nuclides	$f_{L(5\%)} [m^3/s]$	A [Ci]	$C_0 [Ci/m^3]$	$Q_{L(5\%)} [Ci/s]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$
Kr-83m	2.350E-02	4.650E-04	2.748E-07	6.458E-09	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Kr-85m	2.350E-02	1.076E-03	6.359E-07	1.494E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Kr-85	2.350E-02	1.800E-05	1.064E-08	2.500E-10	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Kr-87	2.350E-02	2.070E-03	1.223E-06	2.875E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Kr-88	2.350E-02	2.959E-03	1.749E-06	4.110E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Xe-133m	2.350E-02	1.460E-04	8.629E-08	2.028E-09	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Xe-133	2.350E-02	8.516E-03	5.033E-06	1.183E-07	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Xe-135m	2.350E-02	2.243E-03	1.326E-06	3.115E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Xe-135	2.350E-02	3.844E-03	2.272E-06	5.339E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
Internal Component					A 200	B 200	C 200	E 200	F 200
Nuclides	$f_{L(5\%)} [m^3/s]$	A [Ci]	$C_0 [Ci/m^3]$	$Q_{L(5\%)} [Ci/s]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$	$\chi/Q [s/m^3]$
I-131	2.350E-02	4.050E-03	2.394E-06	5.625E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
I-132	2.350E-02	6.230E-03	3.682E-06	8.653E-08	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
I-133	2.350E-02	7.250E-02	4.285E-05	1.007E-06	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
I-134	2.350E-02	9.540E-03	5.638E-06	1.325E-07	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03
I-135	2.350E-02	8.300E-03	4.905E-06	1.153E-07	1.180E-04	2.654E-04	4.718E-04	4.246E-03	6.635E-03

Plume Model Calculations for MHA Occupational Worker Ventillation OFF (continued)

A 200	B 200	C 200	E 200	F 200	DCF [rem/hr/Ci/ m ³]	A 200	B 200	C 200	E 200	F 200
XL [Ci/m ³]	XL [Ci/m ³]	XL [Ci/m ³]	XL [Ci/m ³]	XL [Ci/m ³]		DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]
7.618E-13	1.714E-12	3.047E-12	2.742E-11	4.285E-11	3.238E-02	2.466E-14	5.549E-14	9.865E-14	8.878E-13	1.387E-12
1.763E-12	3.966E-12	7.051E-12	6.346E-11	9.915E-11	9.096E+01	1.603E-10	3.608E-10	6.413E-10	5.772E-09	9.019E-09
2.949E-14	6.635E-14	1.180E-13	1.062E-12	1.659E-12	3.392E+00	1.000E-13	2.250E-13	4.001E-13	3.600E-12	5.626E-12
3.391E-12	7.630E-12	1.356E-11	1.221E-10	1.908E-10	5.242E+02	1.778E-09	3.999E-09	7.110E-09	6.399E-08	9.999E-08
4.848E-12	1.091E-11	1.939E-11	1.745E-10	2.727E-10	1.295E+03	6.278E-09	1.412E-08	2.511E-08	2.260E-07	3.531E-07
2.392E-13	5.382E-13	9.567E-13	8.611E-12	1.345E-11	1.696E+01	4.056E-12	9.126E-12	1.622E-11	1.460E-10	2.282E-10
1.395E-11	3.139E-11	5.580E-11	5.022E-10	7.848E-10	1.850E+01	2.581E-10	5.807E-10	1.032E-09	9.291E-09	1.452E-08
3.675E-12	8.268E-12	1.470E-11	1.323E-10	2.067E-10	2.467E+02	9.064E-10	2.039E-09	3.626E-09	3.263E-08	5.098E-08
6.297E-12	1.417E-11	2.519E-11	2.267E-10	3.542E-10	1.480E+02	9.320E-10	2.097E-09	3.728E-09	3.355E-08	5.243E-08
Internal component continued					Total DDE	1.032E-08	2.321E-08	4.126E-08	3.714E-07	5.803E-07
				CED		A 200	B 200	C 200	E 200	F 200
B_r [m³/s]				DCF [rem/Ci]		CEDE [rem]	CEDE [rem]	CEDE [rem]	CEDE [rem]	CEDE [rem]
3.330E-04				7.400E+02		3.531E-09	7.946E-09	1.413E-08	1.271E-07	1.986E-07
3.330E-04				4.070E+02		2.988E-09	6.723E-09	1.195E-08	1.076E-07	1.681E-07
3.330E-04				7.770E+03		6.638E-07	1.494E-06	2.655E-06	2.390E-05	3.734E-05
3.330E-04				2.923E+02		3.286E-09	7.393E-09	1.314E-08	1.183E-07	1.848E-07
3.330E-04				1.702E+03		1.665E-08	3.745E-08	6.658E-08	5.993E-07	9.363E-07
					Total CEDE	6.902E-07	1.553E-06	2.761E-06	2.485E-05	3.883E-05
					TEDE [rem]	7.006E-07	1.576E-06	2.802E-06	2.522E-05	3.941E-05

Plume Model Calculations for MHA Occupational Worker Ventillation ON (continued)

Ventilation ON Max Concentration distance 200 m								A 200	B 200	C 200	E 200	F 200	
MHA data Plume Model 200 m Nearest Residence													
Nuclides	f_v [m ³ /s]	$f_L^{(5\%)}$ [m ³ /s]	A [Ci]	C_0 [Ci/m ³]	Q_v [Ci/s]	$Q_L^{(5\%)}$ [Ci/s]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]		
Kr-83m	2.83	0.0235	4.6500E-04	2.7482E-07	7.7775E-07	6.4583E-09	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Kr-85m	2.83	0.0235	1.0760E-03	6.3593E-07	1.7997E-06	1.4944E-08	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Kr-85	2.83	0.0235	1.8000E-05	1.0638E-08	3.0106E-08	2.5000E-10	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Kr-87	2.83	0.0235	2.0700E-03	1.2234E-06	3.4622E-06	2.8750E-08	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Kr-88	2.83	0.0235	2.9590E-03	1.7488E-06	4.9492E-06	4.1097E-08	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Xe-133m	2.83	0.0235	1.4600E-04	8.6288E-08	2.4420E-07	2.0278E-09	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Xe-133	2.83	0.0235	8.5160E-03	5.0331E-06	1.4244E-05	1.1828E-07	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Xe-135m	2.83	0.0235	2.2430E-03	1.3257E-06	3.7516E-06	3.1153E-08	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Xe-135	2.83	0.0235	3.8440E-03	2.2719E-06	6.4294E-06	5.3389E-08	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
Internal component								A 200	B 200	C 200	E 200	F 200	
Nuclides	f_v [m ³ /s]	$f_L^{(5\%)}$ [m ³ /s]	A [Ci]	C_0 [Ci/m ³]	Q_v [Ci/s]	$Q_L^{(5\%)}$ [Ci/s]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]		
I-131	2.83	0.0235	4.0500E-03	2.3936E-06	6.7739E-06	1.5919E-07	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
I-132	2.83	0.0235	6.2300E-03	3.6820E-06	1.0420E-05	2.4487E-07	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
I-133	2.83	0.0235	7.2500E-02	4.2849E-05	1.2126E-04	2.8497E-06	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
I-134	2.83	0.0235	9.5400E-03	5.6383E-06	1.5956E-05	3.7498E-07	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		
I-135	2.83	0.0235	8.3000E-03	4.9054E-06	1.3882E-05	3.2624E-07	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04		

Plume Model Calculations for MHA Occupational Worker Ventilation ON (continued)

A 200	B 200	C 200	E 200	F 200	DCF [rem/hr/Ci/m ³]	A 200	B 200	C 200	E 200	F 200
X _v [Ci/m ³]	X _v [Ci/m ³]	X _v [Ci/m ³]	X _v [Ci/m ³]	X _v [Ci/m ³]		DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]
8.9043E-11	1.9302E-10	3.2570E-10	1.3603E-09	2.6177E-10	3.2375E-02	2.8828E-12	6.2489E-12	1.0544E-11	4.4040E-11	8.4747E-12
2.0604E-10	4.4664E-10	7.5366E-10	3.1477E-09	6.0573E-10	9.0958E+01	1.8741E-08	4.0625E-08	6.8552E-08	2.8631E-07	5.5096E-08
3.4468E-12	7.4716E-12	1.2608E-11	5.2657E-11	1.0133E-11	3.3917E+00	1.1690E-11	2.5341E-11	4.2761E-11	1.7859E-10	3.4368E-11
3.9638E-10	8.5924E-10	1.4499E-09	6.0555E-09	1.1653E-09	5.2417E+02	2.0777E-07	4.5038E-07	7.5998E-07	3.1741E-06	6.1081E-07
5.6662E-10	1.2283E-09	2.0726E-09	8.6562E-09	1.6657E-09	1.2950E+03	7.3377E-07	1.5906E-06	2.6840E-06	1.1210E-05	2.1571E-06
2.7957E-11	6.0603E-11	1.0226E-10	4.2710E-10	8.2190E-11	1.6958E+01	4.7411E-10	1.0277E-09	1.7342E-09	7.2430E-09	1.3938E-09
1.6307E-09	3.5349E-09	5.9648E-09	2.4912E-08	4.7940E-09	1.8500E+01	3.0168E-08	6.5396E-08	1.1035E-07	4.6088E-07	8.8689E-08
4.2951E-10	9.3105E-10	1.5711E-09	6.5616E-09	1.2627E-09	2.4667E+02	1.0595E-07	2.2966E-07	3.8753E-07	1.6185E-06	3.1146E-07
7.3609E-10	1.5956E-09	2.6924E-09	1.1245E-08	2.1640E-09	1.4800E+02	1.0894E-07	2.3615E-07	3.9848E-07	1.6643E-06	3.2026E-07
Internal component continued					Total DDE	1.2058E-06	2.6139E-06	4.4106E-06	1.8421E-05	3.5449E-06
				CEDE		A 200	B 200	C 200	E 200	F 200
B_r [m3/s]				DCF [rem/Ci]		CEDE [rem]	CEDE [rem]	CEDE [rem]	CEDE [rem]	CEDE [rem]
3.33E-04				7.4000E+02		3.4278E-09	7.4304E-09	1.2538E-08	5.2366E-08	1.0077E-08
3.33E-04				4.0700E+02		2.9001E-09	6.2864E-09	1.0608E-08	4.4304E-08	8.5256E-09
3.33E-04				7.7700E+03		6.4429E-07	1.3966E-06	2.3567E-06	9.8428E-06	1.8941E-06
3.33E-04				2.9230E+02		3.1893E-09	6.9135E-09	1.1666E-08	4.8723E-08	9.3761E-09
3.33E-04				1.7020E+03		1.6157E-08	3.5024E-08	5.9099E-08	2.4683E-07	4.7499E-08
					Total CEDE	6.6997E-07	1.4523E-06	2.4506E-06	1.0235E-05	1.9696E-06
					TEDE	1.8758E-06	4.0661E-06	6.8612E-06	2.8656E-05	5.5145E-06

Dose to the nearest member of the public in the case of an MHA

Gamma submersion dose component

Ventilation OFF (leakage)			
MHA Gamma submersion dose at fence line			
Isotope	5% / hr leakage	Gamma submersion dose 2 hr OFF rads	E _y , avg (MeV)
Kr-83m	3.8543E-08	6.6057E-07	0.00939
Kr-85m	1.0939E-07	3.0185E-05	0.15118
Kr-85	2.1276E-09	1.9960E-06	0.514
Kr-87	1.4901E-07	1.0948E-04	0.40256
Kr-88	1.1945E-08	5.2152E-05	2.3921
Xe-133m	1.7032E-08	6.8670E-06	0.2209
Xe-133	1.0011E-06	2.0441E-03	1.1187
Xe-135m	4.8535E-08	2.9271E-06	0.033042
Xe-135	4.2142E-07	1.7922E-05	0.0233
I-131	4.7699E-07	3.3083E-04	0.38
I-132	5.5311E-07	6.7336E-04	0.667
I-133	8.2903E-06	8.6250E-03	0.57
I-134	5.6649E-07	7.4755E-04	0.723
I-135	8.8504E-07	1.3666E-03	0.846
	Total	1.4010E-02	rem

Dose to the nearest member of the public in the case of an MHA

Beta submersion dose component

Ventilation OFF (leakage)				
Beta submersion Dose at fence				
Isotope	C_{avg}[Ci/m³]	10% of C_{avg}[Ci/m³]	E_{avg} [Mev]	rem
Kr-85m	5.29386E-07	5.29386E-08	0.227	1.99003E-05
Kr-85	9.85633E-09	9.85633E-10	0.251	4.09684E-07
Kr-87	1.2234E-06	1.2234E-07	1.27	0.000257296
Kr-88	1.34825E-06	1.34825E-07	0.28	6.25156E-05
Kr-89	1.46857E-07	1.46857E-08	1.4	3.40474E-05
Kr-90	2.42662E-06	2.42662E-07	0.8	0.000321479
Xe-133	5.01927E-06	5.01927E-07	0.1	8.31191E-05
Xe-135m	4.55344E-07	4.55344E-08	0.1	7.54049E-06
Xe-135	2.18743E-06	2.18743E-07	0.28	0.000101427
			Total rem	8.88E-04

Dose to the nearest member of the public in the case of an MHA

Internal dose component

Ventilation OFF (leakage)							
MHA Internal Component at Fence							
Isotope	Release [Ci]	C_{avg} [Ci/m ³]	2 hr leakage (10%)	B_r [m ³ /s]	t_{evac} [s]	DCF [rem/Ci]	Internal rem at fence
I-131	0.00405	2.3893E-06	2.3893E-07	3.33E-04	7200	740	4.2391E-04
I-132	0.00623	3.1791E-06	3.1791E-07	3.33E-04	7200	407	3.1022E-04
I-133	0.07250	4.2142E-05	4.2142E-06	3.33E-04	7200	7770	7.8509E-02
I-134	0.00954	3.8971E-06	3.8971E-07	3.33E-04	7200	292.3	2.7312E-04
I-135	0.00830	4.6570E-06	4.6570E-07	3.33E-04	7200	1702	1.9004E-03
						Total rem	8.1416E-02

Dose to the nearest member of the public in the case of an MHA

External beta dose component from volume cloud inside reactor bay

Ventilation ON/OFF							
Beta Dose rate from the volume cloud inside the reactor at fence							
Dβ = 1.1 x E+3 C Eavg [mrad/hr]							
Isotope	Eβ, avg (keV)	mCi	C [μCi/g]	$\mu\beta$, t air	e^{-$\mu\beta$.t}	Dsurf [mrad/hr]	2 hr exposure Dsurf [mrad]
Kr-85m	230	1.0760	4.9155E-04	2.8994E+01	0.0000E+00	0.0000E+00	0.0000E+00
Kr-85	228	0.0180	8.2229E-06	2.9371E+01	0.0000E+00	0.0000E+00	0.0000E+00
Kr-87	1329	2.0700	9.4564E-04	2.3374E+00	3.6114E-48	4.9925E-48	9.9849E-48
Kr-88	366	2.9590	1.3518E-03	1.4708E+01	2.9816E-299	1.6226E-299	3.2453E-299
Kr-89	1650	3.6380	1.6619E-03	1.7223E+00	1.1015E-35	3.3227E-35	6.6454E-35
Kr-90	800	4.1330	1.8881E-03	4.7975E+00	4.2128E-98	6.9996E-98	1.3999E-97
Xe-133	416	8.5160	3.8904E-03	1.2224E+01	7.6822E-249	1.3676E-248	2.7352E-248
Xe-135m	100	2.2430	1.0247E-03	1.0325E+02	0.0000E+00	0.0000E+00	0.0000E+00
Xe-135	302	3.8440	1.7561E-03	1.9444E+01	0.0000E+00	0.0000E+00	0.0000E+00
Sr-89	584	0.2500	1.1421E-04	7.5127E+00	3.2615E-153	2.3928E-154	4.7857E-154
Sr-91	1354	323.0000	1.4756E-01	2.2767E+00	6.1711E-47	1.3562E-44	2.7124E-44
Sr-92	1521	365.5000	1.6697E-01	1.9319E+00	6.1349E-40	1.7138E-37	3.4277E-37
Sr-93	1000	414.5000	1.8936E-01	3.4953E+00	1.1331E-71	2.3601E-69	4.7202E-69
Cs-134	156	0.8000	3.6546E-04	5.1813E+01	0.0000E+00	0.0000E+00	0.0000E+00
Cs-136	116	6.5000	2.9694E-03	8.1715E+01	0.0000E+00	0.0000E+00	0.0000E+00
Cs-137	170	124.0000	5.6647E-02	4.5502E+01	0.0000E+00	0.0000E+00	0.0000E+00
Cs-138	1239	515.0000	2.3527E-01	2.5809E+00	4.1247E-53	1.3226E-50	2.6451E-50
					Subtotal	3.3398E-35	3.3398E-32

Dose to the nearest member of the public in the case of an MHA

External gamma dose component from volume cloud inside reactor bay

Ventilation ON/OFF										
Gamma Dose rate from the volume cloud inside the reactor at fence										
Nuclides	Gamma Constant [rem/hr/Ci/m ²]	(r ² + h ²)/h ²	A [Ci]	Time [hr]	half-life [hr]	Avg _v [Ci/m ³] ON	linear energy absorption coeff m ⁻¹	Avg _v [Ci/m ³] OFF	Dose _v ON [rem]	Dose _v OFF [rem]
Kr-83m	0.11873	1.25	0.000465	2	1.83	2.286E-07	3.01502E-05	2.28776E-07	3.803E-08	3.8063E-08
Kr-85m	0.16013	1.25	0.001076	2	4.48	5.8871E-07	3.24794E-05	5.89185E-07	1.321E-07	1.3221E-07
Kr-85	0.00156	1.25	0.000018	2	93907.2	1.0629E-08	3.84318E-05	1.06382E-08	2.324E-11	2.3256E-11
Kr-87	0.43253	1.25	0.00207	2	1.271667	9.4246E-07	3.83024E-05	9.43176E-07	5.712E-07	5.7167E-07
Kr-88	1.02453	1.25	0.002959	2	0.047333	1.1943E-07	3.02796E-05	1.19448E-07	1.715E-07	1.7149E-07
Xe-133m	0.11225	1.25	0.000146	2	52.512	8.565E-08	3.01502E-05	8.57209E-08	1.347E-08	1.3484E-08
Xe-133	0.10297	1.25	0.008516	2	125.88	5.0151E-06	3.01502E-05	5.01923E-06	7.236E-07	7.2425E-07
Xe-135m	0.32008	1.25	0.002243	2	0.254833	4.5512E-07	3.83024E-05	4.55342E-07	2.041E-07	2.0424E-07
Xe-135	0.18947	1.25	0.003844	2	9.09	2.1856E-06	3.59732E-05	2.18741E-06	5.803E-07	5.8077E-07
I-131	0.28293	1.25	0.00405	2	192	2.3873E-06	3.83024E-05	2.38929E-06	9.465E-07	9.4729E-07
I-132	1.4274	1.25	0.00623	2	2.3	3.1766E-06	3.79142E-05	3.17906E-06	6.354E-06	6.3589E-06
I-133	0.4088	1.25	0.0725	2	20.8	4.2108E-05	3.83024E-05	4.21425E-05	2.412E-05	2.4142E-05
I-134	1.5728	1.25	0.00954	2	0.876667	3.8943E-06	3.79142E-05	3.8971E-06	8.583E-06	8.5892E-06
I-135	0.8609	1.25	0.0083	2	6.61	4.6532E-06	3.73966E-05	4.65702E-06	5.614E-06	5.6182E-06
Sr-89	0.00008158	1.25	0.00025	2	1212	1.4771E-07	3.01502E-05	1.47712E-07	1.689E-11	1.6886E-11
Sr-91	0.41366	1.25	0.323	2	9.5	0.0001841	3.83024E-05	0.000184102	0.0001067	0.00010672
Sr-92	0.72002	1.25	0.3655	2	2.71	0.00019061	3.46792E-05	0.000190608	0.0001923	0.00019232
Sr-93	1.35605	1.25	0.4145	2	0.13	4.5733E-05	0.00003235	4.57327E-05	8.69E-05	8.6904E-05
Cs-134m	0.070448	1.25	0.0005	2	2.9	2.6285E-07	3.01502E-05	2.62852E-07	2.595E-08	2.5949E-08
Cs-134	0.99937	1.25	0.0008	2	18063	4.728E-07	0.000033644	4.72804E-07	6.621E-07	6.6213E-07
Cs-136	1.34384	1.25	0.0065	2	314.4	3.8374E-06	0.000031056	3.83738E-06	7.226E-06	7.2264E-06
Cs-137	0.38184	1.25	0.124	2	262800	7.3286E-05	3.83024E-05	7.3286E-05	3.921E-05	3.9214E-05
Cs-138	1.26614	1.25	0.515	2	0.54	0.00017145	0.000036232	0.00017145	0.0003042	0.0003042
								Sub Total	7.853E-04	1.836E-03

Dose to the occupational worker in the case of normal operations

External gamma dose component

Release activity TBD

External Occupational Dose to Worker									
Gamma Dose rate from the Cloud (DDE = Dy)									
			χ_0		Avg $\chi_{t w/V}$	Avg $\chi_{t w/L}$	Dose χ_0	Dose χ_v	Dose χ_L
Isotope	$E_{\gamma, avg}$ (MeV)	Release mCi	χ [Ci/m ³]	Dy [rads/s]	Vent factor	Leak factor	300s [rads]	300s [rads]	300s [rads]
Ar-41	1.29300		#VALUE!	#VALUE!	7.870E-01	9.960E-01	#VALUE!	#VALUE!	#VALUE!

External beta dose component

Release activity TBD

External Occupational Dose to Worker				Shallow Dose Equivalent SDE at 7 mg/cm ²						ON	OFF
Beta Dose rate from the Cloud (SDE = D β)				$D_{\beta} = 2.45 \times E^{-7} C E_{avg} e^{-\mu \times 0.007}$ mGy/hr						SDE rem	SDE rem
		release	χ_0				Avg $\chi_{t w/V}$	Avg $\chi_{t w/L}$	Dose χ_0	Dose χ_v	Dose χ_L
Isotope	$E_{\beta, avg}$ (keV)	mCi	χ [Ci/m ³]	$\mu_{\beta, t}$	$e^{-\mu_{\beta, t} \times 0.007}$	D β [mGy/hr]	Vent factor	Leak factor	300s [rads]	300s [rads]	300s [rads]
Ar-41	400		#VALUE!	1.5106E+01	8.9966E-01	#VALUE!	7.870E-01	9.960E-01	#VALUE!	#VALUE!	#VALUE!

Dose to nearest residence in the case of normal operations

Plume model factors

Stability Class factors for 175, 200, and 300 meters downwind on the center line													
	σ_y [m]					σ_z [m]					pi	wind speed	Effective height
$\chi(x,0)$ [m]	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	π	μ [m/s]	<u>H</u> [m]
175	40	27.5	20	10	7	28	18	4	5	2.5	3.14	2	7.3255
200	45	30	22.5	12.5	8	30	20	15	5.5	3	3.14	2	7.3255
300	70	46.5	35	18	13	55	30	22.5	8.5	4.7	3.14	2	7.3255
	$[1/\mu \sigma_y \sigma_z \pi]$					$e^{-[1/2 (H/\sigma)^2]}$							
$\chi(x,0)$ [m]	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>			
175	1.4217E-04	3.2169E-04	1.9904E-03	6.3694E-03	9.0992E-03	9.6636E-01	9.2052E-01	1.8694E-01	3.4189E-01	1.3663E-02			
200	1.1795E-04	2.6539E-04	4.7181E-04	4.2463E-03	6.6348E-03	9.7063E-01	9.3512E-01	8.8758E-01	4.1189E-01	5.0728E-02			
300	4.1360E-05	1.1415E-04	2.0220E-04	1.8822E-03	2.6061E-03	9.9117E-01	9.7063E-01	9.4838E-01	6.8979E-01	2.9682E-01			
	$\chi/Q [s/m^3] = [1/\mu \sigma_y \sigma_z \pi] \times e^{-[1/2 (H/\sigma)^2]}$												
$\chi(x,0)$ [m]	<u>A</u>	<u>B</u>	<u>C</u>	<u>E</u>	<u>F</u>								
175	1.3739E-04	2.9612E-04	3.7209E-04	2.1777E-03	1.2433E-04								
200	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04								
300	4.0995E-05	1.1079E-04	1.9177E-04	1.2983E-03	7.7355E-04								

Dose to nearest residence in the case of normal operations (continued)

Ventilation ON dose to nearest residence using plume model							A 200	B 200	C 200	E 200	F 200
Nuclides	f_v [m ³ /s]	$f_{L(5\%)}$ [m ³ /s]	A [Ci]	C_0 [Ci/m ³]	Q_v [Ci/s]	$Q_{L(5\%)}$ [Ci/s]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]
Ar-41	2.83	0.0235		#VALUE!	#VALUE!	#VALUE!	1.1449E-04	2.4817E-04	4.1877E-04	1.7490E-03	3.3657E-04

A 200	B 200	C 200	E 200	F 200	DCF [rem/hr/Ci/m ³]	A 200	B 200	C 200	E 200	F 200
X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]		DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]
#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	8.1700E+02	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!

Ventilation OFF dose to nearest residence using plume model							A 200	B 200	C 200	E 200	F 200
Nuclides	f_v [m ³ /s]	$f_{L(5\%)}$ [m ³ /s]	A [Ci]	C_0 [Ci/m ³]	Q_v [Ci/s]	$Q_{L(5\%)}$ [Ci/s]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]	χ/Q [s/m ³]
Ar-41	2.83	0.0235		#VALUE!	#VALUE!	#VALUE!	1.1795E-04	2.6539E-04	4.7181E-04	4.2463E-03	6.6348E-03

A 200	B 200	C 200	E 200	F 200	DCF [rem/hr/Ci/m ³]	A 200	B 200	C 200	E 200	F 200
X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]	X_v [Ci/m ³]		DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]	DDE [rem]
#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	8.1700E+02	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!

Dose to nearest member of public in the case of normal operations

Dose to an individual at the fence line surrounding the reactor

Ventilation OFF (leakage) Normal Operations			
Gamma submersion dose at fence line			
Isotope	C_{avg} [Ci/m ³]	$E_{\gamma, avg}$ (MeV)	rem
Ar-41	TBD	1.293	TBD

Ventilation OFF (leakage) Normal Operations			
Beta submersion Dose at fence			
Isotope	C_{avg} [Ci/m ³]	$E_{\beta, avg}$ [MeV]	rem
Ar-41	TBD	0.253	TBD

Ventilation ON/OFF						
Beta Dose rate from the volume cloud inside the reactor at fence						
$D\beta = 1.1 \times E+3 C E_{\beta, avg}$ [mrad/hr]						
Isotope	$E_{\beta, avg}$ (keV)	mCi	C [μCi/g]	$\mu_{\beta, t}$ air	$e^{-\mu_{\beta, t}}$	Dsurf [mrad/hr]
Ar-41	0.253	TBD	TBD	13.25	1.755E-6	TBD

Ventilation ON/OFF										
Gamma Dose rate from the volume cloud inside the reactor at fence										
Nuclides	Γ [rem/hr/Ci/m ²]	$(r^2 + h^2)/h^2$	A [Ci]	Time [hr]	half-life [hr]	Avg _v [Ci/m ³] ON	linear energy absorption coeff m ⁻¹	Avg _v [Ci/m ³] OFF	Dose _v ON [rem]	Dose _t OFF [rem]
Ar-41	.69597	1.25	TBD	2000	1.83	TBD	3.5	TBD	TBD	TBD