

NRC FORM 195 (2-76)		U.S. NUCLEAR REGULATORY COMMISSION		DOCKET NUMBER 37-243	
NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL				FILE NUMBER INCIDENT REPORT	
TO: Mr. J.G. Keppler		FROM: NSP Minneapolis, Minn. 55401 L.O. Mayer		DATE OF DOCUMENT 7/22/77	
<input checked="" type="checkbox"/> LETTER <input type="checkbox"/> ORIGINAL <input checked="" type="checkbox"/> COPY		<input type="checkbox"/> NOTORIZED <input checked="" type="checkbox"/> UNCLASSIFIED		DATE RECEIVED 7-25-77	
		PROP		INPUT FORM	
				NUMBER OF COPIES RECEIVED 100	
DESCRIPTION Ltr trans the following: 1P <div style="text-align: center; font-size: 1.2em; font-weight: bold;"> ACKNOWLEDGED DO NOT REMOVE </div> PLANT NAME: Monticello Plant <div style="text-align: right;">DHL 7-26-77</div>			ENCLOSURE Licensee Event rept #77-16 concerning failure of a recombiner train off gas flow control valve to stay closed after receiving a trip signal due to dirt in valve seat & disc associated solenoid valve.... 1P (1 cy encl rec'd)		
FOR ACTION/INFORMATION					
BRANCH CHIEF:		DAVIS (7)			
W/3 CYS FOR ACTION					
LIC. ASST.:					
W/ CYS					
ACRS CYS HOLDING/SENT					
INTERNAL DISTRIBUTION					
REG FILE					
NRC PDR					
I & E (2)					
MIPC					
SCHROEDER/IPPOLITO					
HOUSTON					
NOVAK/CHECK					
GRIMES					
BUTLER					
HANAUER					
TEDESCO/MACCARY					
EISENHUT					
BAER					
SHAO					
VOLLMER/BUNGH					
KREGER/J. COLLINS					
EXTERNAL DISTRIBUTION					
LPDR: <i>Minneapolis, MN</i>				CONTROL NUMBER 772070019	
TIC:					
NSIC:					

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

July 22, 1977

Mr J G Keppler, Director, Region III
Office of Inspection & Enforcement
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Failure of A Recombiner Train Off Gas Flow Control
Valve (FCV-7489A) to Stay Closed After Receiving a Trip Signal

The Licensee Event Report for this occurrence is reproduced on the
back of this letter. Enclosed are three copies.

Yours very truly,

M R Voth / for

L O Mayer, PE
Manager of Nuclear Support Services

LOM/MHV/deh

cc: ← Director, IE, USNRC (40)
Director, MIPC, USNRC (3)
G Charnoff
MPCA
Attn: J W Ferman

Regulatory

File Cy.

772070019

