). Lanham)

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

September 27, 1977

Mr J G Keppler, Director, Region III Office of Inspection & Enforcement U S Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

Dear Mr Keppler:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Failure of LPCI Injection Valve, MO 2013

The Licensee Event Report for this occurrence is reproduced on the back of this letter. Enclosed are three copies.

Yours very truly,

L O' Mayer, PE V Manager of Nuclear Support Services

LOM/MHV/deh

cc: Director, IE, USNRC (30) Director, MIPC, USNRC (3) G Charnoff MPCA Attn: J W Ferman

> 772850069 SEP 2 9 1977

NRC FORM 195		U.S. NU	CLEAR RE	GULATORY CO	DOCKET NUMBER	
NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL					FILE NUMBER INCIDENT REPORT	
			rn States Pwr Co		DATE OF DOCUMENT 9-27-77	
		Minnea L O Ma	polis, yer	Mn	DATE RECEIVED 10-11-77	
	DRIZED	PROP		INPUT FORM	NUMBER OF COPIES RECEIVED	
COPY	LASSIFIED			· · · · ·	I CC	
DESCRIPTION			ENCLOS	JRE		
lp			con	cerning failure of	(RO# 77-22) on 8-28-77 LPCI injection valve MO failure	
				2. 2. 22 ⁴ eiαγ	and the formation	
lp				lp		
PLANT NAME: Monti	cèllo				• • • • • •••	
10-11-77 ehf						
	· · · · - ··	<u>.</u>			EXPOSURE IS INVOLVED Y TO KREGER/J. COLLINS Rec'd	
		FOR ACTION/				
BRANCH CHIEF:	DAU	is		<u>.</u>		
W/ 3 CYS FOR ACTION	Dige	15				
			 	1		
		<u>.</u>			<u></u>	
	· · · · · · · · · · · · · · · · · · ·	INTERNAL D	ISTRIBL	TION		
REG_FILE	· · · · · · · · · · · · · · · · · · ·					
NRC PDR			 			
I & E (2)	4	· · · ·				
MIPC		· · · ·			· · · · · · · · · · · · · · · · · · ·	
SCHROEDER/IPPOLITO	· · ·		ļ		· · · · · · · · · · · · · · · · · · ·	
HOUSTON				· · · · · · · · · · · · · · · · · · ·		
NOVAK/CHECK			 			
GRIMES						
KNIGHT	<u> </u>		┟──┼╌──		· · · · · · · · · · · · · · · · · · ·	
BUTLER				e		
HANAUER			┟──┟────	···· ·····		
TEDESCO	<u> </u>		┟ ───┤ · ────			
EISENHUT	· · · · · · · · · · · · · · · · · · ·		┞──			
BAER			↓			
SHAO	<u></u>		 			
VOLLMER/BUNCH						
KREGER/ J. COLLINS						
ROSA				с. Д		
				e "f		
	EXTERNAL	DISTRIBUTION			CONTROL NUMBER	
LPDR: MINNER	DOLIS 1	MINN.			(
TIC:					7	
	· • • • • • • • • • • • • • • • • • • •				-1	
ACRS (16) SENT AS					-	
AURS (10) SENT AS		, , , , , , , , , , , , , , , , ,	<u> </u>			
	+ +		<u>├</u>	······		

LICENSEE EVENT REPORT							
	ION)						
LICENSEE NAME 1 M N M N P 1 0 0 - 0 0 0 0 0 0 0 4 1 1 1 0 0 3 7 8 9 14 15 25 26 30 31 32							
CATEGORY REPORT TYPE REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT OATE 01 CON'T 1 1 0 5 0 0 2 6 3 0 8 2 8 7 7 0 9 2 7 7 7 8 57 58 59 60 61 68 69 74 75	7 80						
EVENT OESCRIPTION [D2] During test, MO-2013, "B" RHR injection value failed to open. "A" RHR system oper							
7 8 9 03 able at time of occurrence. One previous similar occurrence. Control relays in							
7 89 04 stalled in breaker to reduce control wire voltage drop. (M-RO-77-22). 7 89							
06 (80						
SYSTEM CAUSE COMPONENT CODE COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT COMPONENT VIOLATION 0 7 8 9 10 11 12 17 43 44 47 48 CAUSE OESCRIPTION							
OB A GE 7700 line motor control center "open" contactor did not close as required 7 8	80						
when given "open" signal. Control wire voltage drop during open signal prevented							
10 slightly worn contactor from closing. Control wire for this value approximately							
FACILITY STATUS % POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION 11 E 0 9 5 NA B NA	I						
7 8 9 10 12 13 44 45 46 FORM OF ACTIVITY CONTENT RELEASED AMOUNT OF ACTIVITY LOCATION OF RELEASE 1 2 2 NA NA	80						
7 8 9 10 11 44 45 PERSONNEL EXPOSURES	80						
NUMBER TYPE DESCRIPTION 13 0 0 2 NA 7 8 9 11 12 13	80						
PERSONNEL INJURIES NUMBER DESCRIPTION	1						
7 B 9 11 12 OFFSITE CONSEQUENCES	80						
15 NA 7 8 9	80						
LOSS OR OAMAGE TO FACILITY							
	80						
7 8 9 ADDITIONAL FACTORS	80						
18 (Cause Description Continued) twice as long as for other safety related valves.	80						
19 Control relays installed in breaker to reduce control wire voltage drop.	1						
7 8 9 7 8 9 7 NAME: Dean D Tilly PHONE: 612/295-5151	80						
GP0 881-	567						