

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240		See me about this. Note and return.	For concurrence. For signature.	For action. For information.
TO (Name and unit) RO Chief, FS&EB RO:HQ (4) Licensing (4) <u>DR Central Files</u> Region I		INITIALS	REMARKS Northern States Power Company 50-263 Monticello	
		DATE		
TO (Name and unit) Region II PDR Local PDR NSIC TIC		INITIALS	REMARKS	
		DATE		
TO (Name and unit) OGC, Beth 506A A. Roisman F. Rizzo, RO:HQ A/D for Info Processing, OOE		INITIALS	REMARKS	
		DATE		
FROM (Name and unit) G. Fiorelli RO:III		REMARKS Attached is a copy of licensee's reply dated November 18, 1974 to RO Bulletin 74-12.		
PHONE NO.	DATE 11-25-74			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469

AD ingram



NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401.

November 18, 1974

Mr J G Keppler, Regional Director
Directorate of Regulatory Operations
Region III
United States Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 61073

Dear Mr Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

In accordance with DRO Bulletin No. 74-12, this report is submitted to inform you that Westinghouse type SG 293-B 255 A20 relays supplied by ITE are not used at the Monticello Nuclear Generating Plant.

Yours very truly,

L J Wachter, Vice President,
Power Production & System Operation

LJW/ts

cc: J F O'Leary, Directorate of Licensing
G Charnoff
Minnesota Pollution Control Agency
Attention: Mr E A Pryzina

NOV 22 1974