



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

NOV 15 1974

Northern States Power Company  
ATTN: Mr. Leo Wachter  
Vice President  
Power Production and  
System Operation  
414 Nicollet Mall  
Minneapolis, Minnesota 54401

Docket No. 50-263

Gentlemen:

The enclosed RO Bulletin requests actions by you with regard to your boiling water reactor (BWR) facility with operating license.

Should you have questions regarding this Bulletin or actions requested of you, please contact this office.

Sincerely,

James G. Keppler  
Regional Director

Enclosure:  
RO Bulletin 74-14

bcc: ✓ DR Central Files  
RO Files  
PDR  
Local PDR  
OGC Beth, P-506A  
A. Rosiman

This request for generic information was approved by GAO under a blanket clearance number B-180225 (RO072); this clearance expires July 31, 1977.

*AS A*

November 15, 1974  
RO Bulletin 74-14

## BWR RELIEF VALVE DISCHARGE TO SUPPRESSION POOL

### Description of Circumstances:

Various BWR licensees have in the recent past, experienced unplanned actuation of reactor coolant system steam relief valves. These valves typically discharge to the suppression pool, where the discharge steam is quenched. With the suppression pool water at its normal temperature, the steam quenching proceeds in the expected manner. Extended discharge of a single relief valve, however, may raise the local temperature of the receiving water to a level at which the steam quenching becomes erratic and local pressure pulses of significant magnitude may be generated.

Past occurrences at several AEC licensed reactors have resulted in varying degrees of damage, such as baffle displacement and piping support damage. This damage has previously been attributed to a variety of causes; however, based upon more recent evaluations by the nuclear steam system supplier, General Electric Company, damage may have resulted from local pressure pulses as described above. Since only a limited number of temperature sensors are provided within the suppression pool, local temperature increases and resulting pressure pulses have not been specifically identified in past occurrences.

It appears that, during events in which relief valves cannot be closed promptly, primary attention by the operator may be directed under current procedures toward minimizing temperature and pressure transients in the reactor coolant system, without sufficient attention to the effects of extended steam discharge on the pressure suppression pool structure. This situation is currently under review by the Regulatory staff including consideration of whether revision to technical specifications may be required.

### Action Requested of Licensees:

1. Review your current operating procedures which are applicable to the situation discussed above, to determine whether they are adequate or should be modified in any of the following areas:
  - a. Limiting bulk suppression pool temperatures during normal operation and during controllable transients.

- b. Requiring reactor trip if the bulk suppression pool temperature exceeds that established as a limit for controllable transients or if relief valve(s) fails to reseal properly.
- c. Taking prompt steps in case of inadvertent relief valve actuation or failure to reseal, to minimize the duration of steam discharge to the suppression pool.
- d. In cases of relief valve discharge, promptly initiating suppression pool circulation to dissipate local peaking of water temperatures.
- e. Conduct of visual internal and external inspection of suppression pool structure for evidence of damage in instances where one or more relief valve(s) fails to reseal properly or discharges to the suppression pool for an extended period of time.

During this review, the various aspects of plant operations should be considered so that procedural changes designed to minimize the effect of steam discharge to the suppression pool do not have an adverse effect in other areas.

2. Report to this office in writing within 20 days of receipt of this Bulletin the results of your procedural review and any changes you have made or plan to make in your operating procedures, including the date when such changes were or will be completed.