CONTROL NO: 9313

PROP INFO currence submit mation concernation pumps.	DATE OF DOC 9-6-74 ORIG 1 signed INPUT		PILE: LTR TWX RPT XX SENT AEC PDR SENT LOCAL PE DOCKET NO: 50-263 CKNOWLEDGED	
PROP INFO	9-6-74 ORIG 1 signed INPUT	9-10-74 CC OTHER NO CYS REC'D 1 ENCLOSURES:	SENT AEC PDR SENT LOCAL PE DOCKET NO: 50-263	XXXX
PROP INFO	9-6-74 ORIG 1 signed INPUT	9-10-74 CC OTHER NO CYS REC'D 1 ENCLOSURES:	SENT AEC PDR SENT LOCAL PE DOCKET NO: 50-263	XXXX
PROP INFO	ORIG 1 signed INPUT	CC OTHER NO CYS REC'D 1 ENCLOSURES:	SENT AEC PDR SENT LOCAL PE DOCKET NO: 50-263	
PROP INFO	ORIG 1 signed INPUT	CC OTHER NO CYS REC'D 1 ENCLOSURES:	SENT AEC PDR SENT LOCAL PE DOCKET NO: 50-263	
PROP INFO	l signed INPUT	NO CYS REC'D 1 ENCLOSURES:	SENT LOCAL PEDOCKET NO: 50-263	
PROP INFO	l signed INPUT	NO CYS REC'D 1 ENCLOSURES:	SENT LOCAL PEDOCKET NO: 50-263	
currence submit mation concern tion pumps.	INPUT	1 ENCLOSURES:	DOCKET NO: 50-263	
currence submit mation concern tion pumps.	ted on 5-31-74	1 ENCLOSURES:	50-263	
rmation concern tion pumps.	ted on 5-31-74 ling cracked	ENCLOSURES:		
rmation concern tion pumps.	ted on 5-31-74 ling cracked	A	CKNOWLEDGED	
rmation concern tion pumps.	ted on 5-31-74 ling cracked	A	CKNOWLEDGED	
rmation concern tion pumps.	ing cracked		CKNUWLEDGED	
tion pumps.				
• ≥11o			•	
• 110	•	•		
ello				
· •11o		מ	O NOT REMOVE	-
2110		יט	7 HOT WEIGHT	•
			· .	
		•		
	FOR ACTION/IN	FORMATION 9-	10-74 ehf	
Cureycen (1)	brever 1	\		
• •				
	•		i e	
• •				
		W/ CYS		•
• •	,			
; •				
- +		• •		
CYS	W/ CYS	W/ CYS		
	INTERNAL DISTRI	BUTION		
TECH REVIEW	DENTON	LIC ASST	· A/T IND	
40.000	GRIMES		BRAITMAN	
	GAMMILL		SALTZMAN	
	KASTNER		(L) B. HURT	
	BALLARD		E)	
	SPANGLER	LEE (L)	PLANS	
		MAIGRET (L) MCDONALD	
	ENVIRO	REED (E)	CHAPMAN	
	MULLER	SERVICE (L		t
,	DICKER		- · · · · · · · · · · · · · · · · · · ·	
ROSS -	KNIGHTON	SLATER (E)		ř
IPPOLITO	YOUNGBLOOD	SMITH (L)	JD. THOMPSON	(2)
TEDESCO	REGAN		JKLECKER	\ - /
LONG				
LAINAS		- · · · · ·	-, - Descript	
BENAROYA	HARLESS			
VOLLMER				
Ε	XTERNAL DISTRIE	BUTION		- D
apolis, MN	1/01//-1			0
apolis, MN) (1)(2)(10)-NATION	MAL LABS (E/W Bldg, Rm 52	1-PDR-SAM/LA/ 1-BROOKHAVEN	
	TECH REVIEW SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO LONG LAINAS BENAROYA	CYS FOLZ (L) FOLZ (E) FOLZ (L) FOLZ (E) FOLZ (L) FOLZ (E) FOLZ (E) FOLZ (L) FOLZ (E) FOL	CYS FOLZ (L) DICKER (E) LEAR CYS W/ CYS INTERNAL DISTRIBUTION TECH REVIEW DENTON GRIMES GRIMES JOIGGS (L) SCHROEDER GAMMILL GEARIN (L) MACCARY KASTNER GOULBCURNE KNIGHT BALLARD KREUTZER (PAWLICKI SPANGLER LEE (L) SHAO STELLO HOUSTON MULLER STELLO HOUSTON MULLER SERVICE (L NOVAK DICKER SHEPPARD (I NOVAK SH	CYS FOLZ (L) DICKER (E) LEAR CYS W/ CYS INTERNAL DISTRIBUTION TECH REVIEW GRIMES DIGGS (L) BRAITMAN SCHROEDER GRIMES DIGGS (L) SCHROEDER GAMMILL GEARIN (L) SALTZMAN MACCARY KASTNER GOULBCURNE (L) KNIGHT BALLARD KREUTZER (E) PAWLICKI SPANGLER LEE (L) PLANS SHAO MAIGRET (L) MCDONALD STELLO HOUSTON MULLER SERVICE (L) MODONALD HOUSTON MULLER SERVICE (L) NOVAK DICKER SHEPPARD (L) E. COUPE ROSS KNIGHTON SLATER (E) LIPPOLITO YOUNGBLOOD SMITH (L) TEDESCO REGAN TEETS (L) KLECKER LAINAS BENAROYA HARLESS

1-CONSULTANTS

MPERSON /DIEME COMPARTAN

1 - Newton Anderson

5 - ACRS SENT TO LIC ASST PIGGS

Company of the Commence

1-B&M SHINEBROAD, Rm E-201 GT 1-AGMED (RUTH GUSSMAN)

Rm B-127 GT


NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

September 6, 1974

Mr. J F O'Leary, Director Directorate of Licensing Office of Regulation U S Atomic Energy Commission Washington, DC 20545





Dear Mr. O'Leary:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Additional Information Concerning Cracked Studs on Recirculation Pumps

Following submittal of our May 31, 1974 letter, additional information became available concerning reactor recirculation pump stuffing box holddown cover studs. This information was subsequently reviewed by Regulatory Operations inspectors during an inspection conducted on July 16-18, 1974. At that time it was agreed to submit the information to your office.

The following information is submitted in accordance with that agreement:

- 1. Abnormal sensitivity to stress corrosion can result if the stud material, ASTM A 193, Grade B6 Type 410 martensitic stainless steel, is improperly heat treated or tempered. Characteristic data from material suppliers indicate that the hardness for hardened and tempered (1100°F) 410 martensitic stainless steel should range from Rockwell C20 to C28. The hardness readings for the failed studs were in the range of Rockwell C31 to C32.
- 2. Two sets of stuffing box holddown cover stude have been ordered from the manufacturer having the following specifications:
 - a. Maximum hardness Rockwell C25.
 - b. Rolled threads.
 - c. 110 Kpsi minimum tensile strength.
 - d. No elongation hole.
 - e. Material heat number to be indicated on the end of each stud.

Mr. J F O'Leary September 6, 1974 Page 2

- 3. Hardness value of each stud will be verified by NSP upon receipt.
- 4. It is planned to replace the existing studs during the Fall 1975 refueling outage. It is also planned at that time to subject the existing studs to non-destructive examination to detect any deterioration.

Yours very truly,

L O Mayer, PE

Director of Nuclear Support Services

LOM/kn

cc: J G Keppler

G Charnoff Minnesota Pollution Control Agency

Attn. E A Pryzina