

FROM: Northern States Power Company Minneapolis, Minnesota C. E. Larson		DATE OF DOC 5-28-74	DATE REC'D 5-31-74	LTR	MEMO	RPT	OTHER TWX
TO: J. G. Keppler		ORIG 1	CC	OTHER	SENT AEC PDR SENT LOCAL PDR		XXX XXX
CLASS UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-263		

DESCRIPTION:
Twx furn info re abnormal occurrence in which Loop 12 torus cooling injection valve (MO 2009) breaker tripped on overload when attempting to close the valve

ENCLOSURES:

ACKNOWLEDGED
DO NOT REMOVE

PLANT NAME: MONTICELLO

FOR ACTION/INFORMATION 6-1-74 GMC

BUTLER(L) W/ Copies	SCHWENCER(L) W/ Copies	✓ ZIEMANN(L) W/ 7 Copies	REGAN(E) W/ Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	DICKER(E) W/ Copies	W/ Copies
PARR(L) W/ Copies	VASSALLO(L) W/ Copies	KNIGHTON(E) W/ Copies	W/ Copies
KNIEL(L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD(E) W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

✓ REG FILE ✓ AEC PDR ✓ OGC, ROOM P-506A ✓ MUNTZING/STAFF ✓ CASE GIAMBUSO BOYD MOORE (L)(BWR) DEYOUNG(L)(PWR) SKOVHOLT (L) ✓ GOLLER(L) P. COLLINS DENISE REG OPR ✓ FILE & REGION(3) ✓ MORRIS	TECH REVIEW ✓ HENDRIE SCHROEDER ✓ MACCARY ✓ KNIGHT ✓ PAWLICKI ✓ SHAO ✓ STELLO ✓ HOUSTON ✓ NOVAK ✓ ROSS ✓ IPPOLITO ✓ TEDESCO ✓ LONG ✓ LAINAS ✓ BENAROYA ✓ VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR HARLESS	LIC ASST ✓ DIGGS (L) GEARIN (L) GOULBOURNE (L) LEE (L) MAIGRET (L) REED (E) SERVICE (L) SHEPPARD (L) SLATER (E) SMITH (L) TEETS (L) WADE (E) WILLIAMS (E) WILSON (L)	A/T IND BRAITMAN SALTZMAN B. HURT PLANS MCDONALD DUBE w/Input INFO C. MILES ✓ KLECKER EISENHUT ✓ AOR FILE D. THOMPSON (2)
--	--	--	--	---


EXTERNAL DISTRIBUTION

✓ 1 - LOCAL PDR MINNEAPOLIS, MINN	(1)(2)(10)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
1 - TIC (ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
1 - NSIC(BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB	1-CONSULTANT'S	1-ACMED(Ruth Gussman)
1 - P. R. DAVIS (AEROJET NUCLEAR)	NEWMARK/BLUME/AGBABIAN	RM-B-127, GT.
✓ 16 - CYS ACRS HOLDING	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT
Sent to Lic Asst Diggs 6-3-74	1-B & M SWINEBROAD, Rm E-201 GT	



NORTHERN STATES POWER COMPANY
Monticello, Minnesota 55362

May 28, 1974



Mr. J. G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
United States Atomic Energy Commission
799 Roosevelt Road
Glen Bllyn, Illinois 61073

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

While performing a routine R-R System surveillance test on May 27, 1974, Loop 12 torus cooling injection valve (MD 2009) breaker tripped on overload when attempting to close the valve. The valve was closed following completion of the surveillance test.

An investigation into the cause of the problem is continuing.

Yours very truly,

C. E. Larson
C. E. Larson
Plant Manager

CEL/nmm

cc: J F O'Leary, Directorate of Licensing
G Charnoff
Minnesota Pollution Control Agency
Attn: B A Pryzina
File

Copies sent by telecopier to Keppler and O'Leary

