DOC.DATE: 80/03/07 NOTARIZED: NO ACCESSION NBR:8003170451 FACIL:50-263 Monticello Nuclear Generating Plant, Northern States 05000263

DOCKET #

AUTH. NAME ELIASON, L.R.

AUTHOR AFFILIATION Northern States Power Co.

RECIP.NAME KEPPLER, J.G.

29 ACRS

RECIPIENT AFFILIATION

Region 3, Chicago, Office of the Director

SUBJECT: RO:on 800307,1980 local leak rate testing of torus instrument air isolation valve CV-7956 indicated that leakage exceeded acceptance criteria for individual

isolation valves. Cause under investigation.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR / ENCL O SIZE: TITLE: Incident Reports

NOTES:____ COPIES RECIPIENT COPIES RECIPIENT ID CODE/NAME LTTR ENCL ID CODE/NAME 05 BC ORB 对3 LTTR ENCL ACTION: INTERNAL: REG FILE 02 NRC PDR 3 11 MPA 15 NOVAK/KNIEL 1 14 TA/EDO 17 AD FOR ENGR 1 16 EEB . 19 I&C SYS BR 18 PLANT SYS BR 22 REAC SAFT BR 20 AD PLANT SYS 1 24 KREGER 1 23 ENGR BR 26 AD/SITE ANAL 25 PWR SYS BR 1 1 28 ACDENT ANLYS 27 OPERA LIC BR AD/ORP-DOR 1 29 AUX SYS BR DOUG MAY-TERA AEOD IRELAND, R. 1 HANAUER, S. JORDAN, E./IE 1 04 NSIC EXTERNAL: 03 LPDR 1

16

16

NSP

NORTHERN STATES POWER COMPANY

Monticello Nuclear Generating Plant Monticello, Minnesota 55362

March 7, 1980

Mr. J. G. Keppler, Director Region III Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

On March 7, 1980 local leak rate testing of the Torus Instrument Air isolation valve, CV-7956, indicated that the leakage exceeded the acceptance criteria for individual isolation valves as defined by Technical Specification 4.7.A.2.f.

The cause of the high leakage rate is being investigated.

Yours very truly,

L. R. Eliason Plant Manager

LRE/kik

cc: Director, Office of Management Information and Program Control File

Copy sent by telecopy to Keppler.

1/03/10