

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8004150543 DOC. DATE: 80/04/08 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MAYER, L.O. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 KEPPLER, J.G. Region 3, Chicago, Office of the Director

SUBJECT: Forwards LERs 80-002/01T-0, 80-003/01T-0, 80-004/01T-0,
 80-005/01T-0, 80-008/01T-0, 80-009/01T-0, 80-010/01T-0,
 80/012/01T-0 & 80-014/01T-0.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+10
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	05 BC <u>ORB 3</u>	4	4			
INTERNAL:	<u>01 REG FILE</u>	1	1	02 NRC PDR	1	1
	09 IRE	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANLYS	1	1
	29 AUX SYS BR	1	1	AD/DRP-DOR	1	1
	AEOD	10	10	BERLINGER, C.	3	3
	DOUG MAY-TERA	1	1	HANAUER, S.	1	1
	JORDAN, E./IE	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

APR 18 1980



A0/I
4

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

April 8, 1980

Mr J G Keppler
Office of Inspection & Enforcement
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Failure of Nine Containment Isolation Valves
to Pass Local Leak Rate Tests

Attached are nine Licensee Event Reports for valves which were found to exceed the Technical Specification leakage limits. Following discussion with your office, all of these Event Reports are being submitted within 14 days of completing repairs to the last valve.

These events are being reported in accordance with Technical Specification 6.7.B.1.c since they represent the discovery of valve leakage in excess of Technical Specification limits. The valve failures would not have led to a loss of containment integrity in the event of an accident.

Yours very truly,

Dain Musolf for

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DMM/ak

cc: Director, IE, USNRC (40)
Director, MIPC, USNRC (3)
MPCA
Attn: J W Ferman

Attachments

A002
S
1/1

8004150 543