## JUL 2 9 1977

1.10

a a prima sua a

Docket No. 50-263

Northern States Power Company ATTN: Mr. Leo Wachter Vite President Power Production and System Operation 414 Nicollet Mall Minneapolis, MN 55401

Gentlemen:

.

Thank you for your letter dated July 20, 1977, informing us of the steps you have taken to correct the noncompliance identified in our letter dated July 6, 1977. We will examine your corrective action during a future inspection.

1.12

÷1. ••

Your cooperation with us is appreciated.

Sincerely,

ĺ,	James	м.	A11	lan,	Chi	lef
	Fuel 1	Fac:	1111	ty a	nđ	
~	Mate	eria	als	Saf	ety	Branch

## cc: Mr. L. R. Eliason, Flant Manager

cc w/ltr dtd 7/20/77: Central Files Reproduction Unit NRC 20b PDR Local PDR NSIC TIC Anthony Roisman, Esq., Attorney

OFFICE	RIII	RIII WX-1	RIII	RIILON					
• BURNAME	Miller/jb	_	Allan-MA	Choules,					
DATE					<i>.</i>				

NRC FORM 318 (9-76) NRCM 0240

4

A U. S. GOVERNMENT PRINTING OFFICEI 1978 - 626-624



## NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

July 20, 1977

Mr. James M. Allan, ChiefFuel Facility and Materials Safety BranchRegion IIIU. S. Nuclear Regulatory Commission799 Roosevelt RoadGlen Ellyn, Illinois 60137

Dear Mr. Allan:

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Your letter of July 6, 1977, identified one item which appeared to be in noncompliance with NRC requirements and requested that we reply within 20 days of the receipt of your letter. The non-compliance, as stated, was:

Contrary to Technical Specification 6.5 and Section E.1.4.III.C.1 of the Operations Manual, Portable Dose Rate Survey Instruments were being calibrated annually.

Approximately six months ago, an evaluation of our portable survey instrument calibration and test program indicated that an annual calibration schedule would be more suitable than the semi-annual schedule existing at that time. The monthly functional tests indicated that the instruments had maintained their calibration over a long period of time. The functional tests will indicate the need for instrument recalibration if it is required prior to the annual calibration. The Computer Program was changed to provide for an annual calibration schedule; however, the description of our calibration program in Section E.1.4.III.C.1 of the Operations Manual was not revised to reflect the change to an annual calibration schedule.

The Operations Manual is presently being revised to indicate that the calibrations are performed on an annual basis. It is expected that the revision will be distributed by July 29, 1977. This will allow full compliance with the requirement that our portable survey instrument calibration program be in agreement with the description contained in the Operations Manual.

Should you have any questions concerning our response, please communicate directly with the plant management.

Yours very truly,

S. J Hashter J. Wachter

Vice President - Power Production and System Operation

JUL 2 2 1977

cc: Mr. Victor Stello Mr. G. Charnoff Minnesota Pollution Control Agency Attention: Mr. J. W. Ferman