

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 7943
FILE: REPORTS FILE

FROM: Northern States Power Co. Minneapolis, Minnesota L.O. Mayer		DATE OF DOC 7-25-75	DATE REC'D 7-28-75	LTR XXX	TWX	RPT	OTHER
TO: A. Giambusso		ORIG NONE	CC	OTHER	SENT AEC PDR <u>XXX</u> SENT LOCAL PDR <u>XXXX</u>		
CLASS	UNCLASS XXX ^X	PROP INFO	INPUT	NO CYS REC'D 40	DOCKET NO: 50-263		
DESCRIPTION: Correction no. 1 to Semiannual Operating Report # 8...covering period of June 1 to Dec. 31, 1974				ENCLOSURES:			
PLANT NAME: Monticello							

ACKNOWLEDGED
DO NOT REMOVE

FOR ACTION/INFORMATION

VCR 7-28-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies	*NOTE: 3 CYS OF THIS PACKAGE ARE FOR DIST TO EPA WITH THE FOLLOWING BREAKDOWN: 2 CYS EPA HDQS; 1 CY EPA REGION.
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies	
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPELS W/ Copies	
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies		
			W/ Copies	

INTERNAL DISTRIBUTION

<u>REG FILE</u> NRC PDR	TECH REVIEW SCHROEDER	DENTON GRIMES	LIC ASST R. DIGGS (L)	A/T IND. BRAITMAN
OGC, ROOM P-506A	MACCARY	GAMMILL	H. GEARIN (L)	SALTZMAN
GOSSICK/STAFF	KNIGHT	KASTNER	E. GOULBOURNE (L)	MELTZ
CASE	PAWLICKI	BALLARD	P. KREUTZER (E)	
GIAMBUSSO	SHAO	SPANGLER	J. LEE (L)	PLANS
BOYD	STELLO		M. RUSHBROOK (L)	MCDONALD
MOORE (L)	HOUSTON	ENVIRO	S. REED (E)	CHAPMAN
DEYOUNG (L)	NOVAK	MULLER	M. SERVICE (L)	DUBE (Ltr)
SKOVHOLT (L)	ROSS	DICKER	S. SHEPPARD (L)	E. COUPE
GOLLER (L) (Ltr)	APPOLITO	KNIGHTON	M. SLATER (E)	PETERSON
P. COLLINS	TEDESCO	YOUNGBLOOD	H. SMITH (L)	HARTFIELD (2)
DENISE		REGAN	S. TEETS (L)	KLECKER
REG OPR	LAINAS	PROJECT LDR	G. WILLIAMS (E)	EISENHUT
FILE & REGION (2)	BENAROYA		V. WILSON (L)	WIGGINTON
MIPC/PE (u)	VOLLMER	HARLESS	R. INGRAM (L)	HANAUER
STEELE	J. COLLINS		M. DUNCAN (E)	

EXTERNAL DISTRIBUTION

(MIA) 2-ll

- 1 - LOCAL PDR *Minneapolis Minn.*
- 1 - TIC (ABERNATHY) (1)(2)(4) - NATIONAL LABS
- 1 - NSIC (BUCHANAN) 1 - W. PENNINGTON, Rm E-201 GT
- 1 - ASLB 1 - CONSULTANTS
- 1 - Newton Anderson NEWMARK/BLUME/AGBABIAN
- 17 - ACRS HOLDING/SENT *Biggs*
- 1 - PDR-SAN/LA/NY
- 1 - BROOKHAVEN NAT LAB
- 1 - G. ULRIKSON, ORNL
- 1 - AGMED (RUTH GUSSMAN) Rm B-127 GT
- 1 - J. D. RUNKLES, Rm E-201 GT

NSP**NORTHERN STATES POWER COMPANY**

MINNEAPOLIS, MINNESOTA 55401

Mr A Giambusso, Director
 Division of Reactor Licensing
 U S Nuclear Regulatory Commission
 Washington, DC 20555

Dear Mr Giambusso:

MONTICELLO NUCLEAR GENERATING PLANT
 Docket No. 50-263 License No. DPR-22

Correction No. 1 to Semiannual Operating Report #8

Monticello Semiannual Operating Report #8 covering the period of June 1 to December 31, 1974 should be corrected as follows:

- 1) Item V.A.2.a, I-135 for September, change to 0.33 Ci. Change total I-135 to 4.25 Ci.
- 2) Items V.A.3.b through V.A.3.d, alpha and particulates, change to read:

b. Gross alpha radioactivity released (Curies)

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
1.5 x 10 ⁻⁶	2.4 x 10 ⁻⁶	2.7 x 10 ⁻⁶	3.3 x 10 ⁻⁶	4.0 x 10 ⁻⁶	3.7 x 10 ⁻⁶	1.8 x 10 ⁻⁵

c. Total Gross radioactivity released of nuclides of greater than an 8 day half life (Curies)

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
3.6 x 10 ⁻³	4.1 x 10 ⁻³	4.6 x 10 ⁻³	6.2 x 10 ⁻³	7.5 x 10 ⁻³	1.2 x 10 ⁻³	3.8 x 10 ⁻²

d. Percent of Technical Specification limit for particulates with greater than an 8 day half-life.

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
0.966	1.40	1.74	1.63	2.30	3.76	1.92

Punched corrected page V-1/V-2 is attached.

Yours very truly,



L O Mayer
 L O Mayer, PE
 Manager of Nuclear Support Services

LOM/DMM/ak

cc: J G Keppler
 G Charnoff

Minnesota Pollution Control Agency
 Attn: J W Ferman

Attachment



7943

V. Radioactive Effluent Releases

A. Gaseous Effluents

1. Gross Radioactive Release

a. Total gross radioactivity (Curies)

	<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
	178990	166226	183686	215680	49664	32212	826458

b. Maximum gross radioactivity release rate in any one hour period (uci/sec)

	<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
	101390	100392	123346	121359	97255	10331	-

c. Total gross radioactivity by nuclide (Curies)

	<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
Kr ⁸⁵	878	831	953	1224	702	1347	5935
Xe ¹³³	16551	17199	20096	23998	11886	16455	106185
Kr ⁸⁸	21267	21098	20933	24702	3828	541	92369
Kr ⁸⁷	21785	23472	26491	34184	4399	23	110354
Kr ^{85m}	11038	10807	10651	11693	1796	694	46679
Xe ¹³⁸	32222	33061	35082	39400	5740	833	146338
Xe ¹³⁵	35278	55741	61450	70686	20088	12325	255568
Ar ⁴¹	x	x	x	x	x	x	x

d. Percent of Technical Specification limit

	<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
	21.9	25.4	28.1	26.4	7.6	4.9	19.5

2. Iodine Releases

a. Total iodine radioactivity by nuclide (Curies)

	<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
I ¹³¹	1.17	0.754	0.655	0.580	0.485	0.118	3.76
I ¹³³	2.56	1.57	1.18	1.24	0.514	0.296	7.36
I ¹³⁵	1.91	0.721	0.33	0.66	0.197	0.429	4.25

Revised 7-25-75

b. Percent of Technical Specification limit of I¹³¹

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
73.2	73.1	63.9	46.3	44.3	39.8	56.8

3. Particulate Releases

a. Gross radioactivity (β, γ) released (Curies)

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
2.2×10^{-2}	2.81×10^{-2}	5.67×10^{-2}	1.19×10^{-1}	5.56×10^{-2}	7.75×10^{-2}	0.359

b. Gross alpha radioactivity released (Curies)

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
1.5×10^{-6}	2.4×10^{-6}	2.7×10^{-6}	3.3×10^{-6}	4.0×10^{-6}	3.7×10^{-6}	1.8×10^{-5}

c. Total gross radioactivity released of nuclides of greater than an 8 day half life (Curies)

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
3.6×10^{-3}	4.1×10^{-3}	4.6×10^{-3}	6.2×10^{-3}	7.5×10^{-3}	1.2×10^{-2}	3.8×10^{-2}

d. Percent of Technical Specification limit for particulates with greater than an 8 day half-life.

<u>July</u>	<u>August</u>	<u>September</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>Total</u>
0.966	1.40	1.74	1.63	2.30	3.76	1.92

B. Liquid Effluents

1. No liquid effluent releases were made during the six month reporting period.

x - Unidentified and/or undetectable.

Revised 7-25-75