

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: Mr. D. L. Ziemann

FROM: NSP
Minneapolis, Minn. 55401
L.O. Mayer

DATE OF DOCUMENT
5-7-76

DATE RECEIVED
5-11-76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED
40 cys

DESCRIPTION Ltr furn addl info on feedwater
nozzle inspection re our 4-6-76 ltr....

PLANT NAME: Monticello Plant

ENCLOSURE

~~Do Not Remove~~

ACKNOWLEDGED

SAFETY

FOR ACTION/INFORMATION

ENVIRO

DHL 5-12-76

ASSIGNED AD :

ASSIGNED AD :

BRANCH CHIEF : (6) **ZIEMANN**
PROJECT MANAGER: **SNRIDER**
LIC. ASST. : **Diggs**

BRANCH CHIEF :
PROJECT MANAGER :
LIC. ASST. :

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	ENVIRO TECH
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ERNST
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BENAROYA	BALLARD
OELD		LAINAS	SPANGLER
<input checked="" type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	
MIPC	MACCARY		SITE TECH
CASE	KNIGHT	OPERATING REACTORS	GAMMILL
HANAUER	SIHWEIL	STELLO	STEPP
HARLESS	PAWLICKI		HULMAN
		OPERATING TECH	
PROJECT MANAGEMENT	REACTOR SAFETY	<input checked="" type="checkbox"/> EISENHUT	SITE ANALYSIS
BOYD	ROSS	<input checked="" type="checkbox"/> SHAO	VOLLMER
P. COLLINS	NOVAK	<input checked="" type="checkbox"/> BAER	BUNCH
HOUSTON	ROSZTOCZY	<input checked="" type="checkbox"/> SCHWENCER	<input checked="" type="checkbox"/> J. COLLINS
PETERSON	CHECK	<input checked="" type="checkbox"/> GRIMES	KREGER
MELTZ			
HELTEMES	AT & I	SITE SAFETY & ENVIRO	
SKOVHOLT	SALTZMAN	ANALYSIS	
	RUTBERG	DENTON & MULLER	

EXTERNAL DISTRIBUTION

CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: Minneapolis, Minn.	NATL LAB	BROOKHAVEN NATL LAB
<input checked="" type="checkbox"/> TIC	REG. V-IE	ULRIKSON(ORNL)
<input checked="" type="checkbox"/> NSIC	LA PDR	
ASLB	CONSULTANTS	
<input checked="" type="checkbox"/> ACRS 16 [redacted] SENT	TO L.A.	

4730

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

May 7, 1976

Mr D L Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors
U S Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr Ziemann:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Feedwater Nozzle Inspection

This letter is in response to your April 6, 1976 request for information on feedwater nozzle inspections. The requests are repeated below with our responses:

NRC Request # 1

Provide date of next planned inspection.

Response:


An in-service inspection program including the feedwater nozzle internal surfaces using an underwater television camera is planned for the next refueling outage which is currently scheduled for the Fall of 1977.

NRC Request # 2

Provide the number of startup/shutdown cycles to the date of inspection already accomplished, and the number of cycles since such inspection. Provide the estimated number of cycles at the next plant inspection date. A startup/shutdown cycle is defined as a power increase from zero and subsequent return to zero.

Response:

Two cold startup/shutdown cycles have occurred in addition to the 95 cycles reported in the first ten Monticello Semi-Annual Operating Reports for a total of 97 cycles to date. Two of these occurred since



NORTHERN STATES POWER COMPANY

D L Ziemann

-2-

May 7, 1976

the November, 1975 feedwater nozzle inspection; 95 preceeded the inspection. Based on past experience, we estimate three additional cycles between now and the subsequent inspection for accumulated total of 100 cycles at the time of the next inspection.

NRC Request # 3

Describe actions taken or planned to minimize cold, intermittent feedwater flow to the reactor pressure vessel. Include changes in operating procedures and any redesign of feedwater heaters, pumps, flow control valves, piping, etc.

Response:

Three changes have been made which minimize cold, intermittent feedwater flow to the reactor vessel. First, system improvements have been made which improve feedwater flow control and reactor water level control during transient and low power operation. Such improvements include the installation of the lead-lag compensation network in the three element controller (feedwater flow/steam flow/reactor vessel level) and the addition of an automatic controller on the feedwater low flow regulating valve as discussed in Monticello Semi-Annual Operating Report Numbers 6 and 7. Second, the original feedwater spargers have been replaced with a new design having an interference fit with the vessel feedwater nozzle so as to minimize cold feedwater flow over the nozzle blend radius. Third, plant operation is much more stable at this time in history, reducing the number of cold startup/shutdown cycles drastically. (In the past two years, there have been eight cold startup/shutdown cycles, including three refueling outages, for an average of 2½ unplanned cycles per year compared to 20 per year for the preceeding years.)

NRC Request # 4

Describe the reactor pressure vessel pressure-temperature limits for operating conditions and especially for the inservice hydrostatic and leak tests.

Response:

The reactor vessel temperature-pressure limitations are found in Monticello Technical Specification 3.6.B.

Yours very truly,



L O Mayer, PE
Manager, Nuclear Support Services

LOM/deb

cc: J G Keppler
G Charnoff
MPCA--Attn: J W Ferman