

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

NRC FORM 195
(2-75)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-263

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: Mr. Victor Stello

FROM: NSP
Minneapolis, Minnesota 55401
L. O. Mayer

DATE OF DOCUMENT
10/31/77

DATE RECEIVED
11/03/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

3 signed 3 rec

DESCRIPTION

ENCLOSURE

Consists of information concerning Documentation of Basis for Continued Operation Swquential SRV Acutations of Isolation Events... Notorized 10/31/77.....

3p

16p

PLANT NAME: MONTICELLO

jcm 11/03/77

40 CYS ENCL Rec'd

SAFETY

FOR ACTION/INFORMATION

BRANCH CHIEF: (7)

DAVIS

INTERNAL DISTRIBUTION

REG FILE

NRC PER

I & E (2)

OELD

HANAUER

CHECK

~~XXXXXXXX~~

EISENHUT

SHAO

BAER

BUTLER

GRIMES

J. COLLINS

J. McGOUGH

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LFDR: **MINNEAPOLIS, MN.**

TIC

NSIC

16 CYS ACRS SENT CATEGORY **B**

NSP REGULATORY DOCKET FILE COPY

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

October 31, 1977

Mr Victor Stello
Division of Operating Reactors
U S Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr Stello:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 263 License No. DPR-22

Documentation of Basis for Continued Operation
Sequential SRV Actuations of Isolation Events

At the request of the NRC Staff, the Mark I Owners Group and General Electric representatives met with the NRC Staff October 27, 1977 to discuss potential influence on Mark I containments of SRV sequential actuations associated with isolation events. In that meeting General Electric presented a preliminary evaluation using most probable loads basis and short term program acceptance criteria for all operating plants.

At the conclusion of the October 27 meeting, Staff requested documentation of the basis for continued operation and requested consideration of commitments to operational procedures to reduce the probable incidence of SRV multiple-valve sequential actuations, said documentation to be submitted by November 1, 1977. Further, NRC Staff indicated an intent to formally request that a plant-unique assessment be provided within 60 to 90 days, with such assessment to be based on the conservative General Electric dynamic model prediction of sequential multiple-valve actuations, application of conservative factors for correlation of multiple and consecutive valve actuation effects, and use of the short term program acceptance criteria.

This submittal is believed to provide all of the requested information, including that which Staff indicated may be required within 60 to 90 days.

The Monticello plant has eight safety relief valves with all setpoints at approximately 1068 psig. All valves are by Target Rock. Each SRV discharge line has a recorded temperature monitor, a pressure switch monitor, a two inch vacuum breaker valve, and an eight inch vacuum breaker valve. All vacuum breaker setpoints are adjusted to be equal to or less than 0.2 psi. The pressure switch monitor setpoints are approximately 5 psig and provide input to the plant computer sequence-of-events monitor for specific discrimination of SRV actuations and closures.



Mr Victor Stello
Page 2
October 31, 1977

Monticello Plant-Unique Transient Analysis

The purpose of using the transient analysis model was to predict the number of SRV's which might participate in multiple valve consecutive actuations for Monticello isolation events. The results of this analysis indicate that all eight SRV's will open and close in perfect unison for all initial and subsequent actuations, independent of the magnitude of demand for over-pressure relief capacity generated by the mass-energy transient of the isolation event.

In the Monticello case this is neither a prediction nor an analysis result. It is the consequence of model assumptions that valves of like nominal setpoint, specification and manufacture will perform with exactly identical characteristics for every actuation of every valve.

Qualification testing of Target Rock valves have demonstrated significant variations, within the limits of specified performance, for pilot actuation delay time and main disc stroke time. Because of the variability of and relation between these two characteristics, it is quite possible for the transient pressure to exceed the effective setpoint of all valves and have the pressure reduced below this level by the first-to-open valve, with no other valves actually actuating. Two isolation events from full rated power have occurred at Monticello. In both cases only a single valve opened for even the initial actuation when all valves were adjusted to the same nominal setpoint. From this experience we must conclude that single valve actuation is the typical characteristic, and that the all-valves, multiple actuation, resulting from the model assumptions is the remotely probable event.

Attachment C provides a summary of four isolation events which have occurred at Monticello since initial operation. For your understanding, Attachment C also includes a summary of relevant design changes and procedure changes since initial operation.

Although the transient analysis model grossly over-predicts consecutive multiple-valve actuation of all eight SRV's, compared to experience of single valve actuation, the eight valve consecutive actuation is used for purposes of conservatism as requested by the NRC Staff.

Justification for Continued Operation

Attachment "A" provides the basis for justification of continued operation of the Monticello plant in light of the potential influence of sequential multiple valve actuations. This is essentially the preliminary assessment for Monticello as presented by General Electric in the October 27, 1977 meeting with NRC Staff.

This assessment in our opinion is reasonable and conservative, and concludes that STP criteria is more than satisfied with limiting strength ratios of .24 for eight valve consecutive actuation. This assessment is especially conservative in light of actual operating experience that single valve actuation is typical of isolation from rated power.

NORTHERN STATES POWER COMPANY

Mr Victor Stello
Page 3
October 31, 1977

No further procedure changes are contemplated in light of procedures in effect since July 25, 1971 and as further revised January 6, 1977.

Plant-Unique Assessment and Action Plan

In the October 27, 1977 meeting with NRC Staff, Staff indicated a requirement for plant-unique assessment using multiple-valve consecutive actuations as predicted by the General Electric transient analysis model and more conservative correlations for multiple valves and consecutive actuations. The NSP assessment for Monticello on the request basis is presented in Attachment "B" with the summary and comparison to the General Electric preliminary assessment shown on the attachment "Summary".


Again, we conclude that the assumption of an 8 SRV multiple consecutive actuation is conservative in the extreme in light of operating experience that a single SRV is typical for even the initial actuation for a rated power isolation event.

The use of arithmetic sum of participation factors is conservative for evaluation of support structure loads because it assumes that both structural response and applied loads combine linearly in composite.

The use of peak stress of all runs and SRSS combination of participation factors is in itself a conservative method of evaluating shell stress; this is illustrated by the circumstance that the same approach bounds the three-valve test results where direct load participation might be expected to be more dominant than response participation.

Since for the extreme assumption of 8 valve sequential actuation all elements of the structure are well within STP acceptance criteria and also within a few percent of code allowable stresses, no structural modifications or procedure changes are warranted at this time.

Yours very truly,



L O Mayer, PE
Manager of Nuclear Support Services

LOM/GHN/ak

cc: J G Keppler
G Charnoff
MPCA - Attn: J W Ferman

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

License No. DPR-22

LETTER DATED October 31, 1977
RESPONDING TO NRC REQUESTS
FOR INFORMATION ON CONTAINMENT DESIGN

Northern States Power Company, a Minnesota corporation, by this letter dated October 31, 1977 hereby submits information in response to NRC requests for information concerning the Mark I Containment.


This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By *L. J. Wachter*
L J Wachter
Vice President, Power Production
& System Operation

On this 31st day of October, 1977, before me a notary public in and for said County, personally appeared L J Wachter, Vice President, Power Production and System Operation, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Denise E. Halvorson



Project SRV 2ND ACTUATION LOADS File No. _____

Owner NORTHERN STATES POWER CO.

Client NORTHERN STATES POWER CO.

ATTACHMENT A

GE LOADS CALCULATION METHOD

A. TORUS SHELL PRINCIPAL STRESSES (MEMBRANE PLUS BENDING)

1. MONTICELLO AND PILGRIM TEST RESULTS

PLANT	MIDBAY 45° FROM BOTTOM SG #18	MIDBAY WATERLINE SG #15	MIDBAY WATERLINE SG #19
MONTICELLO ①	3531 PSI	2676 PSI	2287 PSI
PILGRIM ②	3730 PSI	2710 PSI	1860 PSI

REF. ① MONTI. TEST REPORT PGS. 4.2-19, σ , MAX. (AVE. OF TEST 1 & 701)

② PRESENTATION BY NICK CEVA ON 10-5-77, PILGRIM QUICK LOOK RESULT.


FROM PILGRIM PRESENTATION, S.G @ BOT. OF TORUS HAD A STRESS OF 4000 PSI

RATIO OF STRESS @ 45° TO STRESS @ BOTTOM:

$$\text{RATIO} = 4000/3730$$

$$\text{RATIO} = 1.072 \quad \underline{\text{USE 1.08}}$$

SINCE PILGRIM REPORTED STRESSES COMPARE WELL WITH MONTICELLO, DETERMINE THE STRESS AT THE BOTTOM OF MONTICELLO USING THE SAME RATIO AS DETERMINED AT PILGRIM.



Kamel H. Abedman

Revision						Page <u>A1</u>
Prepared By/Date	<u>KAM 10-28-77</u>					of <u>5</u>
Checked By/Date						

Project SRV File No. _____
 Owner NSP
 Client NSP

2. SHELL STRESS MULTIPLE VALVE MULTIPLIER

MULTIPLIER FOR 8 VALVES (TEST BAY IS BAY D)

BAYS FROM BAY D	4	3	3	2	2	1	1	-
BAY ID	H	A	G	B	F	E	C	D
MULTIPLIER	.2	.4	.4	.4	.4	.75	.75	1.0

PARTICIPATION FACTORS DEVEL. BY GE BASED ON EXPECTED ATTENUATION

$$GRSS = [.2^2 + 4*.4^2 + 2*.75^2 + 1.0^2]^{1/2} = 1.67$$

MULTIPLIER FOR 3 VALVES FROM TEST RESULTS

SG 18

TEST 1	3.4 ksi	BAY D
TEST 11	4.252 ksi	BAY CDE
TEST 15	5.218 ksi	BAY CDE

REF: MONTI TEST REPORT APPENDIX C

$$MULTIPLIER = \frac{(4.252 + 5.218) \cdot 1.5}{3.4} = 1.39$$

$$3 \text{ VALVE SRSS} = [1.0 + 2*.75^2]^{1/2}$$

$$SRSS = 1.46$$

COMPARABLE TO MULTIP. FROM AVERAGE OF TESTS, THEREFORE USE SRSS FOR 8 VALVES

3. SUMMARY OF MULTIPLIERS

TO DETERMINE STRESS AT BOTTOM OF TORUS FROM SG 18 = 1.08
 INCREASE FROM 1 VALUE TO 3 VALVES = 1.39
 INCREASE FROM 1 VALUE TO 8 VALVES = 1.67

4. MONTICELLO CONSECUTIVE VALVE ACTUATION RESULTS

SG 18

TEST 702	5.957 ksi
TEST 703	6.878 ksi
TEST 1602	9.066 ksi
TEST 1603	9.847 ksi

REF: MONTI. TEST REPORT APPENDIX C

FROM TABLE 4.2-5 (PG 4.2-19)
 HOT POP FACTOR FOR TEST 1603 = 2.69
 THEREFORE VERY CONSERVATIVE, SINCE AVERAGE FACTOR = 1.91

USE PEAK STRESS

Revision						Page <u>42</u>
Prepared By/Date	<u>KAN 10-28-77</u>					of <u>5</u>
Checked By/Date						

Project SRV File No. _____
 Owner NSP
 Client NSP

5. MONTICELLO SHELL STRESSES PRESENTED BY GE

MEMBRANE PLUS BENDING STRESS (DOES NOT INCLUDE HYDRO)

1 SRV SHELL STRESS = $9847(1.08) = 10635$ PSI
 ↑ SG 18 TO BOTTOM
 ↑ PEAK HOT POP RESULTS FOR SG 18 (TEST 1603)

3 SRV SHELL STRESS = $9847(1.08)(1.39) = 14780$ PSI (GE REPORTED 13610 PSI IN ERROR)
 ↑ 3 VALVE FACTOR
 ↑ SG 18 TO BOTTOM
 ↑ PEAK HOT POP STRESS SG 18

8 SRV SHELL STRESS = $9847(1.08)(1.67) = 17760$ PSI
 ↑ 8 VALVE FACTOR
 ↑ SG 18 TO BOTTOM
 ↑ PEAK HOT POP STRESS

B. COLUMN LOADS

1. MULTIPLE VALVE FACTOR

	DISCHARGE IN BAY	O.S. COL. LOAD MEASURED IN BAY D	PARTICIPATION FACTOR	
TEST 1	D	202.0 ^K	1.0	} FROM DATA NOT INCLUDED IN REPORT
TEST 2	C	84.5	0.42	
TEST 5	E	16.34	0.08	
TEST 3	B	19.6	0.10	
TEST 6	F	18.5	0.09	
TEST 4	A	10.34	0.05	
USE TEST 4	G	10.34	0.05	
USE TEST 4	H	10.34	0.05	

RESULTS FROM MONTI. TEST DATA

Revision						Page <u>43</u>
Prepared By/Date	<u>KAN 10-28-77</u>					of <u>5</u>
Checked By/Date						

Project SRV

File No. _____

Owner NSP

Client NSP

MULTIPLE VALVE TEST RESULTS

TEST	BAYS	OS. COL LOAD
11	CDE	304 ^k
15	CDE	215 ^k

MONTI TEST RESULTS.
PG. 4.2-23

TEST 1 BAY D OS COL LOAD = 202.0

$$3 \text{ VALVE MULTIPLIER} = \frac{.5(215+304)}{202} = 1.28$$

$$\text{SRSS OF PARTICIPATION FACTORS} = [1.0^2 + .42^2 + .08^2]^{\frac{1}{2}} = 1.09$$

$$\text{RATIO OF SRSS TO TEST RESULTS} = 1.28/1.09 = 1.17$$

8 VALVE MULTIPLIER :

$$\text{SRSS OF PARTICIPATION FACTORS} = [1.0^2 + .42^2 + .08^2 + .10^2 + .09^2 + 3 \times .05^2]^{\frac{1}{2}} = 1.1$$

$$8 \text{ VALVE MULTIPLIER} = 1.1 (1.17) = 1.29$$

↑ TEST RESULT CORRELATION FACTOR

2. CONSECUTIVE VALVE FACTOR

	TEST	O.S COL LOAD
COLD	#1	202 ^k
HOT	702	316 ^k
HOT	703	348 ^k
HOT	1602	360 ^k
HOT	1603	380 ^k

REF. MONTI. TEST RESULTS
PG 4.2-23

$$\text{FACTOR} = \frac{.25(316+348+360+380)}{202} = 1.74$$

Revision						Page <u>44</u>
Prepared By/Date	<u>KAN 10-28-77</u>					of <u>5</u>
Checked By/Date						

Project SRV File No. _____
 Owner NSP
 Client NSP

3. SUMMARY OF MULTIPLIERS

COLD POP TO HOT POP (2ND ACTUATION) = 1.74
 INCREASE FROM 1 VALUE TO 3 VALUES = 1.28
 INCREASE FROM 1 VALUE TO 8 VALUES = 1.29
 PLANT UNIQUE MULTIPLIER = 1.01

4. STRENGTH RATIOS (S.R.)

O.S. COL DL = 164^K
 SEISMIC = 15^K } AT MAX. SUBMERGENCE
 SHELL CONN. CAPACITY = 2820^K

ACCOUNTS FOR DIFFER.
 BETWEEN TEST PRESSURE
 AND VALVE SET POINT
 AND BENEFIT FROM LP

1 SRV LOAD = 202 (1.74)(1.01) = 355^K
 ↑ HOT POP FACTOR
 ↓ SINGLE COLD

3 SRV LOAD = 202 (1.74)(1.28)(1.01) = 454^K
 ↑ HOT POP
 ↓ 3 VALUE MULTIPLIER

8 SRV LOAD = 202 (1.74)(1.29)(1.01) = 458^K
 ↑ HOT
 ↓ 8 VALUE MULTIPLIER

S.R. 1 SRV = (355+164+15)/2820 = 0.19	<u>GE</u> REPORTED .20
S.R. 3 SRV = (454+164+15)/2820 = 0.22	.23
S.R. 8 SRV = (458+164+15)/2820 = 0.23	.24

Project SRV 2ND ACTUATION

File No. _____

Owner NORTHERN STATES POWER CO.

Client NORTHERN STATES POWER CO.

ATTACHMENT B

CONSERVATIVE LOADS CALO. METHOD BY NSP

A. COLUMN LOADS

1. MULTIPLE VALUE FACTOR (8 VALUES)

TEST NO.	BAY	OS COL LOAD MEAS. IN BAY D	
1	D	202.0 ^k	FROM DATA NOT INCLUDED IN MONTI REPORT
2	C	84.5	
5	E	16.34	
3	B	19.6	
6	F	18.5	
4	A	10.34	
USE 4	G	10.34	
USE 4	H	10.34	
TOTAL =		372 ^k	

FACTOR = $372/202 = 1.84$ ASSUMES NO PARTICIPATION FACTORS BUT USES DIRECT ADDITION OF LOADS
(GE FACTOR = 1.29)

2. CONSECUTIVE VALUE FACTOR (HOT POP) MONT. REPORT PG 4.2-23

	TEST	O.S. COL.	IS COL.	OS COL. FAC.	IS COL. FAC.
COLD	1	202 ^k	154 ^k	-	-
HOT	702	316	264	1.56	1.71
HOT	703	348	297	1.72	1.93
HOT	1602	360	301	1.78	1.95
HOT	1603	380	339	1.88	2.20

AVE. IS : OS COL FACTOR = $(1.56 + 1.72 + 1.78 + 1.88 + 1.71 + 1.93 + 1.95 + 2.20) / 8 = 1.84 = \bar{x}$

STD. DEVIATION = $\sigma = \sqrt{\frac{\sum (x_i - \bar{x})^2}{n}} = 0.18$

KAW 10-28-77

Project _____ File No. _____
 Owner _____
 Client _____

AVE. CONSECUTIVE VALUE FACTOR + 1 STD DEVIATION = $1.84 + 0.18 = 2.02$

CONSECUTIVE VALUE FACTOR = 2.02 (GE FACTOR = 1.74)

3. PLANT UNIQUE FACTOR

FOR MONTICELLO = 1.01 PER GE ACCOUNTS FOR INCREASE DUE TO DIFFERENCE IN TEST PRESSURE (985) TO VALUE SET POINT (1068) AND DECREASE IN LOAD DUE TO ΔP

4. SUMMARY OF MULTIPLIERS

<u>MULTIPLIER</u>	<u>NSP</u>	<u>GE</u>
8 VALUE CASE	1.84	1.29
HOT POP	2.02	1.74
PLANT UNIQUE	1.01	1.01

5. LOADS

1 SRV COLD OS COL = 202^k (TEST #1 PAGE 4.2-23
 IS COL = 154^k OF MOUNTI REPORT)

8 SRV HOT OS COL = $202(1.84)(2.02)(1.01) = 758^k$ (GE USED 533^k)
 IS COL = $154(1.84)(2.02)(1.01) = 578^k$

DEAD LOAD: IS COL = 164^k OS COL = 192^k
 SEISMIC: IS COL = 15^k OS COL = 21^k

AT MAX SUBMERGENCE, NUTECH REPORT NSP-01-168 PG 13

TOTAL LOAD: (8 SRV HOT)

IS COL = $164 + 15 + 578 = 757^k$
 OS COL = $192 + 21 + 758 = 971^k$

Revision						Page <u>B2</u>
Prepared By/Date	RAH 10-28-77					of <u>6</u>
Checked By/Date						

Project SRV File No. _____

Owner NSP

Client NSP

6. STRENGTH RATIOS (8 VALUE HOT POP)

COMPONENT	LOAD	CODE ALLOWABLE	ULTIMATE CAPACITY	STRENGTH CODE	RATIO ULTIMATE
IS SHELL CONN.	757 ^k	940 ^k	2820 ^k	0.81	MEETS CODE
IS COLUMN	757 ^k	1123 ^k	3140 ^k	0.67	MEETS CODE
IS PIN	757 ^k	993 ^k	2960 ^k	0.76	MEETS CODE
OS SHELL CONN.	971 ^k	940 ^k	2820 ^k	1.03	0.34
OS COLUMN	971 ^k	1189 ^k	3288 ^k	0.82	MEETS CODE
OS PIN	971 ^k	993 ^k	2960 ^k	0.98	MEETS CODE

ALL COMPONENTS MEET CODE FOR 8 VALUE, 2ND ACTUATION EXCEPT FOR OS SHELL CONN. WHICH IS 3% OVER. STP ULTIMATE STRENGTH RATIO = 0.34 < 0.5.

B. TORUS SHELL STRESSES

1. FACTOR FOR STRESS AT BOTTOM OF TORUS

REF: PILGRIM TEST REPORT TR-2682

RATIO OF STRESS @ 45° TO BOTTOM

R18 @ 45° R17 @ BOTTOM

	GAGE R18	GAGE R17	RATIO
TEST # 1	3288 PSI	4893 PSI	1.49
TEST # 2	2318 PSI	3234 PSI	1.40

TEST REPORT DOES NOT CONFIRM EARLIER PRESENTATION VALUES USED BY GE

USE WORSE CASE FACTOR = 1.49 (GE FACTOR = 1.08)

Revision					
Prepared By/Date	<u>XAN 10-28-77</u>				Page <u>B3</u>
Checked By/Date					of <u>6</u>

Project SRV File No. _____
 Owner NSP
 Client NSP

2. FACTOR FOR MULTIPLE VALVE EFFECT

REFER: APPENDIX C
OF MONT. TEST REPORT

<u>TEST</u>	<u>DISCHARGE BAY</u>	<u>STRESS (SG 18)</u>	
1	D	3.400 ksi	$SRSS \text{ OF } CDE = [3.4^2 + 3.972^2 + 0.215^2]$ (3 VALUE) $SRSS = 5.23 \text{ ksi}$
2	C	3.972	
3	B	0.746	
4	A	1.768	
5	E	0.215	
6	F	1.679	
USE 4	G	1.768	<u>3 VALVE TEST</u> <u>STRESS</u> #11 4,252 ksi #15 5,218 ksi
USE 4	H	1.768	∴ SRSS BOUNDS TEST RESULTS

FROM ABOVE IT APPEARS THAT STRESS IS MORE A FUNCTION OF STRUCTURAL RESPONSE THAN LOAD. CONSERVATIVE ASSUMPTION WOULD BE TO USE SRSS OF RESPONSES.

$$SRSS = [3.4^2 + 3.972^2 + .746^2 + 1.768^2 + .215^2 + 1.679^2 + 1.768^2 + 1.768^2]^{1/2} = 6.34 \text{ ksi}$$

FACTOR = $6.34 / 3.4 = 1.86$ (GE FACTOR = 1.67)

3. CONSECUTIVE VALVE ACTUATION

USE PEAK STRESS FROM 4 TESTS (702, 703, 1602, 1603)

FOR SG 18 $\sigma_s = 9.847 \text{ ksi}$ (APPENDIX C OF TEST REPORT TEST 1603)

4. PLANT UNIQUE FACTOR

FACTOR = 1.01 PER GE ACCOUNTS FOR INCR. DUE TO TEST PRESS. VARIATION AND ΔP

5. STRESS DUE TO HYDROSTATIC LOAD

DEPTH OF WATER = 11.96 AT MAX SUBMERGENCE
 PRESSURE = $.43 (11.96) = 5.14 \text{ psi}$

RADIUS = 166"
 THICKNESS = .584

$$\sigma = PW/r = 5.14(166)/.584 = 1461 \text{ psi}$$

Revision						Page <u>B4</u>
Prepared By/Date	<u>KAN 10-28-77</u>					of <u>6</u>
Checked By/Date						

Project SRV File No. _____
 Owner NSP
 Client NSP

6. 8 VALVE 2ND POP SHELL STRESS

FACTOR FOR STRESS FROM SKIB TO BOTTOM = 1.49 (GE FACTOR = 1.08)
 MULTIPLE VALUE FACTOR (8 VALUES) = 1.86 (GE FACTOR = 1.67)
 PLANT UNIQUE FACTOR = 1.01 (GE FACTOR = 1.01)
 CONSECUTIVE ACTUATION STRESS = 9847 PSI (GE SAME)
 HYDROSTATIC HEAD STRESS = 1461 PSI (GE NOT USED)

STRESS @ BOT. = $9847(1.49)(1.86)(1.01) + 1461 = 29020 \text{ PSI}$
 EXTREME FIBER STRESS
 MEMBRANE PLUS BENDING

CODE ALLOW: MEMBRANE = 19.3 ksi
 MEM. + BEND = $1.5(19.3) = 28.95 \text{ ksi}$

STP ULT. CRITERIA: $2S_y$ or S_u WHICH EVER LESS

$2S_y = 2(38) = 76 > 70 \therefore \text{USE } 70$

STRENGTH RATIO:

LODE = $29/28.95 = 1.01$ 1% OVER CODE
 STP = $29/70 = .41 < .5$

- WORST CASE SHELL STRESS AT BOTTOM OF TORUS
LESS THAN 1% OVER CODE.
- ULTIMATE STRENGTH RATIO $< .5$

NOTE: TEST SERIES 16 CAUSED THE SHELL TO BOTTOM
 OUT ON THE BAY EARTHQUAKE TIE CAUSING
 SIGNIFICANTLY HIGHER EXTREME FIBER STRESSES
 IN SHELL AT GAGE 18

Revision						Page <u>35</u>
Prepared By/Date	<u>RAH</u> 10-28-77					of <u>6</u>
Checked By/Date						

Project SRV 2ND ACTUATION

File No. _____

Owner NSP

Client NSP

STATE OF STRESS IN SHELL AT OTHER THAN SG 18

CLEAN SHELL AREAS:

SG 18 @ 45° MIDBAY

SG 19 @ WATER LINE MIDBAY

SG 15 @ WATER LINE MIDBAY

NEAR RING GIRDER

SG 22 @ WATER LINE

AT EQ TIE

SG 17 SIDE OF EQ TIE

SG 57 END OF EQ TIE

REFERENCE TABLE 4.2-3 OF MONTI REPORT

<u>GAGE</u>	<u>REF. STRESS</u>	<u>TON</u>	<u>PEAK STRESS</u>	
18	2.86 KSI	2.44	6.98 KSI	} CLEAN SHELL
19	1.64	3.39	5.56 KSI	
15	2.27	2.64	5.99 KSI	
22	3.09	1.65	5.10 KSI	} AT DISCONTINUITY
17	4.05	2.05	8.30 KSI	
57	5.99	1.89	11.13 KSI	

$$\text{RATIO OF SG 57/SG 18} = 11.13/6.98 = 1.59$$

- FROM GAGES 19 AND 15, THE CONCLUSIONS BASED ON SG 18 ARE STILL VALID FOR THE CLEAN SHELL AREAS
- FROM GAGES 22, 17 AND 57, THE CONCLUSIONS BASED OF SG 18 ARE ALSO VALID FOR SHELL STRESS AT MAJOR DISCONTINUITIES SUCH AS THE EARTHQUAKE TIE AND THE RING GIRDER. CODE ALLOWABLE EXTREME FIBER STRESS FOR AREAS AT DISCONTINUITIES IS $3S_m$ (TWICE THE CLEAN SHELL ALLOWABLE OF $1.5S_m$).

Kernell P. ...

Revision						Page <u>B6</u>
Prepared By/Date	<u>SAW 10-28-77</u>					of <u>6</u>
Checked By/Date						

1. The Monticello Plant initially had four safety relief valves discharging to the torus and four conventional safety valves. SRV discharge lines terminated in the suppression pool as vertical straight pipe near the torus wall with no discharge device.
2. July 25, 1971-Operating procedures were issued to require operator to take manual control of SRV following isolation and blow down to 950 psig, with pressure to be maintained between 1000 and 950 psig by manual blowdown as necessary.
3. January, 1972-SRV discharge lines were extended to torus center line and rams head discharge devices installed.
4. July 25, 1972-Installed SRV discharge pressure switches with 5 psig setpoints and inputs to computer sequence of events monitor.
5. April, 1974-Replaced the four conventional safety valves with four SRV's. SRV discharge line additions installed with rams heads and pressure switch monitors.
6. January 6, 1977-Operating procedures revised to require operator to take manual control of SRV following isolation and blowdown to 800 psig. Pressure to be maintained between 1000 and 800 psig by manual blowdown as necessary. Specified sequence of blowdown so all SRV's would be actuated once before re-activating first SRV. (Sequence of SRV lifts based on history of SRV actuations, i.e., 1st valve specified for torus bay previously experiencing fewest actuations.)
7. October 1977-Added 8-inch vacuum breakers to all SRV discharge lines. Installed three prototype SRV discharge "T-Quenchers".

EVENT #1

Date: May 20, 1971

Power Level: 75%

Initiating Event: Startup test STP 11, Initiated by tripping RCIS relays with opening of test switch.

Sequence of Events:

1. MSIV closure at 1318.
2. Rx pressure peaks at 1069 psig, approximately six seconds after initiation.
3. No automatic lift on initial pressure peak.
4. "D" safety relief valve manually operated to reduce Rx pressure. Actual number of manual lifts cannot be determined but only one is suspected.

EVENT #2

Date: May 24, 1971

Power Level: 100%

Initiating Event: Oscillations in the steam line flow signal had initiated the high steam flow isolation of Group I.

- Sequence of Events:
1. MSIV closure at 2146.
 2. Auto lift of "D" safety relief valve (1085 Rx pressure peak)
 3. Rx pressure reduced to 976 psig.
 4. Manual lift of "D" safety relief valve at 1035 psig approximately 4 minutes after initial lift.
 5. Rx pressure reduced to 995 psig.
 6. MSIV's opened.

EVENT #3

Date: July 14, 1971

Power Level: 91%

Initiating Event: Pressure transmitter was valved in service following routine calibration, a pressure surge occurred in the instrument sensing line. The surge tripped the main steam line high flow switches connected to the same line causing a group I isolation.

- Sequence of Events:
1. MSIV closure at 1348.
 2. SRV opens Rx press 1060 psig peak.
 3. Rx press drops to 995 psig.
 4. SRV opens Rx press 1090 psig peak, 1352*.
 5. Rx press drops to 1025.
 6. SRV opens Rx press 1095 psig peak, 1353*.
 7. Rx press drops to 1015.
 8. SRV opens Rx press 1095 psig peak, 1355*.
 9. Rx press drops to 1040 psig.
 10. SRV opens Rx press 1090 psig peak, 1357*.
 11. Rx press drops to 1035 psig.
 12. SRV opens Rx press 1090 psig peak, ~1358*.
 13. Rx press drops to 1030 psig.
 14. SRV opens Rx press peak 1090 psig, ~1359*.
 15. Rx press drops to 1030 psig.
 16. SRV opens Rx press peak 1092 psig, ~1401*.
 17. Rx press drops to 1025 psig.
 18. SRV opens Rx press peak 1095 psig, ~1402*.
 19. Rx press drops to 1018 psig.

* Estimates made from measuring Rx press chart.

NOTE: It appears that the least the "A", "B" and "C" valves lifted during this event based on discharge pipe temperature recorder indications. We cannot tell which one lifted at a given time from the available information.

EVENT #4

Date: November 6, 1973

Power Level: 99.5%

Initiating Event: Inadvertant trip of a main steam line high flow sensor during routine instrument surveillance resulted in a Group I isolation.

- Sequence of Events:
1. MSIV closure at 1338:47.62.
 2. Rx pressure peaks at 1065.
 3. "C" safety relief valve auto opens at 1338:51.82.
 4. "C" SRV closes at 1339:11.03 at Rx press. of 970.
 5. "D" SRV manually opened at 1341:08.47, Rx press 1035.
 6. "D" SRV closed at 1341:20.46, Rx press 975.
 7. "D" SRV manually opened at 1341:43.84, Rx press ~1024.
 8. "D" SRV closed at 1341:56.16, Rx press ~970.
 9. "D" SRV manually opened at 1342:20.48, Rx press ~1024.
 10. "D" SRV closed at 1342:33.73, Rx press ~966.
 11. "D" SRV manually opened at 1343:13.41, Rx press ~1024.
 12. "D" SRV closed at 1343:25.75, Rx press ~966.
 13. "D" SRV manually opened at 1344:24.10, Rx press ~1028.
 14. "D" SRV closed at 1344:37.70, Rx press ~964.
 15. "D" SRV manually opened at 1345:38.69, Rx press ~1028.
 16. "D" SRV closed at 1345:51.52, Rx press ~965.
 17. "D" SRV manually opened at 1347:10.93, Rx press ~1043.
 18. "D" SRV closed at 1347:27.54, Rx press ~910.

NOTE: These lift times are accurate times as indicated by the sequence of events recorder.

Project SRV 2ND ACTUATION File No. _____

Owner NORTHERN STATES POWER

Client NORTHERN STATES POWER

SUMMARY

<u>FACTOR</u>	<u>GE (SECT. A)</u>	<u>NSP (SECT. B)</u>
SHELL STRESS SG 18 TO BOT.	1.08	1.49
SHELL STRESS 8 VALVE MULT.	1.67	1.86
SHELL STRESS 2ND POP	9.847 ksi	9.847 ksi
COL. LOAD 8 VALVE MULT.	1.29	1.84
COL. LOAD 2ND POP	1.74	2.02
PLANT UNIQUE FACTOR	1.01	1.01
SHELL STRESS INCR. DUE TO DEAD LOAD	NO	YES

SHELL STRESS @ TORUS BOT.	17760 PSI	29020 PSI
MAXIMUM STRENGTH RATIO FOR SUPPORT STRUCTURE	0.23	0.34

- TORUS SUPPORT : WITH NSP MORE CONSERVATIVE ASSUMPTIONS ALL SUPPORT COMPONENTS WITHIN CODE ALLOW, EXCEPT O.S. COLUMN TO SHELL CONNECTION WHICH IS 3% OVER CODE, STP ULTIMATE STRENGTH RATIO = $0.34 < 0.50$
- TORUS SHELL : WITH NSP MORE CONSERVATIVE ASSUMPTIONS SHELL STRESS AT BOTTOM OF TORUS (EXTREME FIBER MEMBRANE PLUS BENDING) LESS THAN 1% OVER CODE ALLOW, STP ULTIMATE STRENGTH RATIO = $0.41 < 0.5$
AN EVALUATION OF SHELL STRESS NEAR RING GIRDER AND EARTHQUAKE TIE SHOW THAT CONCLUSIONS REACHED FOR SG 18 ARE CONSERVATIVE

• ACCEPTANCE CRITERIA

SHELL SA-516 Gr 70 $S_y = 38 \text{ ksi}$ $S_u = 70 \text{ ksi}$ $S_m = 19.3 \text{ ksi}$

CODE ALLOW:

PRIMARY MEMBRANE + PRIMARY BENDING = $1.5 S_m$ (28.95 ksi)

STP ULTIMATE: $SR < 0.5$ ULT. FOR SHELL = S_u (70 ksi)

Revision						Page <u>51</u>
Prepared By/Date	<u>RAV 10-28-77</u>					of <u>1</u>
Checked By/Date						