

DISTIRBUTION:

Docket
 NRC PDR
 L PDR
 ORB#2 Rdg.
 VStello
 KGoeller
 OELD
 OI&E (3)
 DDavis
 RSnaider
 BBuckley
 WButler
 DEisenhut
 TAbenthy
 JBuchanan
 ACRS (16)

Docket No. 50-263

SEP 21 1977

Northern States Power Company
 ATTN: Mr. L. O. Mayer, Manager
 Nuclear Support Services
 414 Nicollet Mall - 8th Floor
 Minneapolis, Minnesota 55401

Gentlemen:

We have commenced review of your September 2, 1977 request for amendment of Provisional Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. The proposed amendment would allow completion of the primary integrated leak rate test in less than 24 hours.

We have also received a General Electric topical report on this subject and are aware of the interest of many other BWR licensees in our completing a rapid review and approval. However, because of certain unresolved concerns, especially those related to statistical propagation of errors, an in-depth generic review of this issue is warranted prior to approval of the new techniques. Therefore, although review of your submittal has been initiated, we do not anticipate completion in time for your use of the new technique during the present refueling outage at Monticello.

Sincerely,

Original signed by

Don K. Davis

Don K. Davis, Acting Chief
 Operating Reactors Branch #2
 Division of Operating Reactors

cc: See next page

OFFICE >	ORB#2:DOR	PS-SB/OT:DOR	PS/OT:DOR	OT:DOR	ORB#2:DOR	AD'OR
SURNAME >	RSnaider	BBuckely	WButler	DEisenhut	DDavis	K.Goeller
DATE >	9/16/77	9/19/77	9/19/77	9/19/77	9/20/77	9/21/77

September 21, 1977

cc:

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Sandra S. Gardebring
Executive Director
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 5113

Jocelyn F. Olson, Esquire
Special Assistant Attorney General
Minnesota Pollution Control Agency
1935 West County Road B-2
Roseville, Minnesota 55113

Mr. Robert L. Nybo, Jr., Chairman
Minnesota-Wisconsin Boundary Area Commission
619 Second Street
Hudson, Wisconsin 54016

Mr. F. P. Tierney
Plant Manager
Prairie Island Nuclear Generating Plant
Northern States Power Company
Route 2
Welch, Minnesota 55089

Mr. Steve Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

The Environmental Conservation Library
Minneapolis Public Library
300 Nicollet Mall
Minneapolis, Minnesota 55401