

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: Mr Goller

FROM: Northern States Pwr Co
Minneapolis, Mn
L O Mayer

DATE OF DOCUMENT 3-1-77

DATE RECEIVED 3-3-77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP INPUT FORM

NUMBER OF COPIES RECEIVED
one signed

DESCRIPTION
Ltr re our 2-4-77 ltr....furnishing info re torus level & drywell to torus pressure differential instrumentation.....& advising that info will be submitted by 4-15-77.....

ENCLOSURE

lp

PLANT NAME: Monticello

Do Not Remove
ACKNOWLEDGED

SAFETY FOR ACTION/INFORMATION ENVIRO 3-4-77 ehf

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	Ziemann (5)	BRANCH CHIEF:
PROJECT MANAGER:	Snajder	PROJECT MANAGER:
LIC. ASST. :	Diss	LIC. ASST. :

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
<input checked="" type="checkbox"/> OELD		LAINAS	
<input checked="" type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SIHWELL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: Minneapolis, Mn	NAT. LAB:	BROOKHAVEN NAT. LAB.
<input checked="" type="checkbox"/> TIC:	REG V.IE	ULRIKSON (ORNL)
<input checked="" type="checkbox"/> NSIC:	LA PDR	
<input checked="" type="checkbox"/> ASLB:	CONSULTANTS:	
<input checked="" type="checkbox"/> ACRS 16 CYS HOLDING/SENT	As CAT 3	

2191

NSP

Docket File

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

March 1, 1977

Mr K R Goller
Assistant Director For Operating Reactors
Division of Reactor Licensing
U S Nuclear Regulatory Commission
Washington, DC 20555



Dear Mr Goller:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No 50-263 License No DPR-42

Torus Level and Drywell To Torus Pressure
Differential Instrumentation

This letter is in response to your February 4, 1977 letter seeking commitments on containment instrumentation.

Additional instrumentation has been installed to monitor torus level and drywell to torus pressure differential. Each parameter is monitored by two channels of instrumentation having accuracies within the range specified by the NRC staff technical position attached to your February 4, 1977 letter.


We are not convinced that it is appropriate that the Technical Specifications include requirements for monitoring instrumentation of this nature. However, in compliance with your request, we will submit proposed changes on or before April 15, 1977.

Yours very truly,

L O Mayer, PE
Manager of Nuclear Support Services

LOM/MHV/deh

cc: J G Keppler
G Charnoff
MPCA
Attn: J W Ferman



2191